


CENTER OF GRAVITY			
DESCRIPTION	X (MM)	Y (MM)	Z (MM)
CONDENSER	3131	1575	4000
VESSEL SKID	2217	1153	1045
COMPRESSOR SKID	790	450	860

WEIGHT		
DESCRIPTION	DRY WEIGHT (KG)	WET WEIGHT (KG)
CONDENSER	5600	6200
VESSEL SKID	6000	7000
COMPRESSOR SKID	3500	4500


- NOTES:
- ALL DIMENSIONS ARE IN MM.
 - ANCHOR HOLES TOLERANCES: ± 0.13 in (± 3.2 mm).
 - BEAM LOCATION TOLERANCES: ± 0.13 in (± 3.2 mm).
 - SKID FLATNESS SHALL BE 0.0625" (1.6 mm).
 - SURFACE PREPARATION SHALL BE PER PROJECT PAINTING SPECIFICATION.
 - FOR CONDENSER DYNAMIC & STATIC LOADS, REFER TO CONDENSER DRAWINGS.
 - BEAM SIZE : W8 X 48#, MATERIAL - ASTM A572 OR EQUIVALENT.



TOP VIEW

REV.	STATUS	DATE	PURPOSE OF ISSUE	PREP.	CHKD.	APPD.	AUTH.
1	F	22.08.24	FOR APPROVAL	AJD	AJD	IES	SES
0	F	26.07.24	FOR APPROVAL	AJD	AJD	IES	SES

CLIENT:	ENER TECHNOLOGI		
SERVICE:	PROPANE REFRIGERATION PACKAGE		
LOCATION:	IRAQ		
UNIT TAG NO.:	RU-001 AB		
VENDOR LOGO			
Contract No.	P.O No. ENER-MME-2024-100-001		
SCALE			
DRAWING TITLE:			
FOUNDATION DRAWING			
DRAWING NO.	REV.	SHEET No.	SIZE
MPE007-20021-1	1	1 OF 2	D



1	F	22.08.24	FOR APPROVAL	AJD	AJD	IES	SES
0	F	26.07.24	FOR APPROVAL	AJD	AJD	IES	SES
REV.	STATUS	DATE	PURPOSE OF ISSUE	PREP.	CHKD.	APPD.	AUTH.
CLIENT: ENER TECHNOLOGI			PROPANE REFRIGERATION PACKAGE				
SERVICE: IRAG							
LOCATION: RU-001 AB							
UNIT TAG NO.:							
VENDOR LOGO							
Contract No.		P.O. No. ENER-MME-2024-100-001		SCALE			
DRAWING TITLE: FOUNDATION DRAWING							
DRAWING NO. MPE007-20021-2				REV.	SHEET No.	SIZE	
				1	2 OF 2	D	