



شرکت مهندسی صنعتی
فهامه

Inspection Daily Report

Project Name	ABS & RUBBER PLANT PROJECT
Client	Pad Jam Development Co (PJPC)
Contractor	Petro Electric
Notification/Reference Number & Date	HSE-05-413 19 May 2025
Inspection Report Number & Rev.	IR-FAH-PJPC-HSE-05-413/01-00
Page Number	Page 1 of 4

PO Number	-
Discipline (Based on PO Number)	-
MRQ Number	-
Inspection Date	21,22 May 2025 2Days
Vendor / Supplier	HSE Group- Damafin Co.
Product	Piping
Inspector Name	H.Saneyan
Place of Inspection	Damafin co.- Zamyad st.- Iran khodro bld.- Makhsos karaj Rod
Attendance	<input checked="" type="checkbox"/> Client (<input checked="" type="checkbox"/> R <input type="checkbox"/> RA <input type="checkbox"/> H <input type="checkbox"/> W <input type="checkbox"/> SW) <input checked="" type="checkbox"/> Contractor (<input checked="" type="checkbox"/> R <input type="checkbox"/> RA <input checked="" type="checkbox"/> H <input type="checkbox"/> W <input type="checkbox"/> SW)



Inspected Items & Equipment

Item No	Description of Goods	QTY		Units	Heat/Serial /Tag No	Reference Standards / Document & Rev
		PO	Inspected			
1	Piping For Chiller Skid (RECEIVER HEDER)	1	1	PCs	RU0001B-D0-2	DWG No: EI 027--HSE -VD -ME - DWG -0009-Rev.R 4
2	Piping For Chiller Skid (RECEIVER HEDER)	1	1	PCs	RU0001A-D0-2	DWG No: EI 027--HSE -VD -ME - DWG -0009-Rev.R 4

Remarks:

Brief Scope of Inspection and Tests

<input type="checkbox"/> Raw Materials Inspection	<input type="checkbox"/> WPS, PQR & WQT
<input type="checkbox"/> Review of Material Certificates	<input type="checkbox"/> Joint Fit-up Control
<input type="checkbox"/> Review of Personnel Qualification Certificates	NDT: <input type="checkbox"/> VT <input type="checkbox"/> MT <input type="checkbox"/> PT <input type="checkbox"/> RT <input type="checkbox"/> UT
<input type="checkbox"/> Quantity Check	<input type="checkbox"/> Heat Treatment
<input checked="" type="checkbox"/> Visual & Dimensional Check	<input type="checkbox"/> Hardness
<input type="checkbox"/> Chemical Analysis Test (PMI)	<input type="checkbox"/> PWHT
<input type="checkbox"/> Sampling & Laboratory Analysis	<input type="checkbox"/> Surface Preparation
<input type="checkbox"/> Marking & Packing Check	<input type="checkbox"/> Coating Inspection
<input type="checkbox"/> Pneumatic Test	<input type="checkbox"/> Holiday Test
<input type="checkbox"/> Mechanical Ruining Test	<input type="checkbox"/> Thickness Test
<input type="checkbox"/> NPSH Test	<input type="checkbox"/> Adhesion Test
<input type="checkbox"/> Performance Test	<input type="checkbox"/> Color Code Check
<input checked="" type="checkbox"/> Hydrostatic	<input type="checkbox"/> Surface Finish Check
<input type="checkbox"/> Leakage Test	<input type="checkbox"/> Electrical Function Test

Name of Inspector	Mr. H.Saneyan	Revised & approved by	Mr. S.M.Peyghambari
Signature & Stamp		Signature & Stamp	



شرکت مهندسی صنعتی
فهامه

Inspection Daily Report

Project Name	ABS & RUBBER PLANT PROJECT
Client	Pad Jam Development Co (PJPC)
Contractor	Petro Electric
Notification/Reference Number & Date	HSE-05-413 19 May 2025
Inspection Report Number & Rev.	IR-FAH-PJPC-HSE-05-413/01-00
Page Number	Page 2 of 4

<input type="checkbox"/> FAT	<input type="checkbox"/> Dielectric Test
<input type="checkbox"/> SAT	<input type="checkbox"/> Instrument Functional Test
Others	

Visit Report (In Details)

1-Inspection Description

(Conclusions, Remarks, Open Questions of Last Reports and Required Actions)




Inspection Activity	Descriptions for inspection activities	Result
Visual & Dimensional Check	<ul style="list-style-type: none"> Visual, dimensional and assembly inspection of the piping system of the RECEIVER HEADER packages was carried out in accordance with the attached drawings, the results of which were satisfactory. DWG shall be approved by client. 	Conditional
Hydrostatic Check EI027-HSE-VD- QC-ITP-001-R3	<ul style="list-style-type: none"> Hydrostatic test inspection of the RECEIVER HEADER equipment piping system with tag number RU0001A/B-D0-2 (whole package) was performed in accordance with hydrotest procedure number EI027-HSE-VD - QC- PRO-004- R0 at a pressure of 33 bar for 1 hour, and no pressure drop or leakage was observed. Hydro test procedure shall be approved by client. 	Conditional
Review Document	<ul style="list-style-type: none"> the quality control reports (including dimensional, NDT, and hydrotest) shall be provided. Analyse of water of test shall be provided. 	Conditional

2-Areas of Concern

- the quality control reports (including dimensional, NDT, and hydrotest) shall be provided.
- Analyse of water of test shall be provided.
- Hydro test procedure and DWG shall be approved by client.

- مدارک کنترل ابعادی، تست های غیر مخرب و رپورت هایپروت تست باید ارائه شود.
- آنالیز آبی که برای تست استفاده شده باید ارائه گردد.
- پروسیجر هایپروتست و نقشه باید توسط کارفرما تایید شود

3-NCR(s)

Name of Inspector	Mr. H.Saneyan	Revised & approved by	Mr. S.M.Peyghambari
Signature & Stamp		Signature & Stamp	 



شرکت مهندسی صنعتی
فهامه

Inspection Daily Report

Project Name	ABS & RUBBER PLANT PROJECT
Client	Pad Jam Development Co (PJPC)
Contractor	Petro Electric
Notification/Reference Number & Date	HSE-05-413 19 May 2025
Inspection Report Number & Rev.	IR-FAH-PJPC-HSE-05-413/01-00
Page Number	Page 3 of 4




Inspection Document:

- | | |
|---|--|
| <input checked="" type="checkbox"/> Reference Drawings
<input type="checkbox"/> Reference Standard
<input type="checkbox"/> Packing List
<input checked="" type="checkbox"/> Test Procedures
<input checked="" type="checkbox"/> ITP
<input type="checkbox"/> Purchase order | <input type="checkbox"/> Materials Certificate
<input type="checkbox"/> Test Certificate
<input type="checkbox"/> Test Report
<input type="checkbox"/> Certificate of Origin
<input type="checkbox"/> Technical Data Sheet
<input type="checkbox"/> Others: |
|---|--|

Conclusion

Quantity & Packing Check	<i>Number of Items:</i>
	<i>Number of Items in a Package:</i>
	<i>Number of Packages in a pallet:</i>
	<i>Packing Type:</i>
	<i>Total Net weight:</i>
Status of Items (acc. to P.O.)	<input checked="" type="checkbox"/> Complete
	<input type="checkbox"/> Not complete (During Manufacturing)
	<input type="checkbox"/> Released for packing
	<input type="checkbox"/> Ready for shipment
	<input type="checkbox"/>
Means of Transport	<input type="checkbox"/> Truck <input type="checkbox"/> Train
	<input type="checkbox"/> Vessel <input type="checkbox"/> Ship
	<input type="checkbox"/> Air Plain
Attachments	<input checked="" type="checkbox"/> M.O.M
	<input type="checkbox"/> Certificates
	<input type="checkbox"/> NCR
	<input type="checkbox"/> Packing List
	<input checked="" type="checkbox"/> Drawings
Result of Inspection	<input type="checkbox"/> Others:
	<input type="checkbox"/> Accepted
	<input type="checkbox"/> Accepted with Minor Comments
	<input checked="" type="checkbox"/> Conditional
	<input type="checkbox"/> NCR Issued
	<input type="checkbox"/> Rejected

Photo Report








Name of Inspector	Mr. H.Saneyan	Revised & approved by	Mr. S.M.Peyghambari
<i>Signature & Stamp</i>		<i>Signature & Stamp</i>	 




شرکت مهندسی صنعتی
فهامه

Inspection Daily Report

Project Name	ABS & RUBBER PLANT PROJECT
Client	Pad Jam Development Co (PJPC)
Contractor	Petro Electric
Notification/Reference Number & Date	HSE-05-413 19 May 2025
Inspection Report Number & Rev.	IR-FAH-PJPC-HSE-05-413/01-00
Page Number	Page 4 of 4

	
Visual & Dimensional Control	Visual & Dimensional Control
	
Hydrotest control	Visual & Dimensional Control
	
Hydrotest control	Hydrotest control
	
Hydrotest control	Hydrotest control

Name of Inspector	Mr. H.Saneyan	Revised & approved by	Mr. S.M.Peyghambari
Signature & Stamp		Signature & Stamp	