

Customer:	---	Drum Number:	---
Company:	Moghan	Size:	---
Issue Date of Results:	1404/01/26	Standard:	BSEN50288-7
Page:	1 of 1	Insulation/Sheath Material:	XLPE/LSHF

Row	Tests	Unit	Requirements	Measurements	Result
1	Flame retardant	mm	Min=50	445	OK

Conclusion

All results { ☒ are ☐ are not } in accordance with requirements above

Accredited Laboratory of Moghan Wire & Cable .

.....
Name & Signature of
Laboratory Expert



آزمایشگاه مغان
MOGHAN Co. Laboratory
شرکت تولیدی و صنعتی سیم و کابل مغان
Moghan wire & cable co.

.....
Name & Signature of
Laboratory Manager

.....
Name & Signature of
Owner inspector