

API 661 Air-Cooled Heat Exchanger - Specification Sheet



Job No.	_____	Item No.	_____	Air Cooler
Page	Page 1 of 2	By	_____	
Date	April 2, 2024	Revision	_____	B02
Proposal No.	_____	Contract No.	_____	
Inquiry No.	_____	Order No.	_____	
		No. of Item	_____	2

Manufacturer	_____	Heat exchanged	(kW)	_____	252.
Model no.	_____	Surface/Item-Finned tube	(m ²)	_____	1579.2
Customer	ENER Teknologi	Bare tube	(m ²)	_____	68.101
Plant location	_____	MTD, Eff.	(Deg. C)	_____	6.8
Service	_____	Transfer rate-Finned	(W/m ² -K)	_____	26.509
Type draft	FORCED	Bare tube, service	(W/m ² -K)	_____	614.72
Bay size (WxL)	(m) 2.65 X 6.4	Bare tube, clean	(W/m ² -K)	_____	708.15
No. of bays/Items	1				

Basic design data

Pressure design code	ASME VIII div 1 + API 661	Structural code	_____	UBC 97
Tube bundle code stamped	No. _____	Flammable service	_____	Yes.
Heating coil code stamped	No. _____	Lethal/toxic service	_____	No.

Performance Data - Tube Side

Fluid name	Propane		In	Out
Total fluid entering	(kg/hr) 3089.2	Total flow rate (Liq/Vap)	(kg/hr) 0.0000 / 3089.2	3089.2 / 0.0000
Dew/bubble point	(Deg. C) _____ / _____	Water/Steam	(kg/hr) 0.0000 / 0.0000	0.0000 / 0.0000
	(Deg. C) _____	Noncondensables	(kg/hr) 0.0000	0.0000
Latent heat	(kJ/kg) _____	Molecular Wt. (Vap/Non-cond)	_____ / _____	_____ / _____
Inlet pressure	(bara) 19.867	Density (Liq/Vap)	(kg/m ³) 435.50 / 42.251	435.58 / 46.266
Pressure drop (All/Calc)	(bar) 0.200 / 0.015	Specific heat (Liq/Vap)	(kJ/kg-C) 3.6130 / 2.3072	3.6115 / 2.3963
Velocity (Allow/Calc)	(m/s) _____ / 0.83	Thermal cond. (Liq/Vap)	(W/m-C) 0.0763 / 0.0248	0.0763 / 0.0239
Inside fouling resistance (m ² -K/W)	0.000170	Viscosity (Liq/Vap)	(cP) 0.0728 / 0.0105	0.0729 / 0.0103
Temperature	(Deg. C) In 67.94 / Out 56.66			

Performance Data - Air Side

Air inlet temperature	(Deg. C) 48.00	Face velocity	(m/s) 3.25
Air flow rate/item	(m ³ /s) 46.975	Minimum design ambient temp.(Deg. C)	5.00
Mass velocity	(kg/s-m ²) _____	Altitude	(m) 20.000
Air outlet temperature	(Deg. C) 52.06	Static pressure	(Pa) 108.40
Air flow rate/fan	(m ³ /s) 27.733		

Design, Material, and Construction

Design pressure	(barG) 22 + F.V	Heating Coil	NO.
Test pressure	(barG) _____	No. of tubes	_____
Design temperature	(Deg. C) 120.00	Tube outside diameter	(mm) _____
Min. design metal temp.	(Deg. C) _____	Tube material	_____
Tube bundle		Fin material and type	_____
Size (WxL)	(m) 2.5 X 6.4	Fin thickness	(mm) _____
No./Bay	1	ASME Code, Sec. VIII, Div. 1	_____
Number of tube rows	4	Heating fluid	_____
Bundles in parallel	1	Heating fluid flow rate	(kg/hr) _____
Bundles in series	_____	Temperature (In/Out)	(Deg. C) _____ / _____
Structure mounting	Grade	Inlet pressure	(bar) _____
Pipe rack beams	_____	Pressure drop (All/Calc)	(kPa) _____ / _____
Ladders, walkways, platforms	_____	Design temperature	(Deg. C) _____
Structure surface prep.	_____	Design pressure	(bar) _____
Header surface prep.	_____	Inlet/Outlet nozzle	_____ / _____
Louver	NO.	Header	
Material	_____	Type	Plug
Action control	_____	Material	SA-516 Gr70(N)
Action type	_____	Corrosion Allowance	(mm) 3
		No. of passes	4
		Tube / Tubesheet	Strength weld

API 661 Air-Cooled Heat Exchanger - Specification Sheet



Job No. _____
 Page _____ Page 2 of 2
 Date April 2, 2024
 Proposal No. _____
 Inquiry No. _____

Item No. _____ Air Cooler
 By _____
 Revision _____ B02
 Contract No. _____
 Order No. _____

Design, Material, and Construction (continued)

Header (continued)

Slope / Split	1% on last pass /	No
Plug material	SA 350 LF2 CL.1	
Gasket material	Soft Iron	
Nozzle	No.	Size, (in)
Inlet	1	4
Outlet	2	2
Vent		
Drain		
Chemical Cleaning		
Min. Wall Thk.		
Tube		
Material	SA-334 6	
Tube outside diameter	(mm)	25.400
Min wall thickness	(mm)	1.651

No./Bundle	140
Length	(m) 6.096
Pitch	(mm) 69.850
Layout	Triangular
Fin	
Type	Extruded
Material	Aluminum
Thickness (Base / Tip)	(mm) 1 / 0.24
Selection temp.	(C)
Outside diameter	(mm) 57.150
Fin density	(fin/meter) 433.1
ASME Code, Sec. VIII, Div. 1	
Customer Specifications	

Mechanical Equipment

Fan		
Manufacturer	Axial Fans Int Srl (or equivalent)	
No./Bay	2	
RPM	(Revs/min.)	404
Diameter	(ft)	7
No. of blades		
Angle	(degrees)	
Pitch adjustment	100% Manual	
Blade material	Aluminium	
Hub material	Manufacturer Standard	
@design temp	(kW)	
@min. ambient temp		
Tip speed		
Driver		
Type	Electrical	
Manufacturer	OME ELECTRIC OR AVL	
No./Bay		
Driver	(kW)	7.5

RPM	1500
Service factor	
Enclosure	Exec / IP55
Voltage	400
Phase	3
Cycle	50
Fan noise level	(dB) max 85
Speed Reducer	
Type	V- belt
Manufacturer	
No./Bay	2
Service factor	
Speed ratio	
Support	
Vib. switch	YES
Enclosure	

Controls - Air Side

Air recirculation	
Degree control of outlet process temp. (Max. Cooling), +/-	_____ / _____
Action on control signal failure	
Fan pitch	
Louvers	
Actuator air supply	
Fan	

Louvers	
Positioner	
Signal air pressure (bar)	
From _____ To _____	
From _____ To _____	
Supply air pressure (bar)	
From _____ To _____	
From _____ To _____	

Shipping

Plot area (WxL)	(m) 2.65 X 6.4
Bundle weight	(kg)
Bay	(kg)

Total weight, Dry / Wet (Kg)	(Based On HTRI) 11,800 / 12,300
Shipping (kg)	

1) STD. nominated power.