




This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.

	DEHDASHT PETROCHEMICAL INDUSTRY COMPANY DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT	
	DOCUMENT TITLE: Mechanical Calculation for K.O. Drum	POI: IFA
Contract No.: DPIC/98-12	DOCUMENT No:DPIC9812-000-VD-1002-ME-CLN-0095	Rev. No.: D1

Mechanical Calculation for K.O. Drum

(D-PK6101-3)

PURCHASER'S COMMENT/APPROVAL STATUS					Purchaser: NARGAN
1	AP: Approved (Released for Manufacturing)				Requisition No.: DPIC98-12-001-000-ME-MR-4150-0001-D1
2	AN: Approved With Minor Comments (Fabrication may Proceed)				
3	NF: Approved With Comments (Fabrication not Proceed)				Item No. (Tag No.): (D-PK6101-3)
4	RJ: Rejected				
5	NR: Not be Returned				Vendor Doc. No.:DPIC9812-000-VD-1002-ME-CLN-0095
Date:		Signature:			
					
D1	18.Feb.2022	A.VOSOUGH	DR.A.NEJATI	DR.A.NEJATI	
D0	23.Dec.21	A.VOSOUGH	DR.A.NEJATI	DR.A.NEJATI	
REV	DATE ISSUE	PREPARED	CHECKED	APPROVED	



DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT



DOCUMENT TITLE: Mechanical Calculation for K.O. Drum

POI: IFA

Contract No.: DPIC/98-12

DOCUMENT No: DPIC9812-000-VD-1002-ME-CLN-0095

Rev. No.: D1

This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
1	x	x			
2	x	x			
3	x	x			
4	x	x			
5	x	x			
6	x	x			
7	x	x			
8	x	x			
9	x	x			
10	x	x			
11	x	x			
12	x	x			
13	x	x			
14	x	x			
15	x	x			
16	x	x			
17	x	x			
18	x	x			
19	x	x			
20	x	x			
21	x	x			
22	x	x			
23	x	x			
24	x	x			
25	x	x			
26	x	x			
27	x	x			
28	x	x			
29	x	x			
30	x	x			
31	x	x			
32	x	x			
33	x	x			
34	x	x			
35	x	x			

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
36	x	x			
37	x	x			
38	x	x			
39	x	x			
40	x	x			
41	x	x			
42	x	x			
43	x	x			
44	x	x			
45	x	x			
46	x	x			
47	x	x			
48	x	x			
49	x	x			
50	x	x			
51	x	x			
52	x	x			
53	x	x			
54	x	x			
55	x	x			
56	x	x			
57	x	x			
58	x	x			
59	x	x			
60	x	x			
61	x	x			
62	x	x			
63	x	x			
64	x	x			
65	x	x			
66	x	x			
67	x	x			
68	x	x			
69	x	x			
70	x	x			



DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT



DOCUMENT TITLE: Mechanical Calculation for K.O. Drum

POI: IFA

Contract No.: DPIC/98-12

DOCUMENT No: DPIC9812-000-VD-1002-ME-CLN-0095

Rev. No.: D1

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
71	x	x			
72	x	x			
73	x	x			
74	x	x			
75	x	x			
76	x	x			
77	x	x			
78	x	x			
79	x	x			
80	x	x			
81	x	x			
82	x	x			
83	x	x			
84	x	x			
85	x	x			
86	x	x			
87	x	x			
88	x	x			
89	x	x			
90	x	x			
91	x	x			
92	x	x			
93	x	x			
94	x	x			
95	x	x			
96	x	x			
97	x	x			
98	x	x			
99	x	x			
100	x	x			
101	x	x			
102	x	x			
103	x	x			
104	x	x			
105	x	x			

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
106	x	x			
107	x	x			
108	x	x			
109	x	x			
110	x	x			
111	x	x			
112	x	x			
113	x	x			
114	x	x			
115	x	x			
116	x	x			
117	x	x			
118	x	x			
119	x	x			
120	x	x			
121	x	x			
122	x	x			
123	x	x			
124	x	x			
125	x	x			
126	x	x			
127	x	x			
128	x	x			
129	x	x			
130	x	x			
131	x	x			
132	x	x			
133	x	x			
134	x	x			
135	x	x			
136	x	x			
137	x	x			
138	x	x			
139	x	x			
140	x	x			

This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.



DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT



DOCUMENT TITLE: Mechanical Calculation for K.O. Drum

POI: IFA

Contract No.: DPIC/98-12

DOCUMENT No: DPIC9812-000-VD-1002-ME-CLN-0095

Rev. No.: D1

This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
141	x	x			
142	x	x			
143	x	x			
144	x	x			
145	x	x			
146	x	x			
147	x	x			
148	x	x			
149	x	x			
150	x	x			
151	x	x			
152	x	x			
153	x	x			
154	x	x			
155					
156					
157					
158					
159					
160					
161					
162					
163					
164					
165					
166					
167					
168					
169					
170					
171					
172					
173					
174					
175					

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
176					
177					
178					
179					
180					
181					
182					
183					
184					
185					
186					
187					
188					
189					
190					
191					
192					
193					
194					
195					
196					
197					
198					
199					
200					
201					
202					
203					
204					
205					
206					
207					
208					
209					
210					

Table of Contents

Warnings and Errors:	8
Input Echo:.....	9
XY Coordinate Calculations:.....	16
Internal Pressure Calculations:.....	17
External Pressure Calculations:.....	22
Element and Detail Weights:.....	25
Nozzle Flange MAWP:.....	28
Natural Frequency Calculation:.....	29
Wind Load Calculation:.....	30
Earthquake Load Calculation:.....	33
Wind/Earthquake Shear, Bending:.....	35
Wind Deflection:.....	36
Longitudinal Stress Constants:.....	37
Longitudinal Allowable Stresses:.....	38
Longitudinal Stresses due to:.....	39
Stress due to Combined Loads:.....	41
Center of Gravity Calculation:.....	45
Leg Check, (Operating Case):.....	46
Leg Check, (Filled w/Water):.....	50
Nozzle Summary:.....	53
Nozzle Calcs.: D.....	54
Nozzle Calcs.: LT1.....	64
Nozzle Calcs.: A1.....	73
Nozzle Calcs.: A2.....	83
Nozzle Calcs.: B.....	93
Nozzle Calcs.: LT2.....	103
Nozzle Calcs.: SV.....	111
Nozzle Calcs.: M2.....	119
Nozzle Calcs.: TI.....	129
Nozzle Calcs.: M1.....	134
Nozzle Calcs.: V.....	139
Nozzle Schedule:.....	149
MDMT Summary:.....	151
Vessel Design Summary:.....	153

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no: K.O. Drum (D-PK6101-3)

DESIGN CALCULATION

In Accordance with ASME Section VIII Division 1

ASME Code Version : 2017

Analysis Performed by : SPLM Licensed User

Job File :

Date of Analysis : Feb 18, 2022 8:33pm

PV Elite 2018 SP2, June 2018

Note:

PV Elite performs all calculations internally in Imperial Units to remain compliant with the ASME Code and any built in assumptions in the ASME Code formulas. The finalized results are reflected to show the user's set of selected units.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no: K.O. Drum (D-PK6101-3)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : Calculation Book for K.O. Drum (D-PK6101-3)
Warnings and Errors: Step: 0 8:33pm Feb 18,2022

Class From To : Basic Element Checks.
=====

Class From To: Check of Additional Element Data
=====

There were no geometry errors or warnings.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

PV Elite Vessel Analysis Program: Input Data

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)

Design Internal Pressure (for Hydrotest) 23 bars
 Design Internal Temperature 135.0 °C
 Type of Hydrotest UG-99(b) Note [36]
 Hydrotest Position Vertical
 Projection of Nozzle from Vessel Top 0 mm.
 Projection of Nozzle from Vessel Bottom 0 mm.
 Minimum Design Metal Temperature -45.0 °C
 Type of Construction Welded
 Special Service None
 Degree of Radiography RT-1
 Use Higher Longitudinal Stresses (Flag) Y
 Select t for Internal Pressure (Flag) N
 Select t for External Pressure (Flag) N
 Select t for Axial Stress (Flag) N
 Select Location for Stiff. Rings (Flag) N
 Consider Vortex Shedding N
 Perform a Corroded Hydrotest Y
 Is this a Heat Exchanger No
 User Defined Hydro. Press. (Used if > 0) 0 bars
 User defined MAWP 0 bars
 User defined MAPnc 0 bars

Load Case 1 NP+EW+WI+FW+BW
 Load Case 2 NP+EW+EE+FS+BS
 Load Case 3 NP+OW+WI+FW+BW
 Load Case 4 NP+OW+EQ+FS+BS
 Load Case 5 NP+HW+HI
 Load Case 6 NP+HW+HE
 Load Case 7 IP+OW+WI+FW+BW
 Load Case 8 IP+OW+EQ+FS+BS
 Load Case 9 EP+OW+WI+FW+BW
 Load Case 10 EP+OW+EQ+FS+BS
 Load Case 11 HP+HW+HI
 Load Case 12 HP+HW+HE
 Load Case 13 IP+WE+EW
 Load Case 14 IP+WF+CW
 Load Case 15 IP+VO+OW
 Load Case 16 IP+VE+EW
 Load Case 17 NP+VO+OW
 Load Case 18 FS+BS+IP+OW
 Load Case 19 FS+BS+EP+OW

Wind Design Code ASCE-7 2010
 Wind Load Reduction Scale Factor 0.600
 Basic Wind Speed [V] 200 Km/hr
 Surface Roughness Category C: Open Terrain
 Importance Factor 1.0
 Type of Surface Moderately Smooth
 Base Elevation 300 mm.
 Percent Wind for Hydrotest 33.0
 Using User defined Wind Press. Vs Elev. N
 Height of Hill or Escarpment H or Hh 0 mm.
 Distance Upwind of Crest Lh 0 mm.
 Distance from Crest to the Vessel x 0 mm.
 Type of Terrain (Hill, Escarpment) Flat
 Damping Factor (Beta) for Wind (Ope) 0.0100

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

Damping Factor (Beta) for Wind (Empty)	0.0000	
Damping Factor (Beta) for Wind (Filled)	0.0000	
Seismic Design Code	ASCE 7-2010	
Seismic Load Reduction Scale Factor	0.700	
Importance Factor	1.500	
Table Value Fa	1.000	
Table Value Fv	1.300	
Short Period Acceleration value Ss	0.900	
Long Period Acceleration Value Sl	0.537	
Moment Reduction Factor Tau	1.000	
Force Modification Factor R	2.500	
Site Class	C	
Component Elevation Ratio	z/h	1.000
Amplification Factor	Ap	2.500
Force Factor	0.000	
Consider Vertical Acceleration	Yes	
Minimum Acceleration Multiplier	0.000	
User Value of Sds (used if > 0)	0.624	
Design Pressure + Static Head	Y	
Consider MAP New and Cold in Noz. Design	N	
Consider External Loads for Nozzle Des.	Y	
Use ASME VIII-1 Appendix 1-9	N	
Material Database Year	Current w/Addenda or Code Year	

Configuration Directives:

Do not use Nozzle MDMT Interpretation VIII-1 01-37	No
Use Table G instead of exact equation for "A"	Yes
Shell Head Joints are Tapered	Yes
Compute "K" in corroded condition	Yes
Use Code Case 2286	No
Use the MAWP to compute the MDMT	Yes
For thickness ratios <= 0.35, MDMT will be -155F (-104C)	Yes
For PWHT & P1 Materials the MDMT can be < -55F (-48C)	No
Using Metric Material Databases, ASME II D	No
Calculate B31.3 type stress for Nozzles with Loads	Yes
Reduce the MDMT due to lower membrane stress	Yes

Complete Listing of Vessel Elements and Details:

Element From Node	10
Element To Node	20
Element Type	Elliptical
Description	HEAD 001
Distance "FROM" to "TO"	50 mm.
Inside Diameter	1800 mm.
Element Thickness	18.5 mm.
Internal Corrosion Allowance	3 mm.
Nominal Thickness	22 mm.
External Corrosion Allowance	0 mm.
Design Internal Pressure	23 bars
Design Temperature Internal Pressure	135 °C
Design External Pressure	1.1 bars
Design Temperature External Pressure	135 °C
Effective Diameter Multiplier	1.2
Material Name	SA-516 70 [Impact Tested]
Allowable Stress, Ambient	137.9 N./mm ²
Allowable Stress, Operating	137.9 N./mm ²
Allowable Stress, Hydrotest	235.8 N./mm ²

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

Material Density	0.00775	kg./cm ³
P Number Thickness	29.007	mm.
Yield Stress, Operating	233.7	N./mm ²
UCS-66 Chart Curve Designation	Impact Tested	
External Pressure Chart Name	CS-2	
UNS Number	K02700	
Product Form	Plate	
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Elliptical Head Factor	2.0	
Weld is pre-Heated	No	
Element From Node	10	
Detail Type	Liquid	
Detail ID	VAM + HQ	
Dist. from "FROM" Node / Offset dist	-450	mm.
Height/Length of Liquid	500	mm.
Liquid Density	0	kg./cm ³
Element From Node	10	
Detail Type	Insulation	
Detail ID	Ins: 20	
Dist. from "FROM" Node / Offset dist	-450	mm.
Height/Length of Insulation	500	mm.
Thickness of Insulation	100	mm.
Density	0.00023	kg./cm ³
Element From Node	10	
Detail Type	Nozzle	
Detail ID	D	
Dist. from "FROM" Node / Offset dist	0	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	XXS	
Nozzle Class	300	
Layout Angle	0.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.2179	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]
Element From Node	10	
Detail Type	Nozzle	
Detail ID	LT1	
Dist. from "FROM" Node / Offset dist	200	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	XXS	
Nozzle Class	300	
Layout Angle	180.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.2179	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]

Element From Node	20	
Element To Node	30	
Element Type	Cylinder	
Description	SHELL	
Distance "FROM" to "TO"	2700	mm.
Inside Diameter	1800	mm.
Element Thickness	20	mm.
Internal Corrosion Allowance	3	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

Nominal Thickness	20	mm.
External Corrosion Allowance	0	mm.
Design Internal Pressure	23	bars
Design Temperature Internal Pressure	135	°C
Design External Pressure	1.1	bars
Design Temperature External Pressure	135	°C
Effective Diameter Multiplier	1.2	
Material Name	SA-516 70	[Impact Tested]
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Weld is pre-Heated	No	

Element From Node	20	
Detail Type	Liquid	
Detail ID	VAM + HQ	
Dist. from "FROM" Node / Offset dist	0	mm.
Height/Length of Liquid	2700	mm.
Liquid Density	0	kg./cm ³

Element From Node	20	
Detail Type	Insulation	
Detail ID	Ins: 20	
Dist. from "FROM" Node / Offset dist	0	mm.
Height/Length of Insulation	2700	mm.
Thickness of Insulation	100	mm.
Density	0.00023	kg./cm ³

Element From Node	20	
Detail Type	Nozzle	
Detail ID	A1	
Dist. from "FROM" Node / Offset dist	500	mm.
Nozzle Diameter	12	in.
Nozzle Schedule	80	
Nozzle Class	300	
Layout Angle	90.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	1.4833	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]

Element From Node	20	
Detail Type	Nozzle	
Detail ID	A2	
Dist. from "FROM" Node / Offset dist	1100	mm.
Nozzle Diameter	8	in.
Nozzle Schedule	80	
Nozzle Class	300	
Layout Angle	45.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.755	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]

Element From Node	20	
Detail Type	Nozzle	
Detail ID	B	
Dist. from "FROM" Node / Offset dist	2400	mm.
Nozzle Diameter	12	in.
Nozzle Schedule	80	
Nozzle Class	300	
Layout Angle	270.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	1.4833	kN

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

Grade of Attached Flange GR 1.1
 Nozzle Matl SA-333 6 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID LT2
 Dist. from "FROM" Node / Offset dist 300 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule None
 Nozzle Class 300
 Layout Angle 180.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.09794 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-350 LF2 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID SV
 Dist. from "FROM" Node / Offset dist 1500 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule None
 Nozzle Class 300
 Layout Angle 0.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.09794 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-350 LF2 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID M2
 Dist. from "FROM" Node / Offset dist 2450 mm.
 Nozzle Diameter 6 in.
 Nozzle Schedule 80
 Nozzle Class 300
 Layout Angle 90.0
 Blind Flange (Y/N) Y
 Weight of Nozzle (Used if > 0) 0.8833 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-333 6 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID TI
 Dist. from "FROM" Node / Offset dist 200 mm.
 Nozzle Diameter 1.5 in.
 Nozzle Schedule None
 Nozzle Class 300
 Layout Angle 270.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.07803 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-350 LF2 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID M1
 Dist. from "FROM" Node / Offset dist 700 mm.
 Nozzle Diameter 20 in.
 Nozzle Schedule None
 Nozzle Class 300
 Layout Angle 0.0

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

Blind Flange (Y/N)	Y
Weight of Nozzle (Used if > 0)	5.1958 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-516 70 [Impact Tested]

Element From Node	20
Detail Type	Leg
Detail ID	LEGS
Dist. from "FROM" Node / Offset dist	300 mm.
Diameter at Leg Centerline	1844 mm.
Leg Orientation	1
Number of Legs	4

Element From Node	20
Detail Type	Weight
Detail ID	DEMISTER WEIGHT
Dist. from "FROM" Node / Offset dist	2000 mm.
Miscellaneous Weight	4.903 kN
Offset from Element Centerline	0 mm.

Element From Node	30
Element To Node	40
Element Type	Elliptical
Description	HEAD 002
Distance "FROM" to "TO"	50 mm.
Inside Diameter	1800 mm.
Element Thickness	18.5 mm.
Internal Corrosion Allowance	3 mm.
Nominal Thickness	22 mm.
External Corrosion Allowance	0 mm.
Design Internal Pressure	23 bars
Design Temperature Internal Pressure	135 °C
Design External Pressure	1.1 bars
Design Temperature External Pressure	135 °C
Effective Diameter Multiplier	1.2
Material Name	SA-516 70 [Impact Tested]
Efficiency, Longitudinal Seam	1.0
Efficiency, Circumferential Seam	1.0
Elliptical Head Factor	2.0
Weld is pre-Heated	No

Element From Node	30
Detail Type	Liquid
Detail ID	VAM + HQ
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Liquid	500 mm.
Liquid Density	0 kg./cm ³

Element From Node	30
Detail Type	Insulation
Detail ID	Ins: 20
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Insulation	500 mm.
Thickness of Insulation	100 mm.
Density	0.00023 kg./cm ³

Element From Node	30
Detail Type	Nozzle
Detail ID	V
Dist. from "FROM" Node / Offset dist	0 mm.
Nozzle Diameter	2 in.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Input Echo: Step: 1 8:33pm Feb 18,2022

Nozzle Schedule	XXS	
Nozzle Class	300	
Layout Angle	0.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.1108	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 XY Coordinate Calculations: Step: 2 8:33pm Feb 18,2022

XY Coordinate Calculations:

From	To	X (Horiz.) mm.	Y (Vert.) mm.	DX (Horiz.) mm.	DY (Vert.) mm.
HEAD 001		...	50	...	50
SHELL		...	2750	...	2700
HEAD 002		...	2800	...	50

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Internal Pressure Calculations: Step: 3 8:33pm Feb 18,2022

Element Thickness, Pressure, Diameter and Allowable Stress :

From	To	Int. Press + Liq. Hd bars	Nominal Thickness mm.	Total Corr Allowance mm.	Element Diameter mm.	Allowable Stress (SE) N./mm ²
HEAD 001		23.002	22	3	1800	137.9
SHELL		23.002	20	3	1800	137.9
HEAD 002		23	22	3	1800	137.9

Element Required Thickness and MAWP :

From	To	Design Pressure bars	M.A.W.P. Corroded bars	M.A.P. New & Cold bars	Minimum Thickness mm.	Required Thickness mm.
HEAD 001		23	23.7309	28.2863	18.5	18.0218
SHELL		23	25.668	30.2395	20	18.2153
HEAD 002		23	23.7328	28.2863	18.5	18.0206
Minimum			23.731	28.286		

MAWP: 23.731 bars, limited by: HEAD 001.

Internal Pressure Calculation Results :

ASME Code, Section VIII Division 1, 2017

Elliptical Head From 10 To 20 SA-516 70 at 135 °C

HEAD 001

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)}$$

$$= (23 \cdot 1806 \cdot 0.996) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23)$$

$$= 15.0218 + 3.0000 = 18.0218 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.002 bars

$$= (2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 137.9 \cdot 1 \cdot 15.5) / (0.996 \cdot 1806 + 0.2 \cdot 15.5)$$

$$= 23.733 - 0.002 = 23.731 \text{ bars}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D + 0.2 \cdot t) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 137.9 \cdot 1 \cdot 18.5) / (1 \cdot 1800 + 0.2 \cdot 18.5)$$

$$= 28.286 \text{ bars}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \cdot (K_{cor} \cdot D + 0.2 \cdot t)) / (2 \cdot E \cdot t)$$

$$= (23 \cdot (0.996 \cdot 1806 + 0.2 \cdot 15.5)) / (2 \cdot 1 \cdot 15.5)$$

$$= 133.653 \text{ N./mm}^2$$

Straight Flange Required Thickness:

$$= (P \cdot R) / (S \cdot E - 0.6 \cdot P) + c \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23) + 3$$

$$= 18.215 \text{ mm.}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Internal Pressure Calculations: Step: 3 8:33pm Feb 18,2022

Straight Flange Maximum Allowable Working Pressure:

Less Operating Hydrostatic Head Pressure of 0.002 bars

$$= (S*E*t)/(R+0.6*t) \text{ per UG-27 (c) (1)}$$

$$= (137.9 * 1 * 19)/(903 + 0.6 * 19)$$

$$= 28.652 - 0.002 = 28.650 \text{ bars}$$

Factor K, corroded condition [Kcor]:

$$= (2 + (\text{Inside Diameter}/(2 * \text{Inside Head Depth}))^2)/6$$

$$= (2 + (1806/(2 * 453))^2)/6$$

$$= 0.995592$$

Percent Elong. per UCS-79, VIII-1-01-57 $(75*t_{nom}/R_f)*(1-R_f/R_o)$ 5.205 %

Note: Please Check Requirements of UCS-79 as Elongation is > 5%.

MDMT Calculations in the Knuckle Portion:

Note: This Element/Detail was specified as being Impact Tested.

MDMT Calculations in the Head Straight Flange:

Note: This Element/Detail was specified as being Impact Tested.

Cylindrical Shell From 20 To 30 SA-516 70 at 135 °C

SHELL

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$= (P*R)/(S*E-0.6*P) \text{ per UG-27 (c) (1)}$$

$$= (23*903)/(137.9*1-0.6*23)$$

$$= 15.2153 + 3.0000 = 18.2153 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.002 bars

$$= (S*E*t)/(R+0.6*t) \text{ per UG-27 (c) (1)}$$

$$= (137.9*1*17)/(903+0.6*17)$$

$$= 25.670 - 0.002 = 25.668 \text{ bars}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (S*E*t)/(R+0.6*t) \text{ per UG-27 (c) (1)}$$

$$= (137.9*1*20)/(900+0.6*20)$$

$$= 30.239 \text{ bars}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P*(R+0.6*t))/(E*t)$$

$$= (23*(903+0.6*17))/(1*17)$$

$$= 123.568 \text{ N./mm}^2$$

% Elongation per Table UG-79-1 $(50*t_{nom}/R_f)*(1-R_f/R_o)$ 1.099 %

Minimum Design Metal Temperature Results:

Note: This Element/Detail was specified as being Impact Tested.

Elliptical Head From 30 To 40 SA-516 70 at 135 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Internal Pressure Calculations: Step: 3 8:33pm Feb 18,2022

HEAD 002

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:
 = $(P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P)$ Appendix 1-4 (c)
 = $(23 \cdot 1806 \cdot 0.996) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23)$
 = 15.0206 + 3.0000 = 18.0206 mm.

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:
 Less Operating Hydrostatic Head Pressure of 0.000 bars
 = $(2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t)$ per Appendix 1-4 (c)
 = $(2 \cdot 137.9 \cdot 1 \cdot 15.5) / (0.996 \cdot 1806 + 0.2 \cdot 15.5)$
 = 23.733 - 0.000 = 23.733 bars

Maximum Allowable Pressure, New and Cold [MAPNC]:
 = $(2 \cdot S \cdot E \cdot t) / (K \cdot D + 0.2 \cdot t)$ per Appendix 1-4 (c)
 = $(2 \cdot 137.9 \cdot 1 \cdot 18.5) / (1 \cdot 1800 + 0.2 \cdot 18.5)$
 = 28.286 bars

Actual stress at given pressure and thickness, corroded [Sact]:
 = $(P \cdot (K_{cor} \cdot D + 0.2 \cdot t)) / (2 \cdot E \cdot t)$
 = $(23 \cdot (0.996 \cdot 1806 + 0.2 \cdot 15.5)) / (2 \cdot 1 \cdot 15.5)$
 = 133.642 N./mm²

Straight Flange Required Thickness:
 = $(P \cdot R) / (S \cdot E - 0.6 \cdot P) + c$ per UG-27 (c) (1)
 = $(23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23) + 3$
 = 18.214 mm.

Straight Flange Maximum Allowable Working Pressure:
 Less Operating Hydrostatic Head Pressure of 0.000 bars
 = $(S \cdot E \cdot t) / (R + 0.6 \cdot t)$ per UG-27 (c) (1)
 = $(137.9 \cdot 1 \cdot 19) / (903 + 0.6 \cdot 19)$
 = 28.652 - 0.000 = 28.652 bars

Factor K, corroded condition [Kcor]:
 = $(2 + (\text{Inside Diameter} / (2 \cdot \text{Inside Head Depth}))^2) / 6$
 = $(2 + (1806 / (2 \cdot 453))^2) / 6$
 = 0.995592

Percent Elong. per UCS-79, VIII-1-01-57 $(75 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$ 5.205 %
 Note: Please Check Requirements of UCS-79 as Elongation is > 5%.

MDMT Calculations in the Knuckle Portion:

Note: This Element/Detail was specified as being Impact Tested.

MDMT Calculations in the Head Straight Flange:

Note: This Element/Detail was specified as being Impact Tested.

Hydrostatic Test Pressure Results:

Pressure per UG99b	= 1.30 * M.A.W.P. * Sa/S	30.850 bars
Pressure per UG99b[36]	= 1.30 * Design Pres * Sa/S	29.900 bars
Pressure per UG99c	= 1.30 * M.A.P. - Head (Hyd)	36.723 bars
Pressure per UG100	= 1.10 * M.A.W.P. * Sa/S	26.104 bars

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Internal Pressure Calculations: Step: 3 8:33pm Feb 18,2022

Pressure per PED = $\max(1.43*DP, 1.25*DP*ratio)$ 32.775 bars
 Pressure per App 27-4 = $1.30 * M.A.W.P. * Sa/S$ 30.850 bars

UG-99(b) Note 36, Test Pressure Calculation:

= Test Factor * Design Pressure * Stress Ratio
 = $1.3 * 23 * 1$
 = 29.900 bars

Vertical Test performed per: UG-99b (Note 36)

Please note that Nozzle, Shell, Head, Flange, etc MAWPs are all considered when determining the hydrotest pressure for those test types that are based on the MAWP of the vessel.

Stresses on Elements due to Test Pressure (N./mm² & bars):

From To	Stress	Allowable	Ratio	Pressure
HEAD 001	175.8	235.8	0.746	30.26
SHELL	162.3	235.8	0.688	30.21
HEAD 002	174.0	235.8	0.738	29.95

Stress ratios for Nozzle and Pad Materials (N./mm²):

Description	Pad/Nozzle	Ambient	Operating	Ratio
D	Nozzle	117.90	117.90	1.000
D	Pad	137.90	137.90	1.000
LT1	Nozzle	117.90	117.90	1.000
LT1	Pad	137.90	137.90	1.000
A1	Nozzle	117.90	117.90	1.000
A1	Pad	137.90	137.90	1.000
A2	Nozzle	117.90	117.90	1.000
A2	Pad	137.90	137.90	1.000
B	Nozzle	117.90	117.90	1.000
B	Pad	137.90	137.90	1.000
LT2	Nozzle	137.90	137.90	1.000
SV	Nozzle	137.90	137.90	1.000
M2	Nozzle	117.90	117.90	1.000
M2	Pad	137.90	137.90	1.000
TI	Nozzle	137.90	137.90	1.000
M1	Nozzle	137.90	137.90	1.000
M1	Pad	137.90	137.90	1.000
V	Nozzle	117.90	117.90	1.000
V	Pad	137.90	137.90	1.000
Minimum				1.000

Stress ratios for Pressurized Vessel Elements (N./mm²):

Description	Ambient	Operating	Ratio
HEAD 001	137.90	137.90	1.000
SHELL	137.90	137.90	1.000
HEAD 002	137.90	137.90	1.000
Minimum			1.000

Hoop Stress in Nozzle Wall during Pressure Test (N./mm²):

Description	Ambient	Operating	Ratio
-------------	---------	-----------	-------

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Internal Pressure Calculations: Step: 3 8:33pm Feb 18,2022

D	12.43	217.19	0.057
LT1	12.43	217.19	0.057
A1	38.61	217.19	0.178
A2	39.45	217.19	0.182
B	38.37	217.19	0.177
LT2	8.11	223.40	0.036
SV	8.08	223.40	0.036
M2	37.01	217.19	0.170
TI	6.95	223.40	0.031
M1	43.84	235.81	0.186
V	12.31	217.20	0.057

Elements Suitable for Internal Pressure.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 External Pressure Calculations: Step: 4 8:33pm Feb 18,2022

External Pressure Calculation Results :

External Pressure Calculations:

From	To	Section Length mm.	Outside Diameter mm.	Corroded Thickness mm.	Factor A	Factor B N./mm ²
10	20	No Calc	1837	15.5	0.0011719	90.0274
20	30	3100	1840	17	0.00069012	68.996
30	40	No Calc	1837	15.5	0.0011719	90.0274

External Pressure Calculations:

From	To	External Actual T. mm.	External Required T. mm.	External Design Pressure bars	External M.A.W.P. bars
10	20	18.5	7.90534	1.1	8.43975
20	30	20	10.5181	1.1	8.49902
30	40	18.5	7.90534	1.1	8.43975
Minimum					8.440

External Pressure Calculations:

From	To	Actual Length Bet. Stiffeners mm.	Allowable Length Bet. Stiffeners mm.	Ring Inertia Required cm**4	Ring Inertia Available cm**4
10	20	No Calc	No Calc	No Calc	No Calc
20	30	3100	63928.7	No Calc	No Calc
30	40	No Calc	No Calc	No Calc	No Calc

Elements Suitable for External Pressure.

ASME Code, Section VIII Division 1, 2017

Elliptical Head From 10 to 20 Ext. Chart: CS-2 at 135 °C

HEAD 001

Elastic Modulus from Chart: CS-2 at 135 °C : 0.200E+09 KPa.

Results for Maximum Allowable External Pressure (MAEP):

Tca	OD	D/t	Factor A	B
15.500	1837.00	118.52	0.0011719	90.03

EMAP = B/(K0*D/t) = 90.03/(0.9 *118.5) = 8.44 bars

Results for Required Thickness (Tca):

Tca	OD	D/t	Factor A	B
4.905	1837.00	374.49	0.0003709	37.08

EMAP = B/(K0*D/t) = 37.08/(0.9 *374.5) = 1.1 bars

Check the requirements of UG-33(a)(1) using $P = 1.67 * \text{External Design pressure for this head.}$

Material UNS Number: K02700

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 External Pressure Calculations: Step: 4 8:33pm Feb 18,2022

Required Thickness due to Internal Pressure [tr]:

$$= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)}$$

$$= (1.837 \cdot 1806 \cdot 0.996) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 1.837)$$

$$= 1.1978 + 3.0000 = 4.1978 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$= ((2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t)) / 1.67 \text{ per Appendix 1-4 (c)}$$

$$= ((2 \cdot 137.9 \cdot 1 \cdot 15.5) / (0.996 \cdot 1806 + 0.2 \cdot 15.5)) / 1.67$$

$$= 14.211 \text{ bars}$$

Maximum Allowable External Pressure [MAEP]:

$$= \min(\text{MAEP}, \text{MAWP})$$

$$= \min(8.44, 14.21)$$

$$= 8.440 \text{ bars}$$

Thickness requirements per UG-33(a)(1) do not govern the required thickness of this head.

Cylindrical Shell From 20 to 30 Ext. Chart: CS-2 at 135 °C

SHELL

Elastic Modulus from Chart: CS-2 at 135 °C : 0.200E+09 KPa.

Results for Maximum Allowable External Pressure (MAEP):

Tca	OD	SLEN	D/t	L/D	Factor A	B
17.000	1840.00	3100.00	108.24	1.6848	0.0006901	69.00

$$\text{EMAP} = (4 \cdot B) / (3 \cdot (D/t)) = (4 \cdot 69) / (3 \cdot 108.2) = 8.499 \text{ bars}$$

Results for Required Thickness (Tca):

Tca	OD	SLEN	D/t	L/D	Factor A	B
7.518	1840.00	3100.00	244.74	1.6848	0.0002020	20.19

$$\text{EMAP} = (4 \cdot B) / (3 \cdot (D/t)) = (4 \cdot 20.19) / (3 \cdot 244.7) = 1.1 \text{ bars}$$

Results for Maximum Stiffened Length (Slen):

Tca	OD	SLEN	D/t	L/D	Factor A	B
17.000	1840.00	63928.74	108.24	34.7439	0.0000955	9.55

$$\text{EMAP} = (4 \cdot B) / (3 \cdot (D/t)) = (4 \cdot 9.548) / (3 \cdot 108.2) = 1.176 \text{ bars}$$

Elliptical Head From 30 to 40 Ext. Chart: CS-2 at 135 °C

HEAD 002

Elastic Modulus from Chart: CS-2 at 135 °C : 0.200E+09 KPa.

Results for Maximum Allowable External Pressure (MAEP):

Tca	OD	D/t	Factor A	B
15.500	1837.00	118.52	0.0011719	90.03

$$\text{EMAP} = B / (K_0 \cdot D/t) = 90.03 / (0.9 \cdot 118.5) = 8.44 \text{ bars}$$

Results for Required Thickness (Tca):

Tca	OD	D/t	Factor A	B
4.905	1837.00	374.49	0.0003709	37.08

$$\text{EMAP} = B / (K_0 \cdot D/t) = 37.08 / (0.9 \cdot 374.5) = 1.1 \text{ bars}$$

Check the requirements of UG-33(a)(1) using $P = 1.67 \cdot \text{External Design pressure}$ for this head.

Material UNS Number: K02700

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no: K.O. Drum (D-PK6101-3)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : Calculation Book for K.O. Drum (D-PK6101-3)
External Pressure Calculations: Step: 4 8:33pm Feb 18,2022

Required Thickness due to Internal Pressure [tr]:
= $(P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P)$ Appendix 1-4 (c)
= $(1.837 \cdot 1806 \cdot 0.996) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 1.837)$
= $1.1978 + 3.0000 = 4.1978$ mm.

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:
= $((2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t)) / 1.67$ per Appendix 1-4 (c)
= $((2 \cdot 137.9 \cdot 1 \cdot 15.5) / (0.996 \cdot 1806 + 0.2 \cdot 15.5)) / 1.67$
= 14.211 bars

Maximum Allowable External Pressure [MAEP]:
= min(MAEP, MAWP)
= min(8.44, 14.21)
= 8.440 bars

Thickness requirements per UG-33(a)(1) do not govern the required thickness of this head.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Element and Detail Weights: Step: 5 8:33pm Feb 18,2022

Element and Detail Weights:

From	To	Element Metal Wgt. kg.	Element ID Volume Cm3	Corroded Metal Wgt. kg.	Corroded ID Volume Cm3	Extra due Misc % kg.
10	20	726.27	890801	627.233	899312	21.7881
20	30	2393.01	6871894	2037.42	6917783	71.7904
30	40	726.27	890801	627.233	899312	21.7881
Total		3845	8653497.00	3291	8716407.00	115

Weight of Details:

From	Type	Weight of Detail kg.	X Offset, Dtl. Cent. mm.	Y Offset, Dtl. Cent. mm.	Description
10	Liqd	5.16349	...	-225	VAM + HQ
10	Insl	124.236	...	-200	Ins: 20
10	Nozl	22.8845	...	-757.084	D
10	Nozl	22.8845	-200	-1095.83	LT1
20	Liqd	39.8327	...	1350	VAM + HQ
20	Insl	378.923	...	1350	Ins: 20
20	Nozl	155.801	1061.92	500	A1
20	Nozl	79.3002	1009.54	1100	A2
20	Nozl	155.801	1061.92	2400	B
20	Nozl	10.2877	925.4	300	LT2
20	Nozl	10.2877	925.4	1500	SV
20	Nozl	92.7838	984.138	2450	M2
20	Nozl	8.19652	919.05	200	TI
20	Nozl	545.758	1154	700	M1
20	Legs	411.778	...	-490	LEGS
20	Wght	500	...	2000	DEMISTER WEIGHT
30	Liqd	5.16349	...	275	VAM + HQ
30	Insl	124.236	...	250	Ins: 20
30	Nozl	11.636	...	600	V

Total Weight of Each Detail Type

Total Weight of Liquid	50.2
Total Weight of Insulation	627.4
Total Weight of Nozzles	1115.6
Total Weight of Legs	411.8
Total Weight of Weights	500.0

Sum of the Detail Weights	2705.0 kg.

Weight Summation: kg.

Fabricated	Shop Test	Shipping	Erected	Empty	Operating
3960.9	5488.3	3960.9	5488.3	3960.9	6615.7
...	8648.2	50.2
1115.6	...	1115.6
411.8	...	411.8	627.4
...	627.4	...
...	500.0
...	-500.0
...	1115.6	...
...	411.8	...

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Element and Detail Weights: Step: 5 8:33pm Feb 18,2022

...	500.0	500.0	...
5488.3	14136.5	5488.3	6615.7	6615.7	6665.9

Miscellaneous Weight Percent: 3.0 %

Note that the above value for the miscellaneous weight percent has been applied to the shells/heads/flange/tubesheets/tubes etc. in the weight calculations for metallic components.

Weight Summary

Fabricated Wt. - Bare Weight W/O Removable Internals	5488.3 kg.
Shop Test Wt. - Fabricated Weight + Water (Full)	14136.5 kg.
Shipping Wt. - Fab. Wt + Rem. Intls.+ Shipping App.	5488.3 kg.
Erected Wt. - Fab. Wt + Rem. Intls.+ Insul. (etc)	6615.7 kg.
Ope. Wt. no Liq - Fab. Wt + Intls. + Details + Wghts.	6615.7 kg.
Operating Wt. - Empty Wt + Operating Liq. Uncorroded	6665.9 kg.
Field Test Wt. - Empty Weight + Water (Full)	14256.5 kg.
Mass of the Upper 1/3 of the Vertical Vessel	2382.1 kg.

Note: The Field Test weight as computed in the corroded condition.

Outside Surface Areas of Elements:

From	To	Surface Area cm ²
10	20	39755.7
20	30	156074
30	40	39755.7
Total		235585.719 cm ²

Element and Detail Weights:

From	To	Total Ele. Empty Wgt. kg.	Total. Ele. Oper. Wgt. kg.	Total. Ele. Hydro. Wgt. kg.	Total Dtl. Offset Mom. N-m	Oper. Wgt. No Liquid kg.
10	20	793.827	923.227	1714.82	44.8993	918.064
20	Legs	447.002	493.531	1161.03	1262.92	489.105
Legs	30	3576.02	3948.25	9288.21	10103.3	3912.84
30	40	759.694	889.094	1680.69	...	883.931

Cumulative Vessel Weight

From	To	Cumulative Ope Wgt. No Liquid kg.	Cumulative Oper. Wgt. kg.	Cumulative Hydro. Wgt. kg.
10	20
20	Legs	-918.064	-923.227	-1714.82
Legs	30	4796.77	4837.34	10968.9
30	40	883.931	889.094	1680.69

Note: The cumulative operating weights no liquid in the column above are the cumulative operating weights minus the operating liquid weight minus any weights absent in the empty condition.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Element and Detail Weights: Step: 5 8:33pm Feb 18,2022

Cumulative Vessel Moment

From	To	Cumulative Empty Mom. N-m	Cumulative Oper. Mom. N-m	Cumulative Hydro. Mom. N-m
10	20	44.8993	44.8993	44.8993
20	Legs	1307.82	1307.82	1307.82
Legs	30	10103.3	10103.3	10103.3
30	40

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Flange MAWP: Step: 6 8:33pm Feb 18,2022

Nozzle Flange MAWP Results:

Nozzle Description	Flange Rating		Design Temp °C	Class	Grade/Group	Equiv. Press	Max Pressure		
	Ope. bars	Ambient bars					PVP	50%	DNV bars
D	45.5	51.1	135	300	GR 1.1
LT1	45.5	51.1	135	300	GR 1.1
A1	45.5	51.1	135	300	GR 1.1	25.4	43.0	45.5	43.0
A2	45.5	51.1	135	300	GR 1.1
B	45.5	51.1	135	300	GR 1.1
LT2	45.5	51.1	135	300	GR 1.1
SV	45.5	51.1	135	300	GR 1.1
M2	45.5	51.1	135	300	GR 1.1
TI	45.5	51.1	135	300	GR 1.1
M1	45.5	51.1	135	300	GR 1.1
V	45.5	51.1	135	300	GR 1.1
Min Rating	45.550	51.100 bars [for Core Elements]					42.968	45.550	42.968

Selected Method for Derating ANSI Flange MAWP: None Selected

Note: ANSI Ratings are per ANSI/ASME B16.5 2013 Metric Edition

The PVP Method is based on the paper PVP 2013-97814. PV Elite uses the maximum loads from each load category to determine ME and FE. In many cases, the computed maximum allowable pressure will be greater than the flange rating. In these cases, the minimum of the rating from the table and the PVP method will be used. SA-193 B8 Cl. 2 bolts or ones with higher allowable stresses at the specified bolt size shall be used. Note that ANSI pipe nominal sizes up to 24 inch (600mm) are addressed.

How the 50% Stress Method Works:

If the computed stress/allowable stress is < 0.5 on the pipe wall, then the allowable pressure is the table rating from the ANSI/ASME standard. If the stress ratio is >= 0.5, then the full equivalent pressure is subtracted from the flange rating.

The DNV Method:

minimum(table rating, 1.5 * Operating rating - equivalent pressure)

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no: K.O. Drum (D-PK6101-3)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : Calculation Book for K.O. Drum (D-PK6101-3)
Natural Frequency Calculation: Step: 7 8:33pm Feb 18,2022

The Natural Frequencies for the vessel have been computed iteratively by solving a system of matrices. These matrices describe the mass and the stiffness of the vessel. This is the generalized eigenvalue/eigenvector problem and is referenced in some mathematical texts.

The Natural Frequency for the Vessel (Empty.) is 25.888 Hz.

The Natural Frequency for the Vessel (Ope...) is 25.7833 Hz.

The Natural Frequency for the Vessel (Filled) is 17.3178 Hz.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Wind Load Calculation: Step: 8 8:33pm Feb 18,2022

Input Values:

Wind Design Code	ASCE-7 2010
Wind Load Reduction Scale Factor	0.600
Basic Wind Speed	[V] 200 Km/hr
Surface Roughness Category	C: Open Terrain
Importance Factor	1.0
Type of Surface	Moderately Smooth
Base Elevation	300 mm.
Percent Wind for Hydrottest	33.0
Using User defined Wind Press. Vs Elev.	N
Height of Hill or Escarpment H or Hh	0 mm.
Distance Upwind of Crest Lh	0 mm.
Distance from Crest to the Vessel x	0 mm.
Type of Terrain (Hill, Escarpment)	Flat
Damping Factor (Beta) for Wind (Ope)	0.0100
Damping Factor (Beta) for Wind (Empty)	0.0000
Damping Factor (Beta) for Wind (Filled)	0.0000

Wind Analysis Results

Static Gust-Effect Factor, Operating Case [G]:

$$\begin{aligned}
 &= \min(0.85, 0.925((1 + 1.7 * gQ * Izbar * Q) / (1 + 1.7 * gV * Izbar))) \\
 &= \min(0.85, 0.925((1+1.7*3.4*0.228*0.963) / (1+1.7*3.4*0.228))) \\
 &= \min(0.85, 0.905) \\
 &= 0.850
 \end{aligned}$$

Natural Frequency of Vessel (Operating)	25.783 Hz
Natural Frequency of Vessel (Empty)	25.888 Hz
Natural Frequency of Vessel (Test)	17.318 Hz

Force Coefficient	[Cf] 0.512
Structure Height to Diameter ratio	1.714
Height to top of Structure	3368.500 mm.

This is classified as a rigid structure. Static analysis performed.

Sample Calculation for the First Element

The ASCE code performs all calculations in Imperial Units only. The wind pressure is therefore computed in these units.

Value of [Alpha] and [Zg]:

Exposure Category: C from Table 26.9.1
 Alpha = 9.5 : Zg = 274320 mm.

Effective Height [z]:

$$\begin{aligned}
 &= \text{Centroid Height} + \text{Vessel Base Elevation} \\
 &= 354 + 300 = 654 \text{ mm.} \\
 &= 2.146 \text{ ft. Imperial Units}
 \end{aligned}$$

Velocity Pressure coefficient evaluated at height z [Kz]:

$$\begin{aligned}
 &\text{Because } z (2.146 \text{ ft.}) < 15 \text{ ft.} \\
 &= 2.01 * (15 / Zg) ^ { 2 / \text{Alpha}} \\
 &= 2.01 * (15/900) ^ {2/9.5} \\
 &= 0.849
 \end{aligned}$$

Type of Hill: No Hill

Wind Directionality Factor [Kd]:

$$= 0.95 \text{ per Table 26.6-1}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY**DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT****Tag no: K.O. Drum (D-PK6101-3)****PV Elite 2018 SP2 Licensee: SPLM Licensed User****FileName : Calculation Book for K.O. Drum (D-PK6101-3)****Wind Load Calculation: Step: 8 8:33pm Feb 18,2022**

As there is No Hill Present: [Kzt]:

$$K1 = 0, K2 = 0, K3 = 0$$

Topographical Factor [Kzt]:

$$= (1 + K1 * K2 * K3)^2$$

$$= (1 + 0 * 0 * 0)^2$$

$$= 1$$

Velocity Pressure evaluated at height z, Imperial Units [qz]:

$$= \max(16, 0.00256 * Kz * Kzt * Kd * V(\text{mph})^2)$$

$$= \max(16, 0.00256 * 0.849 * 1 * 0.95 * 124.3^2)$$

$$= 31.89 \text{ psf [155.7] Kgs/m}^2$$

Force on the first element [F]:

$$= qz * G * Cf * \text{WindArea}$$

$$= 31.89 * 0.85 * 0.512 * 13.06$$

$$= 181.2 \text{ lbs. [0.806] kN}$$

Element	Hgt (z) mm.	K1	K2	K3	Kz	Kzt	qz Kgs/m ²
HEAD 001	654.0	0.000	0.000	0.000	0.849	1.000	155.683
SHELL	2150.0	0.000	0.000	0.000	0.849	1.000	155.683
HEAD 002	3764.5	0.000	0.000	0.000	0.849	1.000	155.683

Wind Vibration Calculations

This evaluation is based on work by Kanti Mahajan and Ed Zorilla

Nomenclature

- Cf - Correction factor for natural frequency
- D - Average internal diameter of vessel mm.
- Df - Damping Factor < 0.75 Unstable, > 0.95 Stable
- Dr - Average internal diameter of top half of vessel mm.
- f - Natural frequency of vibration (Hertz)
- f1 - Natural frequency of bare vessel based on a unit value of (D/L²) (10⁴)
- L - Total height of structure mm.
- Lc - Total length of conical section(s) of vessel mm.
- tb - Uncorroded plate thickness at bottom of vessel mm.
- V30 - Design Wind Speed provided by user Km/hr
- Vc - Critical wind velocity Km/hr
- Vw - Maximum wind speed at top of structure Km/hr
- W - Total corroded weight of structure kN
- Ws - Cor. vessel weight excl. weight of parts which do not effect stiff. kN
- Z - Maximum amplitude of vibration at top of vessel mm.
- Dl - Logarithmic decrement (taken as 0.03 for Welded Structures)
- Vp - Vib. Chance, <= 0.000 (High); 0.000 < 0.000 (Probable)
- P30 - wind pressure 30 feet above the base

Check other Conditions and Basic Assumptions:

$$\#1 - \text{Total Cone Length} / \text{Total Length} < 0.5$$

$$0/2800 = 0$$

$$\#2 - (D / L^2) * 10^4 < 8.0 \text{ (English Units)}$$

$$- (6.693/9.186^2) * 10^4 = 793.1 \text{ [Geometry Violation]}$$

Compute the vibration possibility. If Vp > 0.000 no chance. [Vp]:

$$= W / (L * Dr^2)$$

$$= 59.77 / (2800 * 1806^2)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Wind Load Calculation: Step: 8 8:33pm Feb 18,2022

= 0.65451E-08

Since V_p is > 0.000 no further vibration analysis is required !

Wind Loads on Masses/Equipment/Piping

ID	Wind Area cm ²	Elevation mm.	Pressure Kgs/m ²	Force kN
DEMISTER WEIG	0.00	2350.00	155.68	0.00

The Natural Frequency for the Vessel (Ope...) is 25.7833 Hz.

Wind Load Calculation:

From	To	Wind Height mm.	Wind Diameter mm.	Wind Area cm ²	Wind Pressure Kgs/m ²	Element Wind Load kN
10	20	654.037	2444.4	12136.4	155.683	0.4837
20	30	2150	2448	66096	155.683	2.63426
30	40	3764.46	2444.4	12136.4	155.683	0.4837

Note:

The Wind Loads calculated and printed in the Wind Load calculation report have been factored by the input scalar/load reduction factor of: 0.600.

Be sure the wind speed is in accordance with the specified wind design code.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Earthquake Load Calculation: Step: 9 8:33pm Feb 18,2022

Earthquake Load Calculation:

Input Values:

Seismic Design Code		ASCE 7-2010
Seismic Load Reduction Scale Factor		0.700
Importance Factor		1.500
Table Value Fa		1.000
Table Value Fv		1.300
Short Period Acceleration value Ss		0.900
Long Period Acceleration Value S1		0.537
Moment Reduction Factor Tau		1.000
Force Modification Factor R		2.500
Site Class		C
Component Elevation Ratio	z/h	1.000
Amplification Factor	Ap	2.500
Force Factor		0.000
Consider Vertical Acceleration		Yes
Minimum Acceleration Multiplier		0.000
User Value of Sds (used if > 0)		0.624

Seismic Analysis Results:

$$\begin{aligned} S_{ms} &= F_a * S_s = 1 * 0.9 = 0.9 \\ S_{m1} &= F_v * S_1 = 1.3 * 0.537 = 0.698 \\ S_{ds} &= 2/3 * S_{ms} = 2/3 * 0.9 = 0.6 \end{aligned}$$

$$\begin{aligned} S_{ds} &= \text{Max}(0.8*S_{ds}, S_{dsUser}) \\ &= \text{Max}(0.48, 0.624) \\ &= 0.624 \end{aligned}$$

$$S_{d1} = 2/3 * S_{m1} = 2/3 * 0.698 = 0.465$$

$$\begin{aligned} S_{d1} &= \text{Max}(0.8*S_{d1}, S_{d1User}) \\ &= \text{Max}(0.372, 0.39) \\ &= 0.390 \end{aligned}$$

Check Approximate Fundamental Period from 12.8-7 [Ta]:

$$\begin{aligned} &= C_t * h_n^x \text{ where } C_t = 0.020, x = 0.75 \text{ and } h_n = \text{Structural Height (ft.)} \\ &= 0.020 * (14.7^{0.75}) \\ &= 0.150 \text{ seconds} \end{aligned}$$

The Coefficient Cu from Table 12.8-1 is : 1.400

Fundamental Period (1/Frequency) [T]:

$$\begin{aligned} &= (1/\text{Natural Frequency}) = (1/25.78) \\ &= 0.039 \end{aligned}$$

Check the Value of T which is the smaller of Cu*Ta and T:

$$\begin{aligned} &= \text{Minimum Value of } (1.4 * 0.15, 0.0388) \text{ per 12.8.2} \\ &= 0.039 \end{aligned}$$

Compute the Seismic Force per equation 13.3-1, [Fp]:

$$\begin{aligned} &= 0.4 * A_p * S_{ds} * W * (1 + 2*(z/h)) / (R / I_e) \\ &= 0.4 * 2.5 * 0.624 * 61.33 * (1 + 2*1) / (2.5/1.5) \\ &= 68.883 \text{ kN} \end{aligned}$$

Check the Maximum value of Fp per equation 13.3-2:

$$\begin{aligned} &= 1.6 * S_{ds} * I * W \\ &= 1.6 * 0.624 * 1.5 * 61.33 = 91.84 \text{ kN} \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Earthquake Load Calculation: Step: 9 8:33pm Feb 18,2022

Check the Minimum value of Fp per equation 13.3-3:

$$= 0.3 * 0.624 * 1.5 * 61.33$$

$$= 17.221 \text{ kN}$$

Compute the Total Base Shear V = Fp, [V]:

$$= 68.883 \text{ kN}$$

Vertical load per 12.4-4, [YEq]:

$$= 0.2 * Sds * W$$

$$= 0.2 * 0.624 * 61.33 = 7.654 \text{ kN}$$

Final Base Shear, V = 48.22 kN
 Final Vertical Load, YEq = 5.36 kN

Distribute the Base shear force to each element according to the equations $F_x = C_{vx} * V$ (eqn. 12.8-11) and the vertical distribution factor $C_{vx} = W_x * h_x^k / (\text{Sum of } W_i * h_i^k)$ and k is an exponent which is related to the period of Vibration.

In this case, the value of k was 1

The Natural Frequency for the Vessel (Ope...) is 25.7833 Hz.

Earthquake Load Calculation:

From	To	Earthquake Height mm.	Earthquake Weight kN	Element Ope Load kN	Element Emp Load kN
10	20	25	9.05316	0.12671	0.10901
20	Legs	350	4.83956	0.94833	0.85937
Legs	30	1550	38.7165	33.5979	30.4462
30	40	2775	8.71845	13.5453	11.5798

Note:
 The Earthquake Loads calculated and printed in the Earthquake Load calculation report have been factored by the input scalar/load reduction factor of: 0.700.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Wind/Earthquake Shear, Bending: Step: 10 8:33pm Feb 18,2022

The following table is for the Operating Case.

Wind/Earthquake Shear, Bending:

From	To	Distance to Support mm.	Cumulative Wind Shear kN	Earthquake Shear kN	Wind Bending N-m	Earthquake Bending N-m
10	20	564.463
20	Legs	150	0.4837	0.12671	127.972	33.5248
Legs	30	1200	3.30896	47.2699	3783.27	76225.5
30	40	2664.46	0.4837	13.5453	127.972	3583.68

Note:
 The Wind Shears/Moments and the Earthquake Shears/Moments calculated and printed in the Wind/Earthquake Shear and Bending report have been factored by the input Scalar/Load reductions factors of; Wind: 0.600; Earthquake: 0.700.

Note:
 Review the Vessel Design Summary for the cumulative shear force and bending moment on the support.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Wind Deflection: Step: 11 8:33pm Feb 18,2022

Wind Deflection Calculations:

The following table is for the Operating Case.

Wind Deflection:

From	To	Cumulative Wind Shear kN	Centroid Deflection mm.	Elem. End Deflection mm.	Elem. Ang. Rotation
10	20	...	0.17721	0.17721	0.0001681
20	Legs	0.4837	0.17722	0.17723	0.00016826
Legs	30	3.30896	0.17774	0.17855	0.00016882
30	40	0.4837	0.17857	0.17859	0.00016882

Critical Wind Velocity for Tower Vibration:

From	To	1st Crit. Wind Speed Km/hr	2nd Crit. Wind Speed Km/hr
10	20	1131.39	7071.18
20	30	1133.05	7081.59
30	40	1131.39	7071.18

Allowable deflection at the Tower Top (Ope) (6.000"/100ft. Criteria)
 Allowable deflection : 14.000 Actual Deflection : 0.179 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Longitudinal Stress Constants: Step: 12 8:33pm Feb 18,2022

Longitudinal Stress Constants:

From	To	Metal Area New cm ²	Metal Area Corroded cm ²	Section Modulus New mm. ³	Section Modulus Corroded mm. ³
10	20	1056.9	886.976	47570540	40052732
20	30	1143.54	973.613	51471832	43966288
30	40	1056.9	886.976	47570540	40052732

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Longitudinal Allowable Stresses: Step: 13 8:33pm Feb 18,2022

Longitudinal Allowable Stresses:

From	To	Tensile N./mm ²	Hydrotest Tensile N./mm ²	Compressive N./mm ²	Hydrotest Compressive N./mm ²
10	20	165.48	282.96	-125.926	-125.926
20	Legs	165.48	282.96	-128.249	-128.249
Legs	30	165.48	282.96	-128.249	-128.249
30	40	165.48	282.96	-125.926	-125.926

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Longitudinal Stresses due to: Step: 14 8:33pm Feb 18,2022

Longitudinal Stress Report

Note: Longitudinal Operating and Empty Stresses are computed in the corroded condition. Stresses due to loads in the hydrostatic test cases have also been computed in the corroded condition.

Longitudinal Pressure Stresses due to:

From	To	Longitudinal Stress Internal Pressure N./mm ²	Longitudinal Stress External Pressure N./mm ²	Longitudinal Stress Hydrotest Pressure N./mm ²
10	20	66.5406	-3.28711	86.5028
20	30	60.6288	-3.00439	78.8175
30	40	66.5406	-3.28711	86.5028

Longitudinal Stresses due to Weight Loads for these Conditions:

From	To	Wght. Str. Empty N./mm ²	Wght. Str. Operating N./mm ²	Wght. Str. Hydrotest N./mm ²	Wght. Str. Emp. Mom. N./mm ²	Wght. Str. Opr. Mom. N./mm ²
10	20	0.0011206	0.0011206
20	Legs	0.092473	0.092993	0.17273	0.029736	0.029736
Legs	30	-0.48316	-0.48271	-0.48316	0.22972	0.22972
30	40	-0.097732	-0.097732	-0.097732

Longitudinal Stresses due to Weight Loads and Bending for these Conditions:

From	To	Wght. Str. Hyd. Mom. N./mm ²	Bend. Str. Oper. Wind N./mm ²	Bend. Str. Oper. Equ. N./mm ²	Bend. Str. Hyd. Wind N./mm ²	Bend. Str. Hyd. Equ. N./mm ²
10	20	0.0011206
20	Legs	0.029736	0.0029098	0.00076227	0.00096022	...
Legs	30	0.22972	0.086022	1.73317	0.028387	...
30	40	...	0.0031941	0.089445	0.001054	...

Longitudinal Stresses due to these Conditions:

From	To	Vortex Shedding Operating Case N./mm ²	Vortex Shedding Empty Case N./mm ²	Vortex Shedding Test Case N./mm ²	Earthquake Empty Case N./mm ²
10	20
20	Legs	0.00065577
Legs	30	1.52855
30	40	0.076467

Longitudinal Stresses due to Applied Axial Forces:

From	To	Longitudinal Stress Y Forces Wind N./mm ²	Longitudinal Stress Y Forces Seismic N./mm ²
10	20	...	-0.0089174
20	Legs	...	-0.012467

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Longitudinal Stresses due to: Step: 14 8:33pm Feb 18,2022

Legs	30	...	0.042566
	30	40	0.0085877

Longitudinal Stresses due to User Forces and Moments:

From	To	Wind For/Mom Corroded N./mm ²	Earthquake For/Mom Corroded N./mm ²	Wind For/Mom No Corrosion N./mm ²	Earthquake For/Mom No Corrosion N./mm ²
10	20
20	Legs
Legs	30
30	40

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Stress due to Combined Loads: Step: 15 8:33pm Feb 18,2022

Stress Combination Load Cases for Vertical Vessels:

Load Case Definition Key

IP = Longitudinal Stress due to Internal Pressure
 EP = Longitudinal Stress due to External Pressure
 HP = Longitudinal Stress due to Hydrotest Pressure
 NP = No Pressure
 EW = Longitudinal Stress due to Weight (No Liquid)
 OW = Longitudinal Stress due to Weight (Operating)
 HW = Longitudinal Stress due to Weight (Hydrotest)
 WI = Bending Stress due to Wind Moment (Operating)
 EQ = Bending Stress due to Earthquake Moment (Operating)
 EE = Bending Stress due to Earthquake Moment (Empty)
 HI = Bending Stress due to Wind Moment (Hydrotest)
 HE = Bending Stress due to Earthquake Moment (Hydrotest)
 WE = Bending Stress due to Wind Moment (Empty) (no CA)
 WF = Bending Stress due to Wind Moment (Filled) (no CA)
 CW = Longitudinal Stress due to Weight (Empty) (no CA)
 VO = Bending Stress due to Vortex Shedding Loads (Ope)
 VE = Bending Stress due to Vortex Shedding Loads (Emp)
 VF = Bending Stress due to Vortex Shedding Loads (Test No CA.)
 FW = Axial Stress due to Vertical Forces for the Wind Case
 FS = Axial Stress due to Vertical Forces for the Seismic Case
 BW = Bending Stress due to Lat. Forces for the Wind Case, Corroded
 BS = Bending Stress due to Lat. Forces for the Seismic Case, Corroded
 BN = Bending Stress due to Lat. Forces for the Wind Case, UnCorroded
 BU = Bending Stress due to Lat. Forces for the Seismic Case, UnCorroded

General Notes:

Case types HI and HE are in the Corroded condition.

Case types WE, WF, and CW are in the Un-Corroded condition.

A blank stress and stress ratio indicates that the corresponding stress comprising those components that did not contribute to that type of stress.

An asterisk (*) in the final column denotes overstress.

Analysis of Load Case 1 : NP+EW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	165.48	-0.00	125.93	0.0000	0.0000
20	0.13	165.48		128.25	0.0008	
20		165.48	-0.80	128.25		0.0062
30		165.48	-0.10	125.93		0.0008

Analysis of Load Case 2 : NP+EW+EE+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		165.48	-0.01	125.93		0.0001
20	0.11	165.48		128.25	0.0007	
20	1.32	165.48	-2.20	128.25	0.0080	0.0171
30		165.48	-0.17	125.93		0.0013

Analysis of Load Case 3 : NP+OW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
-----------	----------------	-------------------	--------------	-------------------	-------------	-------------

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Stress due to Combined Loads: Step: 15 8:33pm Feb 18,2022

Node	Stress	Stress	Stress	Stress	Ratio	Ratio
10	0.00	165.48	-0.00	125.93	0.0000	0.0000
20	0.13	165.48		128.25	0.0008	
20		165.48	-0.80	128.25		0.0062
30		165.48	-0.10	125.93		0.0008

Analysis of Load Case 4 : NP+OW+EQ+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		165.48	-0.01	125.93		0.0001
20	0.11	165.48		128.25	0.0007	
20	1.52	165.48	-2.40	128.25	0.0092	0.0187
30	0.00	165.48	-0.18	125.93	0.0000	0.0014

Analysis of Load Case 5 : NP+HW+HI

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	282.96	-0.00	125.93	0.0000	0.0000
20	0.20	282.96		128.25	0.0007	
20		282.96	-0.74	128.25		0.0058
30		282.96	-0.10	125.93		0.0008

Analysis of Load Case 6 : NP+HW+HE

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	282.96	-0.00	125.93	0.0000	0.0000
20	0.20	282.96		128.25	0.0007	
20		282.96	-0.71	128.25		0.0056
30		282.96	-0.10	125.93		0.0008

Analysis of Load Case 7 : IP+OW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.54	165.48		125.93	0.4021	
20	60.75	165.48		128.25	0.3671	
20	60.46	165.48		128.25	0.3654	
30	66.45	165.48		125.93	0.4015	

Analysis of Load Case 8 : IP+OW+EQ+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.53	165.48		125.93	0.4021	
20	60.74	165.48		128.25	0.3671	
20	62.15	165.48		128.25	0.3756	
30	66.54	165.48		125.93	0.4021	

Analysis of Load Case 9 : EP+OW+WI+FW+BW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		165.48	-3.29	125.93		0.0261
20		165.48	-2.94	128.25		0.0230
20		165.48	-3.80	128.25		0.0297
30		165.48	-3.39	125.93		0.0269

Analysis of Load Case 10 : EP+OW+EQ+FS+BS

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10		165.48	-3.30	125.93		0.0262
20		165.48	-2.95	128.25		0.0230
20		165.48	-5.41	128.25		0.0422
30		165.48	-3.47	125.93		0.0275

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Stress due to Combined Loads: Step: 15 8:33pm Feb 18,2022

Analysis of Load Case 11 : HP+HW+HI

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	86.50	282.96		125.93	0.3057	
20	79.02	282.96		128.25	0.2793	
20	78.59	282.96		128.25	0.2778	
30	86.41	282.96		125.93	0.3054	

Analysis of Load Case 12 : HP+HW+HE

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	86.50	282.96		125.93	0.3057	
20	79.02	282.96		128.25	0.2793	
20	78.56	282.96		128.25	0.2777	
30	86.41	282.96		125.93	0.3054	

Analysis of Load Case 13 : IP+WE+EW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.54	165.48		125.93	0.4021	
20	60.75	165.48		128.25	0.3671	
20	60.38	165.48		128.25	0.3649	
30	66.44	165.48		125.93	0.4015	

Analysis of Load Case 14 : IP+WF+CW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.54	165.48		125.93	0.4021	
20	60.71	165.48		128.25	0.3669	
20	60.22	165.48		128.25	0.3639	
30	66.46	165.48		125.93	0.4016	

Analysis of Load Case 15 : IP+VO+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.54	165.48		125.93	0.4021	
20	60.75	165.48		128.25	0.3671	
20	60.38	165.48		128.25	0.3649	
30	66.44	165.48		125.93	0.4015	

Analysis of Load Case 16 : IP+VE+EW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.54	165.48		125.93	0.4021	
20	60.75	165.48		128.25	0.3671	
20	60.38	165.48		128.25	0.3649	
30	66.44	165.48		125.93	0.4015	

Analysis of Load Case 17 : NP+VO+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	0.00	165.48	-0.00	125.93	0.0000	0.0000
20	0.12	165.48		128.25	0.0007	
20		165.48	-0.71	128.25		0.0056
30		165.48	-0.10	125.93		0.0008

Analysis of Load Case 18 : FS+BS+IP+OW

From Node	Tensile Stress	All. Tens. Stress	Comp. Stress	All. Comp. Stress	Tens. Ratio	Comp. Ratio
10	66.53	165.48		125.93	0.4021	
20	60.74	165.48		128.25	0.3670	
20	60.42	165.48		128.25	0.3651	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Center of Gravity Calculation: Step: 16 8:33pm Feb 18,2022

Shop/Field Installation Options :

Insulation is installed in the Field.

Note : The CG is computed from the first Element From Node

Center of Gravity of Liquid	1400.000 mm.
Center of Gravity of Insulation	1400.000 mm.
Center of Gravity of Nozzles	1091.813 mm.
Center of Gravity of Legs	-440.000 mm.
Center of Gravity of Added Weights (Operating)	2050.000 mm.
Center of Gravity of Added Weights (Empty)	2050.000 mm.
Center of Gravity of Bare Shell New and Cold	1400.000 mm.
Center of Gravity of Bare Shell Corroded	1400.000 mm.
Vessel CG in the Operating Condition	1272.614 mm.
Vessel CG in the Fabricated (Shop/Empty) Condition	1270.332 mm.
Vessel CG in the Test Condition	1346.948 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Leg Check, (Operating Case): Step: 17 8:33pm Feb 18,2022

RESULTS FOR LEGS : Operating Case Description: LEGS

Legs attached to: SHELL

Section Properties : Circular Steel Pipe: PIPE

USA AISC 1989 Steel Table

Overall Leg Length		1580.000	mm.
Effective Leg Length	Leglen	1180.000	mm.
Distance Leg Up Side of Vessel		300.000	mm.
Number of Legs	Nleg	4	
Cross Sectional Area for PIPE	Aleg	54.190	cm ²
Section Inertia (strong axis)		3017.292	cm ⁴
Section Inertia (weak axis)		3017.292	cm ⁴
Section Modulus (strong axis)		275457.688	mm. ³
Section Modulus (weak axis)		275457.688	mm. ³
Radius of Gyration (strong axis)		74.619	mm.
Radius of Gyration (weak axis)		74.619	mm.

Leg Orientation - Strong Axis

Overturning Moment at top of Legs		76225.5	N-m
Total Weight Load at top of Legs	W	66.8	kN
Total Shear force at top of Legs		48.2	kN
Additional force in leg due to Bracing	Fadd	15.5	kN
Occasional Load Factor	Occfac	1.333	
Effective Leg End Condition Factor	k	1.000	
Pipe Leg Inside Diameter (Pid)		202.717	mm.
Pipe Leg Outside Diameter (Pod)		219.075	mm.

Note: The Legs Are Cross Braced

The Leg Shear Force includes Wind and Seismic Effects

Pad Width along Circumference	C11P	300.000	mm.
Pad Length along Vessel Axis	C22P	400.000	mm.
Pad Thickness	Tpad	15.000	mm.

Maximum Shear at top of one Leg [Vleg]:

$$\begin{aligned}
 &= (\max(\text{Wind}, \text{Seismic}) + \text{applied forces}) (I_{\max} / I_{\text{tot}}) \\
 &= (48.22) (3017/12069) \\
 &= 12.05 \text{ kN}
 \end{aligned}$$

Axial Compression, Leg furthest from the Neutral Axis [Sma]:

$$\begin{aligned}
 &= W/N_{\text{leg}} + (M_{\text{leg}} / (N_{\text{leg}} * R_n)) / A_{\text{leg}} \\
 &= 66806/4 + (76195160 / (2 * 922)) / 5419 \\
 &= 10.71 \text{ N./mm}^2
 \end{aligned}$$

Axial Compression, Leg closest to the Neutral Axis [Sva]:

$$\begin{aligned}
 &= (W / N_{\text{leg}} + F_{\text{add}}) / A_{\text{leg}} \\
 &= (66.8/4 + 15.46) / 54.19 \\
 &= 5.94 \text{ N./mm}^2
 \end{aligned}$$

Allowable Comp. for the Selected Leg (KL/r < Cc) [Sa]:

$$\begin{aligned}
 &= \text{Occfac} * (1 - (kl/r)^2 / (2 * C_c^2)) * F_y / \\
 &\quad (5/3 + 3 * (kl/r) / (8 * C_c) - (kl/r)^3 / (8 * C_c^3)) \\
 &= 1.333 * (1 - (15.81)^2 / (2 * 127.2^2)) * 248.2 / \\
 &\quad (5/3 + 3 * (15.81) / (8 * 127.2) - (15.81^3) / (8 * 127.2^3)) \\
 &= 191.66 \text{ N./mm}^2
 \end{aligned}$$

Bending at the Bottom of the Leg closest to the N.A. [S]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Leg Check, (Operating Case): Step: 17 8:33pm Feb 18,2022

= (Vleg * Leglen / Smdsa)
 = (12.05 * 1180/275458)
 = 0 since the legs are Cross Braced

Allowable Bending Stress[Sb]:

= (0.6 * Fy * Occfac)
 = (0.6 * 248.2 * 1.333)
 = 198.53 N./mm²

AISC Unity Check [Sc](must be < or = to 1.00) :

= (Sma/Sa)+(0.85*S)/((1-Sma/Spex)*Sb)
 = (10.71/191.7)+(0.85 *0)/((1 -10.71/5583) *198.5)
 = 0.0559

Bolting Size Requirement for Leg Baseplates :

Baseplate Material		SA-516	70
Baseplate Allowable Stress	SBA	137.90	N./mm ²
Baseplate Length	B	350.0000	mm.
Baseplate Width	D	350.0000	mm.
Baseplate Thickness	BTHK	35.0000	mm.
Leg Dimension Along Baseplate Length	d	219.0750	mm.
Leg Dimension Along Baseplate Width	b	219.0750	mm.
Dist. from the Leg Edge to Bolt Hole Center	z	45.0000	mm.
Bolt Material		SA-193	B7
Bolt Allowable Stress	STBA	172.38	N./mm ²
Anchor Bolt Nominal Diameter	BOD	27.0000	mm.
Number of Anchor Bolts in Tension per Leg	NB	2	
Total Number of Anchors Bolt per Leg	NBT	4	
Ultimate 28-day Concrete Strength	FCPRIME	20.685	N./mm ²

LEG BASEPLATE and BOLTING Analysis, including Moments

Pipe Leg

Base Plate Available Area (AA):

= B * D
 = 350 * 350
 = 1225.00 cm²

Clearance Between The Bolt And The Leg Edge (BCL):

= z - BOD / 2
 = 45 - 27/2
 = 31.50 mm.

Moment at Baseplate (MOMENT):

= Vleg * Lleg
 = 12.05 * 1580
 = 19053.93 N-m

Axial Load on the baseplate (P):

= Operating Weight per leg (as Seismic + Operating case is controlling)
 = 16.70 kN

Eccentricity (e):

= MOMENT * Conv_Factor / P
 = 19054 *999.68/16.7
 = 1140.44 mm. > D/6 [Plate Uplift Condition]

a = (MAX[B,D] - 0.707 * Pod) / 2

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Leg Check, (Operating Case): Step: 17 8:33pm Feb 18,2022

$$= (350 - 0.707 * 219.1) / 2$$

$$= 97.56 \text{ mm.}$$

Modular Ratio Of Steel/Concrete (n):

$$= ES / EC$$

$$= 203402 / 21526$$

$$= 9.45$$

$$F = 0.5 * d + z$$

$$= 0.5 * 219.1 + 45$$

$$= 154.54 \text{ mm.}$$

$$K1 = 3.0 (e - 0.5 * D)$$

$$= 3.0 (1140 - 0.5 * 350)$$

$$= 2896.33$$

$$K2 = 6 * n * Ast / B * (F + e)$$

$$= 6 * 9.449 * 8.277 / 350 * (154.5 + 1140)$$

$$= 1736.23$$

$$K3 = -K2 * (0.5 * D + F)$$

$$= -1736 * (0.5 * 350 + 154.5)$$

$$= -572153.90$$

Solving For The Effective Bearing Length Using Iteration:

$$Y^3 + K1 * Y^2 + K2 * Y + K3 = 0$$

$$Y^3 + 114 * Y^2 + 269.1 * Y - 3491 = 0$$

$$Y = 112.04 \text{ mm.}$$

$$NUM = (D / 2 - Y / 3 - e)$$

$$= (350 / 2 - 112 / 3 - 1140)$$

$$= -1002.79$$

$$DENOM = (D / 2 - Y / 3 + F)$$

$$= (350 / 2 - 112 / 3 + 154.5)$$

$$= 292.19$$

Total Bolt Tension Force (T):

$$= -P * NUM / DENOM$$

$$= -16.7 * -1003 / 292.2$$

$$= 57.32 \text{ kN}$$

Overturning Moment Due To Bolt In Tension (Mt):

$$= T * (0.5 * D + F - Y)$$

$$= 57.32 * (0.5 * 350 + 154.5 - 112)$$

$$= 12471.27 \text{ N-m}$$

Bearing Pressure (FC):

$$= 2 * (P + T) / (Y * B)$$

$$= 2 * (16.7 + 57.32) / (112 * 350)$$

$$= 37.75 \text{ bars [} \leq \text{ FCPRIME (206.84)]}$$

Equivalent Bearing Pressure (f1):

$$= FC * (Y - a) / Y$$

$$= 37.75 * (112 - 97.56) / 112$$

$$= 4.88 \text{ bars}$$

Overturning Moment Due To Bearing Pressure (Mc):

$$= (a^2 * B / 6) * (f1 + 2 * FC)$$

$$= (97.56^2 * 350 / 6) * (4.88 + 2 * 37.75)$$

$$= 4464.40 \text{ N-m}$$

The Baseplate Required Thickness (TREQ):

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Leg Check, (Operating Case): Step: 17 8:33pm Feb 18,2022

$$= (6 * \text{MAX}(Mt, Mc) / (B * 1.5 * SBA))^{1/2}$$

$$= (6 * 12471 / (350 * 206.9))^{1/2}$$

$$= 32.14 \text{ mm.}$$

Required bolt area (ABREQM): per D. Moss

$$= T / STBA$$

$$= 57.32 / 172.4$$

$$= 3.3254 \text{ cm}^2 [< \text{Ast} (8.28) \text{ --> PASSED}]$$

Distance from Top of Legs to Vessel CG (CD_DIST):

$$= 922.6 \text{ mm.}$$

Total Overturning Moment at Baseplate (Mbb):

$$= (M_{leg} / \max([CD_DIST], \text{minDist})) * (CD_DIST + L_{leg})$$

$$= (76226 / \max(922.6, 38.1)) * (922.6 + 1580)$$

$$= 206763.59 \text{ N-m}$$

Required Total Bolt Area per Leg (ABREQB): per H. Bednar

$$= (1 / (N_{leg} * STBA)) * ((4 * M_{bb} / (R_n * 2)) - W)$$

$$= (1 / (4 * 172.4)) * ((4 * 206764 / (1844)) - 66.8)$$

$$= 5.5338 \text{ cm}^2$$

Available Total Bolt Corr. Area per Leg (ABAVL):

$$= A_s * N_{BT}$$

$$= 4.139 * 4$$

$$= 16.5541 \text{ cm}^2 [> \text{ABREQB} (5.53) \text{ --> PASSED}]$$

Summary of Results:

		Actual	Required	Pass/Fail
Baseplate Thickness	(mm.):	35.000	32.144	Pass
Bolt Root Area (Bednar)	(cm ²):	16.55	5.53	Pass
Bolt Root Area (D. Moss)	(cm ²):	8.28	3.33	Pass

Note: The required thickness calculation is performed based on:

Beam leg analysis per Moss.

Even number of bolts installed only on the B dimension sides

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Leg Check, (Filled w/Water): Step: 18 8:33pm Feb 18,2022

RESULTS FOR LEGS : HydroTest Case Description: LEGS

Legs attached to: SHELL

Section Properties : Circular Steel Pipe: PIPE

USA AISC 1989 Steel Table

Overall Leg Length		1580.000	mm.
Effective Leg Length	Leglen	1180.000	mm.
Distance Leg Up Side of Vessel		300.000	mm.
Number of Legs	Nleg	4	
Cross Sectional Area for PIPE	Aleg	54.190	cm ²
Section Inertia (strong axis)		3017.292	cm ⁴
Section Inertia (weak axis)		3017.292	cm ⁴
Section Modulus (strong axis)		275457.688	mm. ³
Section Modulus (weak axis)		275457.688	mm. ³
Radius of Gyration (strong axis)		74.619	mm.
Radius of Gyration (weak axis)		74.619	mm.

Leg Orientation - Strong Axis

Overturning Moment at top of Legs		1248.5	N-m
Total Weight Load at top of Legs	W	134.7	kN
Total Shear force at top of Legs		1.2	kN
Additional force in Leg due to Bracing	Fadd	0.4	kN
Occasional Load Factor	Occfac	1.333	
Effective Leg End Condition Factor	k	1.000	
Pipe Leg Inside Diameter (Pid)		202.717	mm.
Pipe Leg Outside Diameter (Pod)		219.075	mm.

Note: The Legs Are Cross Braced

The Leg Shear Force includes Wind and Seismic Effects

Pad Width along Circumference	C11P	300.000	mm.
Pad Length along Vessel Axis	C22P	400.000	mm.
Pad Thickness	Tpad	15.000	mm.

Maximum Shear at top of one Leg [Vleg]:

$$\begin{aligned}
 &= (\max(\text{Wind}, \text{Seismic}) + \text{applied forces}) (I_{\max} / I_{\text{tot}}) \\
 &= (1.189) (3017/12069) \\
 &= 0.30 \text{ kN}
 \end{aligned}$$

Axial Compression, Leg furthest from the Neutral Axis [Sma]:

$$\begin{aligned}
 &= W/N_{\text{leg}} + (M_{\text{leg}} / (N_{\text{leg}} * R_n)) / A_{\text{leg}} \\
 &= 134709/4 + (1247983 / (2 * 922)) / 5419 \\
 &= 6.34 \text{ N./mm}^2
 \end{aligned}$$

Axial Compression, Leg closest to the Neutral Axis [Sva]:

$$\begin{aligned}
 &= (W / N_{\text{leg}} + F_{\text{add}}) / A_{\text{leg}} \\
 &= (134.7/4 + 0.381) / 54.19 \\
 &= 6.29 \text{ N./mm}^2
 \end{aligned}$$

Allowable Comp. for the Selected Leg (KL/r < Cc) [Sa]:

$$\begin{aligned}
 &= \text{Occfac} * (1 - (kl/r)^2 / (2 * C_c^2)) * F_y / \\
 &\quad (5/3 + 3 * (kl/r) / (8 * C_c) - (kl/r)^3 / (8 * C_c^3)) \\
 &= 1.333 * (1 - (15.81)^2 / (2 * 127.2^2)) * 248.2 / \\
 &\quad (5/3 + 3 * (15.81) / (8 * 127.2) - (15.81^3) / (8 * 127.2^3)) \\
 &= 191.66 \text{ N./mm}^2
 \end{aligned}$$

Bending at the Bottom of the Leg closest to the N.A. [S]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Leg Check, (Filled w/Water): Step: 18 8:33pm Feb 18,2022

$$\begin{aligned}
 &= (Vleg * Leglen / Smdsa) \\
 &= (0.297 * 1180/275458) \\
 &= 0 \text{ since the legs are Cross Braced}
 \end{aligned}$$

Allowable Bending Stress[Sb]:

$$\begin{aligned}
 &= (0.6 * Fy * Occfac) \\
 &= (0.6 * 248.2 * 1.333) \\
 &= 198.53 \text{ N./mm}^2
 \end{aligned}$$

AISC Unity Check [Sc](must be < or = to 1.00) :

$$\begin{aligned}
 &= (Sma/Sa) + (0.85 * S) / ((1 - Sma/Spex) * Sb) \\
 &= (6.34/191.7) + (0.85 * 0) / ((1 - 6.34/5583) * 198.5) \\
 &= 0.0331
 \end{aligned}$$

Bolting Size Requirement for Leg Baseplates :

Baseplate Material		SA-516	70
Baseplate Allowable Stress	SBA	137.90	N./mm ²
Baseplate Length	B	350.0000	mm.
Baseplate Width	D	350.0000	mm.
Baseplate Thickness	BTHK	35.0000	mm.
Leg Dimension Along Baseplate Length	d	219.0750	mm.
Leg Dimension Along Baseplate Width	b	219.0750	mm.
Dist. from the Leg Edge to Bolt Hole Center	z	45.0000	mm.
Bolt Material		SA-193	B7
Bolt Allowable Stress	STBA	172.38	N./mm ²
Anchor Bolt Nominal Diameter	BOD	27.0000	mm.
Number of Anchor Bolts in Tension per Leg	NB	2	
Total Number of Anchors Bolt per Leg	NBT	4	
Ultimate 28-day Concrete Strength	FCPRIME	20.685	N./mm ²

LEG BASEPLATE and BOLTING Analysis, including Moments

Pipe Leg

Base Plate Available Area (AA):

$$\begin{aligned}
 &= B * D \\
 &= 350 * 350 \\
 &= 1225.00 \text{ cm}^2
 \end{aligned}$$

Clearance Between The Bolt And The Leg Edge (BCL):

$$\begin{aligned}
 &= z - BOD / 2 \\
 &= 45 - 27/2 \\
 &= 31.50 \text{ mm.}
 \end{aligned}$$

Moment at Baseplate (MOMENT):

$$\begin{aligned}
 &= Vleg * Lleg \\
 &= 0.297 * 1580 \\
 &= 469.67 \text{ N-m}
 \end{aligned}$$

Axial Load on the baseplate (P):

$$\begin{aligned}
 &= \text{Operating Weight per leg (as Seismic + Operating case is controlling)} \\
 &= 16.70 \text{ kN}
 \end{aligned}$$

Eccentricity (e):

$$\begin{aligned}
 &= \text{MOMENT} * \text{Conv_Factor} / P \\
 &= 469.7 * 999.68/16.7 \\
 &= 28.11 \text{ mm. } \leq D/6 \text{ [No Plate Uplift]}
 \end{aligned}$$

$$a = (\text{MAX}[B,D] - 0.707 * Pod) / 2$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Leg Check, (Filled w/Water): Step: 18 8:33pm Feb 18,2022

$$= (350 - 0.707 * 219.1) / 2$$

$$= 97.56 \text{ mm.}$$

Bearing Pressure (FC):

$$= P / AA * (1 + 6 * e / D)$$

$$= 16.7/1225 * (1 + 6 * 28.11/350)$$

$$= 2.02 \text{ bars}$$

Equivalent Bearing Pressure (F1):

$$= P / AA * (1 + (6 * e * (D - 2 * a) / D^2))$$

$$= 16.7/1225 * (1 + (6 * 28.11 * (350 - 2 * 97.56) / 350^2))$$

$$= 1.65 \text{ bars}$$

Bending Moment (MB):

$$= a^2 * B / 6 * (F1 + 2 * FC) / 12.0$$

$$= 97.56^2 * 350/6 * (1.654 + 2 * 0.202) / 12.0$$

$$= 316.29 \text{ N-m}$$

The Baseplate Required Thickness (TREQ):

$$= (6 * Mb / (B * 1.5 * Sba))^{1/2}$$

$$= (6 * 26.36 / (350 * 206.9))^{1/2}$$

$$= 5.12 \text{ mm.}$$

Distance from Top of Legs to Vessel CG (CD_DIST):

$$= 996.9 \text{ mm.}$$

Total Overturning Moment at Baseplate (Mbb):

$$= (Mleg / \max([CD_DIST], \text{minDist})) * (CD_DIST + Lleg)$$

$$= (1248 / \max(996.9, 38.1)) * (996.9 + 1580)$$

$$= 3227.12 \text{ N-m}$$

Required Total Bolt Area per Leg (ABREQB): per H. Bednar

$$= (1 / (Nleg * STBA)) * ((4 * Mbb / (Rn * 2)) - W)$$

$$= (1 / (4 * 172.4)) * ((4 * 3227 / (1844)) - 66.8)$$

$$= -0.8674 \text{ cm}^2 \text{ --> (No tension in bolts)}$$

** No Tensile Bolt Loads. Choose a practical bolt size! **

Summary of Results:

		Actual	Required	Pass/Fail
Baseplate Thickness	(mm.):	35.000	5.119	Pass

Note: The required thickness calculation is performed based on:

Beam leg analysis per Moss.

Even number of bolts installed only on the B dimension sides

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Summary: Step: 31 8:33pm Feb 18,2022

Nozzle Calculation Summary:

Description	MAWP bars	Ext	MAPNC bars	UG-45	[tr] mm.	Weld Path	Areas or Stresses
D	23.73	OK	...	OK	6.42	OK	Passed
LT1	23.73	OK	...	OK	6.42	OK	Passed
LT1	23.73	OK	...	OK	6.42	OK	Passed
A1	24.13	OK	...	OK	11.33	OK	Passed
A2	24.74	OK	...	OK	10.16	OK	Passed
B	24.14	OK	...	OK	11.33	OK	Passed
LT2	25.67	OK	...	OK	7.80	OK	Passed
SV	25.67	OK	...	OK	7.80	OK	Passed
M2	24.74	OK	...	OK	9.22	OK	Passed
TI	25.67	OK	...	OK	7.52	OK	Passed
M1	24.11	OK	OK	Passed
V	23.73	OK	...	OK	6.42	OK	Passed

MAWP Summary:

Minimum MAWP Nozzles : 23.731 Nozzle : LT1
 Minimum MAWP Shells/Flanges : 23.731 Element : HEAD 001
 Minimum MAPnc Shells/Flanges : 28.286 Element : HEAD 002

 Computed Vessel M.A.W.P. : 23.731 bars

Note: MAWPs (Internal Case) shown above are at the High Point.

Check the Spatial Relationship between the Nozzles

From Node	Nozzle Description	Y Coordinate mm.	Layout Angle deg	Dia. Limit mm.
10	D	0.000	0.000	93.890
10	LT1	0.000	180.000	93.890
20	A1	550.000	90.000	598.626
20	A2	1150.000	45.000	405.700
20	B	2450.000	270.000	598.626
20	LT2	350.000	180.000	118.000
20	SV	1550.000	0.000	118.000
20	M2	2500.000	90.000	310.145
20	TI	250.000	270.000	104.000
20	M1	750.000	0.000	948.000
30	V	0.000	0.000	93.890


The nozzle spacing is computed by the following:

= Sqrt(ll² + lc²) where
 ll - Arc length along the inside vessel surface in the long. direction.
 lc - Arc length along the inside vessel surface in the circ. direction

If any interferences/violations are found, they will be noted below.
 No interference violations have been detected !

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: D

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.382 in.

Nozzle input data check completed without errors.

Req'd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]
 $= (P \cdot K_1 \cdot D) / (2 \cdot S_v \cdot E - 0.2 \cdot P)$ per UG-37(a) (3)
 $= (23 \cdot 0.897 \cdot 1806) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23)$
 $= 13.5366 \text{ mm.}$

Req'd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]
 $= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 $= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$
 $= 0.5839 \text{ mm.}$

Required Nozzle thickness under External Pressure per UG-28 : 0.3261 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	93.8896 mm.
Parallel to Vessel Wall, opening length	d	46.9448 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		28.7253 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:
 $= \min(1, S_n / S_v)$
 $= \min(1, 117.9 / 137.9)$
 $= 0.855$

Weld Strength Reduction Factor [fr2]:
 $= \min(1, S_n / S_v)$
 $= \min(1, 117.9 / 137.9)$
 $= 0.855$

Weld Strength Reduction Factor [fr4]:
 $= \min(1, S_p / S_v)$
 $= \min(1, 137.9 / 137.9)$
 $= 1.000$

Weld Strength Reduction Factor [fr3]:
 $= \min(fr2, fr4)$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D

Noz1: 12 8:33pm Feb 18,2022

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	6.617	1.199	NA
Area in Shell	A1	0.884	4.768	NA
Area in Nozzle Wall	A2	2.999	3.126	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	0.547	0.547	NA
Area in Element	A5	4.028	4.028	NA
TOTAL AREA AVAILABLE	Atot	8.458	12.469	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	78.5511	12.0000 mm.
Based on given Pad Diameter:	190.0000	6.5162 mm.
Based on Shell or Nozzle Thickness:	82.8958	9.6901 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (46.94 \cdot 13.54 \cdot 1 + 2 \cdot 6.69 \cdot 13.54 \cdot 1 \cdot (1 - 0.855))$$

$$= 6.617 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 46.94 (1 \cdot 15.5 - 1 \cdot 13.54) - 2 \cdot 6.69$$

$$(1 \cdot 15.5 - 1 \cdot 13.54) \cdot (1 - 0.855)$$

$$= 0.884 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 28.73) \cdot (6.69 - 0.584) \cdot 0.855$$

$$= 2.999 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 8^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.547 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (93.89 - 60.33) \cdot 12 \cdot 1$$

$$= 4.028 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5839 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.0218 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.0218 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7172 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: D Noz1: 12 8:33pm Feb 18,2022

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(18.02, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 9.6901 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	5.3,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	289.4 N./mm ²	Passed
Occasional	:	3.5,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	5.8,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D Nozl: 12 8:33pm Feb 18,2022

Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -45 °C
 Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -18 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -96 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: D

Intermediate Calc. for nozzle/shell Welds Tmin 6.6901 mm.
 Intermediate Calc. for pad/shell Welds TminPad 12.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.6831 = 0.7 * tmin.	5.6560 = 0.7 * Wo mm.
Pad Weld	6.0000 = 0.5*TminPad	7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (6.617 - 0.884 + 2 * 6.69 * 0.855 * (1 * 15.5 - 13.54))) 137.9)$$

$$= 82.16 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (2.999 + 4.028 + 0.547 - 0 * 0.855) * 137.9$$

$$= 104.44 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (2.999 + 0 + 0.547 + (1.773)) * 137.9$$

$$= 73.35 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (2.999 + 0 + 0.547 + 4.028 + (1.773)) * 137.9$$

$$= 128.89 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.142/2.0) * 60.33 * 8 * 0.49 * 117.9$$

$$= 44. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 190 * 10 * 0.49 * 137.9$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D Nozl: 12 8:33pm Feb 18,2022

= 202. kN

Shear, Nozzle Wall [Snw]:

= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn
 = (3.142 * 26.82) * (9.69 - 3) * 0.7 * 117.9
 = 47. kN

Tension, Pad Groove Weld [Tpgw]:

= (pi / 2) * Dlo * Wgpn * 0.74 * Seg
 = (3.142 / 2) * 60.33 * 12 * 0.74 * 137.9
 = 116. kN

Tension, Shell Groove Weld [Tngw]:

= (pi / 2) * Dlo * (Wgnvi - Cas) * 0.74 * Sng
 = (3.142 / 2.0) * 60.33 * (18.5 - 3) * 0.74 * 137.9
 = 150. kN

Strength of Failure Paths:

PATH11 = (SPEW + SNW) = (201.6 + 46.51) = 248.2 kN
 PATH22 = (Sonw + Tpgw + Tngw + Sinw)
 = (43.79 + 116 + 149.9 + 0) = 309.7 kN
 PATH33 = (Spew + Tngw + Sinw)
 = (201.6 + 149.9 + 0) = 351.5 kN

Summary of Failure Path Calculations:

Path 1-1 = 248 kN , must exceed W = 82 kN or W1 = 104 kN
 Path 2-2 = 309 kN , must exceed W = 82 kN or W2 = 73 kN
 Path 3-3 = 351 kN , must exceed W = 82 kN or W3 = 128 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 23.733 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 0.2783 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 218.7783 mm.

Input Echo, WRC107/537 Item 1, Description: D :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Spherical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	3240.000	mm.
Vessel Thickness	Tv	18.500	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
WRC107 Attachment Classification	Holsol	Hollow	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.
Nozzle Thickness	Tn	9.690	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D Nozl: 12 8:33pm Feb 18,2022

Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	190.000	mm.
Design Internal Pressure	Dp	23.002	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	(Vl) V1	2.0	kN
Circumferential Shear (SUS)	(Vc) V2	2.0	kN
Circumferential Moment (SUS)	(Mc) M1	0.4	N-m
Longitudinal Moment (SUS)	(Ml) M2	0.4	N-m
Torsional Moment (SUS)	Mt	0.5	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(t - ca))$$

$$= 60.325 + 2 * 1.65 * \text{sqrt}(1630.75 (18.5 - 3.0))$$

$$= 584.980 \text{ mm.}$$

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	(VC) V2	2.0	kN
Longitudinal Shear	(VL) V1	2.0	kN
Circumferential Moment	(MC) M1	0.4	N-m
Longitudinal Moment	(ML) M2	0.4	N-m
Torsional Moment	MT	0.5	N-m

Unitless Prm: U = 0.14 TAU = 5.00 (4.01) RHO = 4.00 (4.11)

Dimensionless Loads for Spherical Shells at Attachment Junction:

Curves read for 1979	Figure	Value	Location
N(x) * T / P	SP 4	0.10094	(A,B,C,D)
M(x) / P	SP 4	0.03588	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / MC	SM 4	0.39546	(A,B,C,D)
M(x) * SQRT(Rm * T) / MC	SM 4	0.16243	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / ML	SM 4	0.39546	(A,B,C,D)
M(x) * SQRT(Rm * T) / ML	SM 4	0.16243	(A,B,C,D)
N(y) * T / P	SP 4	0.33817	(A,B,C,D)
M(y) / P	SP 4	0.25612	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / MC	SM 4	0.10351	(A,B,C,D)
M(y) * SQRT(Rm * T) / MC	SM 4	1.27108	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / ML	SM 4	0.10351	(A,B,C,D)
M(y) * SQRT(Rm * T) / ML	SM 4	1.27108	(A,B,C,D)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D

Noz1: 12 8:33pm Feb 18,2022

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad. Memb. P		-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Rad. Bend. P		-0.6	0.6	-0.6	0.6	-0.6	0.6	-0.6	0.6
Rad. Memb. MC		0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0
Rad. Memb. MC		0.0	0.0	0.0	0.0	-0.0	0.0	0.0	-0.0
Rad. Memb. ML		-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0
Rad. Bend. ML		-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0
Tot. Rad. Str.		-0.8	0.3	-0.8	0.3	-0.8	0.3	-0.8	0.3
Tang. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9
Tang. Bend. P		-4.1	4.1	-4.1	4.1	-4.1	4.1	-4.1	4.1
Tang. Memb. MC		0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0
Tang. Bend. MC		0.0	0.0	0.0	0.0	-0.0	0.0	0.0	-0.0
Tang. Memb. ML		-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tang. Bend. ML		-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0
Tot. Tang. Str.		-5.0	3.2	-4.9	3.2	-5.0	3.2	-4.9	3.2
Shear VC		0.8	0.8	-0.8	-0.8	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.8	-0.8	0.8	0.8
Shear MT		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tot. Shear		0.8	0.8	-0.8	-0.8	-0.8	-0.8	0.8	0.8
Str. Int.		5.1	3.4	5.1	3.3	5.1	3.4	5.1	3.3

Unitless Prm: U = 0.60 TAU = 0.00 (13.70) RHO = 0.00 (2.32)

Dimensionless Loads for Spherical Shells at Pad edge:

Curves read for 1979	Figure	Value	Location
N(x) * T / P	SR 2	0.11542	(A,B,C,D)
M(x) / P	SR 2	0.06771	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / MC	SR 3	0.12880	(A,B,C,D)
M(x) * SQRT(Rm * T) / MC	SR 3	0.18723	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / ML	SR 3	0.12880	(A,B,C,D)
M(x) * SQRT(Rm * T) / ML	SR 3	0.18723	(A,B,C,D)
N(y) * T / P	SR 2	0.03465	(A,B,C,D)
M(y) / P	SR 2	0.02066	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / MC	SR 3	0.03895	(A,B,C,D)
M(y) * SQRT(Rm * T) / MC	SR 3	0.05574	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / ML	SR 3	0.03895	(A,B,C,D)
M(y) * SQRT(Rm * T) / ML	SR 3	0.05574	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D

Noz1: 12 8:33pm Feb 18,2022

Rad. Memb. P	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0
Rad. Bend. P	-3.4	3.4	-3.4	3.4	-3.4	3.4	-3.4	3.4	3.4
Rad. Memb. MC	0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0	0.0
Rad. Memb. MC	0.0	0.0	0.0	0.0	-0.0	0.0	0.0	0.0	-0.0
Rad. Memb. ML	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Rad. Bend. ML	-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0	0.0
Tot. Rad. Str.	-4.4	2.4	-4.3	2.4	-4.4	2.4	-4.3	2.4	2.4
Tang. Memb. P	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Tang. Bend. P	-1.0	1.0	-1.0	1.0	-1.0	1.0	-1.0	1.0	1.0
Tang. Memb. MC	0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0	0.0
Tang. Bend. MC	0.0	0.0	0.0	0.0	-0.0	0.0	0.0	0.0	-0.0
Tang. Memb. ML	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tang. Bend. ML	-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0	0.0
Tot. Tang. Str.	-1.3	0.7	-1.3	0.7	-1.3	0.7	-1.3	0.7	0.7
Shear VC	0.4	0.4	-0.4	-0.4	0.0	0.0	0.0	0.0	0.0
Shear VL	0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	0.4
Shear MT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tot. Shear	0.4	0.4	-0.4	-0.4	-0.4	-0.4	0.4	0.4	0.4
Str. Int.	4.4	2.5	4.4	2.5	4.4	2.5	4.4	2.5	2.5

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad. Pm (SUS)		67.9	67.9	67.9	67.9	67.9	67.9	67.9	67.9
Rad. Pl (SUS)		-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Rad. Q (SUS)		-0.6	0.6	-0.6	0.6	-0.6	0.6	-0.6	0.6
Long. Pm (SUS)		67.9	67.9	67.9	67.9	67.9	67.9	67.9	67.9
Long. Pl (SUS)		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9
Long. Q (SUS)		-4.1	4.1	-4.0	4.0	-4.1	4.1	-4.0	4.0
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.8	0.8	-0.8	-0.8	-0.8	-0.8	0.8	0.8
Shear Q (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Pm (SUS)		67.9	67.9	67.9	67.9	67.9	67.9	67.9	67.9
Pm+Pl (SUS)		68.1	68.1	68.1	68.1	68.1	68.1	68.1	68.1
Pm+Pl+Q (Total)		67.2	71.3	67.2	71.2	67.2	71.3	67.2	71.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	67.89	137.90	Passed
Pm+Pl (SUS)	68.14	206.85	Passed
Pm+Pl+Q (TOTAL)	71.28	413.70	Passed

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: D

Noz1: 12 8:33pm Feb 18,2022

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad.	Pm (SUS)	120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Rad.	Pl (SUS)	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0
Rad.	Q (SUS)	-3.4	3.4	-3.4	3.4	-3.4	3.4	-3.4	3.4
Long.	Pm (SUS)	120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Long.	Pl (SUS)	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Long.	Q (SUS)	-1.0	1.0	-1.0	1.0	-1.0	1.0	-1.0	1.0
Shear	Pm (SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear	Pl (SUS)	0.4	0.4	-0.4	-0.4	-0.4	-0.4	0.4	0.4
Shear	Q (SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Pm (SUS)		120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Pm+Pl (SUS)		120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Pm+Pl+Q (Total)		119.2	123.0	119.2	123.0	119.2	123.0	119.2	123.0

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	120.44	137.90	Passed
Pm+Pl (SUS)	120.36	206.85	Passed
Pm+Pl+Q (TOTAL)	122.98	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: LT1 From : 10

Pressure for Reinforcement Calculations	P	23.002	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Elliptical Head	D	1800.00	mm.
Aspect Ratio of Elliptical Head	Ar	2.00	
Head Finished (Minimum) Thickness	t	18.5000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.
Distance from Head Centerline	L1	200.0000	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C


Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		180.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	XXS	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	8.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	18.5000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	190.0000	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		64.8375	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle in the Meridional direction.

Reinforcement CALCULATION, Description: LT1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.382 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]
 $= (P \cdot K1 \cdot D) / (2 \cdot Sv \cdot E - 0.2 \cdot P)$ per UG-37(a) (3)
 $= (23 \cdot 0.897 \cdot 1806) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23)$
 $= 13.5366 \text{ mm.}$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]
 $= (P \cdot Ro) / (Sn \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 $= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$
 $= 0.5839 \text{ mm.}$

Required Nozzle thickness under External Pressure per UG-28 : 0.3261 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	94.4965 mm.
Parallel to Vessel Wall, opening length	d	47.2483 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		28.7253 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$= \min(1, Sn/Sv)$
 $= \min(1, 117.9/137.9)$
 $= 0.855$

Weld Strength Reduction Factor [fr2]:

$= \min(1, Sn/Sv)$
 $= \min(1, 117.9/137.9)$
 $= 0.855$

Weld Strength Reduction Factor [fr4]:

$= \min(1, Sp/Sv)$
 $= \min(1, 137.9/137.9)$
 $= 1.000$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: LTI

Noz1: 13 8:33pm Feb 18,2022

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	6.658	1.206	NA
Area in Shell	A1	0.890	4.800	NA
Area in Nozzle Wall	A2	3.014	3.141	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	0.547	0.547	NA
Area in Element	A5	4.054	4.054	NA
TOTAL AREA AVAILABLE	Atot	8.504	12.542	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 83.50 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 78.7242 12.0000 mm.

Based on given Pad Diameter: 190.0000 6.5358 mm.

Based on Shell or Nozzle Thickness: 83.5000 9.6901 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) UG-37(c)$$

$$= (47.25 * 13.54 * 1 + 2 * 6.69 * 13.54 * 1 * (1 - 0.855))$$

$$= 6.658 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 47.25 (1 * 15.5 - 1 * 13.54) - 2 * 6.69$$

$$(1 * 15.5 - 1 * 13.54) * (1 - 0.855)$$

$$= 0.890 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2 / \sin(\alpha3)$$

$$= (2 * 28.73) * (6.69 - 0.584) * 0.855 / \sin(84.41)$$

$$= 3.014 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 8^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.547 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (94.5 - 60.71) * 12 * 1$$

$$= 4.054 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification -46 °C
 Calculated Minimum Design Metal Temperature -104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification -46 °C
 Calculated Minimum Design Metal Temperature -104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification -46 °C
 Calculated Minimum Design Metal Temperature -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -45 °C
 Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -18 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -96 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: LT1

Intermediate Calc. for nozzle/shell Welds Tmin 6.6901 mm.
 Intermediate Calc. for pad/shell Welds TminPad 12.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.6831 = 0.7 * tmin.	5.6560 = 0.7 * Wo mm.
Pad Weld	6.0000 = 0.5*TminPad	7.0700 = 0.7 * Wp mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Noz1: 13 8:33pm Feb 18,2022

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (6.658 - 0.89 + 2 * 6.69 * 0.855 * \\
 &\quad (1 * 15.5 - 13.54)))137.9) \\
 &= 82.64 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (3.014 + 4.054 + 0.547 - 0 * 0.855) * 137.9 \\
 &= 105.00 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (3.014 + 0 + 0.547 + (1.773)) * 137.9 \\
 &= 73.55 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (3.014 + 0 + 0.547 + 4.054 + (1.773)) * 137.9 \\
 &= 129.45 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 60.71 * 8 * 0.49 * 117.9 \\
 &= 44. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 190 * 10 * 0.49 * 137.9 \\
 &= 202. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo)/4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.142 * 26.99) * (9.69 - 3) * 0.7 * 117.9 \\
 &= 47. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wgpn * 0.74 * Seg \\
 &= (3.142/2) * 60.71 * 12 * 0.74 * 137.9 \\
 &= 117. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.142/2.0) * 60.71 * (18.5 - 3) * 0.74 * 137.9 \\
 &= 151. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (201.6 + 46.82) = 248.5 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (44.08 + 116.8 + 150.8 + 0) = 311.7 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (201.6 + 150.8 + 0) = 352.5 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 248 kN , must exceed W = 82 kN or W1 = 104 kN

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

Path 2-2 = 311 kN , must exceed W = 82 kN or W2 = 73 kN
 Path 3-3 = 352 kN , must exceed W = 82 kN or W3 = 129 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 23.733 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

Note : Checking Nozzle in the Latitudinal direction.

Reinforcement CALCULATION, Description: LT1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation 2.375 in.
 Actual Thickness Used in Calculation 0.382 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]

$$= (P \cdot K_1 \cdot D) / (2 \cdot S_v \cdot E - 0.2 \cdot P) \text{ per UG-37(a) (3)}$$

$$= (23 \cdot 0.897 \cdot 1806) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23)$$

$$= 13.5366 \text{ mm.}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$$

$$= 0.5839 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3261 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	93.8896	mm.
Parallel to Vessel Wall, opening length	d	46.9448	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		28.7253	mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	6.617	1.199	NA
Area in Shell	A1	0.884	4.768	NA
Area in Nozzle Wall	A2	2.999	3.126	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.547	0.547	NA
Area in Element	A5	4.028	4.028	NA
TOTAL AREA AVAILABLE	Atot	8.458	12.469	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	78.5510	12.0000 mm.
Based on given Pad Diameter:	190.0000	6.5162 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

Based on Shell or Nozzle Thickness: 82.8957 9.6901 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) UG-37(c)$$

$$= (46.94 * 13.54 * 1 + 2 * 6.69 * 13.54 * 1 * (1 - 0.855))$$

$$= 6.617 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 46.94 (1 * 15.5 - 1 * 13.54) - 2 * 6.69$$

$$(1 * 15.5 - 1 * 13.54) * (1 - 0.855)$$

$$= 0.884 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 28.73) * (6.69 - 0.584) * 0.855$$

$$= 2.999 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 8^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.547 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (93.89 - 60.33) * 12 * 1$$

$$= 4.028 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5839 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.0218 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.0218 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7172 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[6.42, \max(18.02, 4.5)]$$

$$= 6.4200 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.584, 6.42)$$

$$= 6.4200 \text{ mm.}$$

Available Nozzle Neck Thickness = 9.6901 mm. --> OK

Weld Size Calculations, Description: LT1

Intermediate Calc. for nozzle/shell Welds	Tmin	6.6901 mm.
Intermediate Calc. for pad/shell Welds	TminPad	12.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.6831 = 0.7 * tmin.	5.6560 = 0.7 * Wo mm.
Pad Weld	6.0000 = 0.5 * TminPad	7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (6.617 - 0.884 + 2 * 6.69 * 0.855 * \\
 &\quad (1 * 15.5 - 13.54))137.9) \\
 &= 82.16 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (2.999 + 4.028 + 0.547 - 0 * 0.855) * 137.9 \\
 &= 104.44 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (2.999 + 0 + 0.547 + (1.773)) * 137.9 \\
 &= 73.35 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (2.999 + 0 + 0.547 + 4.028 + (1.773)) * 137.9 \\
 &= 128.89 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 60.33 * 8 * 0.49 * 117.9 \\
 &= 44. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 190 * 10 * 0.49 * 137.9 \\
 &= 202. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo)/4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.142 * 26.82) * (9.69 - 3) * 0.7 * 117.9 \\
 &= 47. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wgpn * 0.74 * Seg \\
 &= (3.142/2) * 60.33 * 12 * 0.74 * 137.9 \\
 &= 116. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.142/2.0) * 60.33 * (18.5 - 3) * 0.74 * 137.9 \\
 &= 150. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (201.6 + 46.51) = 248.2 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (43.79 + 116 + 149.9 + 0) = 309.7 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (201.6 + 149.9 + 0) = 351.5 \text{ kN}
 \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 248 kN , must exceed W = 82 kN or W1 = 104 kN
 Path 2-2 = 309 kN , must exceed W = 82 kN or W2 = 73 kN

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no: K.O. Drum (D-PK6101-3)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : Calculation Book for K.O. Drum (D-PK6101-3)
Nozzle Calcs.: LT1 Nozl: 13 8:33pm Feb 18,2022

Path 3-3 = 351 kN , must exceed W = 82 kN or W3 = 128 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 23.733 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 4.0032 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 222.6418 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1

Nozl: 14 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: A1**From : 20**


Pressure for Reinforcement Calculations	P	23.002	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		550.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		90.00	deg
Diameter		12.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	20.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	563.8500	mm.
Thickness of Pad	te	20.0000	mm.
Weld leg size between Pad and Shell	Wp	14.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	20.0000	mm.
Reinforcing Pad Width		120.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: A1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	12.750 in.
Actual Thickness Used in Calculation	0.601 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23) \\
 &= 15.2151 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (23 \cdot 161.9) / (117.9 \cdot 1 + 0.4 \cdot 23) \\
 &= 3.1347 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.8692 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	598.6257	mm.
Parallel to Vessel Wall, opening length	d	299.3128	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		42.5000	mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr4]:

$$\begin{aligned}
 &= \min(1, S_p / S_v) \\
 &= \min(1, 137.9 / 137.9) \\
 &= 1.000
 \end{aligned}$$

Weld Strength Reduction Factor [fr3]:

$$\begin{aligned}
 &= \min(fr2, fr4) \\
 &= \min(0.855, 1) \\
 &= 0.855
 \end{aligned}$$

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1 Nozl: 14 8:33pm Feb 18,2022

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	46.082	11.385	NA
Area in Shell	A1	5.279	28.043	NA
Area in Nozzle Wall	A2	6.638	8.284	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		2.815	2.815	NA
Area in Element	A5	36.000	36.000	NA
TOTAL AREA AVAILABLE	Atot	50.732	75.143	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	532.8495	20.0000 mm.
Based on given Pad Diameter:	563.8500	17.4166 mm.
Based on Shell or Nozzle Thickness:	597.6143	15.2686 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) UG-37(c)$$

$$= (299.3 * 15.22 * 1 + 2 * 12.27 * 15.22 * 1 * (1 - 0.855))$$

$$= 46.082 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 299.3 (1 * 17 - 1 * 15.22) - 2 * 12.27$$

$$(1 * 17 - 1 * 15.22) * (1 - 0.855)$$

$$= 5.279 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 42.5) * (12.27 - 3.135) * 0.855$$

$$= 6.638 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 14^2 * 1$$

$$= 2.815 \text{ cm}^2$$

Area Available in Element, also see UG-37(h) [A5]:

$$= (\min(Dp, DL) - (Nozzle OD)) (\min(tp, Tlwp, te)) * fr4 * 0.75$$

$$= (563.8 - 323.9) 20 * 1 * 0.75$$

$$= 36.000 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 6.1347 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2151 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2151 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 11.3312 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: A1 Nozl: 14 8:33pm Feb 18,2022

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[11.33, max(18.22, 4.5)]
 = 11.3312 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(6.135, 11.33)
 = 11.3312 mm.

Available Nozzle Neck Thickness = 15.2686 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	38.5,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	256.3 N./mm ²	Passed
Occasional	:	13.5,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	13.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C
Governing MDMT of the Nozzle	: -104 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1 Nozl: 14 8:33pm Feb 18,2022

Governing MDMT of the Reinforcement Pad : -45 °C

Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C

Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C

Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: A1

Intermediate Calc. for nozzle/shell Welds Tmin 12.2686 mm.

Intermediate Calc. for pad/shell Welds TminPad 17.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	7.0700 = 0.7 * Wo mm.
Pad Weld	8.5000 = 0.5*TminPad	9.8980 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (46.08 - 5.279 + 2 * 12.27 * 0.855 * \\
 &\quad (1 * 17 - 15.22)) 137.9) \\
 &= 567.79 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (6.638 + 36 + 2.815 - 0 * 0.855) * 137.9 \\
 &= 626.74 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (6.638 + 0 + 0.855 + (3.566)) * 137.9 \\
 &= 152.50 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (6.638 + 0 + 2.815 + 36 + (3.566)) * 137.9 \\
 &= 675.92 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 323.9 * 10 * 0.49 * 117.9 \\
 &= 294. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 563.8 * 14 * 0.49 * 137.9 \\
 &= 838. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1 Noz1: 14 8:33pm Feb 18,2022

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 155.8) * (15.27 - 3) * 0.7 * 117.9$$

$$= 496. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 323.9 * 20 * 0.74 * 137.9$$

$$= 1038. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi - Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 323.9 * (20 - 3) * 0.74 * 137.9$$

$$= 882. \text{ kN}$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (837.8 + 495.5) = 1333 \text{ kN}$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (293.9 + 1038 + 882.4 + 0) = 2214 \text{ kN}$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (837.8 + 882.4 + 0) = 1720 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 1333 kN , must exceed W = 567 kN or W1 = 626 kN

Path 2-2 = 2214 kN , must exceed W = 567 kN or W2 = 152 kN

Path 3-3 = 1720 kN , must exceed W = 567 kN or W3 = 675 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 24.136 bars

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 14.6863 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 234.6864 mm.

Input Echo, WRC107/537 Item 1, Description: A1 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1800.000	mm.
Vessel Thickness	Tv	20.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	323.850	mm.
Nozzle Thickness	Tn	15.269	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	20.000	mm.
Diameter of Reinforcing Pad	Dpad	563.850	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1 Nozl: 14 8:33pm Feb 18,2022

Design Internal Pressure	Dp	23.002	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load	(SUS)	P	12.0	kN
Longitudinal Shear	(SUS)	Vl	12.0	kN
Circumferential Shear	(SUS)	Vc	12.0	kN
Circumferential Moment	(SUS)	Mc	15300.0	N-m
Longitudinal Moment	(SUS)	Ml	15300.0	N-m
Torsional Moment	(SUS)	Mt	18900.0	N-m

Use Interactive Control		No
WRC107 Version	Version	March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(t - ca))$$

$$= 323.85 + 2 * 1.65 * \text{sqrt}(911.5 (20.0 - 3.0))$$

$$= 734.637 \text{ mm.}$$

WRC 107 Stress Calculation for SUSTAINED loads:

Radial Load	P	12.0	kN
Circumferential Shear	VC	12.0	kN
Longitudinal Shear	VL	12.0	kN
Circumferential Moment	MC	15300.0	N-m
Longitudinal Moment	ML	15300.0	N-m
Torsional Moment	MT	18900.0	N-m

Dimensionless Parameters used : Gamma = 24.91

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.154	4C	4.060	(A,B)
N(PHI) / (P/Rm)	0.154	3C	3.302	(C,D)
M(PHI) / (P)	0.154	2C1	0.070	(A,B)
M(PHI) / (P)	0.154	1C	0.103	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.154	3A	0.857	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.154	1A	0.092	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.154	3B	2.736	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.154	1B	0.040	(A,B,C,D)
N(x) / (P/Rm)	0.154	3C	3.302	(A,B)
N(x) / (P/Rm)	0.154	4C	4.060	(C,D)
M(x) / (P)	0.154	1C1	0.108	(A,B)
M(x) / (P)	0.154	2C	0.070	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.154	4A	1.316	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.154	2A	0.049	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.154	4B	0.831	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.154	2B	0.066	(A,B,C,D)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1

Noz1: 14 8:33pm Feb 18,2022

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-1.4	-1.4	-1.4	-1.4	-1.2	-1.2	-1.2	-1.2
Circ. Bend. P		-3.7	3.7	-3.7	3.7	-5.4	5.4	-5.4	5.4
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.7	-2.7	2.7	2.7
Circ. Memb. MC		0.0	0.0	0.0	0.0	-43.7	43.7	43.7	-43.7
Circ. Memb. ML		-8.7	-8.7	8.7	8.7	0.0	0.0	0.0	0.0
Circ. Bend. ML		-18.9	18.9	18.9	-18.9	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-32.7	12.5	22.5	-8.0	-53.0	45.2	39.8	-36.7
Long. Memb. P		-1.2	-1.2	-1.2	-1.2	-1.4	-1.4	-1.4	-1.4
Long. Bend. P		-5.7	5.7	-5.7	5.7	-3.7	3.7	-3.7	3.7
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.2	-4.2	4.2	4.2
Long. Bend. MC		0.0	0.0	0.0	0.0	-23.0	23.0	23.0	-23.0
Long. Memb. ML		-2.6	-2.6	2.6	2.6	0.0	0.0	0.0	0.0
Long. Bend. ML		-31.3	31.3	31.3	-31.3	0.0	0.0	0.0	0.0
Tot. Long. Str.		-40.7	33.2	27.1	-24.2	-32.3	21.1	22.1	-16.6
Shear VC		0.6	0.6	-0.6	-0.6	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.6	-0.6	0.6	0.6
Shear MT		3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
Tot. Shear		3.7	3.7	2.5	2.5	2.5	2.5	3.7	3.7
Str. Int.		42.2	33.8	28.2	24.5	53.2	45.5	40.6	37.4

Dimensionless Parameters used : Gamma = 53.62

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.271	4C	5.892	(A,B)
N(PHI) / (P/Rm)	0.271	3C	2.812	(C,D)
M(PHI) / (P)	0.271	2C1	0.016	(A,B)
M(PHI) / (P)	0.271	1C !	0.066	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.271	3A	1.804	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.271	1A	0.061	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.271	3B	3.868	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.271	1B	0.012	(A,B,C,D)
N(x) / (P/Rm)	0.271	3C	2.812	(A,B)
N(x) / (P/Rm)	0.271	4C	5.892	(C,D)
M(x) / (P)	0.271	1C1	0.038	(A,B)
M(x) / (P)	0.271	2C !	0.034	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.271	4A	4.954	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.271	2A	0.025	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.271	4B	1.945	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.271	2B	0.017	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1

Noz1: 14 8:33pm Feb 18,2022

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-4.6	-4.6	-4.6	-4.6	-2.2	-2.2	-2.2	-2.2
Circ. Bend. P		-3.9	3.9	-3.9	3.9	-16.3	16.3	-16.3	16.3
Circ. Memb. MC		0.0	0.0	0.0	0.0	-7.2	-7.2	7.2	7.2
Circ. Memb. MC		0.0	0.0	0.0	0.0	-78.6	78.6	78.6	-78.6
Circ. Memb. ML		-15.5	-15.5	15.5	15.5	0.0	0.0	0.0	0.0
Circ. Bend. ML		-15.0	15.0	15.0	-15.0	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-38.9	-1.2	22.0	-0.2	-104.4	85.6	67.4	-57.3
Long. Memb. P		-2.2	-2.2	-2.2	-2.2	-4.6	-4.6	-4.6	-4.6
Long. Bend. P		-9.5	9.5	-9.5	9.5	-8.4	8.4	-8.4	8.4
Long. Memb. MC		0.0	0.0	0.0	0.0	-19.8	-19.8	19.8	19.8
Long. Bend. MC		0.0	0.0	0.0	0.0	-32.4	32.4	32.4	-32.4
Long. Memb. ML		-7.8	-7.8	7.8	7.8	0.0	0.0	0.0	0.0
Long. Bend. ML		-22.3	22.3	22.3	-22.3	0.0	0.0	0.0	0.0
Tot. Long. Str.		-41.7	21.8	18.4	-7.2	-65.2	16.4	39.2	-8.7
Shear VC		0.8	0.8	-0.8	-0.8	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.8	-0.8	0.8	0.8
Shear MT		2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2
Tot. Shear		3.0	3.0	1.4	1.4	1.4	1.4	3.0	3.0
Str. Int.		43.6	23.8	22.5	7.6	104.4	85.6	67.7	57.5

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		55.0	57.3	55.0	57.3	55.0	57.3	55.0	57.3
Circ. Pl (SUS)		-10.1	-10.1	7.2	7.2	-3.9	-3.9	1.6	1.6
Circ. Q (SUS)		-22.6	22.6	15.3	-15.3	-49.1	49.1	38.3	-38.3
Long. Pm (SUS)		27.5	27.5	27.5	27.5	27.5	27.5	27.5	27.5
Long. Pl (SUS)		-3.8	-3.8	1.5	1.5	-5.6	-5.6	2.7	2.7
Long. Q (SUS)		-37.0	37.0	25.6	-25.6	-26.7	26.7	19.4	-19.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.6	0.6	-0.6	-0.6	-0.6	-0.6	0.6	0.6
Shear Q (SUS)		3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
Pm (SUS)		55.0	57.3	55.0	57.3	55.0	57.3	55.0	57.3
Pm+Pl (SUS)		44.9	47.2	62.3	64.6	51.2	53.4	56.6	58.9
Pm+Pl+Q (Total)		36.3	71.1	77.8	49.4	8.4	102.6	95.1	21.9

Stress Summation Comparison (N./mm²):

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A1 Nozl: 14 8:33pm Feb 18,2022

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	57.31	137.90	Passed
Pm+Pl (SUS)	64.56	206.85	Passed
Pm+Pl+Q (TOTAL)	102.63	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Circ. Pl (SUS)		-20.0	-20.0	10.9	10.9	-9.4	-9.4	5.0	5.0
Circ. Q (SUS)		-18.8	18.8	11.1	-11.1	-95.0	95.0	62.3	-62.3
Long. Pm (SUS)		60.5	60.5	60.5	60.5	60.5	60.5	60.5	60.5
Long. Pl (SUS)		-10.0	-10.0	5.6	5.6	-24.4	-24.4	15.3	15.3
Long. Q (SUS)		-31.7	31.7	12.8	-12.8	-40.8	40.8	23.9	-23.9
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.8	0.8	-0.8	-0.8	-0.8	-0.8	0.8	0.8
Shear Q (SUS)		2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2
Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Pm+Pl (SUS)		101.0	103.3	132.0	134.3	111.7	114.0	126.1	128.4
Pm+Pl+Q (Total)		82.3	122.4	143.1	123.2	21.5	209.0	188.5	66.7

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	123.35	137.90	Passed
Pm+Pl (SUS)	134.27	206.85	Passed
Pm+Pl+Q (TOTAL)	208.95	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Nozl: 15 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: A2**From : 20**

Pressure for Reinforcement Calculations	P	23.001	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested] SA-516 70			
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1150.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C


Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		45.00	deg
Diameter		8.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	20.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested] SA-516 70			
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	419.0750	mm.
Thickness of Pad	te	15.0000	mm.
Weld leg size between Pad and Shell	Wp	14.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	15.0000	mm.
Reinforcing Pad Width		100.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: A2 Noz1: 15 8:33pm Feb 18,2022

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: A2

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	8.625 in.
Actual Thickness Used in Calculation	0.438 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23) \\
 &= 15.2148 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (23 \cdot 109.5) / (117.9 \cdot 1 + 0.4 \cdot 23) \\
 &= 2.1205 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.6930 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	405.7000 mm.
Parallel to Vessel Wall, opening length	d	202.8500 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		35.2813 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr4]:

$$\begin{aligned}
 &= \min(1, S_p / S_v) \\
 &= \min(1, 137.9 / 137.9) \\
 &= 1.000
 \end{aligned}$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Noz1: 15 8:33pm Feb 18,2022

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	31.221	7.714	NA
Area in Shell	A1	3.579	19.011	NA
Area in Nozzle Wall	A2	3.615	4.476	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	27.994	27.994	NA
TOTAL AREA AVAILABLE	Atot	36.043	52.336	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	373.5552	15.0000 mm.
Based on given Pad Diameter:	419.0750	12.4164 mm.
Based on the Estimated Diameter Limit:	404.1125	12.5229 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (202.8 * 15.21 * 1 + 2 * 8.113 * 15.21 * 1 * (1 - 0.855))$$

$$= 31.221 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 202.8 (1 * 17 - 1 * 15.21) - 2 * 8.113 (1 * 17 - 1 * 15.21) * (1 - 0.855)$$

$$= 3.579 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 35.28) * (8.113 - 2.12) * 0.855$$

$$= 3.615 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (405.7 - 219.1) * 15 * 1$$

$$= 27.994 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 5.1205 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2148 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2148 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: A2 Noz1: 15 8:33pm Feb 18,2022

Wall Thickness per table UG-45 $tb_3 = 10.1600$ mm.

Determine Nozzle Thickness candidate [tb]:
 $= \min[tb_3, \max(tb_1, tb_2)]$
 $= \min[10.16, \max(18.21, 4.5)]$
 $= 10.1600$ mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 $= \max(ta, tb)$
 $= \max(5.12, 10.16)$
 $= 10.1600$ mm.

Available Nozzle Neck Thickness = 11.1125 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	50.5,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	244.3 N./mm ²	Passed
Occasional	:	13.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	20.4,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY**DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT**

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Noz1: 15 8:33pm Feb 18,2022

Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -45 °C
 Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

*Note:**Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.***Weld Size Calculations, Description: A2**

Intermediate Calc. for nozzle/shell Welds Tmin 8.1125 mm.
 Intermediate Calc. for pad/shell Welds TminPad 15.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	5.6788 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.
Pad Weld	7.5000 = 0.5*TminPad	9.8980 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (31.22 - 3.579 + 2 * 8.113 * 0.855 * \\
 &\quad (1 * 17 - 15.21)) 137.9) \\
 &= 384.57 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (3.615 + 27.99 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 447.64 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (3.615 + 0 + 0.855 + (2.358)) * 137.9 \\
 &= 94.15 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (3.615 + 0 + 0.855 + 27.99 + (2.358)) * 137.9 \\
 &= 480.16 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 219.1 * 10 * 0.49 * 117.9 \\
 &= 199. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 419.1 * 14 * 0.49 * 137.9
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Noz1: 15 8:33pm Feb 18,2022

= 623. kN

Shear, Nozzle Wall [Snw]:

= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn
 = (3.142 * 105.5) * (11.11 - 3) * 0.7 * 117.9
 = 222. kN

Tension, Pad Groove Weld [Tpgw]:

= (pi / 2) * Dlo * Wgpn * 0.74 * Seg
 = (3.142 / 2) * 219.1 * 15 * 0.74 * 137.9
 = 527. kN

Tension, Shell Groove Weld [Tngw]:

= (pi / 2) * Dlo * (Wgnvi - Cas) * 0.74 * Sng
 = (3.142 / 2.0) * 219.1 * (20 - 3) * 0.74 * 137.9
 = 597. kN

Strength of Failure Paths:

PATH11 = (SPEW + SNW) = (622.7 + 221.9) = 844.5 kN
 PATH22 = (Sonw + Tpgw + Tngw + Sinw)
 = (198.8 + 526.7 + 596.9 + 0) = 1322 kN
 PATH33 = (Spew + Tngw + Sinw)
 = (622.7 + 596.9 + 0) = 1220 kN

Summary of Failure Path Calculations:

Path 1-1 = 844 kN , must exceed W = 384 kN or W1 = 447 kN
 Path 2-2 = 1322 kN , must exceed W = 384 kN or W2 = 94 kN
 Path 3-3 = 1219 kN , must exceed W = 384 kN or W3 = 480 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 24.743 bars

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 6.6907 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 226.6907 mm.

Input Echo, WRC107/537 Item 1, Description: A2 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1800.000	mm.
Vessel Thickness	Tv	20.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	219.075	mm.
Nozzle Thickness	Tn	11.113	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	15.000	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Noz1: 15 8:33pm Feb 18,2022

Diameter of Reinforcing Pad	Dpad	419.075	mm.
Design Internal Pressure	Dp	23.001	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	8.0	kN
Longitudinal Shear (SUS)	VL	8.0	kN
Circumferential Shear (SUS)	Vc	8.0	kN
Circumferential Moment (SUS)	Mc	6800.0	N-m
Longitudinal Moment (SUS)	ML	6800.0	N-m
Torsional Moment (SUS)	Mt	8400.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 219.075 + 2 * 1.65 * sqrt(911.5 (20.0 - 3.0))
 = 629.862 mm.

WRC 107 Stress Calculation for SUSTAINED loads:

Radial Load	P	8.0	kN
Circumferential Shear	VC	8.0	kN
Longitudinal Shear	VL	8.0	kN
Circumferential Moment	MC	6800.0	N-m
Longitudinal Moment	ML	6800.0	N-m
Torsional Moment	MT	8400.0	N-m

Dimensionless Parameters used : Gamma = 28.72

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.104	4C	5.151	(A,B)
N(PHI) / (P/Rm)	0.104	3C	4.518	(C,D)
M(PHI) / (P)	0.104	2C1	0.100	(A,B)
M(PHI) / (P)	0.104	1C	0.135	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.104	3A	0.791	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.104	1A	0.098	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.104	3B	2.706	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.104	1B	0.048	(A,B,C,D)
N(x) / (P/Rm)	0.104	3C	4.518	(A,B)
N(x) / (P/Rm)	0.104	4C	5.151	(C,D)
M(x) / (P)	0.104	1C1	0.139	(A,B)
M(x) / (P)	0.104	2C	0.100	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.104	4A	1.120	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.104	2A	0.055	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.104	4B	0.757	(A,B,C,D)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2 Noz1: 15 8:33pm Feb 18,2022

M(x) / (ML/(Rm * Beta)) 0.104 2B 0.078 (A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb.	P	-1.4	-1.4	-1.4	-1.4	-1.2	-1.2	-1.2	-1.2
Circ. Bend.	P	-4.7	4.7	-4.7	4.7	-6.3	6.3	-6.3	6.3
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-1.9	-1.9	1.9	1.9
Circ. Memb.	ML	-6.5	-6.5	6.5	6.5	0.0	0.0	40.8	-40.8
Circ. Bend.	ML	-19.9	19.9	19.9	-19.9	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-32.5	16.6	20.3	-10.1	-50.3	44.0	35.2	-33.8
Long. Memb.	P	-1.2	-1.2	-1.2	-1.2	-1.4	-1.4	-1.4	-1.4
Long. Bend.	P	-6.5	6.5	-6.5	6.5	-4.7	4.7	-4.7	4.7
Long. Memb.	MC	0.0	0.0	0.0	0.0	-2.7	-2.7	2.7	2.7
Long. Bend.	MC	0.0	0.0	0.0	0.0	-22.7	22.7	22.7	-22.7
Long. Memb.	ML	-1.8	-1.8	1.8	1.8	0.0	0.0	0.0	0.0
Long. Bend.	ML	-32.6	32.6	32.6	-32.6	0.0	0.0	0.0	0.0
Tot. Long. Str.		-42.2	36.1	26.7	-25.5	-31.5	23.2	19.3	-16.7
Shear	VC	0.7	0.7	-0.7	-0.7	0.0	0.0	0.0	0.0
Shear	VL	0.0	0.0	0.0	0.0	-0.7	-0.7	0.7	0.7
Shear	MT	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
Tot. Shear		4.2	4.2	2.8	2.8	2.8	2.8	4.2	4.2
Str. Int.		43.7	36.9	27.7	26.0	50.7	44.4	36.2	34.8

Dimensionless Parameters used : Gamma = 53.62

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.201	4C	7.045	(A,B)
N(PHI) / (P/Rm)	0.201	3C	4.207	(C,D)
M(PHI) / (P)	0.201	2C1	0.028	(A,B)
M(PHI) / (P)	0.201	1C !	0.066	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.201	3A	2.111	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.201	1A	0.069	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.201	3B	5.017	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.201	1B	0.020	(A,B,C,D)
N(x) / (P/Rm)	0.201	3C	4.207	(A,B)
N(x) / (P/Rm)	0.201	4C	7.045	(C,D)
M(x) / (P)	0.201	1C1	0.058	(A,B)
M(x) / (P)	0.201	2C !	0.034	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.201	4A	4.420	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.201	2A	0.032	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.201	4B	2.156	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.201	2B	0.028	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Noz1: 15 8:33pm Feb 18,2022

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.6	-3.6	-3.6	-3.6	-2.2	-2.2	-2.2	-2.2
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-10.9	10.9	-10.9	10.9
Circ. Memb. MC		0.0	0.0	0.0	0.0	-5.1	-5.1	5.1	5.1
Circ. Memb. MC		0.0	0.0	0.0	0.0	-53.1	53.1	53.1	-53.1
Circ. Memb. ML		-12.0	-12.0	12.0	12.0	0.0	0.0	0.0	0.0
Circ. Bend. ML		-15.4	15.4	15.4	-15.4	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-35.7	4.4	19.2	-2.5	-71.2	56.7	45.1	-39.3
Long. Memb. P		-2.2	-2.2	-2.2	-2.2	-3.6	-3.6	-3.6	-3.6
Long. Bend. P		-9.6	9.6	-9.6	9.6	-5.6	5.6	-5.6	5.6
Long. Memb. MC		0.0	0.0	0.0	0.0	-10.6	-10.6	10.6	10.6
Long. Bend. MC		0.0	0.0	0.0	0.0	-24.5	24.5	24.5	-24.5
Long. Memb. ML		-5.2	-5.2	5.2	5.2	0.0	0.0	0.0	0.0
Long. Bend. ML		-21.8	21.8	21.8	-21.8	0.0	0.0	0.0	0.0
Tot. Long. Str.		-38.7	24.1	15.1	-9.2	-44.4	15.9	25.9	-12.0
Shear VC		0.7	0.7	-0.7	-0.7	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.7	-0.7	0.7	0.7
Shear MT		1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8
Tot. Shear		2.5	2.5	1.1	1.1	1.1	1.1	2.5	2.5
Str. Int.		40.1	24.4	19.5	9.3	71.2	56.8	45.4	39.5

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		63.8	66.1	63.8	66.1	63.8	66.1	63.8	66.1
Circ. Pl (SUS)		-7.9	-7.9	5.1	5.1	-3.1	-3.1	0.7	0.7
Circ. Q (SUS)		-24.6	24.6	15.2	-15.2	-47.2	47.2	34.5	-34.5
Long. Pm (SUS)		31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9
Long. Pl (SUS)		-3.1	-3.1	0.6	0.6	-4.1	-4.1	1.3	1.3
Long. Q (SUS)		-39.1	39.1	26.1	-26.1	-27.4	27.4	18.0	-18.0
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.7	0.7	-0.7	-0.7	-0.7	-0.7	0.7	0.7
Shear Q (SUS)		3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
Pm (SUS)		63.8	66.1	63.8	66.1	63.8	66.1	63.8	66.1
Pm+Pl (SUS)		55.9	58.2	68.9	71.2	60.7	63.0	64.5	66.8
Pm+Pl+Q (Total)		42.4	83.8	84.4	56.2	14.1	110.3	99.3	33.3

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: A2

Noz1: 15 8:33pm Feb 18,2022

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	66.08	137.90	Passed
Pm+Pl (SUS)	71.22	206.85	Passed
Pm+Pl+Q (TOTAL)	110.27	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Circ. Pl (SUS)		-15.6	-15.6	8.4	8.4	-7.2	-7.2	2.9	2.9
Circ. Q (SUS)		-20.0	20.0	10.8	-10.8	-64.0	64.0	42.2	-42.2
Long. Pm (SUS)		60.5	60.5	60.5	60.5	60.5	60.5	60.5	60.5
Long. Pl (SUS)		-7.3	-7.3	3.0	3.0	-14.2	-14.2	6.9	6.9
Long. Q (SUS)		-31.4	31.4	12.1	-12.1	-30.1	30.1	18.9	-18.9
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.7	0.7	-0.7	-0.7	-0.7	-0.7	0.7	0.7
Shear Q (SUS)		1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8
Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Pm+Pl (SUS)		105.4	107.7	129.4	131.7	113.8	116.1	123.9	126.2
Pm+Pl+Q (Total)		85.5	127.9	140.3	120.9	49.9	180.1	166.2	84.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	123.34	137.90	Passed
Pm+Pl (SUS)	131.72	206.85	Passed
Pm+Pl+Q (TOTAL)	180.10	413.70	Passed

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B

Noz1: 16 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: B From : 20


Pressure for Reinforcement Calculations	P	23.000	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		2450.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		270.00	deg
Diameter		12.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	20.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	563.8500	mm.
Thickness of Pad	te	20.0000	mm.
Weld leg size between Pad and Shell	Wp	14.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	20.0000	mm.
Reinforcing Pad Width		120.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: B

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	12.750 in.
Actual Thickness Used in Calculation	0.601 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23) \\
 &= 15.2144 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (23 \cdot 161.9) / (117.9 \cdot 1 + 0.4 \cdot 23) \\
 &= 3.1345 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.8692 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	598.6257	mm.
Parallel to Vessel Wall, opening length	d	299.3128	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		42.5000	mm.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr4]:

$$\begin{aligned}
 &= \min(1, S_p / S_v) \\
 &= \min(1, 137.9 / 137.9) \\
 &= 1.000
 \end{aligned}$$

Weld Strength Reduction Factor [fr3]:

$$\begin{aligned}
 &= \min(fr2, fr4) \\
 &= \min(0.855, 1) \\
 &= 0.855
 \end{aligned}$$

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B Nozl: 16 8:33pm Feb 18,2022

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	46.080	11.385	NA
Area in Shell	A1	5.281	28.043	NA
Area in Nozzle Wall	A2	6.638	8.284	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		2.815	2.815	NA
Area in Element	A5	36.000	36.000	NA
TOTAL AREA AVAILABLE	Atot	50.734	75.143	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	532.8200	20.0000 mm.
Based on given Pad Diameter:	563.8500	17.4142 mm.
Based on Shell or Nozzle Thickness:	597.5757	15.2686 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (299.3 * 15.21 * 1 + 2 * 12.27 * 15.21 * 1 * (1 - 0.855))$$

$$= 46.080 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1 * t - F * tr) - 2 * tn(E1 * t - F * tr) * (1 - fr1)$$

$$= 299.3 (1 * 17 - 1 * 15.21) - 2 * 12.27$$

$$(1 * 17 - 1 * 15.21) * (1 - 0.855)$$

$$= 5.281 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 42.5) * (12.27 - 3.135) * 0.855$$

$$= 6.638 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 14^2 * 1$$

$$= 2.815 \text{ cm}^2$$

Area Available in Element, also see UG-37(h) [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) (\min(tp, Tlwp, te)) * fr4 * 0.75$$

$$= (563.8 - 323.9) 20 * 1 * 0.75$$

$$= 36.000 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 6.1345 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2144 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2144 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 11.3312 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: B Nozl: 16 8:33pm Feb 18,2022

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[11.33, max(18.21, 4.5)]
 = 11.3312 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(6.135, 11.33)
 = 11.3312 mm.

Available Nozzle Neck Thickness = 15.2686 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	38.5,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	256.3 N./mm ²	Passed
Occasional	:	13.5,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	13.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C
Governing MDMT of the Nozzle	: -104 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B Nozl: 16 8:33pm Feb 18,2022

Governing MDMT of the Reinforcement Pad : -45 °C

Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C

Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C

Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: B

Intermediate Calc. for nozzle/shell Welds Tmin 12.2686 mm.

Intermediate Calc. for pad/shell Welds TminPad 17.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	7.0700 = 0.7 * Wo mm.
Pad Weld	8.5000 = 0.5*TminPad	9.8980 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (46.08 - 5.281 + 2 * 12.27 * 0.855 * \\
 &\quad (1 * 17 - 15.21))) 137.9) \\
 &= 567.73 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (6.638 + 36 + 2.815 - 0 * 0.855) * 137.9 \\
 &= 626.75 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (6.638 + 0 + 0.855 + (3.566)) * 137.9 \\
 &= 152.50 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (6.638 + 0 + 2.815 + 36 + (3.566)) * 137.9 \\
 &= 675.92 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 323.9 * 10 * 0.49 * 117.9 \\
 &= 294. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 563.8 * 14 * 0.49 * 137.9 \\
 &= 838. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B Nozl: 16 8:33pm Feb 18,2022

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 155.8) * (15.27 - 3) * 0.7 * 117.9$$

$$= 496. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 323.9 * 20 * 0.74 * 137.9$$

$$= 1038. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi - Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 323.9 * (20 - 3) * 0.74 * 137.9$$

$$= 882. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (837.8 + 495.5) = 1333 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (293.9 + 1038 + 882.4 + 0) = 2214 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (837.8 + 882.4 + 0) = 1720 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 1333 kN , must exceed W = 567 kN or W1 = 626 kN

Path 2-2 = 2214 kN , must exceed W = 567 kN or W2 = 152 kN

Path 3-3 = 1720 kN , must exceed W = 567 kN or W3 = 675 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 24.136 bars

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 14.6863 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 234.6864 mm.

Input Echo, WRC107/537 Item 1, Description: B :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1800.000	mm.
Vessel Thickness	Tv	20.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	323.850	mm.
Nozzle Thickness	Tn	15.269	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	20.000	mm.
Diameter of Reinforcing Pad	Dpad	563.850	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B Nozl: 16 8:33pm Feb 18,2022

Design Internal Pressure	Dp	23.000	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load	(SUS)	P	12.0	kN
Longitudinal Shear	(SUS)	Vl	12.0	kN
Circumferential Shear	(SUS)	Vc	12.0	kN
Circumferential Moment	(SUS)	Mc	15300.0	N-m
Longitudinal Moment	(SUS)	Ml	15300.0	N-m
Torsional Moment	(SUS)	Mt	18900.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(t - ca))$$

$$= 323.85 + 2 * 1.65 * \text{sqrt}(911.5 (20.0 - 3.0))$$

$$= 734.637 \text{ mm.}$$

WRC 107 Stress Calculation for SUSTAINED loads:

Radial Load	P	12.0	kN
Circumferential Shear	VC	12.0	kN
Longitudinal Shear	VL	12.0	kN
Circumferential Moment	MC	15300.0	N-m
Longitudinal Moment	ML	15300.0	N-m
Torsional Moment	MT	18900.0	N-m

Dimensionless Parameters used : Gamma = 24.91

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.154	4C	4.060	(A,B)
N(PHI) / (P/Rm)	0.154	3C	3.302	(C,D)
M(PHI) / (P)	0.154	2C1	0.070	(A,B)
M(PHI) / (P)	0.154	1C	0.103	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.154	3A	0.857	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.154	1A	0.092	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.154	3B	2.736	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.154	1B	0.040	(A,B,C,D)
N(x) / (P/Rm)	0.154	3C	3.302	(A,B)
N(x) / (P/Rm)	0.154	4C	4.060	(C,D)
M(x) / (P)	0.154	1C1	0.108	(A,B)
M(x) / (P)	0.154	2C	0.070	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.154	4A	1.316	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.154	2A	0.049	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.154	4B	0.831	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.154	2B	0.066	(A,B,C,D)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B

Noz1: 16 8:33pm Feb 18,2022

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-1.4	-1.4	-1.4	-1.4	-1.2	-1.2	-1.2	-1.2
Circ. Bend. P		-3.7	3.7	-3.7	3.7	-5.4	5.4	-5.4	5.4
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.7	-2.7	2.7	2.7
Circ. Memb. MC		0.0	0.0	0.0	0.0	-43.7	43.7	43.7	-43.7
Circ. Memb. ML		-8.7	-8.7	8.7	8.7	0.0	0.0	0.0	0.0
Circ. Bend. ML		-18.9	18.9	18.9	-18.9	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-32.7	12.5	22.5	-8.0	-53.0	45.2	39.8	-36.7
Long. Memb. P		-1.2	-1.2	-1.2	-1.2	-1.4	-1.4	-1.4	-1.4
Long. Bend. P		-5.7	5.7	-5.7	5.7	-3.7	3.7	-3.7	3.7
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.2	-4.2	4.2	4.2
Long. Bend. MC		0.0	0.0	0.0	0.0	-23.0	23.0	23.0	-23.0
Long. Memb. ML		-2.6	-2.6	2.6	2.6	0.0	0.0	0.0	0.0
Long. Bend. ML		-31.3	31.3	31.3	-31.3	0.0	0.0	0.0	0.0
Tot. Long. Str.		-40.7	33.2	27.1	-24.2	-32.3	21.1	22.1	-16.6
Shear VC		0.6	0.6	-0.6	-0.6	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.6	-0.6	0.6	0.6
Shear MT		3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
Tot. Shear		3.7	3.7	2.5	2.5	2.5	2.5	3.7	3.7
Str. Int.		42.2	33.8	28.2	24.5	53.2	45.5	40.6	37.4

Dimensionless Parameters used : Gamma = 53.62

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.271	4C	5.892	(A,B)
N(PHI) / (P/Rm)	0.271	3C	2.812	(C,D)
M(PHI) / (P)	0.271	2C1	0.016	(A,B)
M(PHI) / (P)	0.271	1C !	0.066	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.271	3A	1.804	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.271	1A	0.061	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.271	3B	3.868	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.271	1B	0.012	(A,B,C,D)
N(x) / (P/Rm)	0.271	3C	2.812	(A,B)
N(x) / (P/Rm)	0.271	4C	5.892	(C,D)
M(x) / (P)	0.271	1C1	0.038	(A,B)
M(x) / (P)	0.271	2C !	0.034	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.271	4A	4.954	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.271	2A	0.025	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.271	4B	1.945	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.271	2B	0.017	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B

Noz1: 16 8:33pm Feb 18,2022

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb.	P	-4.6	-4.6	-4.6	-4.6	-2.2	-2.2	-2.2	-2.2
Circ. Bend.	P	-3.9	3.9	-3.9	3.9	-16.3	16.3	-16.3	16.3
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-7.2	-7.2	7.2	7.2
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-78.6	78.6	78.6	-78.6
Circ. Memb.	ML	-15.5	-15.5	15.5	15.5	0.0	0.0	0.0	0.0
Circ. Bend.	ML	-15.0	15.0	15.0	-15.0	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-38.9	-1.2	22.0	-0.2	-104.4	85.6	67.4	-57.3
Long. Memb.	P	-2.2	-2.2	-2.2	-2.2	-4.6	-4.6	-4.6	-4.6
Long. Bend.	P	-9.5	9.5	-9.5	9.5	-8.4	8.4	-8.4	8.4
Long. Memb.	MC	0.0	0.0	0.0	0.0	-19.8	-19.8	19.8	19.8
Long. Bend.	MC	0.0	0.0	0.0	0.0	-32.4	32.4	32.4	-32.4
Long. Memb.	ML	-7.8	-7.8	7.8	7.8	0.0	0.0	0.0	0.0
Long. Bend.	ML	-22.3	22.3	22.3	-22.3	0.0	0.0	0.0	0.0
Tot. Long. Str.		-41.7	21.8	18.4	-7.2	-65.2	16.4	39.2	-8.7
Shear	VC	0.8	0.8	-0.8	-0.8	0.0	0.0	0.0	0.0
Shear	VL	0.0	0.0	0.0	0.0	-0.8	-0.8	0.8	0.8
Shear	MT	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2
Tot. Shear		3.0	3.0	1.4	1.4	1.4	1.4	3.0	3.0
Str. Int.		43.6	23.8	22.5	7.6	104.4	85.6	67.7	57.5

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm	(SUS)	55.0	57.3	55.0	57.3	55.0	57.3	55.0	57.3
Circ. Pl	(SUS)	-10.1	-10.1	7.2	7.2	-3.9	-3.9	1.6	1.6
Circ. Q	(SUS)	-22.6	22.6	15.3	-15.3	-49.1	49.1	38.3	-38.3
Long. Pm	(SUS)	27.5	27.5	27.5	27.5	27.5	27.5	27.5	27.5
Long. Pl	(SUS)	-3.8	-3.8	1.5	1.5	-5.6	-5.6	2.7	2.7
Long. Q	(SUS)	-37.0	37.0	25.6	-25.6	-26.7	26.7	19.4	-19.4
Shear Pm	(SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl	(SUS)	0.6	0.6	-0.6	-0.6	-0.6	-0.6	0.6	0.6
Shear Q	(SUS)	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
Pm	(SUS)	55.0	57.3	55.0	57.3	55.0	57.3	55.0	57.3
Pm+Pl (SUS)		44.9	47.2	62.3	64.6	51.1	53.4	56.6	58.9
Pm+Pl+Q (Total)		36.3	71.1	77.8	49.4	8.4	102.6	95.1	21.9

Stress Summation Comparison (N./mm²):

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: B Nozl: 16 8:33pm Feb 18,2022

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	57.31	137.90	Passed
Pm+Pl (SUS)	64.56	206.85	Passed
Pm+Pl+Q (TOTAL)	102.63	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Circ. Pl (SUS)		-20.0	-20.0	10.9	10.9	-9.4	-9.4	5.0	5.0
Circ. Q (SUS)		-18.8	18.8	11.1	-11.1	-95.0	95.0	62.3	-62.3
Long. Pm (SUS)		60.5	60.5	60.5	60.5	60.5	60.5	60.5	60.5
Long. Pl (SUS)		-10.0	-10.0	5.6	5.6	-24.4	-24.4	15.3	15.3
Long. Q (SUS)		-31.7	31.7	12.8	-12.8	-40.8	40.8	23.9	-23.9
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.8	0.8	-0.8	-0.8	-0.8	-0.8	0.8	0.8
Shear Q (SUS)		2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2
Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Pm+Pl (SUS)		101.0	103.3	132.0	134.3	111.7	114.0	126.1	128.4
Pm+Pl+Q (Total)		82.3	122.4	143.1	123.2	21.5	208.9	188.5	66.7

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	123.34	137.90	Passed
Pm+Pl (SUS)	134.26	206.85	Passed
Pm+Pl+Q (TOTAL)	208.95	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT2 Nozl: 17 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: LT2 From : 20


Pressure for Reinforcement Calculations	P	23.002	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested] SA-516 70			
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		350.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-350 LF2	
Material UNS Number		K03011	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		180.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material [Normalized]		SA-350 LF2	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	18.5000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: LT2

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]
 = $(P \cdot R) / (S_v \cdot E - 0.6 \cdot P)$ per UG-27 (c) (1)
 = $(23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23)$
 = 15.2152 mm.

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]
 = $(P \cdot R) / (S_n \cdot E - 0.6 \cdot P)$ per UG-27 (c) (1)
 = $(23 \cdot 28.4) / (137.9 \cdot 1 - 0.6 \cdot 23)$
 = 0.4785 mm.

Required Nozzle thickness under External Pressure per UG-28 : 0.3963 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	118.0000	mm.
Parallel to Vessel Wall	Rn+tn+t	59.0000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	34.0000	mm.

Weld Strength Reduction Factor [fr1]:
 = $\min(1, S_n/S_v)$
 = $\min(1, 137.9/137.9)$
 = 1.000

Weld Strength Reduction Factor [fr2]:
 = $\min(1, S_n/S_v)$
 = $\min(1, 137.9/137.9)$
 = 1.000

Weld Strength Reduction Factor [fr3]:
 = $\min(fr2, fr4)$
 = $\min(1, 1)$
 = 1.000

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	8.642	2.135	NA
Area in Shell	A1	1.092	5.803	NA
Area in Nozzle Wall	A2	8.923	8.979	NA

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: LT2

Noz1: 17 8:33pm Feb 18,2022

Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	1.000	1.000	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	11.015	15.781	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (56.8 * 15.22 * 1 + 2 * 13.6 * 15.22 * 1 * (1 - 1))$$

$$= 8.642 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 61.2 (1 * 17 - 1 * 15.22) - 2 * 13.6$$

$$(1 * 17 - 1 * 15.22) * (1 - 1)$$

$$= 1.092 \text{ cm}^2$$

Area Available in Nozzle Projecting Outward [A2]:

$$= (2 * tlnp) (tn - trn) fr2$$

$$= (2 * 34) (13.6 - 0.479) 1$$

$$= 8.923 \text{ cm}^2$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2$$

$$= 10^2 * 1 + (0)^2 * 1$$

$$= 1.000 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4785 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2152 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2152 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[7.8, \max(18.22, 4.5)]$$

$$= 7.8000 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.479, 7.8)$$

$$= 7.8000 \text{ mm.}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained	: 14.9, Allowable	: 137.9 N./mm ²	Passed
Expansion	: 0.0, Allowable	: 329.9 N./mm ²	Passed
Occasional	: 1.9, Allowable	: 183.4 N./mm ²	Passed
Shear	: 9.6, Allowable	: 96.5 N./mm ²	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT2 Noz1: 17 8:33pm Feb 18,2022

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C
Governing MDMT of all the sub-joints of this Junction :	-104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification	-46 °C
Flange MDMT with Temp reduction per UCS-66(i)(2)	-48 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Weld Size Calculations, Description: LT2

Intermediate Calc. for nozzle/shell Welds T_{min} 13.6000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	7.0700 = 0.7 * W _o mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (8.642 - 1.092 + 2 * 13.6 * 1 * \\
 &\quad (1 * 17 - 15.22)) 137.9) \\
 &= 110.80 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (8.923 + 0 + 1 - 0 * 1) * 137.9 \\
 &= 136.82 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (8.923 + 0 + 1 + (4.624)) * 137.9 \\
 &= 200.58 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (8.923 + 0 + 1 + 0 + (4.624)) * 137.9 \\
 &= 200.58 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.142/2.0) * 84 * 10 * 0.49 * 137.9
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: LT2 Nozl: 17 8:33pm Feb 18,2022

= 89. kN

Shear, Nozzle Wall [Snw]:

= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn
 = (3.142 * 35.2) * (16.6 - 3) * 0.7 * 137.9
 = 145. kN

Tension, Shell Groove Weld [Tngw]:

= (pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng
 = (3.142/2.0) * 84 * (18.5 - 3) * 0.74 * 137.9
 = 209. kN

Strength of Failure Paths:

PATH11 = (SONW + SNW) = (89.15 + 145.2) = 234.3 kN
 PATH22 = (Sonw + Tpgw + Tngw + Sinw)
 = (89.15 + 0 + 208.7 + 0) = 297.8 kN
 PATH33 = (Sonw + Tngw + Sinw)
 = (89.15 + 208.7 + 0) = 297.8 kN

Summary of Failure Path Calculations:

Path 1-1 = 234 kN , must exceed W = 110 kN or W1 = 136 kN
 Path 2-2 = 297 kN , must exceed W = 110 kN or W2 = 200 kN
 Path 3-3 = 297 kN , must exceed W = 110 kN or W3 = 200 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 25.670 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 0.9806 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 220.9806 mm.

Input Echo, WRC107/537 Item 1, Description: LT2 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1800.000	mm.
Vessel Thickness	Tv	20.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	ID	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	50.800	mm.
Nozzle Thickness	Tn	16.600	mm.
Nozzle Material		SA-350 LF2	
Nozzle Cold S.I. Allowable	SNmc	137.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	137.90	N./mm ²
Design Internal Pressure	Dp	23.002	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: LT2

Noz1: 17 8:33pm Feb 18,2022

Radial Load	(SUS)	P	2.0	kN
Longitudinal Shear	(SUS)	Vl	2.0	kN
Circumferential Shear	(SUS)	Vc	2.0	kN
Circumferential Moment	(SUS)	Mc	400.0	N-m
Longitudinal Moment	(SUS)	ML	400.0	N-m
Torsional Moment	(SUS)	Mt	500.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(\text{t} - \text{ca}))$$

$$= 84.0 + 2 * 1.65 * \text{sqrt}(911.5 (20.0 - 3.0))$$

$$= 494.787 \text{ mm.}$$
WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 53.62

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.040	4C	10.132	(A,B)
N(PHI) / (P/Rm)	0.040	3C	10.199	(C,D)
M(PHI) / (P)	0.040	2C1	0.155	(A,B)
M(PHI) / (P)	0.040	1C	0.196	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.040	3A	0.626	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.040	1A	0.103	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.040	3B	2.664	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.040	1B	0.060	(A,B,C,D)

N(x) / (P/Rm)	0.040	3C	10.199	(A,B)
N(x) / (P/Rm)	0.040	4C	10.132	(C,D)
M(x) / (P)	0.040	1C1	0.203	(A,B)
M(x) / (P)	0.040	2C	0.154	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.040	4A	0.831	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.040	2A	0.062	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.040	4B	0.647	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.040	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: LT2

Noz1: 17 8:33pm Feb 18,2022

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb.	P	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3
Circ. Bend.	P	-6.4	6.4	-6.4	6.4	-8.1	8.1	-8.1	8.1
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-23.3	23.3	23.3	-23.3
Circ. Memb.	ML	-1.9	-1.9	1.9	1.9	0.0	0.0	0.0	0.0
Circ. Bend.	ML	-13.5	13.5	13.5	-13.5	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-23.1	16.8	7.7	-6.5	-33.2	29.7	14.3	-16.0
Long. Memb.	P	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3
Long. Bend.	P	-8.4	8.4	-8.4	8.4	-6.4	6.4	-6.4	6.4
Long. Memb.	MC	0.0	0.0	0.0	0.0	-0.6	-0.6	0.6	0.6
Long. Bend.	MC	0.0	0.0	0.0	0.0	-14.0	14.0	14.0	-14.0
Long. Memb.	ML	-0.5	-0.5	0.5	0.5	0.0	0.0	0.0	0.0
Long. Bend.	ML	-22.3	22.3	22.3	-22.3	0.0	0.0	0.0	0.0
Tot. Long. Str.		-32.5	29.0	13.0	-14.7	-22.3	18.6	6.9	-8.4
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		2.7	2.7	2.7	2.7	2.7	2.7	2.7	2.7
Tot. Shear		3.5	3.5	1.8	1.8	1.8	1.8	3.5	3.5
Str. Int.		33.7	30.0	13.5	15.1	33.5	30.0	15.7	17.4

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm	(SUS)	121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Circ. Pl	(SUS)	-3.2	-3.2	0.6	0.6	-1.8	-1.8	-0.9	-0.9
Circ. Q	(SUS)	-20.0	20.0	7.1	-7.1	-31.5	31.5	15.2	-15.2
Long. Pm	(SUS)	60.5	60.5	60.5	60.5	60.5	60.5	60.5	60.5
Long. Pl	(SUS)	-1.8	-1.8	-0.9	-0.9	-1.9	-1.9	-0.7	-0.7
Long. Q	(SUS)	-30.8	30.8	13.9	-13.9	-20.5	20.5	7.6	-7.6
Shear Pm	(SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl	(SUS)	0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q	(SUS)	2.7	2.7	2.7	2.7	2.7	2.7	2.7	2.7
Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Pm+Pl (SUS)		117.9	120.2	121.6	123.9	119.3	121.6	120.2	122.5
Pm+Pl+Q (Total)		98.1	140.4	128.8	116.8	87.9	153.1	135.5	107.5

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
---------------------	-----------	----------------	--------

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: SV Nozl: 18 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: SV From : 20


Pressure for Reinforcement Calculations	P	23.001	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1550.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-350 LF2	
Material UNS Number		K03011	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	16.6000	mm.
Flange Material [Normalized]		SA-350 LF2	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	18.5000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: SV

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 2.000 in.
 Actual Thickness Used in Calculation 0.654 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]
 = $(P \cdot R) / (S_v \cdot E - 0.6 \cdot P)$ per UG-27 (c) (1)
 = $(23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23)$
 = 15.2147 mm.

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]
 = $(P \cdot R) / (S_n \cdot E - 0.6 \cdot P)$ per UG-27 (c) (1)
 = $(23 \cdot 28.4) / (137.9 \cdot 1 - 0.6 \cdot 23)$
 = 0.4785 mm.

Required Nozzle thickness under External Pressure per UG-28 : 0.3963 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	118.0000	mm.
Parallel to Vessel Wall	Rn+tn+t	59.0000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	34.0000	mm.

Weld Strength Reduction Factor [fr1]:

= min(1, S_n / S_v)
 = min(1, $137.9 / 137.9$)
 = 1.000

Weld Strength Reduction Factor [fr2]:

= min(1, S_n / S_v)
 = min(1, $137.9 / 137.9$)
 = 1.000

Weld Strength Reduction Factor [fr3]:

= min(fr2, fr4)
 = min(1, 1)
 = 1.000

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	8.642	2.135	NA
Area in Shell	A1	1.093	5.803	NA
Area in Nozzle Wall	A2	8.923	8.979	NA

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY**DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT**

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: SV Nozl: 18 8:33pm Feb 18,2022

Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	1.000	1.000	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	11.015	15.781	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.**Area Required [A]:**

$$\begin{aligned}
 &= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)} \\
 &= (56.8 * 15.21 * 1 + 2 * 13.6 * 15.21 * 1 * (1 - 1)) \\
 &= 8.642 \text{ cm}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1**Area Available in Shell [A1]:**

$$\begin{aligned}
 &= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1) \\
 &= 61.2 (1 * 17 - 1 * 15.21) - 2 * 13.6 \\
 &\quad (1 * 17 - 1 * 15.21) * (1 - 1) \\
 &= 1.093 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 * tlnp) (tn - trn) fr2 \\
 &= (2 * 34) (13.6 - 0.479) 1 \\
 &= 8.923 \text{ cm}^2
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2 \\
 &= 10^2 * 1 + (0)^2 * 1 \\
 &= 1.000 \text{ cm}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.4785 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2147 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2147 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.8000 mm.

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[7.8, \max(18.21, 4.5)] \\
 &= 7.8000 \text{ mm.}
 \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned}
 &= \max(ta, tb) \\
 &= \max(3.479, 7.8) \\
 &= 7.8000 \text{ mm.}
 \end{aligned}$$

Available Nozzle Neck Thickness = 16.6000 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME**B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	: 14.9, Allowable	: 137.9 N./mm ²	Passed
Expansion	: 0.0, Allowable	: 329.9 N./mm ²	Passed
Occasional	: 1.9, Allowable	: 183.4 N./mm ²	Passed
Shear	: 9.6, Allowable	: 96.5 N./mm ²	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: SV Nozl: 18 8:33pm Feb 18,2022

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C
Governing MDMT of all the sub-joints of this Junction :	-104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification	-46 °C
Flange MDMT with Temp reduction per UCS-66(i)(2)	-48 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Weld Size Calculations, Description: SV

Intermediate Calc. for nozzle/shell Welds Tmin 13.6000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (8.642 - 1.093 + 2 * 13.6 * 1 * \\
 &\quad (1 * 17 - 15.21))137.9) \\
 &= 110.79 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (8.923 + 0 + 1 - 0 * 1) * 137.9 \\
 &= 136.82 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (8.923 + 0 + 1 + (4.624)) * 137.9 \\
 &= 200.58 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (8.923 + 0 + 1 + 0 + (4.624)) * 137.9 \\
 &= 200.58 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 84 * 10 * 0.49 * 137.9
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: SV

Noz1: 18 8:33pm Feb 18,2022

= 89. kN

Shear, Nozzle Wall [Snw]:

= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn
 = (3.142 * 35.2) * (16.6 - 3) * 0.7 * 137.9
 = 145. kN

Tension, Shell Groove Weld [Tngw]:

= (pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng
 = (3.142/2.0) * 84 * (18.5 - 3) * 0.74 * 137.9
 = 209. kN

Strength of Failure Paths:

PATH11 = (SONW + SNW) = (89.15 + 145.2) = 234.3 kN
 PATH22 = (Sonw + Tpgw + Tngw + Sinw)
 = (89.15 + 0 + 208.7 + 0) = 297.8 kN
 PATH33 = (Sonw + Tngw + Sinw)
 = (89.15 + 208.7 + 0) = 297.8 kN

Summary of Failure Path Calculations:

Path 1-1 = 234 kN , must exceed W = 110 kN or W1 = 136 kN
 Path 2-2 = 297 kN , must exceed W = 110 kN or W2 = 200 kN
 Path 3-3 = 297 kN , must exceed W = 110 kN or W3 = 200 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 25.669 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 0.9806 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 220.9806 mm.

Input Echo, WRC107/537 Item 1, Description: SV :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1800.000	mm.
Vessel Thickness	Tv	20.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516	70
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	ID	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	50.800	mm.
Nozzle Thickness	Tn	16.600	mm.
Nozzle Material		SA-350	LF2
Nozzle Cold S.I. Allowable	SNmc	137.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	137.90	N./mm ²
Design Internal Pressure	Dp	23.001	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: SV Nozl: 18 8:33pm Feb 18,2022

Radial Load	(SUS)	P	2.0	kN
Longitudinal Shear	(SUS)	Vl	2.0	kN
Circumferential Shear	(SUS)	Vc	2.0	kN
Circumferential Moment	(SUS)	Mc	400.0	N-m
Longitudinal Moment	(SUS)	ML	400.0	N-m
Torsional Moment	(SUS)	Mt	500.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(\text{t} - \text{ca}))$$

$$= 84.0 + 2 * 1.65 * \text{sqrt}(911.5 (20.0 - 3.0))$$

$$= 494.787 \text{ mm.}$$
WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 53.62

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.040	4C	10.132	(A,B)
N(PHI) / (P/Rm)	0.040	3C	10.199	(C,D)
M(PHI) / (P)	0.040	2C1	0.155	(A,B)
M(PHI) / (P)	0.040	1C	0.196	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.040	3A	0.626	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.040	1A	0.103	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.040	3B	2.664	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.040	1B	0.060	(A,B,C,D)

N(x) / (P/Rm)	0.040	3C	10.199	(A,B)
N(x) / (P/Rm)	0.040	4C	10.132	(C,D)
M(x) / (P)	0.040	1C1	0.203	(A,B)
M(x) / (P)	0.040	2C	0.154	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.040	4A	0.831	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.040	2A	0.062	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.040	4B	0.647	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.040	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: SV

Noz1: 18 8:33pm Feb 18,2022

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3
Circ. Bend. P		-6.4	6.4	-6.4	6.4	-8.1	8.1	-8.1	8.1
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4
Circ. Memb. MC		0.0	0.0	0.0	0.0	-23.3	23.3	23.3	-23.3
Circ. Memb. ML		-1.9	-1.9	1.9	1.9	0.0	0.0	0.0	0.0
Circ. Bend. ML		-13.5	13.5	13.5	-13.5	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-23.1	16.8	7.7	-6.5	-33.2	29.7	14.3	-16.0
Long. Memb. P		-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3	-1.3
Long. Bend. P		-8.4	8.4	-8.4	8.4	-6.4	6.4	-6.4	6.4
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.6	-0.6	0.6	0.6
Long. Bend. MC		0.0	0.0	0.0	0.0	-14.0	14.0	14.0	-14.0
Long. Memb. ML		-0.5	-0.5	0.5	0.5	0.0	0.0	0.0	0.0
Long. Bend. ML		-22.3	22.3	22.3	-22.3	0.0	0.0	0.0	0.0
Tot. Long. Str.		-32.5	29.0	13.0	-14.7	-22.3	18.6	6.9	-8.4
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		2.7	2.7	2.7	2.7	2.7	2.7	2.7	2.7
Tot. Shear		3.5	3.5	1.8	1.8	1.8	1.8	3.5	3.5
Str. Int.		33.7	30.0	13.5	15.1	33.5	30.0	15.7	17.4

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Circ. Pl (SUS)		-3.2	-3.2	0.6	0.6	-1.8	-1.8	-0.9	-0.9
Circ. Q (SUS)		-20.0	20.0	7.1	-7.1	-31.5	31.5	15.2	-15.2
Long. Pm (SUS)		60.5	60.5	60.5	60.5	60.5	60.5	60.5	60.5
Long. Pl (SUS)		-1.8	-1.8	-0.9	-0.9	-1.9	-1.9	-0.7	-0.7
Long. Q (SUS)		-30.8	30.8	13.9	-13.9	-20.5	20.5	7.6	-7.6
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		2.7	2.7	2.7	2.7	2.7	2.7	2.7	2.7
Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Pm+Pl (SUS)		117.9	120.2	121.6	123.9	119.3	121.6	120.2	122.5
Pm+Pl+Q (Total)		98.1	140.4	128.8	116.8	87.9	153.1	135.5	107.5

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
---------------------	-----------	----------------	--------

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: SV Nozl: 18 8:33pm Feb 18,2022

```
-----  
Pm (SUS) | 123.34 | 137.90 | | Passed |  
Pm+P1 (SUS) | 123.92 | 206.85 | | Passed |  
Pm+P1+Q (TOTAL) | 153.09 | 413.70 | | Passed |
```

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2

Noz1: 19 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: M2 From : 20


Pressure for Reinforcement Calculations	P	23.000	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		2500.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		90.00	deg
Diameter		6.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	20.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	368.2750	mm.
Thickness of Pad	te	15.0000	mm.
Weld leg size between Pad and Shell	Wp	14.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	15.0000	mm.
Reinforcing Pad Width		100.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: M2

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	6.625 in.
Actual Thickness Used in Calculation	0.378 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a) of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23) \\
 &= 15.2143 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (23 \cdot 84.14) / (117.9 \cdot 1 + 0.4 \cdot 23) \\
 &= 1.6287 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.5944 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	310.1452 mm.
Parallel to Vessel Wall, opening length	d	155.0726 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		31.5030 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr4]:

$$\begin{aligned}
 &= \min(1, S_p / S_v) \\
 &= \min(1, 137.9 / 137.9) \\
 &= 1.000
 \end{aligned}$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2

Noz1: 19 8:33pm Feb 18,2022

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	23.885	5.901	NA
Area in Shell	A1	2.735	14.522	NA
Area in Nozzle Wall	A2	2.679	3.236	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	0.855	0.855	NA
Area in Element	A5	21.281	21.281	NA
TOTAL AREA AVAILABLE	Atot	27.549	39.894	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	285.7146	15.0000 mm.
Based on given Pad Diameter:	368.2750	12.4169 mm.
Based on the Estimated Diameter Limit:	308.5577	12.5575 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (155.1 * 15.21 * 1 + 2 * 6.601 * 15.21 * 1 * (1 - 0.855))$$

$$= 23.885 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1**Area Available in Shell [A1]:**

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 155.1 (1 * 17 - 1 * 15.21) - 2 * 6.601$$

$$(1 * 17 - 1 * 15.21) * (1 - 0.855)$$

$$= 2.735 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 31.5) * (6.601 - 1.629) * 0.855$$

$$= 2.679 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (310.1 - 168.3) * 15 * 1$$

$$= 21.281 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 4.6287 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2143 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2143 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: M2 Noz1: 19 8:33pm Feb 18,2022

Wall Thickness per table UG-45 tb3 = 9.2200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[9.22, max(18.21, 4.5)]
 = 9.2200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(4.629, 9.22)
 = 9.2200 mm.

Available Nozzle Neck Thickness = 9.6012 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	55.9,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	238.8 N./mm ²	Passed
Occasional	:	13.0,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	24.1,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2 Nozl: 19 8:33pm Feb 18,2022

Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -45 °C
 Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: M2

Intermediate Calc. for nozzle/shell Welds Tmin 6.6012 mm.
 Intermediate Calc. for pad/shell Welds TminPad 15.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.6208 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.
Pad Weld	7.5000 = 0.5*TminPad	9.8980 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (23.88 - 2.735 + 2 * 6.601 * 0.855 * \\
 &\quad (1 * 17 - 15.21)) 137.9) \\
 &= 294.41 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (2.679 + 21.28 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 342.16 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (2.679 + 0 + 0.855 + (1.919)) * 137.9 \\
 &= 75.19 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (2.679 + 0 + 0.855 + 21.28 + (1.919)) * 137.9 \\
 &= 368.62 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 168.3 * 10 * 0.49 * 117.9 \\
 &= 153. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 368.3 * 14 * 0.49 * 137.9
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: M2 Nozl: 19 8:33pm Feb 18,2022

= 547. kN

Shear, Nozzle Wall [Snw]:

= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn
 = (3.142 * 80.84) * (9.601 - 3) * 0.7 * 117.9
 = 138. kN

Tension, Pad Groove Weld [Tpgw]:

= (pi / 2) * Dlo * Wgpn * 0.74 * Seg
 = (3.142 / 2) * 168.3 * 15 * 0.74 * 137.9
 = 405. kN

Tension, Shell Groove Weld [Tngw]:

= (pi / 2) * Dlo * (Wgnvi - Cas) * 0.74 * Sng
 = (3.142 / 2.0) * 168.3 * (20 - 3) * 0.74 * 137.9
 = 459. kN

Strength of Failure Paths:

PATH11 = (SPEW + SNW) = (547.2 + 138.3) = 685.5 kN
 PATH22 = (Sonw + Tpgw + Tngw + Sinw)
 = (152.7 + 404.6 + 458.5 + 0) = 1016 kN
 PATH33 = (Spew + Tngw + Sinw)
 = (547.2 + 458.5 + 0) = 1006 kN

Summary of Failure Path Calculations:

Path 1-1 = 685 kN , must exceed W = 294 kN or W1 = 342 kN
 Path 2-2 = 1015 kN , must exceed W = 294 kN or W2 = 75 kN
 Path 3-3 = 1005 kN , must exceed W = 294 kN or W3 = 368 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 24.736 bars

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 3.9414 mm.
 The Cut Length for this Nozzle is, Drop + Ho + H + T : 223.9415 mm.

Input Echo, WRC107/537 Item 1, Description: M2 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	1800.000	mm.
Vessel Thickness	Tv	20.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516	70
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	168.275	mm.
Nozzle Thickness	Tn	9.601	mm.
Nozzle Material		SA-333	6
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	15.000	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2

Noz1: 19 8:33pm Feb 18,2022

Diameter of Reinforcing Pad	Dpad	368.275	mm.
Design Internal Pressure	Dp	23.000	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load	(SUS)	P	6.0	kN
Longitudinal Shear	(SUS)	Vl	6.0	kN
Circumferential Shear	(SUS)	Vc	6.0	kN
Circumferential Moment	(SUS)	Mc	3800.0	N-m
Longitudinal Moment	(SUS)	Ml	3800.0	N-m
Torsional Moment	(SUS)	Mt	4700.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 168.275 + 2 * 1.65 * sqrt(911.5 (20.0 - 3.0))
 = 579.062 mm.

WRC 107 Stress Calculation for SUSTAINED loads:

Radial Load	P	6.0	kN
Circumferential Shear	VC	6.0	kN
Longitudinal Shear	VL	6.0	kN
Circumferential Moment	MC	3800.0	N-m
Longitudinal Moment	ML	3800.0	N-m
Torsional Moment	MT	4700.0	N-m

Dimensionless Parameters used : Gamma = 28.72

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.080	4C	5.294	(A,B)
N(PHI) / (P/Rm)	0.080	3C	4.919	(C,D)
M(PHI) / (P)	0.080	2C1	0.124	(A,B)
M(PHI) / (P)	0.080	1C	0.161	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.080	3A	0.596	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.080	1A	0.102	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.080	3B	2.107	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.080	1B	0.053	(A,B,C,D)
N(x) / (P/Rm)	0.080	3C	4.919	(A,B)
N(x) / (P/Rm)	0.080	4C	5.294	(C,D)
M(x) / (P)	0.080	1C1	0.163	(A,B)
M(x) / (P)	0.080	2C	0.124	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.080	4A	0.790	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.080	2A	0.059	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.080	4B	0.580	(A,B,C,D)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2 Noz1: 19 8:33pm Feb 18,2022

M(x) / (ML/(Rm * Beta)) 0.080 2B 0.088 (A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb.	P	-1.1	-1.1	-1.1	-1.1	-1.0	-1.0	-1.0	-1.0
Circ. Bend.	P	-4.4	4.4	-4.4	4.4	-5.7	5.7	-5.7	5.7
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0
Circ. Memb.	ML	-3.7	-3.7	3.7	3.7	0.0	0.0	0.0	0.0
Circ. Bend.	ML	-16.0	16.0	16.0	-16.0	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-25.1	15.5	14.2	-9.0	-38.4	34.3	25.1	-25.0
Long. Memb.	P	-1.0	-1.0	-1.0	-1.0	-1.1	-1.1	-1.1	-1.1
Long. Bend.	P	-5.7	5.7	-5.7	5.7	-4.4	4.4	-4.4	4.4
Long. Memb.	MC	0.0	0.0	0.0	0.0	-1.4	-1.4	1.4	1.4
Long. Bend.	MC	0.0	0.0	0.0	0.0	-17.7	17.7	17.7	-17.7
Long. Memb.	ML	-1.0	-1.0	1.0	1.0	0.0	0.0	0.0	0.0
Long. Bend.	ML	-26.5	26.5	26.5	-26.5	0.0	0.0	0.0	0.0
Tot. Long. Str.		-34.3	30.2	20.8	-20.8	-24.5	19.6	13.6	-13.0
Shear	VC	0.7	0.7	-0.7	-0.7	0.0	0.0	0.0	0.0
Shear	VL	0.0	0.0	0.0	0.0	-0.7	-0.7	0.7	0.7
Shear	MT	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3
Tot. Shear		4.0	4.0	2.6	2.6	2.6	2.6	4.0	4.0
Str. Int.		35.8	31.3	21.7	21.3	38.9	34.7	26.4	26.2

Dimensionless Parameters used : Gamma = 53.62

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.177	4C	7.506	(A,B)
N(PHI) / (P/Rm)	0.177	3C	4.920	(C,D)
M(PHI) / (P)	0.177	2C1	0.034	(A,B)
M(PHI) / (P)	0.177	1C !	0.068	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.177	3A	2.156	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.177	1A	0.074	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.177	3B	5.439	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.177	1B	0.025	(A,B,C,D)
N(x) / (P/Rm)	0.177	3C	4.920	(A,B)
N(x) / (P/Rm)	0.177	4C	7.506	(C,D)
M(x) / (P)	0.177	1C1	0.068	(A,B)
M(x) / (P)	0.177	2C !	0.036	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.177	4A	4.137	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.177	2A	0.035	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.177	4B	2.166	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.177	2B	0.034	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2

Noz1: 19 8:33pm Feb 18,2022

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-2.9	-2.9	-2.9	-2.9	-1.9	-1.9	-1.9	-1.9
Circ. Bend. P		-4.3	4.3	-4.3	4.3	-8.5	8.5	-8.5	8.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-3.3	-3.3	3.3	3.3
Circ. Memb. MC		0.0	0.0	0.0	0.0	-36.1	36.1	36.1	-36.1
Circ. Memb. ML		-8.3	-8.3	8.3	8.3	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.0	12.0	12.0	-12.0	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-27.5	5.1	13.1	-2.3	-49.8	39.4	29.0	-26.2
Long. Memb. P		-1.9	-1.9	-1.9	-1.9	-2.9	-2.9	-2.9	-2.9
Long. Bend. P		-8.5	8.5	-8.5	8.5	-4.5	4.5	-4.5	4.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-6.3	-6.3	6.3	6.3
Long. Bend. MC		0.0	0.0	0.0	0.0	-17.3	17.3	17.3	-17.3
Long. Memb. ML		-3.3	-3.3	3.3	3.3	0.0	0.0	0.0	0.0
Long. Bend. ML		-16.7	16.7	16.7	-16.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-30.4	20.0	9.6	-6.9	-31.0	12.6	16.2	-9.5
Shear VC		0.6	0.6	-0.6	-0.6	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.6	-0.6	0.6	0.6
Shear MT		1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
Tot. Shear		1.9	1.9	0.7	0.7	0.7	0.7	1.9	1.9
Str. Int.		31.4	20.3	13.2	7.0	49.8	39.4	29.2	26.4

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		63.8	66.1	63.8	66.1	63.8	66.1	63.8	66.1
Circ. Pl (SUS)		-4.8	-4.8	2.6	2.6	-2.1	-2.1	0.0	0.0
Circ. Q (SUS)		-20.3	20.3	11.6	-11.6	-36.3	36.3	25.0	-25.0
Long. Pm (SUS)		31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9
Long. Pl (SUS)		-2.0	-2.0	0.0	0.0	-2.5	-2.5	0.3	0.3
Long. Q (SUS)		-32.3	32.3	20.8	-20.8	-22.1	22.1	13.3	-13.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.7	0.7	-0.7	-0.7	-0.7	-0.7	0.7	0.7
Shear Q (SUS)		3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3
Pm (SUS)		63.8	66.1	63.8	66.1	63.8	66.1	63.8	66.1
Pm+Pl (SUS)		59.0	61.3	66.4	68.7	61.7	64.0	63.8	66.1
Pm+Pl+Q (Total)		41.9	82.4	78.2	57.3	25.7	100.5	89.2	41.8

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M2

Noz1: 19 8:33pm Feb 18,2022

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	66.08	137.90	Passed
Pm+Pl (SUS)	68.71	206.85	Passed
Pm+Pl+Q (TOTAL)	100.51	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Circ. Pl (SUS)		-11.2	-11.2	5.4	5.4	-5.2	-5.2	1.4	1.4
Circ. Q (SUS)		-16.3	16.3	7.7	-7.7	-44.6	44.6	27.6	-27.6
Long. Pm (SUS)		60.5	60.5	60.5	60.5	60.5	60.5	60.5	60.5
Long. Pl (SUS)		-5.2	-5.2	1.4	1.4	-9.2	-9.2	3.4	3.4
Long. Q (SUS)		-25.2	25.2	8.2	-8.2	-21.8	21.8	12.9	-12.9
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.6	0.6	-0.6	-0.6	-0.6	-0.6	0.6	0.6
Shear Q (SUS)		1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3
Pm (SUS)		121.0	123.3	121.0	123.3	121.0	123.3	121.0	123.3
Pm+Pl (SUS)		109.9	112.2	126.4	128.7	115.9	118.2	122.4	124.7
Pm+Pl+Q (Total)		93.6	128.5	134.1	121.0	71.3	162.7	150.0	97.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	123.34	137.90	Passed
Pm+Pl (SUS)	128.71	206.85	Passed
Pm+Pl+Q (TOTAL)	162.73	413.70	Passed

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: TI

Noz1: 20 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: TI From : 20

Pressure for Reinforcement Calculations	P	23.002	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		250.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C


Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-350 LF2	
Material UNS Number		K03011	
Material Specification/Type		Forgings	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		ID	
Layout Angle		270.00	deg
Diameter		1.5000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.9500	mm.
Flange Material [Normalized]		SA-350 LF2	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	18.5000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: TI Nozl: 20 8:33pm Feb 18,2022



Insert/Set-in Nozzle No Pad, no Inside projection

Reinforcement CALCULATION, Description: TI

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Inside Diameter Used in Calculation 1.500 in.
 Actual Thickness Used in Calculation 0.628 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23)$$

$$= 15.2152 \text{ mm.}$$

Reqd thk per App. 1 of Nozzle Wall, Trn [Int. Press]

$$= R \left(\exp \left(\frac{P}{S_n \cdot E} \right) - 1 \right) \text{ per Appendix 1-2 (a) (1)}$$

$$= 22.05 \left(\exp \left(\frac{23}{137.9 \cdot 1} \right) - 1 \right)$$

$$= 0.3709 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3569 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	104.0000	mm.
Parallel to Vessel Wall	Rn+tn+t	52.0000	mm.
Normal to Vessel Wall (Thickness Limit), no pad	Tlnp	32.3750	mm.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(1, 1)$$

$$= 1.000$$

Results of Nozzle Reinforcement Area Calculations: (cm^2)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	6.710	1.658	NA
Area in Shell	A1	1.069	5.680	NA
Area in Nozzle Wall	A2	8.145	8.154	NA

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: TI Nozl: 20 8:33pm Feb 18,2022

Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	1.000	1.000	NA
Area in Element	A5	0.000	0.000	NA
TOTAL AREA AVAILABLE	Atot	10.214	14.834	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Sufficient.

Area Required [A]:

$$\begin{aligned}
 &= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)} \\
 &= (44.1 * 15.22 * 1 + 2 * 12.95 * 15.22 * 1 * (1 - 1)) \\
 &= 6.710 \text{ cm}^2
 \end{aligned}$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$\begin{aligned}
 &= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1) \\
 &= 59.9 (1 * 17 - 1 * 15.22) - 2 * 12.95 \\
 &\quad (1 * 17 - 1 * 15.22) * (1 - 1) \\
 &= 1.069 \text{ cm}^2
 \end{aligned}$$

Area Available in Nozzle Projecting Outward [A2]:

$$\begin{aligned}
 &= (2 * tlnp) (tn - trn) fr2 \\
 &= (2 * 32.37) (12.95 - 0.371) 1 \\
 &= 8.145 \text{ cm}^2
 \end{aligned}$$

Area Available in Inward Weld + Outward Weld [A41 + A43]:

$$\begin{aligned}
 &= Wo^2 * fr2 + (Wi - can / 0.707)^2 * fr2 \\
 &= 10^2 * 1 + (0)^2 * 1 \\
 &= 1.000 \text{ cm}^2
 \end{aligned}$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.3709 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.2152 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.2152 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7207 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 7.5200 mm.

Determine Nozzle Thickness candidate [tb]:

$$\begin{aligned}
 &= \min[tb3, \max(tb1, tb2)] \\
 &= \min[7.52, \max(18.22, 4.5)] \\
 &= 7.5200 \text{ mm.}
 \end{aligned}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$\begin{aligned}
 &= \max(ta, tb) \\
 &= \max(3.371, 7.52) \\
 &= 7.5200 \text{ mm.}
 \end{aligned}$$

Available Nozzle Neck Thickness = 15.9500 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: TI Noz1: 20 8:33pm Feb 18,2022

Impact Test Temperature provided per Specification -46 °C

Calculated Minimum Design Metal Temperature -104 °C

Governing MDMT of all the sub-joints of this Junction : -104 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C

Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Weld Size Calculations, Description: TI

Intermediate Calc. for nozzle/shell Welds Tmin 12.9500 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	7.0700 = 0.7 * Wo mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (6.71 - 1.069 + 2 * 12.95 * 1 * \\
 &\quad (1 * 17 - 15.22)) 137.9) \\
 &= 84.15 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (8.145 + 0 + 1 - 0 * 1) * 137.9 \\
 &= 126.10 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (8.145 + 0 + 1 + (4.403)) * 137.9 \\
 &= 186.81 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (8.145 + 0 + 1 + 0 + (4.403)) * 137.9 \\
 &= 186.81 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 70 * 10 * 0.49 * 137.9 \\
 &= 74. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.142 * 28.52) * (15.95 - 3) * 0.7 * 137.9 \\
 &= 112. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.142/2.0) * 70 * (18.5 - 3) * 0.74 * 137.9
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: TI

Noz1: 20 8:33pm Feb 18,2022

= 174. kN

Strength of Failure Paths:

PATH11 = (SONW + SNW) = (74.29 + 112) = 186.3 kN

PATH22 = (Sonw + Tpgw + Tngw + Sinw)
= (74.29 + 0 + 173.9 + 0) = 248.2 kN

PATH33 = (Sonw + Tngw + Sinw)
= (74.29 + 173.9 + 0) = 248.2 kN

Summary of Failure Path Calculations:

Path 1-1 = 186 kN , must exceed W = 84 kN or W1 = 126 kN

Path 2-2 = 248 kN , must exceed W = 84 kN or W2 = 186 kN

Path 3-3 = 248 kN , must exceed W = 84 kN or W3 = 186 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 25.670 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 0.6808 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 220.6808 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M1

Noz1: 21 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: M1 From : 20


Pressure for Reinforcement Calculations	P	23.001	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	1800.00	mm.
Design Length of Section	L	3099.9998	mm.
Shell Finished (Minimum) Thickness	t	20.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		750.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-516 70	
Material UNS Number		K02700	
Material Specification/Type		Plate	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		20.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	20.0000	mm.
Flange Material [Normalized]		SA-350 LF2	
Flange Type		Long Weld Neck	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	250.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	20.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	20.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	868.0000	mm.
Thickness of Pad	te	20.0000	mm.
Weld leg size between Pad and Shell	Wp	14.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	20.0000	mm.
Reinforcing Pad Width		180.0000	mm.
This is a Manway or Access Opening.			
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: M1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	20.000 in.
Actual Thickness Used in Calculation	0.787 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 903) / (137.9 \cdot 1 - 0.6 \cdot 23)$$

$$= 15.2150 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23 \cdot 254) / (137.9 \cdot 1 + 0.4 \cdot 23)$$

$$= 4.2088 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 1.2465 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	948.0001 mm.
Parallel to Vessel Wall, opening length	d	474.0000 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		42.5000 mm.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(1, 1)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: M1 Nozl: 21 8:33pm Feb 18,2022

= 1.000

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	72.119	17.818	NA
Area in Shell	A1	8.461	44.944	NA
Area in Nozzle Wall	A2	10.872	13.390	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		5.960	5.960	NA
Area in Element	A5	54.000	54.000	NA
TOTAL AREA AVAILABLE	Atot	79.293	118.295	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	820.1714	20.0000 mm.
Based on given Pad Diameter:	868.0000	17.3429 mm.
Based on Shell or Nozzle Thickness:	820.1714	20.0000 mm.

Area Required [A]:
 = (d * tr*F + 2 * tn * tr*F * (1-fr1)) UG-37(c)
 = (474*15.22*1+2*17*15.22*1*(1-1))
 = 72.119 cm²

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:
 = d(E1*t - F*tr) - 2 * tn(E1*t - F*tr) * (1 - fr1)
 = 474 (1 * 17 - 1 * 15.22) - 2 * 17
 (1 * 17 - 1 * 15.22) * (1 - 1)
 = 8.461 cm²

Area Available in Nozzle Wall Projecting Outward [A2]:
 = (2 * Tlwp) * (tn - trn) * fr2
 = (2 * 42.5) * (17 - 4.209) * 1
 = 10.872 cm²

Area Available in Welds [A41 + A42 + A43]:
 = Wo² * fr3 + (Wi-can/0.707)² * fr2 + Wp² * fr4
 = 20² * 1 + (0)² * 1 + 14² * 1
 = 5.960 cm²

Area Available in Element, also see UG-37(h) [A5]:
 = (min(Dp,DL)-(Nozzle OD))(min(tp,Tlwp,te)) * fr4 * 0.75
 = (868 - 508)20 * 1 * 0.75
 = 54.000 cm²

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: M1 Noz1: 21 8:33pm Feb 18,2022

 Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Governing MDMT of the Nozzle : -45 °C
 Governing MDMT of the Reinforcement Pad : -45 °C
 Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i) (2) -48 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Weld Size Calculations, Description: M1

Intermediate Calc. for nozzle/shell Welds Tmin 17.0000 mm.
 Intermediate Calc. for pad/shell Welds TminPad 17.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	14.1400 = 0.7 * Wo mm.
Pad Weld	8.5000 = 0.5*TminPad	9.8980 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (72.12 - 8.461 + 2 * 17 * 1 * (1 * 17 - 15.22)) 137.9)$$

$$= 886.14 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4 - (Wi-Can/.707)^2*fr2)*Sv$$

$$= (10.87 + 54 + 5.96 - 0 * 1) * 137.9$$

$$= 976.70 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (10.87 + 0 + 4 + (5.78)) * 137.9$$

$$= 284.77 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (10.87 + 0 + 5.96 + 54 + (5.78)) * 137.9$$

$$= 1056.40 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: M1

Noz1: 21 8:33pm Feb 18,2022

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.142/2.0) * 508 * 20 * 0.49 * 137.9$$

$$= 1078. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.142/2.0) * 868 * 14 * 0.49 * 137.9$$

$$= 1290. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.142 * 245.5) * (20 - 3) * 0.7 * 137.9$$

$$= 1266. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.142/2) * 508 * 20 * 0.74 * 137.9$$

$$= 1628. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi-Cas}) * 0.74 * S_{ng}$$

$$= (3.142/2.0) * 508 * (20 - 3) * 0.74 * 137.9$$

$$= 1384. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (S_{PEW} + S_{NW}) = (1290 + 1266) = 2555 \text{ kN}$$

$$\text{PATH22} = (S_{onw} + T_{pgw} + T_{ngw} + S_{inw})$$

$$= (1078 + 1628 + 1384 + 0) = 4091 \text{ kN}$$

$$\text{PATH33} = (S_{pew} + T_{ngw} + S_{inw})$$

$$= (1290 + 1384 + 0) = 2674 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 2555 kN , must exceed W = 886 kN or W1 = 976 kN
 Path 2-2 = 4090 kN , must exceed W = 886 kN or W2 = 284 kN
 Path 3-3 = 2673 kN , must exceed W = 886 kN or W3 = 1056 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 24.106 bars

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 36.5858 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 306.5859 mm.

Percent Elongation Calculations:

% Elongation per Table UG-79-1 (50*tnom/Rf*(1-Rf/Ro)) 4.098 %

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V

Noz1: 22 8:33pm Feb 18,2022

INPUT VALUES, Nozzle Description: V**From : 30**


Pressure for Reinforcement Calculations	P	23.000	bars
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bars
Temperature for External Pressure	Tempex	135	°C
Shell Material [Impact Tested] SA-516 70			
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Elliptical Head	D	1800.00	mm.
Aspect Ratio of Elliptical Head	Ar	2.00	
Head Finished (Minimum) Thickness	t	18.5000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.
Distance from Head Centerline	L1	0.0000	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	XXS	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	8.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	18.5000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Impact Tested] SA-516 70			
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	190.0000	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		64.8375	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: V

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.382 in.

Nozzle input data check completed without errors.

Req'd thk per UG-37(a) of Elliptical Head, Tr [Int. Press]
 = $(P \cdot K_1 \cdot D) / (2 \cdot S_v \cdot E - 0.2 \cdot P)$ per UG-37(a) (3)
 = $(23 \cdot 0.897 \cdot 1806) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23)$
 = 13.5353 mm.

Req'd thk per UG-37(a) of Nozzle Wall, Trn [Int. Press]
 = $(P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 = $(23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$
 = 0.5839 mm.

Required Nozzle thickness under External Pressure per UG-28 : 0.3261 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	93.8896 mm.
Parallel to Vessel Wall, opening length	d	46.9448 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		28.7253 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:
 = $\min(1, S_n / S_v)$
 = $\min(1, 117.9 / 137.9)$
 = 0.855

Weld Strength Reduction Factor [fr2]:
 = $\min(1, S_n / S_v)$
 = $\min(1, 117.9 / 137.9)$
 = 0.855

Weld Strength Reduction Factor [fr4]:
 = $\min(1, S_p / S_v)$
 = $\min(1, 137.9 / 137.9)$
 = 1.000

Weld Strength Reduction Factor [fr3]:
 = $\min(fr2, fr4)$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V

Noz1: 22 8:33pm Feb 18,2022

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	6.617	1.199	NA
Area in Shell	A1	0.884	4.768	NA
Area in Nozzle Wall	A2	2.999	3.126	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	0.547	0.547	NA
Area in Element	A5	4.028	4.028	NA
TOTAL AREA AVAILABLE	Atot	8.458	12.469	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	78.5429	12.0000 mm.
Based on given Pad Diameter:	190.0000	6.5133 mm.
Based on Shell or Nozzle Thickness:	82.8857	9.6901 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (46.94 \cdot 13.54 \cdot 1 + 2 \cdot 6.69 \cdot 13.54 \cdot 1 \cdot (1 - 0.855))$$

$$= 6.617 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 \cdot t - F \cdot tr) - 2 \cdot tn (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 46.94 (1 \cdot 15.5 - 1 \cdot 13.54) - 2 \cdot 6.69$$

$$(1 \cdot 15.5 - 1 \cdot 13.54) \cdot (1 - 0.855)$$

$$= 0.884 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 28.73) \cdot (6.69 - 0.584) \cdot 0.855$$

$$= 2.999 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 8^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.547 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - \text{Nozzle OD}) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (93.89 - 60.33) \cdot 12 \cdot 1$$

$$= 4.028 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5839 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 18.0205 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 18.0205 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.7172 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no: K.O. Drum (D-PK6101-3)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : Calculation Book for K.O. Drum (D-PK6101-3)
 Nozzle Calcs.: V Noz1: 22 8:33pm Feb 18,2022

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(18.02, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 9.6901 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	5.3,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	289.4 N./mm ²	Passed
Occasional	:	3.5,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	5.8,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinf. pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Shell to Pad Weld at Pad OD for pad (Impact tested) :

Note: This Element/Detail was specified as being Impact Tested.

Nozzle-Shell/Head Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V Nozl: 22 8:33pm Feb 18,2022

Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -45 °C
 Governing MDMT of all the sub-joints of this Junction : -45 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.00/51.10 = 0.450

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: V

Intermediate Calc. for nozzle/shell Welds Tmin 6.6901 mm.
 Intermediate Calc. for pad/shell Welds TminPad 12.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	4.6831 = 0.7 * tmin.	5.6560 = 0.7 * Wo mm.
Pad Weld	6.0000 = 0.5*TminPad	7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (6.617 - 0.884 + 2 * 6.69 * 0.855 * (1 * 15.5 - 13.54))) 137.9)$$

$$= 82.14 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (2.999 + 4.028 + 0.547 - 0 * 0.855) * 137.9$$

$$= 104.44 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (2.999 + 0 + 0.547 + (1.773)) * 137.9$$

$$= 73.35 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (2.999 + 0 + 0.547 + 4.028 + (1.773)) * 137.9$$

$$= 128.89 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.142/2.0) * 60.33 * 8 * 0.49 * 117.9$$

$$= 44. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 190 * 10 * 0.49 * 137.9$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V Nozl: 22 8:33pm Feb 18,2022

= 202. kN

Shear, Nozzle Wall [Snw]:

= (pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn
 = (3.142 * 26.82) * (9.69 - 3) * 0.7 * 117.9
 = 47. kN

Tension, Pad Groove Weld [Tpgw]:

= (pi / 2) * Dlo * Wgpn * 0.74 * Seg
 = (3.142 / 2) * 60.33 * 12 * 0.74 * 137.9
 = 116. kN

Tension, Shell Groove Weld [Tngw]:

= (pi / 2) * Dlo * (Wgnvi - Cas) * 0.74 * Sng
 = (3.142 / 2.0) * 60.33 * (18.5 - 3) * 0.74 * 137.9
 = 150. kN

Strength of Failure Paths:

PATH11 = (SPEW + SNW) = (201.6 + 46.51) = 248.2 kN
 PATH22 = (Sonw + Tpgw + Tngw + Sinw)
 = (43.79 + 116 + 149.9 + 0) = 309.7 kN
 PATH33 = (Spew + Tngw + Sinw)
 = (201.6 + 149.9 + 0) = 351.5 kN

Summary of Failure Path Calculations:

Path 1-1 = 248 kN , must exceed W = 82 kN or W1 = 104 kN
 Path 2-2 = 309 kN , must exceed W = 82 kN or W2 = 73 kN
 Path 3-3 = 351 kN , must exceed W = 82 kN or W3 = 128 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 23.733 bars

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bars

The Drop for this Nozzle is : 0.2783 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 218.7783 mm.

Input Echo, WRC107/537 Item 1, Description: V :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Spherical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	3240.000	mm.
Vessel Thickness	Tv	18.500	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
WRC107 Attachment Classification	Holsol	Hollow	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.
Nozzle Thickness	Tn	9.690	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V Nozl: 22 8:33pm Feb 18,2022

Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	190.000	mm.
Design Internal Pressure	Dp	23.000	bars
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	(Vl) V1	2.0	kN
Circumferential Shear (SUS)	(Vc) V2	2.0	kN
Circumferential Moment (SUS)	(Mc) M1	0.4	N-m
Longitudinal Moment (SUS)	(Ml) M2	0.4	N-m
Torsional Moment (SUS)	Mt	0.5	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

$$\begin{aligned}
 &= \text{NozzleOD} + 2 * 1.65 * \text{sqrt}(\text{Rmean}(t - ca)) \\
 &= 60.325 + 2 * 1.65 * \text{sqrt}(1630.75 (18.5 - 3.0)) \\
 &= 584.980 \text{ mm.}
 \end{aligned}$$

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	(VC) V2	2.0	kN
Longitudinal Shear	(VL) V1	2.0	kN
Circumferential Moment	(MC) M1	0.4	N-m
Longitudinal Moment	(ML) M2	0.4	N-m
Torsional Moment	MT	0.5	N-m

Unitless Prm: U = 0.14 TAU = 5.00 (4.01) RHO = 4.00 (4.11)

Dimensionless Loads for Spherical Shells at Attachment Junction:

Curves read for 1979	Figure	Value	Location
N(x) * T / P	SP 4	0.10094	(A,B,C,D)
M(x) / P	SP 4	0.03588	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / MC	SM 4	0.39546	(A,B,C,D)
M(x) * SQRT(Rm * T) / MC	SM 4	0.16243	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / ML	SM 4	0.39546	(A,B,C,D)
M(x) * SQRT(Rm * T) / ML	SM 4	0.16243	(A,B,C,D)
N(y) * T / P	SP 4	0.33817	(A,B,C,D)
M(y) / P	SP 4	0.25612	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / MC	SM 4	0.10351	(A,B,C,D)
M(y) * SQRT(Rm * T) / MC	SM 4	1.27108	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / ML	SM 4	0.10351	(A,B,C,D)
M(y) * SQRT(Rm * T) / ML	SM 4	1.27108	(A,B,C,D)

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V

Noz1: 22 8:33pm Feb 18,2022

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

Type of Stress		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad. Memb. P		-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Rad. Bend. P		-0.6	0.6	-0.6	0.6	-0.6	0.6	-0.6	0.6
Rad. Memb. MC		0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0
Rad. Memb. MC		0.0	0.0	0.0	0.0	-0.0	0.0	0.0	-0.0
Rad. Memb. ML		-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0
Rad. Bend. ML		-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0
Tot. Rad. Str.		-0.8	0.3	-0.8	0.3	-0.8	0.3	-0.8	0.3
Tang. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9
Tang. Bend. P		-4.1	4.1	-4.1	4.1	-4.1	4.1	-4.1	4.1
Tang. Memb. MC		0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0
Tang. Bend. MC		0.0	0.0	0.0	0.0	-0.0	0.0	0.0	-0.0
Tang. Memb. ML		-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tang. Bend. ML		-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0
Tot. Tang. Str.		-5.0	3.2	-4.9	3.2	-5.0	3.2	-4.9	3.2
Shear VC		0.8	0.8	-0.8	-0.8	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.8	-0.8	0.8	0.8
Shear MT		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tot. Shear		0.8	0.8	-0.8	-0.8	-0.8	-0.8	0.8	0.8
Str. Int.		5.1	3.4	5.1	3.3	5.1	3.4	5.1	3.3

Unitless Prm: U = 0.60 TAU = 0.00 (13.70) RHO = 0.00 (2.32)

Dimensionless Loads for Spherical Shells at Pad edge:

Curves read for 1979	Figure	Value	Location
N(x) * T / P	SR 2	0.11542	(A,B,C,D)
M(x) / P	SR 2	0.06771	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / MC	SR 3	0.12880	(A,B,C,D)
M(x) * SQRT(Rm * T) / MC	SR 3	0.18723	(A,B,C,D)
N(x) * T * SQRT(Rm * T) / ML	SR 3	0.12880	(A,B,C,D)
M(x) * SQRT(Rm * T) / ML	SR 3	0.18723	(A,B,C,D)
N(y) * T / P	SR 2	0.03465	(A,B,C,D)
M(y) / P	SR 2	0.02066	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / MC	SR 3	0.03895	(A,B,C,D)
M(y) * SQRT(Rm * T) / MC	SR 3	0.05574	(A,B,C,D)
N(y) * T * SQRT(Rm * T) / ML	SR 3	0.03895	(A,B,C,D)
M(y) * SQRT(Rm * T) / ML	SR 3	0.05574	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V

Noz1: 22 8:33pm Feb 18,2022

Rad. Memb. P	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0
Rad. Bend. P	-3.4	3.4	-3.4	3.4	-3.4	3.4	-3.4	3.4	3.4
Rad. Memb. MC	0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0	0.0
Rad. Memb. MC	0.0	0.0	0.0	0.0	-0.0	0.0	0.0	0.0	-0.0
Rad. Memb. ML	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Rad. Bend. ML	-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0	0.0
Tot. Rad. Str.	-4.4	2.4	-4.3	2.4	-4.4	2.4	-4.3	2.4	2.4
Tang. Memb. P	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Tang. Bend. P	-1.0	1.0	-1.0	1.0	-1.0	1.0	-1.0	1.0	1.0
Tang. Memb. MC	0.0	0.0	0.0	0.0	-0.0	-0.0	0.0	0.0	0.0
Tang. Bend. MC	0.0	0.0	0.0	0.0	-0.0	0.0	0.0	0.0	-0.0
Tang. Memb. ML	-0.0	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tang. Bend. ML	-0.0	0.0	0.0	-0.0	0.0	0.0	0.0	0.0	0.0
Tot. Tang. Str.	-1.3	0.7	-1.3	0.7	-1.3	0.7	-1.3	0.7	0.7
Shear VC	0.4	0.4	-0.4	-0.4	0.0	0.0	0.0	0.0	0.0
Shear VL	0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	0.4
Shear MT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Tot. Shear	0.4	0.4	-0.4	-0.4	-0.4	-0.4	0.4	0.4	0.4
Str. Int.	4.4	2.5	4.4	2.5	4.4	2.5	4.4	2.5	2.5

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad. Pm (SUS)		67.9	67.9	67.9	67.9	67.9	67.9	67.9	67.9
Rad. Pl (SUS)		-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Rad. Q (SUS)		-0.6	0.6	-0.6	0.6	-0.6	0.6	-0.6	0.6
Long. Pm (SUS)		67.9	67.9	67.9	67.9	67.9	67.9	67.9	67.9
Long. Pl (SUS)		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9
Long. Q (SUS)		-4.1	4.1	-4.0	4.0	-4.1	4.1	-4.0	4.0
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.8	0.8	-0.8	-0.8	-0.8	-0.8	0.8	0.8
Shear Q (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Pm (SUS)		67.9	67.9	67.9	67.9	67.9	67.9	67.9	67.9
Pm+Pl (SUS)		68.1	68.1	68.1	68.1	68.1	68.1	68.1	68.1
Pm+Pl+Q (Total)		67.2	71.3	67.2	71.2	67.2	71.3	67.2	71.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	67.89	137.90	Passed
Pm+Pl (SUS)	68.14	206.85	Passed
Pm+Pl+Q (TOTAL)	71.27	413.70	Passed

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Calcs.: V

Noz1: 22 8:33pm Feb 18,2022

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress		Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Rad.	Pm (SUS)	120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Rad.	Pl (SUS)	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0	-1.0
Rad.	Q (SUS)	-3.4	3.4	-3.4	3.4	-3.4	3.4	-3.4	3.4
Long.	Pm (SUS)	120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Long.	Pl (SUS)	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3	-0.3
Long.	Q (SUS)	-1.0	1.0	-1.0	1.0	-1.0	1.0	-1.0	1.0
Shear	Pm (SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear	Pl (SUS)	0.4	0.4	-0.4	-0.4	-0.4	-0.4	0.4	0.4
Shear	Q (SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Pm (SUS)		120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Pm+Pl (SUS)		120.4	120.4	120.4	120.4	120.4	120.4	120.4	120.4
Pm+Pl+Q (Total)		119.2	123.0	119.2	122.9	119.2	123.0	119.2	122.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	120.43	137.90	Passed
Pm+Pl (SUS)	120.35	206.85	Passed
Pm+Pl+Q (TOTAL)	122.97	413.70	Passed

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Schedule: Step: 30 8:33pm Feb 18,2022

Nozzle Schedule:

Flg	Nominal or	Schd	Flg	Nozzle	Wall	Reinforcing Pad	Cut		
Class	Actual	or FVC	Type	O/Dia	Thk	Diameter	Thk		
Description	Size	Type		in	mm.	mm.	mm.		
TI	1.500 in	Actual	LWN	2.756	15.950	220.68	300
D	2.000 in	XXS	WNF	2.375	11.074	190.00	12.00	218.78	
LT1	2.000 in	XXS	WNF	2.375	11.074	190.00	12.00	222.64	
LT2	2.000 in	Actual	LWN	3.307	16.600	220.98	300
SV	2.000 in	Actual	LWN	3.307	16.600	220.98	300
V	2.000 in	XXS	WNF	2.375	11.074	190.00	12.00	218.78	
M2	6.000 in	80	WNF	6.625	10.973	368.27	15.00	223.94	
A2	8.000 in	80	WNF	8.625	12.700	419.07	15.00	226.69	
A1	12.000 in	80	WNF	12.750	17.450	563.85	20.00	234.69	
B	12.000 in	80	WNF	12.750	17.450	563.85	20.00	234.69	
M1	20.000 in	Actual	LWN	20.000	20.000	868.00	20.00	306.59	300

General Notes for the above table:

The Cut Length is the Outside Projection + Inside Projection + Drop + In Plane Shell Thickness. This value does not include weld gaps, nor does it account for shrinkage.

In the case of Oblique Nozzles, the Outside Diameter must be increased. The Re-Pad WIDTH around the nozzle is calculated as follows:
 Width of Pad = (Pad Outside Dia. (per above) - Nozzle Outside Dia.)/2

For hub nozzles, the thickness and diameter shown are those of the smaller and thinner section.

Nozzle Material and Weld Fillet Leg Size Details (mm.):

Description	Material	Shl Grve Weld	Noz Shl/Pad Weld	Pad OD Weld	Pad Grve Weld	Inside Weld
TI	SA-350 LF2	18.500	10.000
D	SA-333 6	18.500	8.000	10.000	12.000	...
LT1	SA-333 6	18.500	8.000	10.000	12.000	...
LT2	SA-350 LF2	18.500	10.000
SV	SA-350 LF2	18.500	10.000
V	SA-333 6	18.500	8.000	10.000	12.000	...
M2	SA-333 6	20.000	10.000	14.000	15.000	...
A2	SA-333 6	20.000	10.000	14.000	15.000	...
A1	SA-333 6	20.000	10.000	14.000	20.000	...
B	SA-333 6	20.000	10.000	14.000	20.000	...

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Nozzle Schedule: Step: 30 8:33pm Feb 18,2022

M1 | SA-516 70 | 20.000 | 20.000 | 14.000 | 20.000 | ... |

Note: The Outside projections below do not include the flange thickness.

Nozzle Miscellaneous Data:

Description	Elev/Distance From Datum mm.	Layout Angle deg	Proj Outside mm.	Proj Inside mm.	Installed in Component
TI	200.000	270.0	200.00	0.00	SHELL
D	...	0.0	200.00	0.00	HEAD 001
LT1	...	180.0	200.00	0.00	HEAD 001
LT2	300.000	180.0	200.00	0.00	SHELL
SV	1500.000	0.0	200.00	0.00	SHELL
V	...	0.0	200.00	0.00	HEAD 002
M2	2450.000	90.0	200.00	0.00	SHELL
A2	1100.000	45.0	200.00	0.00	SHELL
A1	500.000	90.0	200.00	0.00	SHELL
B	2400.000	270.0	200.00	0.00	SHELL
M1	700.000	0.0	250.00	0.00	SHELL

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

MDMT Summary: Step: 32 8:33pm Feb 18,2022

Minimum Design Metal Temperature Results Summary :

Description	Curve	Basic	Reduced	UG-20 (f)	Thickness	Gov	E*	PWHT
Notes		MDMT	MDMT	MDMT	ratio	Thk		reqd
		°C	°C	°C		mm.		
HEAD 001	[10]	!	-45		1.000	18.500	1.00	No
HEAD 001	[7]	!	-45		0.827	22.000	1.00	No
SHELL	[8]	!	-45		0.924	20.000	1.00	No
HEAD 002	[10]	!	-45		1.000	18.500	1.00	No
HEAD 002	[7]	!	-45		0.826	22.000	1.00	No
D	[1]	!	-45	-45	0.873	12.000	1.00	No
Nozzle Flg	[4]	!	-18	-96				
LT1	[1]	!	-45	-45	0.873	12.000	1.00	No
Nozzle Flg	[4]	!	-18	-96				
A1	[1]	!	-45	-45	0.895	20.000	1.00	No
Nozzle Flg	[4]	!	-46	-104				
A2	[1]	!	-45	-45	0.895	15.000	1.00	No
Nozzle Flg	[4]	!	-46	-104				
B	[1]	!	-45	-45	0.895	20.000	1.00	No
Nozzle Flg	[4]	!	-46	-104				
LT2	[1]	!	-46	-104	0.035	16.600	1.00	No
Nozzle Flg	[5]	!	-46	-48				
SV	[1]	!	-46	-104	0.035	16.600	1.00	No
Nozzle Flg	[5]	!	-46	-48				
M2	[1]	!	-45	-45	0.895	15.000	1.00	No
Nozzle Flg	[4]	!	-46	-104				
TI	[1]	!	-46	-104	0.029	15.950	1.00	No
Nozzle Flg	[5]	!	-46	-48				
M1	[1]	!	-45	-45	0.895	20.000	1.00	No
Nozzle Flg	[5]	!	-46	-48				
V	[1]	!	-45	-45	0.873	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104				
Warmest MDMT:			-18	-45				
Required Minimum Design Metal Temperature						-45	°C	
Warmest Computed Minimum Design Metal Temperature						-45	°C	

Notes:

- [!] - This was an impact tested material.
- [1] - Governing Nozzle Weld.
- [4] - ANSI Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-c).
- [5] - ANSI Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-b).
- [6] - MDMT Calculations at the Shell/Head Joint.
- [7] - MDMT Calculations for the Straight Flange.
- [8] - Cylinder/Cone/Flange Junction MDMT.
- [9] - Calculations in the Spherical Portion of the Head.
- [10] - Calculations in the Knuckle Portion of the Head.
- [11] - Calculated (Body Flange) Flange MDMT.
- [12] - Calculated Flat Head MDMT per UCS-66.3
- [13] - Tubesheet MDMT, shell side, if applicable
- [14] - Tubesheet MDMT, tube side, if applicable
- [15] - Nozzle Material
- [16] - Shell or Head Material
- [17] - Impact Testing required
- [18] - Impact Testing not required, see UCS-66(b)(3)

UG-84(b)(2) was not considered.

UCS-66(g) was not considered.

UCS-66(i) was not considered.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no: K.O. Drum (D-PK6101-3)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : Calculation Book for K.O. Drum (D-PK6101-3)
MDMT Summary: Step: 32 8:33pm Feb 18,2022

Notes:

Impact test temps were not entered in and not considered in the analysis.
UCS-66(i) applies to impact tested materials not by specification and
UCS-66(g) applies to materials impact tested per UG-84.1 General Note (c).
The Basic MDMT includes the (30F) PWHT credit if applicable.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Vessel Design Summary: Step: 33 8:33pm Feb 18,2022

ASME Code, Section VIII Division 1, 2017

Diameter Spec : 1800.000 mm. ID
Vessel Design Length, Tangent to Tangent 2800.00 mm.

Distance of Bottom Tangent above Grade 300.00 mm.
Specified Datum Line Distance 50.00 mm.

Shell Material SA-516 70 [Impact Tested]
Nozzle Material SA-333 6 [Impact Tested]
Nozzle Material SA-350 LF2 [Impact Tested]
Nozzle Material SA-516 70 [Impact Tested]
Re-Pad Material SA-516 70 [Impact Tested]

Internal Design Temperature 135 °C
Internal Design Pressure 23.000 bars

External Design Temperature 135 °C
External Design Pressure 1.034 bars

Maximum Allowable Working Pressure 23.731 bars
External Max. Allowable Working Pressure 8.440 bars
Hydrostatic Test Pressure 29.900 bars

Required Minimum Design Metal Temperature -45 °C
Warmest Computed Minimum Design Metal Temperature -45 °C

Wind Design Code ASCE-2010
Earthquake Design Code ASCE 7-2010

Element Pressures and MAWP (bars):

Element Description	Design Pres. + Stat. head	External Pressure	M.A.W.P	Corrosion Allowance	Str. Flange Governing
HEAD 001	23.002	1.100	23.731	3.0000	No
SHELL	23.002	1.100	25.668	3.0000	N/A
HEAD 002	23.000	1.100	23.733	3.0000	No

Liquid Level: 3700.00 mm. Dens.: 0.000 kg./cm³ Sp. Gr.: 0.006**Element Types and Properties:**

Element Type	"To" Elev mm.	Length mm.	Element Thk mm.	Req d Int.	Thk Ext.	Joint Eff Long	Circ
Ellipse	0.0	50.0	22.0	18.0	7.9	1.00	1.00
Cylinder	2700.0	2700.0	20.0	18.2	10.5	1.00	1.00
Ellipse	2750.0	50.0	22.0	18.0	7.9	1.00	1.00

Element thicknesses are shown as Nominal if specified, otherwise are Minimum

Loads for Foundation/Support Design:

Total Wind Shear on top of all Legs 4. kN
Total Earthquake Shear on top of all Legs 48. kN
Total Wind Moment at top of all Legs 3783. N-m
Total Earthquake Moment at top of all Legs 76226. N-m

Max. Wind Shear on one Leg (top & bottom) 1. kN
Max. Earthq. Shear on one Leg (top & bottom) 12. kN
Max. Wind Moment at base of one Leg 1423. N-m

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY

DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT

Tag no: K.O. Drum (D-PK6101-3)

PV Elite 2018 SP2 Licensee: SPLM Licensed User

FileName : Calculation Book for K.O. Drum (D-PK6101-3)

Vessel Design Summary: Step: 33 8:33pm Feb 18,2022

Max. Earthquake Moment at base of one Leg	19054.	N-m
Max. Vertical Load (Wt. + Wind) on one Leg	32.	kN
Max. Vertical Load (Wt. + Eq.) on one Leg	58.	kN

Note:

Wind and Earthquake moments include the effects of user defined forces and moments if any exist in the job and were specified to act (compute loads and stresses) during these cases. Also included are moment effects due to eccentric weights if any are present in the input.

Weights:

Fabricated - Bare W/O Removable Internals	5488.3	kg.
Shop Test - Fabricated + Water (Full)	14136.5	kg.
Shipping - Fab. + Rem. Intls.+ Shipping App.	5488.3	kg.
Erected - Fab. + Rem. Intls.+ Insul. (etc)	6615.7	kg.
Empty - Fab. + Intls. + Details + Wghts.	6615.7	kg.
Operating - Empty + Operating Liquid (No CA)	6665.9	kg.
Field Test - Empty Weight + Water (Full)	14256.5	kg.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018