




This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.

	DEHDASHT PETROCHEMICAL INDUSTRY COMPANY DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT	
	DOCUMENT TITLE: Mechanical Calculation for Liquid Receiver	POI: IFA
Contract No.: DPIC/98-12	DOCUMENT NUMBER: DPIC9812-000-VD-1002-ME-CLN-0094	Rev. No.: D0

DOCUMENT TITLE:

**Mechanical Calculation for Liquid Receiver
(D-PK6101-2)**

PURCHASER'S COMMENT/APPROVAL STATUS					Purchaser: NARGAN
1	AP: Approved (Released for Manufacturing)				Requisition No.: DPIC98-12-001-000-ME-MR-4150-0001-D1
2	AN: Approved With Minor Comments (Fabrication may Proceed)				
3	NF: Approved With Comments (Fabrication not Proceed)				Item No. (Tag No.): PK-6101
4	RJ: Rejected				
5	NR: Not be Returned				Vendor Doc. No.: DPIC9812-000-VD-1002-ME-CLN-0094-D0
Date:		Signature:			
					
D0	23.Dec.21	A.VOSOUGH	DR.A.NEJATI	DR.A.NEJATI	
REV	DATE ISSUE	PREPARED	CHECKED	APPROVED	



DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT



DOCUMENT TITLE: Mechanical Calculation for Liquid Receiver

POI: IFA

Contract No.: DPIC/98-12

DOCUMENT NUMBER: DPIC9812-000-VD-1002-ME-CLN-0094

Rev. No.: D0

This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
1	x				
2	x				
3	x				
4	x				
5	x				
6	x				
7	x				
8	x				
9	x				
10	x				
11	x				
12	x				
13	x				
14	x				
15	x				
16	x				
17	x				
18	x				
19	x				
20	x				
21	x				
22	x				
23	x				
24	x				
25	x				
26	x				
27	x				
28	x				
29	x				
30	x				
31	x				
32	x				
33	x				
34	x				
35	x				

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
36	x				
37	x				
38	x				
39	x				
40	x				
41	x				
42	x				
43	x				
44	x				
45	x				
46	x				
47	x				
48	x				
49	x				
50	x				
51	x				
52	x				
53	x				
54	x				
55	x				
56	x				
57	x				
58	x				
59	x				
60	x				
61	x				
62	x				
63	x				
64	x				
65	x				
66	x				
67	x				
68	x				
69	x				
70	x				



DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT



DOCUMENT TITLE: Mechanical Calculation for Liquid Receiver

POI: IFA

Contract No.: DPIC/98-12

DOCUMENT NUMBER: DPIC9812-000-VD-1002-ME-CLN-0094

Rev. No.: D0

This document is the property of PEDEC. Any unauthorized attempt to reproduce it, in any form, is strictly prohibited.

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
71	x				
72	x				
73	x				
74	x				
75	x				
76	x				
77	x				
78	x				
79	x				
80	x				
81	x				
82	x				
83	x				
84	x				
85	x				
86	x				
87	x				
88	x				
89	x				
90	x				
91	x				
92	x				
93	x				
94	x				
95	x				
96	x				
97	x				
98	x				
99	x				
100	x				
101	x				
102	x				
103	x				
104	x				
105	x				

Page	Rev-D0	Rev-D1	Rev-D2	Rev-D3	Rev-D4
106	x				
107	x				
108	x				
109	x				
110	x				
111	x				
112	x				
113	x				
114	x				
115	x				
116	x				
117	x				
118	x				
119	x				
120	x				
121	x				
122	x				
123	x				
124	x				
125	x				
126	x				
127	x				
128	x				
129	x				
130	x				
131	x				
132	x				
133	x				
134	x				
135	x				
136	x				
137	x				
138	x				
139	x				
140	x				

Table of Contents

Warnings and Errors:	8
Input Echo:.....	9
XY Coordinate Calculations:.....	16
Internal Pressure Calculations:.....	17
External Pressure Calculations:.....	22
Element and Detail Weights:.....	25
Nozzle Flange MAWP:.....	27
Wind Load Calculation:.....	28
Earthquake Load Calculation:.....	30
Center of Gravity Calculation:.....	32
Horizontal Vessel Analysis (Ope.):.....	34
Horizontal Vessel Analysis (Test):.....	45
Nozzle Summary:.....	55
Nozzle Calcs.: M.....	56
Nozzle Calcs.: A1.....	62
Nozzle Calcs.: B.....	72
Nozzle Calcs.: A2.....	82
Nozzle Calcs.: PT.....	92
Nozzle Calcs.: A3.....	102
Nozzle Calcs.: LT1.....	112
Nozzle Calcs.: LT2.....	118
Nozzle Calcs.: D.....	128
Nozzle Calcs.: LG1.....	138
Nozzle Calcs.: LG2.....	148
Nozzle Calcs.: TI.....	158
Nozzle Schedule:.....	167
MDMT Summary:.....	169
Vessel Design Summary:.....	171

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)

DESIGN CALCULATION

In Accordance with ASME Section VIII Division 1

ASME Code Version : 2017

Analysis Performed by : SPLM Licensed User

Job File :

Date of Analysis : Dec 24,2021 11:52pm

PV Elite 2018 SP2, June 2018

Note:

PV Elite performs all calculations internally in Imperial Units to remain compliant with the ASME Code and any built in assumptions in the ASME Code formulas. The finalized results are reflected to show the user's set of selected units.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0

Warnings and Errors: Step: 0 11:52pm Dec 24,2021

Class From To : Basic Element Checks.

=====

Class From To: Check of Additional Element Data

=====

There were no geometry errors or warnings.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Input Echo:

Step: 1 11:52pm Dec 24,2021

PV Elite Vessel Analysis Program: Input Data

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)

Design Internal Pressure (for Hydrotest) 23 bar
 Design Internal Temperature 135.0 °C
 Type of Hydrotest UG-99(b) Note [36]
 Hydrotest Position Horizontal
 Projection of Nozzle from Vessel Top 0 mm.
 Projection of Nozzle from Vessel Bottom 0 mm.
 Minimum Design Metal Temperature -45.0 °C
 Type of Construction Welded
 Special Service None
 Degree of Radiography RT-1
 Use Higher Longitudinal Stresses (Flag) Y
 Select t for Internal Pressure (Flag) N
 Select t for External Pressure (Flag) N
 Select t for Axial Stress (Flag) N
 Select Location for Stiff. Rings (Flag) N
 Consider Vortex Shedding N
 Perform a Corroded Hydrotest Y
 Is this a Heat Exchanger No
 User Defined Hydro. Press. (Used if > 0) 0 bar
 User defined MAWP 0 bar
 User defined MAPnc 0 bar

Load Case 1 NP+EW+WI+FW+BW
 Load Case 2 NP+EW+EE+FS+BS
 Load Case 3 NP+OW+WI+FW+BW
 Load Case 4 NP+OW+EQ+FS+BS
 Load Case 5 NP+HW+HI
 Load Case 6 NP+HW+HE
 Load Case 7 IP+OW+WI+FW+BW
 Load Case 8 IP+OW+EQ+FS+BS
 Load Case 9 EP+OW+WI+FW+BW
 Load Case 10 EP+OW+EQ+FS+BS
 Load Case 11 HP+HW+HI
 Load Case 12 HP+HW+HE
 Load Case 13 IP+WE+EW
 Load Case 14 IP+WF+CW
 Load Case 15 IP+VO+OW
 Load Case 16 IP+VE+EW
 Load Case 17 NP+VO+OW
 Load Case 18 FS+BS+IP+OW
 Load Case 19 FS+BS+EP+OW

Wind Design Code ASCE-7 2010
 Wind Load Reduction Scale Factor 0.600
 Basic Wind Speed [V] 195 Km/hr
 Surface Roughness Category C: Open Terrain
 Importance Factor 1.0
 Type of Surface Moderately Smooth
 Base Elevation 123000 mm.
 Percent Wind for Hydrotest 33.0
 Using User defined Wind Press. Vs Elev. N
 Height of Hill or Escarpment H or Hh 0 mm.
 Distance Upwind of Crest Lh 0 mm.
 Distance from Crest to the Vessel x 0 mm.
 Type of Terrain (Hill, Escarpment) Flat
 Damping Factor (Beta) for Wind (Ope) 0.0100

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Input Echo: Step: 1 11:52pm Dec 24,2021

Damping Factor (Beta) for Wind (Empty)		0.0000
Damping Factor (Beta) for Wind (Filled)		0.0000
Seismic Design Code	ASCE 7-2010	
Seismic Load Reduction Scale Factor		0.700
Importance Factor		1.500
Table Value Fa		1.000
Table Value Fv		1.300
Short Period Acceleration value Ss		1.163
Long Period Acceleration Value Sl		6.000
Moment Reduction Factor Tau		1.000
Force Modification Factor R		2.000
Site Class		C
Component Elevation Ratio	z/h	0.000
Amplification Factor	Ap	1.000
Force Factor		0.000
Consider Vertical Acceleration		No
Minimum Acceleration Multiplier		0.000
User Value of Sds (used if > 0)		0.000
Design Pressure + Static Head		Y
Consider MAP New and Cold in Noz. Design		N
Consider External Loads for Nozzle Des.		Y
Use ASME VIII-1 Appendix 1-9		N
Material Database Year	Current w/Addenda or Code Year	

Configuration Directives:

Do not use Nozzle MDMT Interpretation VIII-1 01-37	No
Use Table G instead of exact equation for "A"	Yes
Shell Head Joints are Tapered	Yes
Compute "K" in corroded condition	Yes
Use Code Case 2286	No
Use the MAWP to compute the MDMT	Yes
For thickness ratios <= 0.35, MDMT will be -155F (-104C)	Yes
For PWHT & P1 Materials the MDMT can be < -55F (-48C)	No
Using Metric Material Databases, ASME II D	No
Calculate B31.3 type stress for Nozzles with Loads	Yes
Reduce the MDMT due to lower membrane stress	Yes

Complete Listing of Vessel Elements and Details:

Element From Node	10
Element To Node	20
Element Type	Elliptical
Description	head 001
Distance "FROM" to "TO"	50 mm.
Element Outside Diameter	914 mm.
Element Thickness	12 mm.
Internal Corrosion Allowance	3 mm.
Nominal Thickness	15 mm.
External Corrosion Allowance	0 mm.
Design Internal Pressure	23 bar
Design Temperature Internal Pressure	135 °C
Design External Pressure	1.1 bar
Design Temperature External Pressure	100 °C
Effective Diameter Multiplier	1.2
Material Name	SA-516 70 [Normalized]
Allowable Stress, Ambient	137.9 N./mm ²
Allowable Stress, Operating	137.9 N./mm ²
Allowable Stress, Hydrotest	235.81 N./mm ²

Input Echo: Step: 1 11:52pm Dec 24,2021

Material Density	0.00775	kg./cm ³
P Number Thickness	30.988	mm.
Yield Stress, Operating	233.74	N./mm ²
UCS-66 Chart Curve Designation	D	
External Pressure Chart Name	CS-2	
UNS Number	K02700	
Product Form	Plate	
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Elliptical Head Factor	2.0	
Weld is pre-Heated	No	

Element From Node	10	
Detail Type	Liquid	
Detail ID	Liquid: 10	
Dist. from "FROM" Node / Offset dist	0	mm.
Height/Length of Liquid	890	mm.
Liquid Density	460.79	kg/m ³

Element From Node	10	
Detail Type	Insulation	
Detail ID	Ins: 10	
Dist. from "FROM" Node / Offset dist	-228.5	mm.
Height/Length of Insulation	278.5	mm.
Thickness of Insulation	100	mm.
Density	0.00012	kg./cm ³

Element From Node	10	
Detail Type	Nozzle	
Detail ID	M	
Dist. from "FROM" Node / Offset dist	0	mm.
Nozzle Diameter	20	in.
Nozzle Schedule	None	
Nozzle Class	300	
Layout Angle	0.0	
Blind Flange (Y/N)	Y	
Weight of Nozzle (Used if > 0)	4.6436	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-516 70	[Normalized]

Element From Node	20	
Element To Node	30	
Element Type	Cylinder	
Description	shell 001	
Distance "FROM" to "TO"	3900	mm.
Element Outside Diameter	914	mm.
Element Thickness	12	mm.
Internal Corrosion Allowance	3	mm.
Nominal Thickness	12	mm.
External Corrosion Allowance	0	mm.
Design Internal Pressure	23	bar
Design Temperature Internal Pressure	135	°C
Design External Pressure	1.1	bar
Design Temperature External Pressure	100	°C
Effective Diameter Multiplier	1.2	
Material Name	SA-516 70	[Normalized]
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Weld is pre-Heated	No	

Element From Node	20	
-------------------	----	--

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Input Echo: Step: 1 11:52pm Dec 24,2021

Detail Type	Saddle
Detail ID	Lft Sdl
Dist. from "FROM" Node / Offset dist	630 mm.
Width of Saddle	200 mm.
Height of Saddle at Bottom	1000 mm.
Saddle Contact Angle	120.0
Height of Composite Ring Stiffener	0 mm.
Width of Wear Plate	250 mm.
Thickness of Wear Plate	10 mm.
Contact Angle, Wear Plate (degrees)	130.0
Element From Node	20
Detail Type	Saddle
Detail ID	New Sdl
Dist. from "FROM" Node / Offset dist	3270 mm.
Width of Saddle	200 mm.
Height of Saddle at Bottom	1000 mm.
Saddle Contact Angle	120.0
Height of Composite Ring Stiffener	0 mm.
Width of Wear Plate	250 mm.
Thickness of Wear Plate	10 mm.
Contact Angle, Wear Plate (degrees)	130.0
Element From Node	20
Detail Type	Liquid
Detail ID	Liquid: 20
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Liquid	890 mm.
Liquid Density	460.79 kg/m ³
Element From Node	20
Detail Type	Insulation
Detail ID	Ins: 20
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Insulation	3900 mm.
Thickness of Insulation	100 mm.
Density	0.00012 kg./cm ³
Element From Node	20
Detail Type	Nozzle
Detail ID	A1
Dist. from "FROM" Node / Offset dist	450 mm.
Nozzle Diameter	8 in.
Nozzle Schedule	80
Nozzle Class	300
Layout Angle	0.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	1.0403 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-333 6 [Impact Tested]
Element From Node	20
Detail Type	Nozzle
Detail ID	B
Dist. from "FROM" Node / Offset dist	1950 mm.
Nozzle Diameter	8 in.
Nozzle Schedule	80
Nozzle Class	300
Layout Angle	180.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.7092 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-333 6 [Impact Tested]

Input Echo: Step: 1 11:52pm Dec 24,2021

Element From Node 20
 Detail Type Nozzle
 Detail ID A2
 Dist. from "FROM" Node / Offset dist 2750 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule 160
 Nozzle Class 300
 Layout Angle 0.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.09943 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-333 6 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID PT
 Dist. from "FROM" Node / Offset dist 1750 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule 160
 Nozzle Class 300
 Layout Angle 0.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.09462 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-333 6 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID A3
 Dist. from "FROM" Node / Offset dist 1150 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule 160
 Nozzle Class 300
 Layout Angle 0.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.12 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-333 6 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID LT1
 Dist. from "FROM" Node / Offset dist 3650 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule 160
 Nozzle Class 300
 Layout Angle 180.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.1585 kN
 Grade of Attached Flange GR 1.1
 Nozzle Matl SA-333 6 [Impact Tested]

Element From Node 20
 Detail Type Nozzle
 Detail ID LT2
 Dist. from "FROM" Node / Offset dist 3650 mm.
 Nozzle Diameter 2 in.
 Nozzle Schedule 160
 Nozzle Class 300
 Layout Angle 0.0
 Blind Flange (Y/N) N
 Weight of Nozzle (Used if > 0) 0.1585 kN

Input Echo: Step: 1 11:52pm Dec 24,2021

Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]
Element From Node	20	
Detail Type	Nozzle	
Detail ID	D	
Dist. from "FROM" Node / Offset dist	250	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	160	
Nozzle Class	300	
Layout Angle	180.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.1488	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]
Element From Node	20	
Detail Type	Nozzle	
Detail ID	LG1	
Dist. from "FROM" Node / Offset dist	2450	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	160	
Nozzle Class	300	
Layout Angle	180.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.1585	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]
Element From Node	20	
Detail Type	Nozzle	
Detail ID	LG2	
Dist. from "FROM" Node / Offset dist	2450	mm.
Nozzle Diameter	2	in.
Nozzle Schedule	160	
Nozzle Class	300	
Layout Angle	0.0	
Blind Flange (Y/N)	N	
Weight of Nozzle (Used if > 0)	0.1585	kN
Grade of Attached Flange	GR 1.1	
Nozzle Matl	SA-333 6	[Impact Tested]

Element From Node	30	
Element To Node	40	
Element Type	Elliptical	
Description	head 002	
Distance "FROM" to "TO"	50	mm.
Element Outside Diameter	914	mm.
Element Thickness	12	mm.
Internal Corrosion Allowance	3	mm.
Nominal Thickness	15	mm.
External Corrosion Allowance	0	mm.
Design Internal Pressure	23	bar
Design Temperature Internal Pressure	135	°C
Design External Pressure	1.1	bar
Design Temperature External Pressure	100	°C
Effective Diameter Multiplier	1.2	
Material Name	SA-516 70	[Normalized]
Efficiency, Longitudinal Seam	1.0	
Efficiency, Circumferential Seam	1.0	
Elliptical Head Factor	2.0	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Input Echo: Step: 1 11:52pm Dec 24,2021

Weld is pre-Heated	No
Element From Node	30
Detail Type	Liquid
Detail ID	Liquid: 30
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Liquid	890 mm.
Liquid Density	460.79 kg/m ³
Element From Node	30
Detail Type	Insulation
Detail ID	Ins: 30
Dist. from "FROM" Node / Offset dist	0 mm.
Height/Length of Insulation	278.5 mm.
Thickness of Insulation	100 mm.
Density	0.00012 kg./cm ³
Element From Node	30
Detail Type	Nozzle
Detail ID	TI
Dist. from "FROM" Node / Offset dist	300 mm.
Nozzle Diameter	2 in.
Nozzle Schedule	160
Nozzle Class	300
Layout Angle	180.0
Blind Flange (Y/N)	N
Weight of Nozzle (Used if > 0)	0.09462 kN
Grade of Attached Flange	GR 1.1
Nozzle Matl	SA-333 6 [Impact Tested]

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0

XY Coordinate Calculations: Step: 2 11:52pm Dec 24,2021

XY Coordinate Calculations:

From	To	X (Horiz.) mm.	Y (Vert.) mm.	DX (Horiz.) mm.	DY (Vert.) mm.
head 001		50	...	50	...
shell 001		3950	...	3900	...
head 002		4000	...	50	...

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Internal Pressure Calculations: Step: 3 11:52pm Dec 24,2021

Element Thickness, Pressure, Diameter and Allowable Stress :

From	To	Int. Press + Liq. Hd bar	Nominal Thickness mm.	Total Corr Allowance mm.	Element Diameter mm.	Allowable Stress (SE) N./mm ²
head 001		23.04	15	3	914	137.9
shell 001		23.04	12	3	914	137.9
head 002		23.04	15	3	914	137.9

Element Required Thickness and MAWP :

From	To	Design Pressure bar	M.A.W.P. Corroded bar	M.A.P. New & Cold bar	Minimum Thickness mm.	Required Thickness mm.
head 001		23	27.8493	37.0811	12	10.4581
shell 001		23	27.3289	36.5891	12	10.586
head 002		23	27.8493	37.0811	12	10.4581
Minimum			27.329	36.589		

MAWP: 23.873 bar, limited by: Nozzle Reinforcement.

Internal Pressure Calculation Results :

ASME Code, Section VIII Division 1, 2017

Elliptical Head From 10 To 20 SA-516 70 , UCS-66 Crv. D at 135 °C

head 001

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned}
 &= (P \cdot D_o \cdot K_{cor}) / (2 \cdot S \cdot E + 2 \cdot P \cdot (K_{cor} - 0.1)) \text{ per Appendix 1-4 (c)} \\
 &= (23.04 \cdot 914 \cdot 0.991) / (2 \cdot 137.9 + 2 \cdot 23.04 \cdot (0.991 - 0.1)) \\
 &= 7.4581 + 3.0000 = 10.4581 \text{ mm.}
 \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.040 bar

$$\begin{aligned}
 &= (2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D_o - 2 \cdot t \cdot (K_{cor} - 0.1)) \text{ per Appendix 1-4 (c)} \\
 &= (2 \cdot 137.9 \cdot 12) / (0.991 \cdot 914 - 2 \cdot 12 \cdot (0.991 - 0.1)) \\
 &= 27.890 - 0.040 = 27.849 \text{ bar}
 \end{aligned}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$\begin{aligned}
 &= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)} \\
 &= (2 \cdot 137.9 \cdot 12) / (1 \cdot 914 - 2 \cdot 12 \cdot (1 - 0.1)) \\
 &= 37.081 \text{ bar}
 \end{aligned}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$\begin{aligned}
 &= (P \cdot (K_{cor} \cdot D_o - 2 \cdot t \cdot (K_{cor} - 0.1))) / (2 \cdot E \cdot t) \\
 &= (23.04 \cdot (0.991 \cdot 914 - 2 \cdot 12 \cdot (0.991 - 0.1))) / (2 \cdot 1 \cdot 9) \\
 &= 113.923 \text{ N./mm}^2
 \end{aligned}$$

Straight Flange Required Thickness:

$$\begin{aligned}
 &= (P \cdot R_o) / (S \cdot E + 0.4 \cdot P) + c_a \text{ per Appendix 1-1 (a) (1)} \\
 &= (23.04 \cdot 457) / (137.9 + 0.4 \cdot 23.04) + 3 \\
 &= 10.586 \text{ mm.}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Internal Pressure Calculations: Step: 3 11:52pm Dec 24,2021

Straight Flange Maximum Allowable Working Pressure:

Less Operating Hydrostatic Head Pressure of 0.040 bar

$$= (S \cdot E \cdot t) / (R_o - 0.4 \cdot t) \text{ per Appendix 1-1 (a) (1)}$$

$$= (137.9 \cdot 1 \cdot 12) / (457 - 0.4 \cdot 12)$$

$$= 36.589 - 0.040 = 36.549 \text{ bar}$$

Factor K, corroded condition [Kcor]:

$$= (2 + (\text{Inside Diameter} / (2 \cdot \text{Inside Head Depth}))^2) / 6$$

$$= (2 + (896 / (2 \cdot 225.5))^2) / 6$$

$$= 0.991160$$

Percent Elong. per UCS-79, VIII-1-01-57 $(75 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$ 7.130 %

Note: Please Check Requirements of UCS-79 as Elongation is > 5%.

MDMT Calculations in the Knuckle Portion:

Govrn. thk, tg = 12, tr = 7.736, c = 3 mm., E* = 1
 Thickness Ratio = $tr \cdot (E^*) / (tg - c) = 0.86$, Temp. Reduction = 8 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

MDMT Calculations in the Head Straight Flange:

Govrn. thk, tg = 15, tr = 7.872, c = 3 mm., E* = 1
 Thickness Ratio = $tr \cdot (E^*) / (tg - c) = 0.656$, Temp. Reduction = 19 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -47 °C

Min Metal Temp. at Required thickness (UCS 66.1) -48 °C

Cylindrical Shell From 20 To 30 SA-516 70 , UCS-66 Crv. D at 135 °C

shell 001

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$= (P \cdot R_o) / (S \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.04 \cdot 457) / (137.9 \cdot 1 + 0.4 \cdot 23.04)$$

$$= 7.5860 + 3.0000 = 10.5860 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.040 bar

$$= (S \cdot E \cdot t) / (R_o - 0.4 \cdot t) \text{ per Appendix 1-1 (a) (1)}$$

$$= (137.9 \cdot 1 \cdot 9) / (457 - 0.4 \cdot 9)$$

$$= 27.369 - 0.040 = 27.329 \text{ bar}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (S \cdot E \cdot t) / (R_o - 0.4 \cdot t) \text{ per Appendix 1-1 (a) (1)}$$

$$= (137.9 \cdot 1 \cdot 12) / (457 - 0.4 \cdot 12)$$

$$= 36.589 \text{ bar}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \cdot (R_o - 0.4 \cdot t)) / (E \cdot t)$$

$$= (23.04 \cdot ((457 - 0.4 \cdot 9)) / (1 \cdot 9))$$

$$= 116.089 \text{ N./mm}^2$$

% Elongation per Table UG-79-1 $(50 \cdot t_{nom} / R_f) \cdot (1 - R_f / R_o)$ 1.330 %

Minimum Design Metal Temperature Results:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Internal Pressure Calculations: Step: 3 11:52pm Dec 24,2021

Govrn. thk, tg = 12, tr = 7.872, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.875, Temp. Reduction = 7 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

Elliptical Head From 30 To 40 SA-516 70 , UCS-66 Crv. D at 135 °C

head 002

Material UNS Number: K02700

Required Thickness due to Internal Pressure [tr]:

$$= (P \cdot D_o \cdot K_{cor}) / (2 \cdot S \cdot E \cdot t + 2 \cdot P \cdot (K_{cor} - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (23.04 \cdot 914 \cdot 0.991) / (2 \cdot 137.9 \cdot 1 + 2 \cdot 23.04 \cdot (0.991 - 0.1))$$

$$= 7.4581 + 3.0000 = 10.4581 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

Less Operating Hydrostatic Head Pressure of 0.040 bar

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 137.9 \cdot 1 \cdot 9) / (0.991 \cdot 914 - 2 \cdot 9 \cdot (0.991 - 0.1))$$

$$= 27.890 - 0.040 = 27.849 \text{ bar}$$

Maximum Allowable Pressure, New and Cold [MAPNC]:

$$= (2 \cdot S \cdot E \cdot t) / (K \cdot D_o - 2 \cdot t \cdot (K - 0.1)) \text{ per Appendix 1-4 (c)}$$

$$= (2 \cdot 137.9 \cdot 1 \cdot 12) / (1 \cdot 914 - 2 \cdot 12 \cdot (1 - 0.1))$$

$$= 37.081 \text{ bar}$$

Actual stress at given pressure and thickness, corroded [Sact]:

$$= (P \cdot (K_{cor} \cdot D_o - 2 \cdot t \cdot (K_{cor} - 0.1))) / (2 \cdot E \cdot t)$$

$$= (23.04 \cdot (0.991 \cdot 914 - 2 \cdot 9 \cdot (0.991 - 0.1))) / (2 \cdot 1 \cdot 9)$$

$$= 113.923 \text{ N./mm}^2$$

Straight Flange Required Thickness:

$$= (P \cdot R_o) / (S \cdot E + 0.4 \cdot P) + c_a \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.04 \cdot 457) / (137.9 \cdot 1 + 0.4 \cdot 23.04) + 3$$

$$= 10.586 \text{ mm.}$$

Straight Flange Maximum Allowable Working Pressure:

Less Operating Hydrostatic Head Pressure of 0.040 bar

$$= (S \cdot E \cdot t) / (R_o - 0.4 \cdot t) \text{ per Appendix 1-1 (a) (1)}$$

$$= (137.9 \cdot 1 \cdot 12) / (457 - 0.4 \cdot 12)$$

$$= 36.589 - 0.040 = 36.549 \text{ bar}$$

Factor K, corroded condition [Kcor]:

$$= (2 + (\text{Inside Diameter} / (2 \cdot \text{Inside Head Depth}))^2) / 6$$

$$= (2 + (896 / (2 \cdot 225.5))^2) / 6$$

$$= 0.991160$$

Percent Elong. per UCS-79, VIII-1-01-57 (75 * t_{nom} / R_f) * (1 - R_f / R_o) 7.130 %

Note: Please Check Requirements of UCS-79 as Elongation is > 5%.

MDMT Calculations in the Knuckle Portion:

Govrn. thk, tg = 12, tr = 7.736, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.86, Temp. Reduction = 8 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

MDMT Calculations in the Head Straight Flange:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Internal Pressure Calculations: Step: 3 11:52pm Dec 24,2021

Govrn. thk, tg = 15, tr = 7.872, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.656$, Temp. Reduction = 19 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -47 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -48 °C

Note: Heads and Shells Exempted to -20F (-29C) by paragraph UG-20F

Hydrostatic Test Pressure Results:

Pressure per UG99b	= 1.30 * M.A.W.P. * Sa/S	31.035 bar
Pressure per UG99b[36]	= 1.30 * Design Pres * Sa/S	29.900 bar
Pressure per UG99c	= 1.30 * M.A.P. - Head(Hyd)	47.476 bar
Pressure per UG100	= 1.10 * M.A.W.P. * Sa/S	26.261 bar
Pressure per PED	= max(1.43*DP, 1.25*DP*ratio)	32.775 bar
Pressure per App 27-4	= 1.30 * M.A.W.P. * Sa/S	31.035 bar

UG-99(b) Note 36, Test Pressure Calculation:

= Test Factor * Design Pressure * Stress Ratio
 = 1.3 * 23 * 1
 = 29.900 bar

Horizontal Test performed per: UG-99b (Note 36)

Please note that Nozzle, Shell, Head, Flange, etc MAWPs are all considered when determining the hydrotest pressure for those test types that are based on the MAWP of the vessel.

Stresses on Elements due to Test Pressure (N./mm² & bar):

From To	Stress	Allowable	Ratio	Pressure
head 001	148.3	235.8	0.629	29.99
shell 001	151.1	235.8	0.641	29.99
head 002	148.3	235.8	0.629	29.99

Stress ratios for Nozzle and Pad Materials (N./mm²):

Description	Pad/Nozzle	Ambient	Operating	Ratio
M	Nozzle	137.90	137.90	1.000
M	Pad	137.90	137.90	1.000
A1	Nozzle	117.90	117.90	1.000
A1	Pad	137.90	137.90	1.000
B	Nozzle	117.90	117.90	1.000
B	Pad	137.90	137.90	1.000
A2	Nozzle	117.90	117.90	1.000
A2	Pad	137.90	137.90	1.000
PT	Nozzle	117.90	117.90	1.000
PT	Pad	137.90	137.90	1.000
A3	Nozzle	117.90	117.90	1.000
A3	Pad	137.90	137.90	1.000
LT1	Nozzle	117.90	117.90	1.000
LT1	Pad	137.90	137.90	1.000
LT2	Nozzle	117.90	117.90	1.000
LT2	Pad	137.90	137.90	1.000
D	Nozzle	117.90	117.90	1.000
D	Pad	137.90	137.90	1.000
LG1	Nozzle	117.90	117.90	1.000
LG1	Pad	137.90	137.90	1.000

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Internal Pressure Calculations: Step: 3 11:52pm Dec 24,2021

LG2	Nozzle	117.90	117.90	1.000
LG2	Pad	137.90	137.90	1.000
TI	Nozzle	117.90	117.90	1.000
TI	Pad	137.90	137.90	1.000

Minimum				1.000

Stress ratios for Pressurized Vessel Elements (N./mm²):

Description	Ambient	Operating	Ratio
head 001	137.90	137.90	1.000
shell 001	137.90	137.90	1.000
head 002	137.90	137.90	1.000

Minimum			1.000

Hoop Stress in Nozzle Wall during Pressure Test (N./mm²):

Description	Ambient	Operating	Ratio
M	62.29	235.80	0.264
A1	39.30	217.19	0.181
B	39.30	217.19	0.181
A2	18.28	217.19	0.084
PT	18.28	217.19	0.084
A3	18.28	217.19	0.084
LT1	18.28	217.19	0.084
LT2	18.28	217.19	0.084
D	18.28	217.19	0.084
LG1	18.28	217.19	0.084
LG2	18.28	217.19	0.084
TI	18.28	217.19	0.084

Elements Suitable for Internal Pressure.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

External Pressure Calculations: Step: 4 11:52pm Dec 24,2021

External Pressure Calculation Results :

External Pressure Calculations:

From	To	Section Length mm.	Outside Diameter mm.	Corroded Thickness mm.	Factor A	Factor B N./mm ²
10	20	No Calc	914	9	0.0013676	94.3429
20	30	4148.33	914	9	0.00026007	26.0008
30	40	No Calc	914	9	0.0013676	94.3429

External Pressure Calculations:

From	To	External Actual T. mm.	External Required T. mm.	External Design Pressure bar	External M.A.W.P. bar
10	20	12	5.44078	1.1	10.3205
20	30	12	8.66323	1.1	3.41318
30	40	12	5.44078	1.1	10.3205

Minimum 3.413

External Pressure Calculations:

From	To	Actual Length Bet. Stiffeners mm.	Allowable Length Bet. Stiffeners mm.	Ring Inertia Required cm**4	Ring Inertia Available cm**4
10	20	No Calc	No Calc	No Calc	No Calc
20	30	4148.33	86665.1	No Calc	No Calc
30	40	No Calc	No Calc	No Calc	No Calc

Elements Suitable for External Pressure.

ASME Code, Section VIII Division 1, 2017

Elliptical Head From 10 to 20 Ext. Chart: CS-2 at 100 °C

head 001

Elastic Modulus from Chart: CS-2 at 100 °C : 0.200E+09 KPa.

Results for Maximum Allowable External Pressure (MAEP):

Tca	OD	D/t	Factor A	B
9.000	914.00	101.56	0.0013676	94.34

EMAP = B / (K0 * D / t) = 94.34 / (0.9 * 101.6) = 10.32 bar

Results for Required Thickness (Tca):

Tca	OD	D/t	Factor A	B
2.441	914.00	374.47	0.0003709	37.08

EMAP = B / (K0 * D / t) = 37.08 / (0.9 * 374.5) = 1.1 bar

Check the requirements of UG-33(a)(1) using $P = 1.67 * \text{External Design pressure for this head.}$

Material UNS Number: K02700

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

External Pressure Calculations: Step: 4 11:52pm Dec 24,2021

Required Thickness due to Internal Pressure [tr]:

$$= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)}$$

$$= (1.837 \cdot 896 \cdot 0.991) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 1.837)$$

$$= 0.5917 + 3.0000 = 3.5917 \text{ mm.}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$= ((2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t)) / 1.67 \text{ per Appendix 1-4 (c)}$$

$$= ((2 \cdot 137.9 \cdot 1 \cdot 9) / (0.991 \cdot 896 + 0.2 \cdot 9)) / 1.67$$

$$= 16.700 \text{ bar}$$

Maximum Allowable External Pressure [MAEP]:

$$= \min(\text{MAEP}, \text{MAWP})$$

$$= \min(10.32, 16.7)$$

$$= 10.320 \text{ bar}$$

Thickness requirements per UG-33(a)(1) do not govern the required thickness of this head.

Cylindrical Shell From 20 to 30 Ext. Chart: CS-2 at 100 °C

shell 001

Elastic Modulus from Chart: CS-2 at 100 °C : 0.200E+09 KPa.

Results for Maximum Allowable External Pressure (MAEP):

Tca	OD	SLEN	D/t	L/D	Factor A	B
9.000	914.00	4148.33	101.56	4.5387	0.0002601	26.00

$$\text{EMAP} = (4 \cdot B) / (3 \cdot (D/t)) = (4 \cdot 26) / (3 \cdot 101.6) = 3.413 \text{ bar}$$

Results for Required Thickness (Tca):

Tca	OD	SLEN	D/t	L/D	Factor A	B
5.663	914.00	4148.33	161.39	4.5387	0.0001332	13.32

$$\text{EMAP} = (4 \cdot B) / (3 \cdot (D/t)) = (4 \cdot 13.32) / (3 \cdot 161.4) = 1.1 \text{ bar}$$

Results for Maximum Stiffened Length (Slen):

Tca	OD	SLEN	D/t	L/D	Factor A	B
9.000	914.00	86665.13	101.56	50.0000	0.0001071	10.71

$$\text{EMAP} = (4 \cdot B) / (3 \cdot (D/t)) = (4 \cdot 10.71) / (3 \cdot 101.6) = 1.406 \text{ bar}$$

Elliptical Head From 30 to 40 Ext. Chart: CS-2 at 100 °C

head 002

Elastic Modulus from Chart: CS-2 at 100 °C : 0.200E+09 KPa.

Results for Maximum Allowable External Pressure (MAEP):

Tca	OD	D/t	Factor A	B
9.000	914.00	101.56	0.0013676	94.34

$$\text{EMAP} = B / (K_0 \cdot D/t) = 94.34 / (0.9 \cdot 101.6) = 10.32 \text{ bar}$$

Results for Required Thickness (Tca):

Tca	OD	D/t	Factor A	B
2.441	914.00	374.47	0.0003709	37.08

$$\text{EMAP} = B / (K_0 \cdot D/t) = 37.08 / (0.9 \cdot 374.5) = 1.1 \text{ bar}$$

Check the requirements of UG-33(a)(1) using $P = 1.67 \cdot \text{External Design pressure}$ for this head.

Material UNS Number: K02700

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0

External Pressure Calculations: Step: 4 11:52pm Dec 24,2021

Required Thickness due to Internal Pressure [tr]:

$$\begin{aligned} &= (P \cdot D \cdot K_{cor}) / (2 \cdot S \cdot E - 0.2 \cdot P) \text{ Appendix 1-4 (c)} \\ &= (1.837 \cdot 896 \cdot 0.991) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 1.837) \\ &= 0.5917 + 3.0000 = 3.5917 \text{ mm.} \end{aligned}$$

Max. Allowable Working Pressure at given Thickness, corroded [MAWP]:

$$\begin{aligned} &= ((2 \cdot S \cdot E \cdot t) / (K_{cor} \cdot D + 0.2 \cdot t)) / 1.67 \text{ per Appendix 1-4 (c)} \\ &= ((2 \cdot 137.9 \cdot 1 \cdot 9) / (0.991 \cdot 896 + 0.2 \cdot 9)) / 1.67 \\ &= 16.700 \text{ bar} \end{aligned}$$

Maximum Allowable External Pressure [MAEP]:

$$\begin{aligned} &= \min(\text{MAEP}, \text{MAWP}) \\ &= \min(10.32, 16.7) \\ &= 10.320 \text{ bar} \end{aligned}$$

Thickness requirements per UG-33(a)(1) do not govern the required thickness of this head.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Element and Detail Weights: Step: 5 11:52pm Dec 24,2021

Element and Detail Weights:

From	To	Element Metal Wgt. kg.	Element ID Volume m³	Corroded Metal Wgt. kg.	Corroded ID Volume m³	Extra due Misc % kg.
10	20	130.489	0.12047	104.391	0.12272	13.0489
20	30	1027.86	2.36894	773.455	2.40098	102.786
30	40	130.489	0.12047	104.391	0.12272	13.0489
Total		1288	2.61	982	2.65	128

Weight of Details:

From	Type	Weight of Detail kg.	X Offset, Dtl. Cent. mm.	Y Offset, Dtl. Cent. mm.	Description
10	Liqd	56.8564	-74.1667	...	Liquid: 10
10	Insl	18.9488	-89.25	...	Ins: 10
10	Nozl	520.903	-222.5	...	M
20	Sadl	127.668	630	711.5	Lft Sdl
20	Sadl	127.668	3270	711.5	New Sdl
20	Liqd	1118.02	1950	...	Liquid: 20
20	Insl	149.259	1950	...	Ins: 20
20	Nozl	116.699	450	554.537	A1
20	Nozl	79.5605	1950	554.537	B
20	Nozl	11.1539	2750	475.163	A2
20	Nozl	10.6146	1750	475.163	PT
20	Nozl	13.4637	1150	475.163	A3
20	Nozl	17.7786	3650	475.163	LT1
20	Nozl	17.7786	3650	475.163	LT2
20	Nozl	16.6915	250	475.163	D
20	Nozl	17.7786	2450	475.163	LG1
20	Nozl	17.7786	2450	475.163	LG2
30	Liqd	56.8564	124.167	...	Liquid: 30
30	Insl	18.9488	139.25	...	Ins: 30
30	Nozl	10.6146	214.336	...	TI

Total Weight of Each Detail Type

Total Weight of Saddles	255.3
Total Weight of Liquid	1231.7
Total Weight of Insulation	187.2
Total Weight of Nozzles	850.8

Sum of the Detail Weights	2525.0 kg.

Weight Summation: kg.

Fabricated	Shop Test	Shipping	Erected	Empty	Operating
1417.7	2523.9	1417.7	2523.9	1417.7	2711.0
255.3	2671.9	255.3	...	255.3	1231.7
850.8	...	850.8
...	187.2
...	187.2	...
...
...
...	850.8	...
2523.9	5195.7	2523.9	2711.0	2711.0	3942.8

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Element and Detail Weights:

Step: 5 11:52pm Dec 24,2021

Miscellaneous Weight Percent: 10.0 %

Note that the above value for the miscellaneous weight percent has been applied to the shells/heads/flange/tubesheets/tubes etc. in the weight calculations for metallic components.

Weight Summary

Fabricated Wt.	- Bare Weight W/O Removable Internals	2523.9 kg.
Shop Test Wt.	- Fabricated Weight + Water (Full)	5195.7 kg.
Shipping Wt.	- Fab. Wt + Rem. Intls.+ Shipping App.	2523.9 kg.
Erected Wt.	- Fab. Wt + Rem. Intls.+ Insul. (etc)	2711.0 kg.
Ope. Wt. no Liq	- Fab. Wt + Intls. + Details + Wghts.	2711.0 kg.
Operating Wt.	- Empty Wt + Operating Liq. Uncorroded	3942.8 kg.
Oper. Wt. + CA	- Corr Wt. + Operating Liquid	3605.5 kg.
Field Test Wt.	- Empty Weight + Water (Full)	5083.0 kg.

Note:
 The Corroded Weight and thickness are used in the Horizontal Vessel Analysis (Ope Case) and Earthquake Load Calculations.

Note: The Field Test weight as computed in the corroded condition.

Outside Surface Areas of Elements:

From	To	Surface Area cm ²
10	20	10620
20	30	111985
30	40	10620
Total		133225.188 cm ²

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Nozzle Flange MAWP Results:

Nozzle Description	Flange Rating		Design Temp °C	Class	Grade/Group	Equiv. Press	Max Pressure			
	Ope. bar	Ambient bar					PVP	50%	DNV bar	
M	45.5	51.1	135	300	GR 1.1	
A1	45.5	51.1	135	300	GR 1.1	
B	45.5	51.1	135	300	GR 1.1	
A2	45.5	51.1	135	300	GR 1.1	
PT	45.5	51.1	135	300	GR 1.1	
A3	45.5	51.1	135	300	GR 1.1	
LT1	45.5	51.1	135	300	GR 1.1	
LT2	45.5	51.1	135	300	GR 1.1	
D	45.5	51.1	135	300	GR 1.1	
LG1	45.5	51.1	135	300	GR 1.1	
LG2	45.5	51.1	135	300	GR 1.1	
TI	45.5	51.1	135	300	GR 1.1	
Min Rating	45.546	51.096 bar [for Core Elements]						0.000	0.000	0.000

Selected Method for Derating ANSI Flange MAWP: None Selected

Note: ANSI Ratings are per ANSI/ASME B16.5 2013 Metric Edition

The PVP Method is based on the paper PVP 2013-97814. PV Elite uses the maximum loads from each load category to determine ME and FE. In many cases, the computed maximum allowable pressure will be greater than the flange rating. In these cases, the minimum of the rating from the table and the PVP method will be used. SA-193 B8 Cl. 2 bolts or ones with higher allowable stresses at the specified bolt size shall be used. Note that ANSI pipe nominal sizes up to 24 inch (600mm) are addressed.

How the 50% Stress Method Works:

If the computed stress/allowable stress is < 0.5 on the pipe wall, then the allowable pressure is the table rating from the ANSI/ASME standard. If the stress ratio is >= 0.5, then the full equivalent pressure is subtracted from the flange rating.

The DNV Method:

minimum(table rating, 1.5 * Operating rating - equivalent pressure)

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Wind Load Calculation: Step: 7 11:52pm Dec 24,2021

Input Values:

Wind Design Code		ASCE-7 2010	
Wind Load Reduction Scale Factor		0.600	
Basic Wind Speed	[V]	195	Km/hr
Surface Roughness Category		C: Open Terrain	
Importance Factor		1.0	
Type of Surface		Moderately Smooth	
Base Elevation		123000	mm.
Percent Wind for Hydrottest		33.0	
Using User defined Wind Press. Vs Elev.		N	
Height of Hill or Escarpment	H or Hh	0	mm.
Distance Upwind of Crest	Lh	0	mm.
Distance from Crest to the Vessel	x	0	mm.
Type of Terrain (Hill, Escarpment)		Flat	
Damping Factor (Beta) for Wind (Ope)		0.0100	
Damping Factor (Beta) for Wind (Empty)		0.0000	
Damping Factor (Beta) for Wind (Filled)		0.0000	

Wind Analysis Results

Static Gust-Effect Factor, Operating Case [G]:

$$\begin{aligned}
 &= \min(0.85, 0.925((1 + 1.7 * gQ * Izbar * Q)/(1 + 1.7 * gV * Izbar))) \\
 &= \min(0.85, 0.925((1+1.7*3.4*0.143*0.836)/(1+1.7*3.4*0.143))) \\
 &= \min(0.85, 0.856) \\
 &= 0.850
 \end{aligned}$$

Natural Frequency of Vessel (Operating)	33.000 Hz
Natural Frequency of Vessel (Empty)	33.000 Hz
Natural Frequency of Vessel (Test)	33.000 Hz

Force Coefficient	[Cf] 0.549
Structure Height to Diameter ratio	3.956

This is classified as a rigid structure. Static analysis performed.

Sample Calculation for the First Element

The ASCE code performs all calculations in Imperial Units only. The wind pressure is therefore computed in these units.

Value of [Alpha] and [Zg]:

Exposure Category: C from Table 26.9.1
 Alpha = 9.5 : Zg = 274320 mm.

Effective Height [z]:

= Centroid Height + Vessel Base Elevation
 = 1000 + 123000 = 124000 mm.
 = 406.8 ft. Imperial Units

Velocity Pressure coefficient evaluated at height z [Kz]:

$$\begin{aligned}
 &\text{Because } z (406.8 \text{ ft.}) > 15 \text{ ft.} \\
 &= 2.01 * (z / Zg)^{2 / \text{Alpha}} \\
 &= 2.01 * (406.8/900)^{2/9.5} \\
 &= 1.701
 \end{aligned}$$

Type of Hill: No Hill

Wind Directionality Factor [Kd]:

= 0.95 per Table 26.6-1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Wind Load Calculation: Step: 7 11:52pm Dec 24,2021

As there is No Hill Present: [Kzt]:

$$K1 = 0, K2 = 0, K3 = 0$$

Topographical Factor [Kzt]:

$$= (1 + K1 * K2 * K3)^2$$

$$= (1 + 0 * 0 * 0)^2$$

$$= 1$$

Velocity Pressure evaluated at height z, Imperial Units [qz]:

$$= \max(16, 0.00256 * Kz * Kzt * Kd * V(\text{mph})^2)$$

$$= \max(16, 0.00256 * 1.701 * 1 * 0.95 * 121.2^2)$$

$$= 60.72 \text{ psf [296.5] Kgs/m}^2$$

Force on the first element [F]:

$$= qz * G * Cf * \text{WindArea}$$

$$= 60.72 * 0.85 * 0.549 * 3.87$$

$$= 109.7 \text{ lbs. [0.488] kN}$$

Element	Hgt (z) mm.	K1	K2	K3	Kz	Kzt	qz Kgs/m ²
head 001	*****	0.000	0.000	0.000	1.701	1.000	296.483
shell 001	*****	0.000	0.000	0.000	1.701	1.000	296.483
head 002	*****	0.000	0.000	0.000	1.701	1.000	296.483

Wind Load Calculation:

From	To	Wind Height mm.	Wind Diameter mm.	Wind Area cm ²	Wind Pressure Kgs/m ²	Element Wind Load kN
10	20	124000	1336.8	3595.05	296.483	0.29279
20	30	124000	1336.8	52135.2	296.483	4.24603
30	40	124000	1336.8	3595.05	296.483	0.29279

Note:

The Wind Loads calculated and printed in the Wind Load calculation report have been factored by the input scalar/load reduction factor of: 0.600.

Be sure the wind speed is in accordance with the specified wind design code.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Earthquake Load Calculation: Step: 8 11:52pm Dec 24,2021

Earthquake Load Calculation:

Input Values:

Seismic Design Code		ASCE 7-2010
Seismic Load Reduction Scale Factor		0.700
Importance Factor		1.500
Table Value Fa		1.000
Table Value Fv		1.300
Short Period Acceleration value Ss		1.163
Long Period Acceleration Value S1		6.000
Moment Reduction Factor Tau		1.000
Force Modification Factor R		2.000
Site Class		C
Component Elevation Ratio	z/h	0.000
Amplification Factor	Ap	1.000
Force Factor		0.000
Consider Vertical Acceleration		No
Minimum Acceleration Multiplier		0.000
User Value of Sds (used if > 0)		0.000

Seismic Analysis Results:

Sms = Fa * Ss = 1 * 1.163 = 1.163
 Sm1 = Fv * S1 = 1.3 * 6 = 7.8
 Sds = 2/3 * Sms = 2/3 * 1.163 = 0.775
 Sd1 = 2/3 * Sm1 = 2/3 * 7.8 = 5.2

Check Approximate Fundamental Period from 12.8-7 [Ta]:

= Ct * hn^x where Ct = 0.020, x = 0.75 and hn = Structural Height (ft.)
 = 0.020 * (4.741^{0.75})
 = 0.064 seconds

The Coefficient Cu from Table 12.8-1 is : 1.400

Fundamental Period (1/Frequency) [T]:

= (1/Natural Frequency) = (1/33)
 = 0.030

Check the Value of T which is the smaller of Cu*Ta and T:

= Minimum Value of (1.4 * 0.0643, 0.0303) per 12.8.2
 = 0.030

As the time period is < 0.06 second, use section 15.4.2.

Compute the Base Shear per equation 15.4-5, [V]:

= 0.3 * Sds * W * I
 = 0.3 * 0.775 * 35.36 * 1.5
 = 12.336 kN

Final Base Shear, V = 8.63 kN

Earthquake Load Calculation:

From	To	Earthquake Height mm.	Earthquake Weight kN	Element Ope Load kN
10	20	445	7.0711	1.72698
20	Sadl	445	7.0711	1.72698

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Earthquake Load Calculation: Step: 8 11:52pm Dec 24,2021

Sad1	30	445	7.0711	1.72698
20	30	445	7.0711	1.72698
30	40	445	7.0711	1.72698

Note:
 The Earthquake Loads calculated and printed in the Earthquake Load calculation report have been factored by the input scalar/load reduction factor of: 0.700.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Center of Gravity Calculation: Step: 9 11:52pm Dec 24,2021

Shop/Field Installation Options :

Insulation is installed in the Field.

Note : The CG is computed from the first Element From Node

Center of Gravity of Saddles	2000.000 mm.
Center of Gravity of Liquid	2000.000 mm.
Center of Gravity of Insulation	2000.000 mm.
Center of Gravity of Nozzles	514.481 mm.
Center of Gravity of Bare Shell New and Cold	2000.000 mm.
Center of Gravity of Bare Shell Corroded	2000.000 mm.
Vessel CG in the Operating Condition	1649.452 mm.
Vessel CG in the Fabricated (Shop/Empty) Condition	1499.220 mm.
Vessel CG in the Test Condition	1756.742 mm.

Warning: Lifting Lug is Higher than top of vessel !

Rigging Analysis Results:

Total Effective Length of Vessel for this analysis	4000.00 mm.
Total vessel weight (No Liquid)	Twt 26.58 kN
Impact weight multiplication factor	Imp 1.50
Design lifting weight, DWT = Imp * Twt	39.88 kN
Elevation of the Tailing Lug (bottom)	500.00 mm.
Elevation of the Lifting Lug (top)	5400.00 mm.
Design Reaction force at the tailing lug	31.74 kN
Design Reaction force at the lifting lug	8.13 kN
CG Distance from Tailing Lug	999.22 mm.
CG Distance from the Nearer Lifting Lug	999.22 mm.

Critical Values:

	Max Stress N./mm ²	Elevation mm.	Allowables N./mm ²	
Bending	2.02	3170.00	113.45	(UG-23)
Shear	0.44	10.00	96.53	(0.7*S)

Forces and Moments at selected elevations (not all analysis points shown):

Distance mm.	Bending Moment N-m	Bending Stress N./mm ²	Shear Force kN	Shear Stress N./mm ²
0.00	0.0	0.0	13.8	0.4
830.00	1724.5	0.2	10.2	0.3
2390.00	13363.7	1.8	0.6	0.0
3950.00	13516.1	1.8	8.9	0.3

Unity Check (Actual Stress / Allowable Stress):

Maximum Unity Check is 0.0178 at elevation 3170 mm. - Must be <=1

Note: The rigging analysis is performed using a uniformly distributed load.

--- Plot data successfully generated ...----

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0
Center of Gravity Calculation: Step: 9 11:52pm Dec 24,2021

[PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018](#)

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

ASME Horizontal Vessel Analysis: Stresses for the Left Saddle
 (per ASME Sec. VIII Div. 2 based on the Zick method.)

Horizontal Vessel Stress Calculations : Operating Case

Note:

Wear Pad Width (250.00) is less than $1.56 \cdot \sqrt{r_m \cdot t}$
 and less than 2a. The wear plate will be ignored.

Minimum Wear Plate Width to be considered in analysis [b1]:

$$\begin{aligned}
 &= \min(b + 1.56 \cdot \sqrt{ R_m \cdot t }, 2a) \\
 &= \min(200 + 1.56 \cdot \sqrt{ 452.5 \cdot 9 }, 2 \cdot 680) \\
 &= 299.5532 \text{ mm.}
 \end{aligned}$$

Input and Calculated Values:

Vessel Mean Radius	Rm	452.50	mm.
Stiffened Vessel Length per 4.15.6	L	4000.00	mm.
Distance from Saddle to Vessel tangent	a	680.00	mm.
Saddle Width	b	200.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Inside Depth of Head	h2	225.50	mm.
Shell Allowable Stress used in Calculation		137.90	N./mm ²
Head Allowable Stress used in Calculation		137.90	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Saddle Force Q, Operating Case		37.65	kN

Horizontal Vessel Analysis Results:	Actual N./mm ²	Allowable N./mm ²
-----	-----	-----
Long. Stress at Top of Midspan	56.14	137.90
Long. Stress at Bottom of Midspan	59.62	137.90
Long. Stress at Top of Saddles	66.25	137.90
Long. Stress at Bottom of Saddles	53.24	137.90
-----	-----	-----
Tangential Shear in Shell	6.64	110.32
Circ. Stress at Horn of Saddle	40.34	172.38
Circ. Compressive Stress in Shell	1.06	137.90
-----	-----	-----

Intermediate Results: Saddle Reaction Q due to Wind or Seismic

Saddle Reaction Force due to Wind Ft [Fwt]:

$$\begin{aligned}
 &= F_{tr} \cdot (F_t / \text{Num of Saddles} + Z \text{ Force Load}) \cdot B / E \\
 &= 3 \cdot (4.832 / 2 + 0) \cdot 1000 / 783.8 \\
 &= 9.2 \text{ kN}
 \end{aligned}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$\begin{aligned}
 &= \max(F_l, \text{Friction Load, Sum of X Forces}) \cdot B / L_s \\
 &= \max(1.373, 0, 0) \cdot 1000 / 2640 \\
 &= 0.5 \text{ kN}
 \end{aligned}$$

Saddle Reaction Force due to Earthquake Fl or Friction [Fsl]:

$$\begin{aligned}
 &= \max(F_l, \text{Friction Force, Sum of X Forces}) \cdot B / L_s \\
 &= \max(8.635, 0, 0) \cdot 1000 / 2640 \\
 &= 3.3 \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

Saddle Reaction Force due to Earthquake Ft [Fst]:
 $= F_{tr} * (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$
 $= 3 * (8.635/2 + 0) * 1000/783.8$
 $= 16.5 \text{ kN}$

Load Combination Results for Q + Wind or Seismic [Q]:
 $= \text{Saddle Load} + \text{Max}(F_{wl}, F_{wt}, F_{sl}, F_{st})$
 $= 21.12 + \text{Max}(0.52, 9.247, 3.271, 16.53)$
 $= 37.6 \text{ kN}$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	38.90 kN
Transverse Shear Load Saddle	4.32 kN
Longitudinal Shear Load Saddle	8.63 kN

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:
 $= -Q * a [1 - (1 - a/L + (R^2 - h^2) / (2a * L)) / (1 + (4h^2) / (3L))]$
 $= -37.65 * 680 [1 - (1 - 680/4000 + (452.5^2 - 225.5^2) / (2 * 680 * 4000)) / (1 + (4 * 225.5) / (3 * 4000))]$
 $= -5165.9 \text{ N-m}$

Moment per Equation 4.15.4 [M2]:
 $= Q * L / 4 [1 + 2(R^2 - h^2) / (L^2)] / (1 + (4h^2) / (3L)) - 4a/L$
 $= 37.65 * 4000 / 4 [1 + 2(452.5^2 - 225.5^2) / (4000^2)] / (1 + (4 * 225.5) / (3 * 4000)) - 4 * 680 / 4000$
 $= 10092.7 \text{ N-m}$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:
 $= P * R_m / (2t) - M_2 / (\pi * R_m^2 * t)$
 $= 23.02 * 452.5 / (2 * 9) - 10093 / (\pi * 452.5^2 * 9)$
 $= 56.14 \text{ N./mm}^2$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:
 $= P * R_m / (2t) + M_2 / (\pi * R_m^2 * t)$
 $= 23.02 * 452.5 / (2 * 9) + 10093 / (\pi * 452.5^2 * 9)$
 $= 59.62 \text{ N./mm}^2$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:
 $= P * R_m / (2t) - M_1 / (K_1 * \pi * R_m^2 * t)$
 $= 23.02 * 452.5 / (2 * 9) - 5166 / (0.107 * \pi * 452.5^2 * 9)$
 $= 66.25 \text{ N./mm}^2$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:
 $= P * R_m / (2t) + M_1 / (K_1 * \pi * R_m^2 * t)$
 $= 23.02 * 452.5 / (2 * 9) + 5166 / (0.192 * \pi * 452.5^2 * 9)$
 $= 53.24 \text{ N./mm}^2$

Maximum Shear Force in the Saddle (4.15.5) [T]:
 $= Q(L - 2a) / (L + (4 * h^2 / 3))$
 $= 37.65 (4000 - 2 * 680) / (4000 + (4 * 225.5 / 3))$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

= 23.1 kN

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

= $K2 * T / (Rm * t)$
 = $1.171 * 23.11 / (452.5 * 9)$
 = 6.64 N./mm²

Decay Length (4.15.22) [x1,x2]:

= $0.78 * \text{sqrt}(Rm * t)$
 = $0.78 * \text{sqrt}(452.5 * 9)$
 = 49.777 mm.

Circumferential Stress in shell, no rings (4.15.23) [sigma6]:

= $-K5 * Q * k / (t * (b + X1 + X2))$
 = $-0.76 * 37.65 * 0.1 / (9 * (200 + 49.78 + 49.78))$
 = -1.06 N./mm²

Circ. Comp. Stress at Horn of Saddle, L>=8Rm (4.15.24) [sigma7]:

= $-Q / (4*t*(b+X1+X2)) - 3*K7*Q / (2*t^2)$
 = $-37.65 / (4*9 * (200 + 49.78 + 49.78)) -$
 $3*0.0529 * 37.65 / (2*9^2)$
 = -40.34 N./mm²

Effective reinforcing plate width (4.15.1) [B1]:

= $\min(b + 1.56 * \text{sqrt}(Rm * t), 2a)$
 = $\min(200 + 1.56 * \text{sqrt}(452.5 * 9), 2 * 680)$
 = 299.55 mm.

Free Un-Restrained Thermal Expansion between the Saddles [Exp]:

= $\text{Alpha} * Ls * (\text{Design Temperature} - \text{Ambient Temperature})$
 = $0.00000233 * 2640 * (135 - 21.11)$
 = 3.707 mm.

Results for Vessel Ribs, Web and Base:

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	12.0000	mm.
Baseplate Width	Bpwid	250.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	2	
Rib Thickness	Ribtk	10.0000	mm.
Web Thickness	Webtk	10.0000	mm.
Web Location	Webloc	Center	

Moment of Inertia of Saddle - Lateral Direction

	B	D	Y	A	AY	Io
Shell	349.	9.	4.	31.	14137.	8.48
Wearplate	250.	10.	14.	25.	35000.	51.1
Web	10.	521.	280.	52.	1456195.	0.525E+05
BasePlate	250.	12.	546.	30.	1638000.	0.894E+05
Totals	139.	3143332.	0.142E+06

Value C1 = Sumof (Ay) / Sumof (A) = 227. mm.
 Value I = Sumof (Io) - C1*Sumof (Ay) = 0.707E+05 cm**4
 Value As = Sumof (A) - Ashell = 107. cm²

$K1 = (1 + \cos(\beta) - 0.5 * \sin(\beta)^2) / (\pi - \beta + \sin(\beta) * \cos(\beta)) = 0.2035$

Fh = K1 * Q = 0.204 * 37.65 = 7.662 kN

Tension Stress, St = (Fh/As) = 0.7155 N./mm²
 Allowed Stress, Sa = 0.6 * Yield Str = 143.9676 N./mm²

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

Saddle Splitting Dimension [d]:

$$= B - R * \sin(\theta) / \theta$$

$$= 1000 - 448 * \sin(1.047) / 1.047$$

$$= 629.507 \text{ mm.}$$

$$\text{Bending Moment, } M = F_h * d = 4825.1587 \text{ N-m}$$

$$\text{Bending Stress, } S_b = (M * C_1 / I) = 1.5493 \text{ N./mm}^2$$

$$\text{Allowed Stress, } S_a = 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2$$

Minimum Thickness of Baseplate per Moss:

$$= (3(Q + \text{Saddle Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

$$= (3(37.65 + 1.252)250 / (4 * 1200 * 160))^{1/2}$$

$$= 6.164 \text{ mm.}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Distance between Ribs [e]:

$$= \text{Web Length} / (\text{Nr ribs} - 1)$$

$$= 814.1 / (2 - 1)$$

$$= 814.064 \text{ mm.}$$

Baseplate Pressure Area [Ap]:

$$= e * \text{Bpwid} / 2$$

$$= 814.1 * 250 / 2$$

$$= 1017.580 \text{ cm}^2$$

Axial Load [P]:

$$= A_p * B_p$$

$$= 1018 * 0.0125$$

$$= 12.769 \text{ kN}$$

Area of the Rib and Web [Ar]:

$$= \text{Rib Area} + \text{Web Area}$$

$$= 19 + 40.7$$

$$= 59.703 \text{ cm}^2$$

Compressive Stress [Sc]:

$$= P / A_r$$

$$= 12.77 / 59.7$$

$$= 2.139 \text{ N./mm}^2$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	Io
Rib+Web	10.0	200.0	...	20.0	...	667.

Bending Moment [Rm]:

$$= F_l / (2 * \text{Bplen}) * e * r_l / 2$$

$$= 8.635 / (2 * 1200) * 814.1 * 753 / 2$$

$$= 1103.175 \text{ N-m}$$

Compressive Allowable, KL/R < Cc (22.53 < 128.3) per AISC E2-1 [Sca]:

$$= (1 - (Kl/r)^2 / (2 * Cc^2)) * F_y / (5/3 + 3 * (Kl/r) / (8 * Cc) - (Kl/r)^3 / (8 * Cc^3))$$

$$= (1 - (22.53)^2 / (2 * 128.3^2)) * 239.9 /$$

$$(5/3 + 3 * (22.53) / (8 * 128.3) - (22.53^3) / (8 * 128.3^3))$$

$$= 136.408 \text{ N./mm}^2$$

AISC Unity Check of Outside Ribs (must be <= 1)

$$= S_c / S_{ca} + (R_m * \text{Distance Side} / I) / S_{ba}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

$$= 2.139/136.4 + (1103 * 100/6666666)/160$$

$$= 0.119$$

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4	
Total Number of Bolts in Tension/Baseplate	Nbt	2	
Bolt Material Specification		SA-193 B7	
Bolt Allowable Stress	Stba	172.38	N./mm ²
Bolt Corrosion Allowance	Bca	0.0	mm.
Distance from Bolts to Edge	Edgedis	50.0	mm.
Nominal Bolt Diameter	Bnd	20.0000	mm.
Thread Series	Series	TEMA Metric	
BasePlate Allowable Stress	S	95.15	N./mm ²
Area Available in a Single Bolt	BltArea	2.1705	cm ²
Saddle Load QO (Weight)	QO	22.4	kN
Saddle Load QL (Wind/Seismic contribution)	QL	3.3	kN
Maximum Transverse Force	Ft	4.3	kN
Maximum Longitudinal Force	F1	8.6	kN
Saddle Bolted to Steel Foundation		No	

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:
 = 0.0 (QO > QL --> No Uplift in Longitudinal direction)

Bolt Area due to Shear Load [Bltarears]:
 = F1 / (Stba * Nbolts)
 = 8.635/(172.4 * 4)
 = 0.1252 cm²

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:
 = B * Ft + Sum of X Moments
 = 1000 * 4.317 + 0
 = 4319.19 N-m

Eccentricity (e):
 = Rmom / QO
 = 4319/22.37
 = 192.98 mm. < Bplen/6 --> No Uplift in Transverse direction

Bolt Area due to Transverse Load [Bltareart]:
 = 0 (No Uplift)

Required Area of a Single Bolt [Bltareart]:
 = max[Bltarearl, Bltarears, Bltareart]
 = max[0, 0.125, 0]
 = 0.1252 cm²

ASME Horizontal Vessel Analysis: Stresses for the Right Saddle (per ASME Sec. VIII Div. 2 based on the Zick method.)

Note:
 Wear Pad Width (250.00) is less than 1.56*sqrt(rm*t)
 and less than 2a. The wear plate will be ignored.

Minimum Wear Plate Width to be considered in analysis [b1]:
 = min(b + 1.56*sqrt(Rm * t), 2a)
 = min(200 + 1.56*sqrt(452.5 * 9), 2 * 680)

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

= 299.5532 mm.

Input and Calculated Values:

Vessel Mean Radius	Rm	452.50	mm.
Stiffened Vessel Length per 4.15.6	L	4000.00	mm.
Distance from Saddle to Vessel tangent	a	680.00	mm.
Saddle Width	b	200.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Inside Depth of Head	h2	225.50	mm.
Shell Allowable Stress used in Calculation		137.90	N./mm ²
Head Allowable Stress used in Calculation		137.90	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Saddle Force Q, Operating Case		28.26	kN

Horizontal Vessel Analysis Results:	Actual N./mm ²	Allowable N./mm ²
-----	-----	-----
Long. Stress at Top of Midspan	56.57	137.90
Long. Stress at Bottom of Midspan	59.19	137.90
Long. Stress at Top of Saddles	64.16	137.90
Long. Stress at Bottom of Saddles	54.40	137.90
-----	-----	-----
Tangential Shear in Shell	4.99	110.32
Circ. Stress at Horn of Saddle	30.28	172.38
Circ. Compressive Stress in Shell	0.80	137.90
-----	-----	-----

Intermediate Results: Saddle Reaction Q due to Wind or Seismic

Saddle Reaction Force due to Wind Ft [Fwt]:

$$= F_{tr} * (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$$

$$= 3 * (4.832/2 + 0) * 1000/783.8$$

$$= 9.2 \text{ kN}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$= \max(F_l, \text{Friction Load, Sum of X Forces}) * B / L_s$$

$$= \max(1.373, 5.193, 0) * 1000/2640$$

$$= 2.0 \text{ kN}$$

Saddle Reaction Force due to Earthquake Fl or Friction [Fsl]:

$$= \max(F_l, \text{Friction Force, Sum of X Forces}) * B / L_s$$

$$= \max(8.635, 5.193, 0) * 1000/2640$$

$$= 3.3 \text{ kN}$$

Saddle Reaction Force due to Earthquake Ft [Fst]:

$$= F_{tr} * (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$$

$$= 3 * (8.635/2 + 0) * 1000/783.8$$

$$= 16.5 \text{ kN}$$

Load Combination Results for Q + Wind or Seismic [Q]:

$$= \text{Saddle Load} + \max(F_{wl}, F_{wt}, F_{sl}, F_{st})$$

$$= 11.73 + \max(1.967, 9.247, 3.271, 16.53)$$

$$= 28.3 \text{ kN}$$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	29.51	kN
---	-------	----

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

Transverse Shear Load Saddle 4.32 kN
 Longitudinal Shear Load Saddle 8.63 kN

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

The Computed K values from Table 4.15.1:

K1 = 0.1066 K2 = 1.1707 K3 = 0.8799 K4 = 0.4011
 K5 = 0.7603 K6 = 0.0529 K7 = 0.0529 K8 = 0.3405
 K9 = 0.2711 K10 = 0.0581 K1* = 0.1923

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:

$$= -Q \cdot a \left[1 - \left(1 - \frac{a}{L} + \frac{R^2 - h^2}{2a \cdot L} \right) / \left(1 + \frac{4h^2}{3L} \right) \right]$$

$$= -28.26 \cdot 680 \left[1 - \left(1 - \frac{680}{4000} + \frac{452.5^2 - 225.5^2}{2 \cdot 680 \cdot 4000} \right) / \left(1 + \frac{4 \cdot 225.5}{3 \cdot 4000} \right) \right]$$

$$= -3877.5 \text{ N-m}$$

Moment per Equation 4.15.4 [M2]:

$$= Q \cdot L / 4 \left(1 + 2 \frac{R^2 - h^2}{L^2} \right) / \left(1 + \frac{4h^2}{3L} \right) - 4a/L$$

$$= 28.26 \cdot 4000 / 4 \left(1 + 2 \frac{452.5^2 - 225.5^2}{4000^2} \right) / \left(1 + \frac{4 \cdot 225.5}{3 \cdot 4000} \right) - 4 \cdot 680 / 4000$$

$$= 7575.5 \text{ N-m}$$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:

$$= P \cdot R_m / (2t) - M2 / (\pi \cdot R_m^2 \cdot t)$$

$$= 23.02 \cdot 452.5 / (2 \cdot 9) - 7575 / (\pi \cdot 452.5^2 \cdot 9)$$

$$= 56.57 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$= P \cdot R_m / (2t) + M2 / (\pi \cdot R_m^2 \cdot t)$$

$$= 23.02 \cdot 452.5 / (2 \cdot 9) + 7575 / (\pi \cdot 452.5^2 \cdot 9)$$

$$= 59.19 \text{ N./mm}^2$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$= P \cdot R_m / (2t) - M1 / (K1 \cdot \pi \cdot R_m^2 \cdot t)$$

$$= 23.02 \cdot 452.5 / (2 \cdot 9) - 3877 / (0.107 \cdot \pi \cdot 452.5^2 \cdot 9)$$

$$= 64.16 \text{ N./mm}^2$$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:

$$= P \cdot R_m / (2t) + M1 / (K1 \cdot \pi \cdot R_m^2 \cdot t)$$

$$= 23.02 \cdot 452.5 / (2 \cdot 9) + 3877 / (0.192 \cdot \pi \cdot 452.5^2 \cdot 9)$$

$$= 54.40 \text{ N./mm}^2$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$= Q(L - 2a) / (L + (4 \cdot h^2 / 3))$$

$$= 28.26 \cdot (4000 - 2 \cdot 680) / (4000 + (4 \cdot 225.5 / 3))$$

$$= 17.3 \text{ kN}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

$$= K2 \cdot T / (R_m \cdot t)$$

$$= 1.171 \cdot 17.35 / (452.5 \cdot 9)$$

$$= 4.99 \text{ N./mm}^2$$

Decay Length (4.15.22) [x1,x2]:

$$= 0.78 \cdot \sqrt{R_m \cdot t}$$

$$= 0.78 \cdot \sqrt{452.5 \cdot 9}$$

$$= 49.777 \text{ mm.}$$

Circumferential Stress in shell, no rings (4.15.23) [sigma6]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

$$= -K5 * Q * k / (t * (b + X1 + X2))$$

$$= -0.76 * 28.26 * 0.1 / (9 * (200 + 49.78 + 49.78))$$

$$= -0.80 \text{ N./mm}^2$$

Circ. Comp. Stress at Horn of Saddle, $L \geq 8R_m$ (4.15.24) [σ_7]:

$$= -Q / (4 * t * (b + X1 + X2)) - 3 * K7 * Q / (2 * t^2)$$

$$= -28.26 / (4 * 9 * (200 + 49.78 + 49.78)) -$$

$$3 * 0.0529 * 28.26 / (2 * 9^2)$$

$$= -30.28 \text{ N./mm}^2$$

Effective reinforcing plate width (4.15.1) [B1]:

$$= \min(b + 1.56 * \sqrt{ R_m * t }, 2a)$$

$$= \min(200 + 1.56 * \sqrt{ 452.5 * 9 }, 2 * 680)$$

$$= 299.55 \text{ mm.}$$

Results for Vessel Ribs, Web and Base

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	12.0000	mm.
Baseplate Width	Bpwid	250.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	2	
Rib Thickness	Ribtk	10.0000	mm.
Web Thickness	Webtk	10.0000	mm.
Web Location	Webloc	Center	

Moment of Inertia of Saddle - Lateral Direction

	B	D	Y	A	AY	Io
Shell	349.	9.	4.	31.	14137.	8.48
Wearplate	250.	10.	14.	25.	35000.	51.1
Web	10.	521.	280.	52.	1456195.	0.525E+05
BasePlate	250.	12.	546.	30.	1638000.	0.894E+05
Totals	139.	3143332.	0.142E+06

Value C1 = Sumof (Ay) / Sumof (A) = 227. mm.

Value I = Sumof (Io) - C1 * Sumof (Ay) = 0.707E+05 cm**4

Value As = Sumof (A) - Ashell = 107. cm²

$$K1 = (1 + \cos(\beta) - 0.5 * \sin(\beta)^2) / (\pi - \beta + \sin(\beta) * \cos(\beta)) = 0.2035$$

$$F_h = K1 * Q = 0.204 * 28.26 = 5.751 \text{ kN}$$

Tension Stress, $St = (F_h / A_s) = 0.5370 \text{ N./mm}^2$

Allowed Stress, $Sa = 0.6 * \text{Yield Str} = 143.9676 \text{ N./mm}^2$

Saddle Splitting Dimension [d]:

$$= B - R * \sin(\theta) / \theta$$

$$= 1000 - 448 * \sin(1.047) / 1.047$$

$$= 629.507 \text{ mm.}$$

Bending Moment, $M = F_h * d = 3621.7358 \text{ N-m}$

Bending Stress, $S_b = (M * C1 / I) = 1.1629 \text{ N./mm}^2$

Allowed Stress, $Sa = 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2$

Minimum Thickness of Baseplate per Moss:

$$= (3 * (Q + \text{Saddle Wt}) * \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

$$= (3 * (28.26 + 1.252) * 250 / (4 * 1200 * 160))^{1/2}$$

$$= 5.369 \text{ mm.}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

Distance between Ribs [e]:
 = Web Length / (Nribs - 1)
 = 814.1 / (2 - 1)
 = 814.064 mm.

Baseplate Pressure Area [Ap]:
 = e * Bpwid / 2
 = 814.1 * 250 / 2
 = 1017.580 cm²

Axial Load [P]:
 = Ap * Bp
 = 1018 * 0.00942
 = 9.585 kN

Area of the Rib and Web [Ar]:
 = Rib Area + Web Area
 = 19 + 40.7
 = 59.703 cm²

Compressive Stress [Sc]:
 = P / Ar
 = 9.585 / 59.7
 = 1.606 N./mm²

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	Io
Rib+Web	10.0	200.0	...	20.0	...	667.

Bending Moment [Rm]:
 = Fl / (2 * Bplen) * e * rl / 2
 = 8.635 / (2 * 1200) * 814.1 * 753 / 2
 = 1103.175 N-m

Compressive Allowable, KL/R < Cc (22.53 < 128.3) per AISC E2-1 [Sca]:
 = (1 - (Kl r)² / (2 * Cc²)) * Fy / (5/3 + 3 * (Kl r) / (8 * Cc) - (Kl r³) / (8 * Cc³))
 = (1 - (22.53)² / (2 * 128.3²)) * 239.9 /
 (5/3 + 3 * (22.53) / (8 * 128.3) - (22.53³) / (8 * 128.3³))
 = 136.408 N./mm²

AISC Unity Check of Outside Ribs (must be <= 1)
 = Sc / Sca + (Rm * Distance Side / I) / Sba
 = 1.606 / 136.4 + (1103 * 100 / 6666666) / 160
 = 0.115

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4	
Total Number of Bolts in Tension/Baseplate	Nbt	2	
Bolt Material Specification	SA-193 B7		
Bolt Allowable Stress	Stba	172.38	N./mm ²
Bolt Corrosion Allowance	Bca	0.0	mm.
Distance from Bolts to Edge	Edgedis	50.0	mm.
Nominal Bolt Diameter	Bnd	20.0000	mm.
Thread Series	Series	TEMA Metric	
BasePlate Allowable Stress	S	95.15	N./mm ²
Area Available in a Single Bolt	BltArea	2.1705	cm ²
Saddle Load QO (Weight)	QO	13.0	kN
Saddle Load QL (Wind/Seismic contribution)	QL	3.3	kN

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

Maximum Transverse Force	Ft	4.3	kN
Maximum Longitudinal Force	F1	8.6	kN
Saddle Bolted to Steel Foundation		No	

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarear1]:

$$= 0.0 \text{ (} QO > QL \text{ --> No Uplift in Longitudinal direction)}$$

Bolt Area due to Shear Load [Bltarears]:

$$= F1 / (Stba * Nbolts)$$

$$= 8.635 / (172.4 * 4)$$

$$= 0.1252 \text{ cm}^2$$

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

$$= B * Ft + \text{Sum of X Moments}$$

$$= 1000 * 4.317 + 0$$

$$= 4319.19 \text{ N-m}$$

Eccentricity (e):

$$= Rmom / QO$$

$$= 4319 / 12.98$$

$$= 332.54 \text{ mm.} > Bplen / 6 \text{ --> Uplift in Transverse direction}$$

$$f = Bplen / 2 - Edgedis$$

$$= 1200 / 2 - 50$$

$$= 550.00 \text{ mm.}$$

Modular Ratio Of Steel/Concrete (n1):

$$= ES / EC$$

$$= 203402 / 21526$$

$$= 9.45$$

$$K1 = 3 (e - 0.5 * Bplen)$$

$$= 3 (332.5 - 0.5 * 1200)$$

$$= -802.37 \text{ mm.}$$

$$K2 = 6 * n1 * At / Bpwid * (f + e)$$

$$= 6 * 9.449 * 4.341 / 250 * (550 + 332.5)$$

$$= 86881.06 \text{ mm.}^2$$

$$K3 = -K2 * (0.5 * Bplen + f)$$

$$= -86881 * (0.5 * 1200 + 550)$$

$$= -99913231.95 \text{ mm.}^3$$

Iteratively Solving for the Effective Bearing Length:

$$Y^3 + K1 * Y^2 + K2 * Y + K3 = 0$$

$$Y^3 + -802.4 * Y^2 + 86881 * Y + -99913232 = 0$$

$$Y = 840.45 \text{ mm.}$$

$$\text{Num} = (Bplen / 2 - Y / 3 - e)$$

$$= (1200 / 2 - 840.4 / 3 - 332.5)$$

$$= -12.69$$

$$\text{Denom} = (Bplen / 2 - Y / 3 + f)$$

$$= (1200 / 2 - 840.4 / 3 + 550)$$

$$= 869.85$$

Total Bolt Tension Force [Tforce]:

$$= - QO * \text{Num} / \text{Denom}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Ope.): Step: 10 11:52pm Dec 24,2021

$$= -12.98 * -12.69 / 869.9$$

$$= 0.19 \text{ kN}$$

Bolt Area Required due to Transverse Load [Bltareart]:

$$= Tforce / (Stba * Nbt)$$

$$= 0.189 / (172.4 * 2)$$

$$= 0.0055 \text{ cm}^2$$

Required Area of a Single Bolt [Bltarear]:

$$= \max[\text{Bltarearl}, \text{Bltarears}, \text{Bltareart}]$$

$$= \max[0, 0.125, 0.0055]$$

$$= 0.1252 \text{ cm}^2$$

Baseplate Thickness Calculation per D. Moss:

Bearing Pressure (fc)

$$= 2(QO + Tforce) / (Y * Bpwid)$$

$$= 2(12.98 + 0.189) / (840.4 * 250)$$

$$= 1.25 \text{ bar}$$

Distance from Baseplate Edge to the Web [ADIST]:

$$= (Bplen - Weblngth) / 2$$

$$= (1200 - 1149) / 2$$

$$= 25.4000 \text{ mm.}$$

Overturning Moment due To Bolt Tension [Mt]:

$$= Tforce * Adist$$

$$= 0.189 * 25.4$$

$$= 4.81 \text{ N-m}$$

Equivalent Bearing Pressure (f1):

$$= fc * (Y - Adist) / Y$$

$$= 1.254 * (840.4 - 25.4) / 840.4$$

$$= 1.22 \text{ bar}$$

Overturning Moment due to Bearing Pressure [Mc]:

$$= (Adist^2 * Bpwid / 6) * (f1 + 2 * fc)$$

$$= (25.4^2 * 250 / 6) * (1.216 + 2 * 1.254)$$

$$= 10.01 \text{ N-m}$$

Baseplate Required Thickness [Treq]:

$$= (6 * \max(Mt, Mc) / (Bpwid * Sba))^{1/2}$$

$$= (6 * \max(4.814, 10.01) / (250 * 142.7))^{1/2}$$

$$= 1.2974 \text{ mm.}$$

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

ASME Horizontal Vessel Analysis: Stresses for the Left Saddle
 (per ASME Sec. VIII Div. 2 based on the Zick method.)

Horizontal Vessel Stress Calculations : Test Case

Note:

Wear Pad Width (250.00) is less than $1.56 \cdot \sqrt{r_m \cdot t}$
 and less than 2a. The wear plate will be ignored.

Minimum Wear Plate Width to be considered in analysis [b1]:

$$\begin{aligned}
 &= \min(b + 1.56 \cdot \sqrt{ R_m \cdot t }, 2a) \\
 &= \min(200 + 1.56 \cdot \sqrt{ 452.5 \cdot 9 }, 2 \cdot 680) \\
 &= 299.5532 \text{ mm.}
 \end{aligned}$$

Input and Calculated Values:

Vessel Mean Radius	Rm	452.50	mm.
Stiffened Vessel Length per 4.15.6	L	4000.00	mm.
Distance from Saddle to Vessel tangent	a	680.00	mm.
Saddle Width	b	200.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Inside Depth of Head	h2	225.50	mm.
Shell Allowable Stress used in Calculation		235.81	N./mm ²
Head Allowable Stress used in Calculation		235.81	N./mm ²
Circumferential Efficiency in Plane of Saddle		1.00	
Circumferential Efficiency at Mid-Span		1.00	
Saddle Force Q, Test Case, no Ext. Forces		32.89	kN

Horizontal Vessel Analysis Results:	Actual N./mm ²	Allowable N./mm ²
-----	-----	-----
Long. Stress at Top of Midspan	73.77	235.81
Long. Stress at Bottom of Midspan	76.81	235.81
Long. Stress at Top of Saddles	82.60	235.81
Long. Stress at Bottom of Saddles	71.24	235.81
-----	-----	-----
Tangential Shear in Shell	5.80	188.65
Circ. Stress at Horn of Saddle	35.24	353.71
Circ. Compressive Stress in Shell	0.93	235.81
-----	-----	-----

Intermediate Results: Saddle Reaction Q due to Wind or Seismic

Saddle Reaction Force due to Wind Ft [Fwt]:

$$\begin{aligned}
 &= F_{tr} \cdot (F_t / \text{Num of Saddles} + Z \text{ Force Load}) \cdot B / E \\
 &= 3 \cdot (1.594 / 2 + 0) \cdot 1000 / 783.8 \\
 &= 3.1 \text{ kN}
 \end{aligned}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$\begin{aligned}
 &= \max(F_l, \text{Friction Load, Sum of X Forces}) \cdot B / L_s \\
 &= \max(0.453, 0, 0) \cdot 1000 / 2640 \\
 &= 0.2 \text{ kN}
 \end{aligned}$$

Load Combination Results for Q + Wind or Seismic [Q]:

$$\begin{aligned}
 &= \text{Saddle Load} + \max(F_{wl}, F_{wt}, F_{sl}, F_{st}) \\
 &= 29.84 + \max(0.172, 3.052, 0, 0) \\
 &= 32.9 \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	34.14	kN
Transverse Shear Load Saddle	0.80	kN
Longitudinal Shear Load Saddle	0.45	kN

Hydrostatic Test Pressure at center of Vessel: 29.944 bar

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:

$$\begin{aligned}
 &= -Q \cdot a \left[1 - \left(1 - \frac{a}{L} + \frac{R^2 - h^2}{2a \cdot L} \right) / \left(1 + \frac{4h^2}{3L} \right) \right] \\
 &= -32.89 \cdot 680 \left[1 - \left(1 - \frac{680}{4000} + \frac{452.5^2 - 225.5^2}{2 \cdot 680 \cdot 4000} \right) / \left(1 + \frac{4 \cdot 225.5}{3 \cdot 4000} \right) \right] \\
 &= -4512.7 \text{ N-m}
 \end{aligned}$$

Moment per Equation 4.15.4 [M2]:

$$\begin{aligned}
 &= Q \cdot L / 4 \left(1 + 2 \frac{R^2 - h^2}{L^2} \right) / \left(1 + \frac{4h^2}{3L} \right) - 4a/L \\
 &= 32.89 \cdot 4000 / 4 \left(1 + 2 \frac{452.5^2 - 225.5^2}{4000^2} \right) / \left(1 + \frac{4 \cdot 225.5}{3 \cdot 4000} \right) - 4 \cdot 680 / 4000 \\
 &= 8816.6 \text{ N-m}
 \end{aligned}$$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) - M2 / (\pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) - 8817 / (\pi \cdot 452.5^2 \cdot 9) \\
 &= 73.77 \text{ N./mm}^2
 \end{aligned}$$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) + M2 / (\pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) + 8817 / (\pi \cdot 452.5^2 \cdot 9) \\
 &= 76.81 \text{ N./mm}^2
 \end{aligned}$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) - M1 / (K1 \cdot \pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) - 4513 / (0.107 \cdot \pi \cdot 452.5^2 \cdot 9) \\
 &= 82.60 \text{ N./mm}^2
 \end{aligned}$$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) + M1 / (K1 \cdot \pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) + 4513 / (0.192 \cdot \pi \cdot 452.5^2 \cdot 9) \\
 &= 71.24 \text{ N./mm}^2
 \end{aligned}$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$\begin{aligned}
 &= Q(L - 2a) / (L + (4 \cdot h^2 / 3)) \\
 &= 32.89 \cdot (4000 - 2 \cdot 680) / (4000 + (4 \cdot 225.5 / 3)) \\
 &= 20.2 \text{ kN}
 \end{aligned}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

$$\begin{aligned}
 &= K2 \cdot T / (R_m \cdot t) \\
 &= 1.171 \cdot 20.19 / (452.5 \cdot 9) \\
 &= 5.80 \text{ N./mm}^2
 \end{aligned}$$

Decay Length (4.15.22) [x1,x2]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

$$= 0.78 * \text{sqrt}(Rm * t)$$

$$= 0.78 * \text{sqrt}(452.5 * 9)$$

$$= 49.777 \text{ mm.}$$

Circumferential Stress in shell, no rings (4.15.23) [σ_6]:

$$= -K5 * Q * k / (t * (b + X1 + X2))$$

$$= -0.76 * 32.89 * 0.1 / (9 * (200 + 49.78 + 49.78))$$

$$= -0.93 \text{ N./mm}^2$$

Circ. Comp. Stress at Horn of Saddle, $L \geq 8Rm$ (4.15.24) [σ_7]:

$$= -Q / (4 * t * (b + X1 + X2)) - 3 * K7 * Q / (2 * t^2)$$

$$= -32.89 / (4 * 9 * (200 + 49.78 + 49.78)) - 3 * 0.0529 * 32.89 / (2 * 9^2)$$

$$= -35.24 \text{ N./mm}^2$$

Effective reinforcing plate width (4.15.1) [B1]:

$$= \min(b + 1.56 * \text{sqrt}(Rm * t), 2a)$$

$$= \min(200 + 1.56 * \text{sqrt}(452.5 * 9), 2 * 680)$$

$$= 299.55 \text{ mm.}$$

Results for Vessel Ribs, Web and Base:

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	12.0000	mm.
Baseplate Width	Bpwid	250.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	2	
Rib Thickness	Ribtk	10.0000	mm.
Web Thickness	Webtk	10.0000	mm.
Web Location	Webloc	Center	

Moment of Inertia of Saddle - Lateral Direction

	B	D	Y	A	AY	Io
Shell	349.	9.	4.	31.	14137.	8.48
Wearplate	250.	10.	14.	25.	35000.	51.1
Web	10.	521.	280.	52.	1456195.	0.525E+05
BasePlate	250.	12.	546.	30.	1638000.	0.894E+05
Totals	139.	3143332.	0.142E+06

$$\text{Value } C1 = \text{Sumof}(AY) / \text{Sumof}(A) = 227. \text{ mm.}$$

$$\text{Value } I = \text{Sumof}(Io) - C1 * \text{Sumof}(AY) = 0.707E+05 \text{ cm}^{*4}$$

$$\text{Value } As = \text{Sumof}(A) - A_{\text{shell}} = 107. \text{ cm}^2$$

$$K1 = (1 + \cos(\text{beta}) - 0.5 * \sin(\text{beta})^2) / (\pi - \text{beta} + \sin(\text{beta}) * \cos(\text{beta})) = 0.2035$$

$$Fh = K1 * Q = 0.204 * 32.89 = 6.693 \text{ kN}$$

$$\text{Tension Stress, } St = (Fh / As) = 0.6250 \text{ N./mm}^2$$

$$\text{Allowed Stress, } Sa = 0.6 * \text{Yield Str} = 143.9676 \text{ N./mm}^2$$

Saddle Splitting Dimension [d]:

$$= B - R * \sin(\text{theta}) / \text{theta}$$

$$= 1000 - 448 * \sin(1.047) / 1.047$$

$$= 629.507 \text{ mm.}$$

$$\text{Bending Moment, } M = Fh * d = 4215.0762 \text{ N-m}$$

$$\text{Bending Stress, } Sb = (M * C1 / I) = 1.3534 \text{ N./mm}^2$$

$$\text{Allowed Stress, } Sa = 2/3 * \text{Yield Str} = 159.9640 \text{ N./mm}^2$$

Minimum Thickness of Baseplate per Moss:

$$= (3 (Q + \text{Saddle_Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

$$= (3(32.89 + 1.252)250/(4 * 1200 * 160))^{1/2}$$

$$= 5.775 \text{ mm.}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Distance between Ribs [e]:

$$= \text{Web Length} / (\text{Nr ribs} - 1)$$

$$= 814.1 / (2 - 1)$$

$$= 814.064 \text{ mm.}$$

Baseplate Pressure Area [Ap]:

$$= e * \text{Bpwid} / 2$$

$$= 814.1 * 250 / 2$$

$$= 1017.580 \text{ cm}^2$$

Axial Load [P]:

$$= \text{Ap} * \text{Bp}$$

$$= 1018 * 0.011$$

$$= 11.155 \text{ kN}$$

Area of the Rib and Web [Ar]:

$$= \text{Rib Area} + \text{Web Area}$$

$$= 19 + 40.7$$

$$= 59.703 \text{ cm}^2$$

Compressive Stress [Sc]:

$$= P / \text{Ar}$$

$$= 11.15 / 59.7$$

$$= 1.869 \text{ N./mm}^2$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	Io
-----	-----	-----	-----	-----	-----	-----
Rib+Web	10.0	200.0	...	20.0	...	667.

Bending Moment [Rm]:

$$= \text{Fl} / (2 * \text{Bplen}) * e * \text{rl} / 2$$

$$= 0.453 / (2 * 1200) * 814.1 * 753 / 2$$

$$= 57.904 \text{ N-m}$$

Compressive Allowable, $\text{KL/R} < \text{Cc} (22.53 < 128.3)$ per AISC E2-1 [Sca]:

$$= (1 - (\text{Kl/r})^2 / (2 * \text{Cc}^2)) * \text{Fy} / (5/3 + 3 * (\text{Kl/r}) / (8 * \text{Cc}) - (\text{Kl/r}^3) / (8 * \text{Cc}^3))$$

$$= (1 - (22.53)^2 / (2 * 128.3^2)) * 239.9 /$$

$$(5/3 + 3 * (22.53) / (8 * 128.3) - (22.53^3) / (8 * 128.3^3))$$

$$= 136.408 \text{ N./mm}^2$$

AISC Unity Check of Outside Ribs (must be ≤ 1)

$$= \text{Sc} / \text{Sca} + (\text{Rm} * \text{Distance Side/I}) / \text{Sba}$$

$$= 1.869 / 136.4 + (57.9 * 100 / 6666666) / 160$$

$$= 0.019$$

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4	
Total Number of Bolts in Tension/Baseplate	Nbt	2	
Bolt Material Specification		SA-193 B7	
Bolt Allowable Stress	Stba	172.38	N./mm ²
Bolt Corrosion Allowance	Bca	0.0	mm.
Distance from Bolts to Edge	Edgedis	50.0	mm.
Nominal Bolt Diameter	Bnd	20.0000	mm.
Thread Series	Series	TEMA Metric	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

BasePlate Allowable Stress	S	95.15	N./mm ²
Area Available in a Single Bolt	BltArea	2.1705	cm ²
Saddle Load QO (Weight)	QO	31.1	kN
Saddle Load QL (Wind/Seismic contribution)	QL	0.2	kN
Maximum Transverse Force	Ft	0.8	kN
Maximum Longitudinal Force	Fl	0.5	kN
Saddle Bolted to Steel Foundation		No	

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:

= 0.0 (QO > QL --> No Uplift in Longitudinal direction)

Bolt Area due to Shear Load [Bltarears]:

= Fl / (Stba * Nbolts)
 = 0.453/(172.4 * 4)
 = 0.0066 cm²

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

= B * Ft + Sum of X Moments
 = 1000 * 0.797 + 0
 = 797.54 N-m

Eccentricity (e):

= Rmom / QO
 = 797.5/31.09
 = 25.64 mm. < Bplen/6 --> No Uplift in Transverse direction

Bolt Area due to Transverse Load [Bltareart]:

= 0 (No Uplift)

Required Area of a Single Bolt [Bltarear]:

= max[Bltarearl, Bltarears, Bltareart]
 = max[0, 0.00657, 0]
 = 0.0066 cm²

ASME Horizontal Vessel Analysis: Stresses for the Right Saddle

(per ASME Sec. VIII Div. 2 based on the Zick method.)

Note:

Wear Pad Width (250.00) is less than $1.56*\sqrt{rm*t}$
 and less than 2a. The wear plate will be ignored.

Minimum Wear Plate Width to be considered in analysis [b1]:

= min(b + 1.56*sqrt(Rm * t), 2a)
 = min(200 + 1.56*sqrt(452.5 * 9), 2 * 680)
 = 299.5532 mm.

Input and Calculated Values:

Vessel Mean Radius	Rm	452.50	mm.
Stiffened Vessel Length per 4.15.6	L	4000.00	mm.
Distance from Saddle to Vessel tangent	a	680.00	mm.
Saddle Width	b	200.00	mm.
Saddle Bearing Angle	theta	120.00	degrees
Inside Depth of Head	h2	225.50	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

Shell Allowable Stress used in Calculation	235.81	N./mm ²
Head Allowable Stress used in Calculation	235.81	N./mm ²
Circumferential Efficiency in Plane of Saddle	1.00	
Circumferential Efficiency at Mid-Span	1.00	

Saddle Force Q, Test Case, no Ext. Forces 23.50 kN

Horizontal Vessel Analysis Results:	Actual N./mm ²	Allowable N./mm ²

Long. Stress at Top of Midspan	74.20	235.81
Long. Stress at Bottom of Midspan	76.38	235.81
Long. Stress at Top of Saddles	80.51	235.81
Long. Stress at Bottom of Saddles	72.39	235.81

Tangential Shear in Shell	4.15	188.65
Circ. Stress at Horn of Saddle	25.18	353.71
Circ. Compressive Stress in Shell	0.66	235.81

Intermediate Results: Saddle Reaction Q due to Wind or Seismic

Saddle Reaction Force due to Wind Ft [Fwt]:

$$= F_{tr} * (F_t / \text{Num of Saddles} + Z \text{ Force Load}) * B / E$$

$$= 3 * (1.594/2 + 0) * 1000/783.8$$

$$= 3.1 \text{ kN}$$

Saddle Reaction Force due to Wind Fl or Friction [Fwl]:

$$= \max(F_l, \text{Friction Load, Sum of X Forces}) * B / L_s$$

$$= \max(0.453, 0, 0) * 1000/2640$$

$$= 0.2 \text{ kN}$$

Load Combination Results for Q + Wind or Seismic [Q]:

$$= \text{Saddle Load} + \max(F_{wl}, F_{wt}, F_{sl}, F_{st})$$

$$= 20.45 + \max(0.172, 3.052, 0, 0)$$

$$= 23.5 \text{ kN}$$

Summary of Loads at the base of this Saddle:

Vertical Load (including saddle weight)	24.75	kN
Transverse Shear Load Saddle	0.80	kN
Longitudinal Shear Load Saddle	0.45	kN

Hydrostatic Test Pressure at center of Vessel: 29.944 bar

Formulas and Substitutions for Horizontal Vessel Analysis:

Note: Wear Plate is Welded to the Shell, $k = 0.1$

The Computed K values from Table 4.15.1:

K1 = 0.1066	K2 = 1.1707	K3 = 0.8799	K4 = 0.4011
K5 = 0.7603	K6 = 0.0529	K7 = 0.0529	K8 = 0.3405
K9 = 0.2711	K10 = 0.0581	K1* = 0.1923	

Note: Dimension a is greater than or equal to $R_m / 2$.

Moment per Equation 4.15.3 [M1]:

$$= -Q * a [1 - (1 - a/L + (R^2 - h^2) / (2a * L)) / (1 + (4h^2) / (3L))]$$

$$= -23.5 * 680 [1 - (1 - 680/4000 + (452.5^2 - 225.5^2) / (2 * 680 * 4000)) / (1 + (4 * 225.5) / (3 * 4000))]$$

$$= -3224.3 \text{ N-m}$$

Moment per Equation 4.15.4 [M2]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

$$\begin{aligned}
 &= Q \cdot L / 4 (1 + 2(R^2 - h^2) / (L^2)) / (1 + (4h^2) / (3L)) - 4a / L \\
 &= 23.5 \cdot 4000 / 4 (1 + 2(452.5^2 - 225.5^2) / (4000^2)) / (1 + (4 \cdot 225.5) / (3 \cdot 4000)) - 4 \cdot 680 / 4000 \\
 &= 6299.4 \text{ N-m}
 \end{aligned}$$

Longitudinal Stress at Top of Shell (4.15.6) [Sigma1]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) - M_2 / (\pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) - 6299 / (\pi \cdot 452.5^2 \cdot 9) \\
 &= 74.20 \text{ N./mm}^2
 \end{aligned}$$

Longitudinal Stress at Bottom of Shell (4.15.7) [Sigma2]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) + M_2 / (\pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) + 6299 / (\pi \cdot 452.5^2 \cdot 9) \\
 &= 76.38 \text{ N./mm}^2
 \end{aligned}$$

Longitudinal Stress at Top of Shell at Support (4.15.10) [Sigma*3]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) - M_1 / (K_1 \cdot \pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) - 3224 / (0.107 \cdot \pi \cdot 452.5^2 \cdot 9) \\
 &= 80.51 \text{ N./mm}^2
 \end{aligned}$$

Longitudinal Stress at Bottom of Shell at Support (4.15.11) [Sigma*4]:

$$\begin{aligned}
 &= P \cdot R_m / (2t) + M_1 / (K_1 \cdot \pi \cdot R_m^2 \cdot t) \\
 &= 29.94 \cdot 452.5 / (2 \cdot 9) + 3224 / (0.192 \cdot \pi \cdot 452.5^2 \cdot 9) \\
 &= 72.39 \text{ N./mm}^2
 \end{aligned}$$

Maximum Shear Force in the Saddle (4.15.5) [T]:

$$\begin{aligned}
 &= Q(L - 2a) / (L + (4 \cdot h^2 / 3)) \\
 &= 23.5 (4000 - 2 \cdot 680) / (4000 + (4 \cdot 225.5 / 3)) \\
 &= 14.4 \text{ kN}
 \end{aligned}$$

Shear Stress in the shell no rings, not stiffened (4.15.14) [tau2]:

$$\begin{aligned}
 &= K_2 \cdot T / (R_m \cdot t) \\
 &= 1.171 \cdot 14.42 / (452.5 \cdot 9) \\
 &= 4.15 \text{ N./mm}^2
 \end{aligned}$$

Decay Length (4.15.22) [x1,x2]:

$$\begin{aligned}
 &= 0.78 \cdot \sqrt{R_m \cdot t} \\
 &= 0.78 \cdot \sqrt{452.5 \cdot 9} \\
 &= 49.777 \text{ mm.}
 \end{aligned}$$

Circumferential Stress in shell, no rings (4.15.23) [sigma6]:

$$\begin{aligned}
 &= -K_5 \cdot Q \cdot k / (t \cdot (b + X_1 + X_2)) \\
 &= -0.76 \cdot 23.5 \cdot 0.1 / (9 \cdot (200 + 49.78 + 49.78)) \\
 &= -0.66 \text{ N./mm}^2
 \end{aligned}$$

Circ. Comp. Stress at Horn of Saddle, L >= 8Rm (4.15.24) [sigma7]:

$$\begin{aligned}
 &= -Q / (4 \cdot t \cdot (b + X_1 + X_2)) - 3 \cdot K_7 \cdot Q / (2 \cdot t^2) \\
 &= -23.5 / (4 \cdot 9 \cdot (200 + 49.78 + 49.78)) - 3 \cdot 0.0529 \cdot 23.5 / (2 \cdot 9^2) \\
 &= -25.18 \text{ N./mm}^2
 \end{aligned}$$

Effective reinforcing plate width (4.15.1) [B1]:

$$\begin{aligned}
 &= \min(b + 1.56 \cdot \sqrt{R_m \cdot t}, 2a) \\
 &= \min(200 + 1.56 \cdot \sqrt{452.5 \cdot 9}, 2 \cdot 680) \\
 &= 299.55 \text{ mm.}
 \end{aligned}$$

Results for Vessel Ribs, Web and Base

Baseplate Length	Bplen	1200.0000	mm.
Baseplate Thickness	Bpthk	12.0000	mm.
Baseplate Width	Bpwid	250.0000	mm.
Number of Ribs (inc. outside ribs)	Nribs	2	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

Rib Thickness	Ribtk	10.0000	mm.
Web Thickness	Webtk	10.0000	mm.
Web Location	Webloc	Center	

Moment of Inertia of Saddle - Lateral Direction

	B	D	Y	A	AY	Io
Shell	349.	9.	4.	31.	14137.	8.48
Wearplate	250.	10.	14.	25.	35000.	51.1
Web	10.	521.	280.	52.	1456195.	0.525E+05
BasePlate	250.	12.	546.	30.	1638000.	0.894E+05
Totals	139.	3143332.	0.142E+06

Value C1 = Sumof (Ay) / Sumof (A) = 227. mm.
 Value I = Sumof (Io) - C1*Sumof (Ay) = 0.707E+05 cm**4
 Value As = Sumof (A) - Ashell = 107. cm²

$$K1 = (1 + \cos(\beta) - 0.5 * \sin(\beta)^2) / (\pi - \beta + \sin(\beta) * \cos(\beta)) = 0.2035$$

$$Fh = K1 * Q = 0.204 * 23.5 = 4.782 \text{ kN}$$

Tension Stress, St = (Fh/As) = 0.4466 N./mm²
 Allowed Stress, Sa = 0.6 * Yield Str = 143.9676 N./mm²

Saddle Splitting Dimension [d]:

$$= B - R * \sin(\theta) / \theta$$

$$= 1000 - 448 * \sin(1.047) / 1.047$$

$$= 629.507 \text{ mm.}$$

$$\text{Bending Moment, } M = Fh * d = 3011.6526 \text{ N-m}$$

Bending Stress, Sb = (M * C1 / I) = 0.9670 N./mm²
 Allowed Stress, Sa = 2/3 * Yield Str = 159.9640 N./mm²

Minimum Thickness of Baseplate per Moss:

$$= (3(Q + \text{Saddle_Wt}) \text{BasePlateWidth} / (4 * \text{BasePlateLength} * \text{AllStress}))^{1/2}$$

$$= (3(23.5 + 1.252) 250 / (4 * 1200 * 160))^{1/2}$$

$$= 4.917 \text{ mm.}$$

Calculation of Axial Load, Intermediate Values and Compressive Stress:

Distance between Ribs [e]:

$$= \text{Web Length} / (\text{Nrifs} - 1)$$

$$= 814.1 / (2 - 1)$$

$$= 814.064 \text{ mm.}$$

Baseplate Pressure Area [Ap]:

$$= e * \text{Bpwid} / 2$$

$$= 814.1 * 250 / 2$$

$$= 1017.580 \text{ cm}^2$$

Axial Load [P]:

$$= Ap * Bp$$

$$= 1018 * 0.00783$$

$$= 7.970 \text{ kN}$$

Area of the Rib and Web [Ar]:

$$= \text{Rib Area} + \text{Web Area}$$

$$= 19 + 40.7$$

$$= 59.703 \text{ cm}^2$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

Compressive Stress [Sc]:

$$= P/Ar$$

$$= 7.97/59.7$$

$$= 1.335 \text{ N./mm}^2$$

Check of Outside Ribs:

Inertia of Saddle, Outer Ribs - Longitudinal Direction

	B	D	Y	A	AY	Io
-----	-----	-----	-----	-----	-----	-----
Rib+Web	10.0	200.0	...	20.0	...	667.

Bending Moment [Rm]:

$$= Fl / (2 * Bplen) * e * r1 / 2$$

$$= 0.453 / (2 * 1200) * 814.1 * 753 / 2$$

$$= 57.904 \text{ N-m}$$

Compressive Allowable, $KL/R < Cc$ (22.53 < 128.3) per AISC E2-1 [Sca]:

$$= (1 - (Klr)^2 / (2 * Cc^2)) * Fy / (5/3 + 3 * (Klr) / (8 * Cc) - (Klr^3) / (8 * Cc^3))$$

$$= (1 - (22.53)^2 / (2 * 128.3^2)) * 239.9 /$$

$$(5/3 + 3 * (22.53) / (8 * 128.3) - (22.53^3) / (8 * 128.3^3))$$

$$= 136.408 \text{ N./mm}^2$$

AISC Unity Check of Outside Ribs (must be <= 1)

$$= Sc/Sca + (Rm * Distance Side/I) / Sba$$

$$= 1.335/136.4 + (57.9 * 100/6666666) / 160$$

$$= 0.015$$

Input Data for Base Plate Bolting Calculations:

Total Number of Bolts per BasePlate	Nbolts	4	
Total Number of Bolts in Tension/Baseplate	Nbt	2	
Bolt Material Specification		SA-193 B7	
Bolt Allowable Stress	Stba	172.38	N./mm ²
Bolt Corrosion Allowance	Bca	0.0	mm.
Distance from Bolts to Edge	Edgedis	50.0	mm.
Nominal Bolt Diameter	Bnd	20.0000	mm.
Thread Series	Series	TEMA Metric	
BasePlate Allowable Stress	S	95.15	N./mm ²
Area Available in a Single Bolt	BltArea	2.1705	cm ²
Saddle Load QO (Weight)	QO	21.7	kN
Saddle Load QL (Wind/Seismic contribution)	QL	0.2	kN
Maximum Transverse Force	Ft	0.8	kN
Maximum Longitudinal Force	Fl	0.5	kN
Saddle Bolted to Steel Foundation		No	

Bolt Area Calculation per Dennis R. Moss

Bolt Area Requirement Due to Longitudinal Load [Bltarearl]:

$$= 0.0 \text{ (QO > QL --> No uplift in Longitudinal direction)}$$

Bolt Area due to Shear Load [Bltarears]:

$$= Fl / (Stba * Nbolts)$$

$$= 0.453 / (172.4 * 4)$$

$$= 0.0066 \text{ cm}^2$$

Bolt Area due to Transverse Load:

Moment on Baseplate Due to Transverse Load [Rmom]:

$$= B * Ft + \text{Sum of X Moments}$$

$$= 1000 * 0.797 + 0$$

$$= 797.54 \text{ N-m}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0
Horizontal Vessel Analysis (Test): Step: 11 11:52pm Dec 24,2021

Eccentricity (e):

= R_{mom} / QO
= 797.5/21.7
= 36.74 mm. < $B_{plen}/6$ --> No Uplift in Transverse direction

Bolt Area due to Transverse Load [Bltareart]:

= 0 (No Uplift)

Required Area of a Single Bolt [Bltarear]:

= $\max[Bltarearl, Bltarears, Bltareart]$
= $\max[0, 0.00657, 0]$
= 0.0066 cm^2

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Summary: Step: 25 11:52pm Dec 24,2021

Nozzle Calculation Summary:

Description	MAWP bar	Ext	MAPNC bar	UG-45	[tr] mm.	Weld Path	Areas or Stresses
M	23.87	OK		OK	Passed
A1	27.33	OK	...	OK	10.16	OK	Passed
B	27.33	OK	...	OK	10.16	OK	Passed
A2	27.33	OK	...	OK	6.42	OK	Passed
PT	27.33	OK	...	OK	6.42	OK	Passed
A3	27.33	OK	...	OK	6.42	OK	Passed
LT1	27.33	OK	...	OK	6.42	OK	Passed
LT2	27.33	OK	...	OK	6.42	OK	Passed
D	27.33	OK	...	OK	6.42	OK	Passed
LG1	27.33	OK	...	OK	6.42	OK	Passed
LG2	27.33	OK	...	OK	6.42	OK	Passed
TI	27.85	OK	...	OK	6.42	OK	Passed
TI	27.85	OK	...	OK	6.42	OK	Passed

MAWP Summary:

Minimum MAWP Nozzles : 23.873 Nozzle : M
 Minimum MAWP Shells/Flanges : 27.329 Element : shell 001
 Minimum MAPnc Shells/Flanges : 36.589 Element : shell 001

 Computed Vessel M.A.W.P. : 23.873 bar

Note: MAWPs (Internal Case) shown above are at the High Point.

Warning: A Nozzle Reinforcement is governing the MAWP of this Vessel.

Check the Spatial Relationship between the Nozzles

From Node	Nozzle Description	X Coordinate mm.	Layout Angle deg	Dia. Limit mm.
10	M	0.000	0.000	968.000
20	A1	500.000	0.000	405.700
20	B	2000.000	180.000	405.700
20	A2	2800.000	0.000	102.068
20	PT	1800.000	0.000	102.068
20	A3	1200.000	0.000	102.068
20	LT1	3700.000	180.000	102.068
20	LT2	3700.000	0.000	102.068
20	D	300.000	180.000	102.068
20	LG1	2500.000	180.000	102.068
20	LG2	2500.000	0.000	102.068
30	TI	0.000	180.000	102.068

The nozzle spacing is computed by the following:

= Sqrt($l^2 + l_c^2$) where

l - Arc length along the inside vessel surface in the long. direction.

l_c - Arc length along the inside vessel surface in the circ. direction

If any interferences/violations are found, they will be noted below.

No interference violations have been detected !

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: M

Noz1: 13 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: M From : 10

Pressure for Reinforcement Calculations	P	23.020	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Elliptical Head	D	890.00	mm.
Aspect Ratio of Elliptical Head	Ar	2.00	
Head Finished (Minimum) Thickness	t	12.0000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.
Distance from Head Centerline	L1	0.0000	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Normalized]		SA-516 70	
Material UNS Number		K02700	
Material Specification/Type		Plate	
Allowable Stress at Temperature	Sn	137.90	N./mm ²
Allowable Stress At Ambient	Sna	137.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		20.0000	in.
Size and Thickness Basis		Actual	
Actual Thickness	tn	15.0000	mm.
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	738.0000	mm.
Thickness of Pad	te	15.0000	mm.
Weld leg size between Pad and Shell	Wp	9.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	15.0000	mm.
Reinforcing Pad Width		115.0000	mm.
This is a Manway or Access Opening.			
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: M

Noz1: 13 11:52pm Dec 24,2021

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: M

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	20.000 in.
Actual Thickness Used in Calculation	0.591 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Elliptical Head, Tr [Int. Press]
 $= (P \cdot D \cdot K) / (2 \cdot S_v \cdot E - 0.2 \cdot P)$ Appendix 1-4 (c)
 $= (23.02 \cdot 896 \cdot 0.991) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23.02)$
 $= 7.4260 \text{ mm.}$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]
 $= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 $= (23.02 \cdot 254) / (137.9 \cdot 1 + 0.4 \cdot 23.02)$
 $= 4.2126 \text{ mm.}$

Required Nozzle thickness under External Pressure per UG-28 : 1.1318 mm.

Note: The diameter limit is greater than the head diameter.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	Dl	968.0000 mm.
Parallel to Vessel Wall, opening length	d	484.0000 mm.
Normal to Vessel Wall (Thickness Limit), pad side	Tlwp	22.5000 mm.

Weld Strength Reduction Factor [fr1]:

$= \min(1, S_n / S_v)$
 $= \min(1, 137.9 / 137.9)$
 $= 1.000$

Weld Strength Reduction Factor [fr2]:

$= \min(1, S_n / S_v)$
 $= \min(1, 137.9 / 137.9)$
 $= 1.000$

Weld Strength Reduction Factor [fr4]:

$= \min(1, S_p / S_v)$
 $= \min(1, 137.9 / 137.9)$
 $= 1.000$

Weld Strength Reduction Factor [fr3]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: M Nozl: 13 11:52pm Dec 24,2021

= min(fr2, fr4)
 = min(1, 1)
 = 1.000

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	35.942	5.907	NA
Area in Shell	A1	7.618	31.747	NA
Area in Nozzle Wall	A2	3.504	4.891	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	1.747	1.747	NA
Area in Element	A5	25.875	25.875	NA
TOTAL AREA AVAILABLE	Atot	38.745	64.260	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 713.0812 15.0000 mm.
 Based on given Pad Diameter: 738.0000 13.3749 mm.
 Based on Shell or Nozzle Thickness: 764.3515 12.0000 mm.

Area Required [A]:

= (d * tr * F + 2 * tn * tr * F * (1-fr1)) UG-37(c)
 = (484*7.426*1+2*12*7.426*1*(1-1))
 = 35.942 cm²

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

= d(E1*t - F*tr) - 2 * tn(E1*t - F*tr) * (1 - fr1)
 = 484 (1 * 9 - 1 * 7.426) - 2 * 12
 (1 * 9 - 1 * 7.426) * (1 - 1)
 = 7.618 cm²

Area Available in Nozzle Wall Projecting Outward [A2]:

= (2 * Tlwp) * (tn - trn) * fr2
 = (2 * 22.5) * (12 - 4.213) * 1
 = 3.504 cm²

Area Available in Welds [A41 + A42 + A43]:

= (Wo² - Ar Lost)*Fr3+((Wi-can/0.707)² - Ar Lost)*fr2 + Wp²*fr4
 = (0.938) * 1 + (0) * 1 + 228.6² * 1
 = 1.747 cm²

Area Available in Element, also see UG-37(h) [A5]:

= (min(Dp,DL)-(Nozzle OD))(min(tp,Tlwp,te)) * fr4 * 0.75
 = (738 - 508)15 * 1 * 0.75
 = 25.875 cm²

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld, Curve: D

Govrn. thk, tg = 15, tr = 4.213, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.351, Temp. Reduction = 77 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: M Nozl: 13 11:52pm Dec 24,2021

Min Metal Temp. w/o impact per UCS-66, Curve D -47 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -48 °C

Nozzle Neck to Pad Weld for the Nozzle, Curve: D

Govrn. thk, tg = 15, tr = 4.213, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.351$, Temp. Reduction = 77 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -47 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -48 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 15, tr = 4.213, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.351$, Temp. Reduction = 77 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -47 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -48 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.426, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.825$, Temp. Reduction = 10 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 12, tr = 7.426, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.825$, Temp. Reduction = 10 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

Governing MDMT of the Nozzle : -48 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -48 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.02 / 51.10 = 0.451$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: M

Intermediate Calc. for nozzle/shell Welds Tmin 12.0000 mm.
 Intermediate Calc. for pad/shell Welds TminPad 12.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	6.0000 = Min per Code	7.0700 = 0.7 * Wo mm.
Pad Weld	6.0000 = 0.5*TminPad	6.3630 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: M Noz1: 13 11:52pm Dec 24,2021

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (35.94 - 7.618 + 2 * 12 * 1 * (1 * 9 - 7.426)) 137.9)$$

$$= 395.76 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv$$

$$= (3.504 + 25.88 + 1.747 - 0 * 1) * 137.9$$

$$= 429.20 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (3.504 + 0 + 1 + (2.16)) * 137.9$$

$$= 91.89 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (3.504 + 0 + 1.747 + 25.88 + (2.16)) * 137.9$$

$$= 458.99 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.142/2.0) * 508 * 10 * 0.49 * 137.9$$

$$= 539. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 738 * 9 * 0.49 * 137.9$$

$$= 705. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 248) * (15 - 3) * 0.7 * 137.9$$

$$= 902. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgp * 0.74 * Seg$$

$$= (3.142/2) * 508 * 15 * 0.74 * 137.9$$

$$= 1221. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 508 * (12 - 3) * 0.74 * 137.9$$

$$= 733. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (704.9 + 902.4) = 1607 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (539.1 + 1221 + 732.8 + 0) = 2493 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (704.9 + 732.8 + 0) = 1438 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 1607 kN , must exceed W = 395 kN or W1 = 429 kN
 Path 2-2 = 2493 kN , must exceed W = 395 kN or W2 = 91 kN
 Path 3-3 = 1437 kN , must exceed W = 395 kN or W3 = 458 kN

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0
Nozzle Calcs.: M

Noz1: 13 11:52pm Dec 24,2021

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 23.893 bar

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 40.8232 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 252.8232 mm.

Percent Elongation Calculations:

% Elongation per Table UG-79-1 ($50 * t_{nom} / R_f * (1 - R_f / R_o)$) 3.043 %

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A1

Noz1: 14 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: A1 From : 20

Pressure for Reinforcement Calculations	P	23.000	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		500.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		8.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	600.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	379.0750	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		80.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A1

Noz1: 14 11:52pm Dec 24,2021

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, with Inside projection

Reinforcement CALCULATION, Description: A1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation 8.625 in.
 Actual Thickness Used in Calculation 0.438 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23)$$

$$= 7.5487 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23 \cdot 109.5) / (117.9 \cdot 1 + 0.4 \cdot 23)$$

$$= 2.1205 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.6930 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	405.7000	mm.
Parallel to Vessel Wall, opening length	d	202.8500	mm.
Normal to Vessel Wall (Thickness Limit), pad side	Tlwp	22.5000	mm.
Normal to Vessel Wall, Inward		12.7812	mm.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A1 Noz1: 14 11:52pm Dec 24,2021

= 0.855

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	15.490	5.811	NA
Area in Shell	A1	2.910	6.690	NA
Area in Nozzle Wall	A2	2.305	2.855	NA
Area in Inward Nozzle	A3	1.117	1.117	NA
Area in Welds A41+A42+A43		1.855	1.855	NA
Area in Element	A5	19.200	19.200	NA
TOTAL AREA AVAILABLE	Atot	27.388	31.717	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	279.9300	12.0000 mm.
Based on given Pad Diameter:	379.0750	4.5641 mm.
Based on Shell or Nozzle Thickness:	284.7902	11.1125 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (202.8 * 7.549 * 1 + 2 * 8.113 * 7.549 * 1 * (1 - 0.855))$$

$$= 15.490 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 202.8 (1 * 9 - 1 * 7.549) - 2 * 8.113$$

$$(1 * 9 - 1 * 7.549) * (1 - 0.855)$$

$$= 2.910 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 22.5) * (8.113 - 2.121) * 0.855$$

$$= 2.305 \text{ cm}^2$$

Area Available in Inward Nozzle [A3]:

$$= 2 * ti * \min(h, Tl, 2.5 * ti) * fr2$$

$$= 2 * 5.112 * (12.78) * 0.855$$

$$= 1.117 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 10^2 * 1$$

$$= 1.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (379.1 - 219.1) * 12 * 1$$

$$= 19.200 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $ta = 5.1205 \text{ mm.}$
 Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A1 Noz1: 14 11:52pm Dec 24,2021

Wall Thickness, shell/head, internal pressure trb1 = 10.5487 mm.
 Wall Thickness tb1 = max(trb1, tr16b) = 10.5487 mm.
 Wall Thickness, shell/head, external pressure trb2 = 3.3576 mm.
 Wall Thickness tb2 = max(trb2, tr16b) = 4.5000 mm.
 Wall Thickness per table UG-45 tb3 = 10.1600 mm.

Determine Nozzle Thickness candidate [tb]:

= min[tb3, max(tb1,tb2)]
 = min[10.16, max(10.55, 4.5)]
 = 10.1600 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

= max(ta, tb)
 = max(5.121, 10.16)
 = 10.1600 mm.

Available Nozzle Neck Thickness = 11.1125 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained	: 50.5,	Allowable	: 117.9 N./mm ²	Passed
Expansion	: 0.0,	Allowable	: 244.3 N./mm ²	Passed
Occasional	: 13.8,	Allowable	: 156.8 N./mm ²	Passed
Shear	: 20.4,	Allowable	: 82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 11.11, tr = 2.121, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.261, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.549, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.839, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A1

Noz1: 14 11:52pm Dec 24,2021

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 11.11, tr = 2.121, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.261$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i) (2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i) (3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.00 / 51.10 = 0.450$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: A1

Intermediate Calc. for nozzle/shell Welds Tmin 8.1125 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$5.6788 = 0.7 * tmin.$	$7.0700 = 0.7 * Wo$ mm.
Pad Weld	$4.5000 = 0.5 * TminPad$	$7.0700 = 0.7 * Wp$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (15.49 - 2.91 + 2 * 8.113 * 0.855 * \\
 &\quad (1 * 9 - 7.549))) 137.9) \\
 &= 176.24 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (2.305 + 19.2 + 1.855 - 0 * 0.855) * 137.9 \\
 &= 322.11 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (2.305 + 1.117 + 0.855 + (1.249)) * 137.9 \\
 &= 76.20 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (2.305 + 1.117 + 1.855 + 19.2 + (1.249)) * 137.9 \\
 &= 354.74 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A1 Noz1: 14 11:52pm Dec 24,2021

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw}$$

$$= (3.142/2.0) * 219.1 * 10 * 0.49 * 117.9$$

$$= 199. \text{ kN}$$

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * D_P * W_P * 0.49 * S_{EW}$$

$$= (3.142/2.0) * 379.1 * 10 * 0.49 * 137.9$$

$$= 402. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (D_{lr} + D_{lo}) / 4) * (Thk - Can) * 0.7 * S_n$$

$$= (3.142 * 105.5) * (11.11 - 3) * 0.7 * 117.9$$

$$= 222. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg}$$

$$= (3.142/2) * 219.1 * 12 * 0.74 * 137.9$$

$$= 421. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * D_{lo} * (W_{gnvi-Cas}) * 0.74 * S_{ng}$$

$$= (3.142/2.0) * 219.1 * (12 - 3) * 0.74 * 137.9$$

$$= 316. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (402.3 + 221.9) = 624.2 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (198.8 + 421.4 + 316 + 0) = 936.2 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (402.3 + 316 + 0) = 718.3 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 624 kN , must exceed W = 176 kN or W1 = 322 kN
 Path 2-2 = 936 kN , must exceed W = 176 kN or W2 = 76 kN
 Path 3-3 = 718 kN , must exceed W = 176 kN or W3 = 354 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.329 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 13.6920 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 812.0000 mm.

Input Echo, WRC107/537 Item 1, Description: A1 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516	70
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A1 Nozl: 14 11:52pm Dec 24,2021

Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	219.075	mm.
Nozzle Thickness	Tn	11.113	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	379.075	mm.
Design Internal Pressure	Dp	23.000	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	8.0	kN
Longitudinal Shear (SUS)	Vl	8.0	kN
Circumferential Shear (SUS)	Vc	8.0	kN
Circumferential Moment (SUS)	Mc	6800.0	N-m
Longitudinal Moment (SUS)	Ml	6800.0	N-m
Torsional Moment (SUS)	Mt	8400.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 219.075 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 429.668 mm.

WRC 107 Stress Calculation for SUStained loads:

Radial Load	P	8.0	kN
Circumferential Shear	VC	8.0	kN
Longitudinal Shear	VL	8.0	kN
Circumferential Moment	MC	6800.0	N-m
Longitudinal Moment	ML	6800.0	N-m
Torsional Moment	MT	8400.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.209	4C	3.315	(A,B)
N(PHI) / (P/Rm)	0.209	3C	2.402	(C,D)
M(PHI) / (P)	0.209	2C1	0.050	(A,B)
M(PHI) / (P)	0.209	1C	0.080	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.209	3A	0.874	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.209	1A	0.087	(A,B,C,D)

Nozzle Calcs.: A1 Nozl: 14 11:52pm Dec 24,2021

N(PHI) / (ML/(Rm**2 * Beta))	0.209	3B	2.431	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.209	1B	0.033	(A,B,C,D)
N(x) / (P/Rm)	0.209	3C	2.402	(A,B)
N(x) / (P/Rm)	0.209	4C	3.315	(C,D)
M(x) / (P)	0.209	1C1	0.084	(A,B)
M(x) / (P)	0.209	2C	0.050	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.209	4A	1.433	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.209	2A	0.044	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.209	4B	0.826	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.209	2B	0.054	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb.	P	-2.8	-2.8	-2.8	-2.8	-2.0	-2.0	-2.0	-2.0
Circ. Bend.	P	-5.4	5.4	-5.4	5.4	-8.7	8.7	-8.7	8.7
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-6.4	-6.4	6.4	6.4
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-83.6	83.6	83.6	-83.6
Circ. Memb.	ML	-17.9	-17.9	17.9	17.9	0.0	0.0	0.0	0.0
Circ. Bend.	ML	-32.1	32.1	32.1	-32.1	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-58.2	16.9	41.8	-11.5	-100.8	83.9	79.3	-70.5
Long. Memb.	P	-2.0	-2.0	-2.0	-2.0	-2.8	-2.8	-2.8	-2.8
Long. Bend.	P	-9.1	9.1	-9.1	9.1	-5.5	5.5	-5.5	5.5
Long. Memb.	MC	0.0	0.0	0.0	0.0	-10.6	-10.6	10.6	10.6
Long. Bend.	MC	0.0	0.0	0.0	0.0	-42.7	42.7	42.7	-42.7
Long. Memb.	ML	-6.1	-6.1	6.1	6.1	0.0	0.0	0.0	0.0
Long. Bend.	ML	-52.0	52.0	52.0	-52.0	0.0	0.0	0.0	0.0
Tot. Long. Str.		-69.2	53.0	47.0	-38.8	-61.5	34.9	45.0	-29.4
Shear	VC	1.1	1.1	-1.1	-1.1	0.0	0.0	0.0	0.0
Shear	VL	0.0	0.0	0.0	0.0	-1.1	-1.1	1.1	1.1
Shear	MT	5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3
Tot. Shear		6.4	6.4	4.2	4.2	4.2	4.2	6.4	6.4
Str. Int.		72.1	54.1	49.3	39.4	101.2	84.2	80.5	71.4

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.367	4C	4.320	(A,B)
N(PHI) / (P/Rm)	0.367	3C	1.750	(C,D)
M(PHI) / (P)	0.367	2C1	0.009	(A,B)
M(PHI) / (P)	0.367	1C !	0.065	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.367	3A	1.360	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.367	1A	0.059	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.367	3B	2.531	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.367	1B	0.007	(A,B,C,D)
N(x) / (P/Rm)	0.367	3C	1.750	(A,B)
N(x) / (P/Rm)	0.367	4C	4.320	(C,D)

Nozzle Calcs.: A1 Nozl: 14 11:52pm Dec 24,2021

M(x)	/ (P)	0.367	1C1	0.022	(A,B)
M(x)	/ (P)	0.367	2C !	0.033	(C,D)
N(x)	/ (MC/(Rm**2 * Beta))	0.367	4A	4.848	(A,B,C,D)
M(x)	/ (MC/(Rm * Beta))	0.367	2A	0.023	(A,B,C,D)
N(x)	/ (ML/(Rm**2 * Beta))	0.367	4B	1.484	(A,B,C,D)
M(x)	/ (ML/(Rm * Beta))	0.367	2B	0.010	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb.	P	-8.5	-8.5	-8.5	-8.5	-3.4	-3.4	-3.4	-3.4
Circ. Bend.	P	-5.2	5.2	-5.2	5.2	-38.6	38.6	-38.6	38.6
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-13.7	-13.7	13.7	13.7
Circ. Memb.	MC	0.0	0.0	0.0	0.0	-177.9	177.9	177.9	-177.9
Circ. Memb.	ML	-25.5	-25.5	25.5	25.5	0.0	0.0	0.0	0.0
Circ. Bend.	ML	-20.1	20.1	20.1	-20.1	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-59.3	-8.7	32.0	2.0	-233.7	199.4	149.5	-129.0
Long. Memb.	P	-3.4	-3.4	-3.4	-3.4	-8.5	-8.5	-8.5	-8.5
Long. Bend.	P	-13.2	13.2	-13.2	13.2	-19.8	19.8	-19.8	19.8
Long. Memb.	MC	0.0	0.0	0.0	0.0	-48.8	-48.8	48.8	48.8
Long. Bend.	MC	0.0	0.0	0.0	0.0	-70.3	70.3	70.3	-70.3
Long. Memb.	ML	-14.9	-14.9	14.9	14.9	0.0	0.0	0.0	0.0
Long. Bend.	ML	-31.0	31.0	31.0	-31.0	0.0	0.0	0.0	0.0
Tot. Long. Str.		-62.5	25.8	29.3	-6.3	-147.3	32.8	90.7	-10.1
Shear	VC	1.5	1.5	-1.5	-1.5	0.0	0.0	0.0	0.0
Shear	VL	0.0	0.0	0.0	0.0	-1.5	-1.5	1.5	1.5
Shear	MT	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
Tot. Shear		5.6	5.6	2.6	2.6	2.6	2.6	5.6	5.6
Str. Int.		66.8	36.2	33.6	9.8	233.7	199.4	150.0	129.3

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm	(SUS)	48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl	(SUS)	-20.7	-20.7	15.1	15.1	-8.4	-8.4	4.4	4.4
Circ. Q	(SUS)	-37.5	37.5	26.6	-26.6	-92.3	92.3	74.9	-74.9
Long. Pm	(SUS)	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl	(SUS)	-8.1	-8.1	4.1	4.1	-13.3	-13.3	7.8	7.8
Long. Q	(SUS)	-61.1	61.1	42.9	-42.9	-48.2	48.2	37.2	-37.2

Nozzle Calcs.: A1 Noz1: 14 11:52pm Dec 24,2021

Shear Pm (SUS)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)	1.1	1.1	-1.1	-1.1	-1.1	-1.1	-1.1	1.1	1.1
Shear Q (SUS)	5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3
Pm (SUS)	48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3	50.3

Pm+Pl (SUS)	27.4	29.7	63.1	65.4	39.6	41.9	52.4	54.7	

Pm+Pl+Q (Total)	46.3	80.2	90.6	54.3	53.9	134.4	128.0	22.6	

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.25	137.90	Passed
Pm+Pl (SUS)	65.43	206.85	Passed
Pm+Pl+Q (TOTAL)	134.37	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Circ. Pl (SUS)		-34.0	-34.0	17.0	17.0	-17.1	-17.1	10.3	10.3
Circ. Q (SUS)		-25.3	25.3	15.0	-15.0	-216.5	216.5	139.3	-139.3

Long. Pm (SUS)		56.7	56.7	56.7	56.7	56.7	56.7	56.7	56.7
Long. Pl (SUS)		-18.4	-18.4	11.5	11.5	-57.3	-57.3	40.3	40.3
Long. Q (SUS)		-44.2	44.2	17.8	-17.8	-90.1	90.1	50.4	-50.4

Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.5	1.5	-1.5	-1.5	-1.5	-1.5	1.5	1.5
Shear Q (SUS)		4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7

Pm+Pl (SUS)		79.5	81.8	130.4	132.7	96.9	99.2	123.7	126.0

Pm+Pl+Q (Total)		61.0	108.2	145.4	117.8	120.5	315.1	263.1	60.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.67	137.90	Passed
Pm+Pl (SUS)	132.69	206.85	Passed
Pm+Pl+Q (TOTAL)	315.10	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: B

Noz1: 15 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: B From : 20

Pressure for Reinforcement Calculations	P	23.040	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		2000.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		180.00	deg
Diameter		8.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	80	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	379.0750	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		80.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: B

Noz1: 15 11:52pm Dec 24,2021

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: B

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation 8.625 in.
 Actual Thickness Used in Calculation 0.438 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23.04 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23.04)$$

$$= 7.5621 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.04 \cdot 109.5) / (117.9 \cdot 1 + 0.4 \cdot 23.04)$$

$$= 2.1242 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.6930 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	405.7000	mm.
Parallel to Vessel Wall, opening length	d	202.8500	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000	mm.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1)$$

$$= 0.855$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: B

Noz1: 15 11:52pm Dec 24,2021

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	15.518	5.811	NA
Area in Shell	A1	2.883	6.690	NA
Area in Nozzle Wall	A2	2.304	2.855	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	1.855	1.855	NA
Area in Element	A5	19.200	19.200	NA
TOTAL AREA AVAILABLE	Atot	26.242	30.600	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	289.7040	12.0000 mm.
Based on given Pad Diameter:	379.0750	5.2972 mm.
Based on Shell or Nozzle Thickness:	295.3448	11.1125 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (202.8 * 7.562 * 1 + 2 * 8.113 * 7.562 * 1 * (1 - 0.855))$$

$$= 15.518 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 202.8 (1 * 9 - 1 * 7.562) - 2 * 8.113 (1 * 9 - 1 * 7.562) * (1 - 0.855)$$

$$= 2.883 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 22.5) * (8.113 - 2.124) * 0.855$$

$$= 2.304 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 10^2 * 1$$

$$= 1.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (379.1 - 219.1) * 12 * 1$$

$$= 19.200 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 5.1242 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 10.5621 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 10.5621 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.3576 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 10.1600 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: B Nozl: 15 11:52pm Dec 24,2021

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[10.16, \max(10.56, 4.5)]$$

$$= 10.1600 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(5.124, 10.16)$$

$$= 10.1600 \text{ mm.}$$

Available Nozzle Neck Thickness = 11.1125 mm. --> OK

Stresses on Nozzle due to External and Pressure Loads per the ASME

B31.3 Piping Code (see 319.4.4 and 302.3.5):

Sustained	: 50.5, Allowable	: 117.9 N./mm ²	Passed
Expansion	: 0.0, Allowable	: 244.3 N./mm ²	Passed
Occasional	: 13.9, Allowable	: 156.8 N./mm ²	Passed
Shear	: 20.4, Allowable	: 82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 11.11, tr = 2.124, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.262$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.562, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.84$, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 11.11, tr = 2.124, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.262$, Temp. Reduction = 78 °C

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: B Nozl: 15 11:52pm Dec 24,2021

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = 23.04/51.10 = 0.451

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: B

Intermediate Calc. for nozzle/shell Welds Tmin 8.1125 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	5.6788 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.
Pad Weld	4.5000 = 0.5*TminPad	7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (15.52 - 2.883 + 2 * 8.113 * 0.855 * \\
 &\quad (1 * 9 - 7.562)) 137.9) \\
 &= 176.97 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (2.304 + 19.2 + 1.855 - 0 * 0.855) * 137.9 \\
 &= 322.09 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (2.304 + 0 + 0.855 + (1.249)) * 137.9 \\
 &= 60.77 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (2.304 + 0 + 1.855 + 19.2 + (1.249)) * 137.9 \\
 &= 339.31 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 219.1 * 10 * 0.49 * 117.9 \\
 &= 199. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: B Nozl: 15 11:52pm Dec 24,2021

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 379.1 * 10 * 0.49 * 137.9$$

$$= 402. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 105.5) * (11.11 - 3) * 0.7 * 117.9$$

$$= 222. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 219.1 * 12 * 0.74 * 137.9$$

$$= 421. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 219.1 * (12 - 3) * 0.74 * 137.9$$

$$= 316. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (402.3 + 221.9) = 624.2 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (198.8 + 421.4 + 316 + 0) = 936.2 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (402.3 + 316 + 0) = 718.3 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 624 kN , must exceed W = 176 kN or W1 = 322 kN
 Path 2-2 = 936 kN , must exceed W = 176 kN or W2 = 60 kN
 Path 3-3 = 718 kN , must exceed W = 176 kN or W3 = 339 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.369 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 13.6920 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 225.6920 mm.

Input Echo, WRC107/537 Item 1, Description: B :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	219.075	mm.
Nozzle Thickness	Tn	11.113	mm.
Nozzle Material		SA-333 6	

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: B Nozl: 15 11:52pm Dec 24,2021

Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	379.075	mm.
Design Internal Pressure	Dp	23.040	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	8.0	kN
Longitudinal Shear (SUS)	Vl	8.0	kN
Circumferential Shear (SUS)	Vc	8.0	kN
Circumferential Moment (SUS)	Mc	6800.0	N-m
Longitudinal Moment (SUS)	Ml	6800.0	N-m
Torsional Moment (SUS)	Mt	8400.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979

Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 219.075 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 429.668 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	8.0	kN
Circumferential Shear	VC	8.0	kN
Longitudinal Shear	VL	8.0	kN
Circumferential Moment	MC	6800.0	N-m
Longitudinal Moment	ML	6800.0	N-m
Torsional Moment	MT	8400.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.209	4C	3.315	(A,B)
N(PHI) / (P/Rm)	0.209	3C	2.402	(C,D)
M(PHI) / (P)	0.209	2C1	0.050	(A,B)
M(PHI) / (P)	0.209	1C	0.080	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.209	3A	0.874	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.209	1A	0.087	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.209	3B	2.431	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.209	1B	0.033	(A,B,C,D)
N(x) / (P/Rm)	0.209	3C	2.402	(A,B)
N(x) / (P/Rm)	0.209	4C	3.315	(C,D)
M(x) / (P)	0.209	1C1	0.084	(A,B)

Nozzle Calcs.: B Nozl: 15 11:52pm Dec 24,2021

M(x)	/ (P)	0.209	2C	0.050	(C,D)
N(x)	/ (MC/(Rm**2 * Beta))	0.209	4A	1.433	(A,B,C,D)
M(x)	/ (MC/(Rm * Beta))	0.209	2A	0.044	(A,B,C,D)
N(x)	/ (ML/(Rm**2 * Beta))	0.209	4B	0.826	(A,B,C,D)
M(x)	/ (ML/(Rm * Beta))	0.209	2B	0.054	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-2.8	-2.8	-2.8	-2.8	-2.0	-2.0	-2.0	-2.0
Circ. Bend. P		-5.4	5.4	-5.4	5.4	-8.7	8.7	-8.7	8.7
Circ. Memb. MC		0.0	0.0	0.0	0.0	-6.4	-6.4	6.4	6.4
Circ. Memb. ML		-17.9	-17.9	17.9	17.9	0.0	0.0	0.0	0.0
Circ. Bend. ML		-32.1	32.1	32.1	-32.1	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-58.2	16.9	41.8	-11.5	-100.8	83.9	79.3	-70.5
Long. Memb. P		-2.0	-2.0	-2.0	-2.0	-2.8	-2.8	-2.8	-2.8
Long. Bend. P		-9.1	9.1	-9.1	9.1	-5.5	5.5	-5.5	5.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-10.6	-10.6	10.6	10.6
Long. Bend. MC		0.0	0.0	0.0	0.0	-42.7	42.7	42.7	-42.7
Long. Memb. ML		-6.1	-6.1	6.1	6.1	0.0	0.0	0.0	0.0
Long. Bend. ML		-52.0	52.0	52.0	-52.0	0.0	0.0	0.0	0.0
Tot. Long. Str.		-69.2	53.0	47.0	-38.8	-61.5	34.9	45.0	-29.4
Shear VC		1.1	1.1	-1.1	-1.1	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-1.1	-1.1	1.1	1.1
Shear MT		5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3
Tot. Shear		6.4	6.4	4.2	4.2	4.2	4.2	6.4	6.4
Str. Int.		72.1	54.1	49.3	39.4	101.2	84.2	80.5	71.4

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.367	4C	4.320	(A,B)
N(PHI) / (P/Rm)	0.367	3C	1.750	(C,D)
M(PHI) / (P)	0.367	2C1	0.009	(A,B)
M(PHI) / (P)	0.367	1C !	0.065	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.367	3A	1.360	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.367	1A	0.059	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.367	3B	2.531	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.367	1B	0.007	(A,B,C,D)
N(x) / (P/Rm)	0.367	3C	1.750	(A,B)
N(x) / (P/Rm)	0.367	4C	4.320	(C,D)
M(x) / (P)	0.367	1C1	0.022	(A,B)
M(x) / (P)	0.367	2C !	0.033	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.367	4A	4.848	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.367	2A	0.023	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.367	4B	1.484	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.367	2B	0.010	(A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-8.5	-8.5	-8.5	-8.5	-3.4	-3.4	-3.4	-3.4
Circ. Bend. P		-5.2	5.2	-5.2	5.2	-38.6	38.6	-38.6	38.6
Circ. Memb. MC		0.0	0.0	0.0	0.0	-13.7	-13.7	13.7	13.7
Circ. Memb. MC		0.0	0.0	0.0	0.0	-177.9	177.9	177.9	-177.9
Circ. Memb. ML		-25.5	-25.5	25.5	25.5	0.0	0.0	0.0	0.0
Circ. Bend. ML		-20.1	20.1	20.1	-20.1	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-59.3	-8.7	32.0	2.0	-233.7	199.4	149.5	-129.0
Long. Memb. P		-3.4	-3.4	-3.4	-3.4	-8.5	-8.5	-8.5	-8.5
Long. Bend. P		-13.2	13.2	-13.2	13.2	-19.8	19.8	-19.8	19.8
Long. Memb. MC		0.0	0.0	0.0	0.0	-48.8	-48.8	48.8	48.8
Long. Bend. MC		0.0	0.0	0.0	0.0	-70.3	70.3	70.3	-70.3
Long. Memb. ML		-14.9	-14.9	14.9	14.9	0.0	0.0	0.0	0.0
Long. Bend. ML		-31.0	31.0	31.0	-31.0	0.0	0.0	0.0	0.0
Tot. Long. Str.		-62.5	25.8	29.3	-6.3	-147.3	32.8	90.7	-10.1
Shear VC		1.5	1.5	-1.5	-1.5	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-1.5	-1.5	1.5	1.5
Shear MT		4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
Tot. Shear		5.6	5.6	2.6	2.6	2.6	2.6	5.6	5.6
Str. Int.		66.8	36.2	33.6	9.8	233.7	199.4	150.0	129.3

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-20.7	-20.7	15.1	15.1	-8.4	-8.4	4.4	4.4
Circ. Q (SUS)		-37.5	37.5	26.6	-26.6	-92.3	92.3	74.9	-74.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-8.1	-8.1	4.1	4.1	-13.3	-13.3	7.8	7.8
Long. Q (SUS)		-61.1	61.1	42.9	-42.9	-48.2	48.2	37.2	-37.2
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.1	1.1	-1.1	-1.1	-1.1	-1.1	1.1	1.1
Shear Q (SUS)		5.3	5.3	5.3	5.3	5.3	5.3	5.3	5.3
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Pm+Pl (SUS)		27.5	29.8	63.2	65.5	39.6	41.9	52.5	54.8

Noz1: 15 11:52pm Dec 24,2021

 Pm+Pl+Q (Total) | 46.3 | 80.2 | 90.7 | 54.3 | 53.8 | 134.5 | 128.1 | 22.5 |

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.34	137.90	Passed
Pm+Pl (SUS)	65.52	206.85	Passed
Pm+Pl+Q (TOTAL)	134.46	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.6	115.9	113.6	115.9	113.6	115.9	113.6	115.9
Circ. Pl (SUS)		-34.0	-34.0	17.0	17.0	-17.1	-17.1	10.3	10.3
Circ. Q (SUS)		-25.3	25.3	15.0	-15.0	-216.5	216.5	139.3	-139.3
Long. Pm (SUS)		56.8	56.8	56.8	56.8	56.8	56.8	56.8	56.8
Long. Pl (SUS)		-18.4	-18.4	11.5	11.5	-57.3	-57.3	40.3	40.3
Long. Q (SUS)		-44.2	44.2	17.8	-17.8	-90.1	90.1	50.4	-50.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.5	1.5	-1.5	-1.5	-1.5	-1.5	1.5	1.5
Shear Q (SUS)		4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
Pm (SUS)		113.6	115.9	113.6	115.9	113.6	115.9	113.6	115.9
Pm+Pl (SUS)		79.7	82.0	130.6	132.9	97.0	99.3	123.9	126.2
Pm+Pl+Q (Total)		61.1	108.4	145.6	118.0	120.3	315.3	263.3	60.8

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.87	137.90	Passed
Pm+Pl (SUS)	132.89	206.85	Passed
Pm+Pl+Q (TOTAL)	315.30	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A2

Noz1: 16 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: A2 From : 20

Pressure for Reinforcement Calculations	P	23.000	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		2800.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	200.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A2

Noz1: 16 11:52pm Dec 24,2021

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: A2

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23)$$

$$= 7.5487 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$$

$$= 0.5839 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.3261 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684 mm.
Parallel to Vessel Wall, opening length	d	51.0342 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A2

Noz1: 16 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.954	1.483	NA
Area in Shell	A1	0.721	1.658	NA
Area in Nozzle Wall	A2	1.563	1.662	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.148	9.184	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 67.1197 12.0000 mm.

Based on given Pad Diameter: 160.3250 1.9533 mm.

Based on Shell or Nozzle Thickness: 70.9898 7.6454 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 \cdot 7.549 \cdot 1 + 2 \cdot 4.645 \cdot 7.549 \cdot 1 \cdot (1 - 0.855))$$

$$= 3.954 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 51.03 \cdot (1 \cdot 9 - 1 \cdot 7.549) - 2 \cdot 4.645 \cdot (1 \cdot 9 - 1 \cdot 7.549) \cdot (1 - 0.855)$$

$$= 0.721 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 22.5) \cdot (4.645 - 0.584) \cdot 0.855$$

$$= 1.563 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 10^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (102.1 - 60.33) \cdot 12 \cdot 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $ta = 3.5839 \text{ mm.}$

Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$

Wall Thickness, shell/head, internal pressure $trb1 = 10.5487 \text{ mm.}$

Wall Thickness $tb1 = \max(trb1, tr16b) = 10.5487 \text{ mm.}$

Wall Thickness, shell/head, external pressure $trb2 = 3.3576 \text{ mm.}$

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A2 Noz1: 16 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.55, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.0,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.549, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.839, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A2 Noz1: 16 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.00 / 51.10 = 0.450$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: A2

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$4.5000 = 0.5 * T_{minPad}$	$7.0700 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.954 - 0.721 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 7.549)) 137.9) \\
 &= 46.17 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv \\
 &= (1.563 + 5.009 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 102.41 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.563 + 0 + 0.855 + (0.715)) * 137.9 \\
 &= 43.19 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.563 + 0 + 0.855 + 5.009 + (0.715)) * 137.9 \\
 &= 112.27 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9 \\
 &= 55. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A2

Noz1: 16 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (54.74 + 116 + 87.02 + 0) = 257.8 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (170.2 + 87.02 + 0) = 257.2 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 102 kN
 Path 2-2 = 257 kN , must exceed W = 46 kN or W2 = 43 kN
 Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.329 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 213.0234 mm.

Input Echo, WRC107/537 Item 1, Description: A2 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A2 Nozl: 16 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.325	mm.
Design Internal Pressure	Dp	23.000	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	Vl	2.0	kN
Circumferential Shear (SUS)	Vc	2.0	kN
Circumferential Moment (SUS)	Mc	400.0	N-m
Longitudinal Moment (SUS)	Ml	400.0	N-m
Torsional Moment (SUS)	Mt	500.0	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: A2 Noz1: 16 11:52pm Dec 24,2021

N(x) / (P/Rm)	0.058	4C	4.229	(C,D)
M(x) / (P)	0.058	1C1	0.207	(A,B)
M(x) / (P)	0.058	2C	0.166	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at								
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl	
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4	
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0	
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0	
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4	
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5	
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	-0.5	0.5	0.5	
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9	
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0	
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0	
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8	
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0	
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0	
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2	
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0	

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.575	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.538	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.077	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.450	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.538	(A,B)
N(x) / (P/Rm)	0.155	4C	7.575	(C,D)
M(x) / (P)	0.155	1C1	0.080	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.512	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: A2 Noz1: 16 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.955 (A,B,C,D)
M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.4	33.4	33.4	-33.4
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.6	12.6	12.6	-12.6	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.5	7.8	10.0	-2.2	-50.5	39.3	22.1	-21.8
Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.7	16.7	16.7	-16.7
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.7	17.7	17.7	-17.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.1	24.2	5.8	-5.8	-31.8	14.6	11.5	-9.1
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3
Str. Int.		36.0	24.5	10.1	5.9	50.5	39.3	22.6	22.2

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Pm+Pl (SUS)	45.6	47.9	48.6	50.9	46.7	49.0	47.5	49.8
Pm+Pl+Q (Total)	33.7	66.2	56.9	43.4	20.4	76.2	64.2	35.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.25	137.90	Passed
Pm+Pl (SUS)	50.93	206.85	Passed
Pm+Pl+Q (TOTAL)	76.20	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Circ. Pl (SUS)		-11.3	-11.3	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.1	19.1	6.1	-6.1	-44.9	44.9	22.0	-22.0
Long. Pm (SUS)		56.7	56.7	56.7	56.7	56.7	56.7	56.7	56.7
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.7	29.7	5.8	-5.8	-23.2	23.2	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Pm+Pl (SUS)		102.0	104.3	117.3	119.6	107.8	110.1	113.5	115.8
Pm+Pl+Q (Total)		83.0	123.6	123.4	113.4	62.9	155.0	135.5	93.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.67	137.90	Passed
Pm+Pl (SUS)	119.59	206.85	Passed
Pm+Pl+Q (TOTAL)	155.00	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: PT

Noz1: 17 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: PT From : 20

Pressure for Reinforcement Calculations	P	23.000	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1800.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	8.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: PT

Noz1: 17 11:52pm Dec 24,2021

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: PT

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23)$$

$$= 7.5487 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$$

$$= 0.5839 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684 mm.
Parallel to Vessel Wall, opening length	d	51.0342 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: PT

Noz1: 17 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.954	1.483	NA
Area in Shell	A1	0.721	1.658	NA
Area in Nozzle Wall	A2	1.563	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.547	0.547	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	7.840	8.890	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 69.6847 12.0000 mm.

Based on given Pad Diameter: 160.3250 2.6906 mm.

Based on Shell or Nozzle Thickness: 75.0158 7.6454 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 \cdot 7.549 \cdot 1 + 2 \cdot 4.645 \cdot 7.549 \cdot 1 \cdot (1 - 0.855))$$

$$= 3.954 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 51.03 \cdot (1 \cdot 9 - 1 \cdot 7.549) - 2 \cdot 4.645 \cdot (1 \cdot 9 - 1 \cdot 7.549) \cdot (1 - 0.855)$$

$$= 0.721 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 22.5) \cdot (4.645 - 0.584) \cdot 0.855$$

$$= 1.563 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 8^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.547 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (102.1 - 60.33) \cdot 12 \cdot 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $ta = 3.5839 \text{ mm.}$

Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$

Wall Thickness, shell/head, internal pressure $trb1 = 10.5487 \text{ mm.}$

Wall Thickness $tb1 = \max(trb1, tr16b) = 10.5487 \text{ mm.}$

Wall Thickness, shell/head, external pressure $trb2 = 3.3576 \text{ mm.}$

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: PT Noz1: 17 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.55, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.0,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.549, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.839, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: PT

Noz1: 17 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.00 / 51.10 = 0.450$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: PT

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * tmin.$	$5.6560 = 0.7 * Wo$ mm.
Pad Weld	$4.5000 = 0.5 * TminPad$	$7.0700 = 0.7 * Wp$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (3.954 - 0.721 + 2 * 4.645 * 0.855 * (1 * 9 - 7.549)) 137.9)$$

$$= 46.17 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv$$

$$= (1.563 + 5.009 + 0.547 - 0 * 0.855) * 137.9$$

$$= 98.16 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (1.563 + 0 + 0.547 + (0.715)) * 137.9$$

$$= 38.95 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (1.563 + 0 + 0.547 + 5.009 + (0.715)) * 137.9$$

$$= 108.02 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.142/2.0) * 60.33 * 8 * 0.49 * 117.9$$

$$= 44. \text{ kN}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: PT

Noz1: 17 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (43.79 + 116 + 87.02 + 0) = 246.8 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (170.2 + 87.02 + 0) = 257.2 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 98 kN
 Path 2-2 = 246 kN , must exceed W = 46 kN or W2 = 38 kN
 Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 108 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.329 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

Input Echo, WRC107/537 Item 1, Description: PT :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: PT Nozl: 17 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.325	mm.
Design Internal Pressure	Dp	23.000	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	Vl	2.0	kN
Circumferential Shear (SUS)	Vc	2.0	kN
Circumferential Moment (SUS)	Mc	400.0	N-m
Longitudinal Moment (SUS)	Ml	400.0	N-m
Torsional Moment (SUS)	Mt	500.0	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: PT Noz1: 17 11:52pm Dec 24,2021

N(x) / (P/Rm)	0.058	4C	4.229	(C,D)
M(x) / (P)	0.058	1C1	0.207	(A,B)
M(x) / (P)	0.058	2C	0.166	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at								
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl	
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4	
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0	
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0	
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4	
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5	
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	-0.5	0.5	0.5	
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9	
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0	
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0	
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8	
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0	
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0	
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2	
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0	

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.575	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.538	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.077	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.450	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.538	(A,B)
N(x) / (P/Rm)	0.155	4C	7.575	(C,D)
M(x) / (P)	0.155	1C1	0.080	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.512	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: PT Noz1: 17 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.955 (A,B,C,D)
 M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.4	33.4	33.4	-33.4
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.6	12.6	12.6	-12.6	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.5	7.8	10.0	-2.2	-50.5	39.3	22.1	-21.8
Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.7	16.7	16.7	-16.7
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.7	17.7	17.7	-17.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.1	24.2	5.8	-5.8	-31.8	14.6	11.5	-9.1
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3
Str. Int.		36.0	24.5	10.1	5.9	50.5	39.3	22.6	22.2

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Pm+Pl (SUS)	45.6	47.9	48.6	50.9	46.7	49.0	47.5	49.8
Pm+Pl+Q (Total)	33.7	66.2	56.9	43.4	20.4	76.2	64.2	35.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.25	137.90	Passed
Pm+Pl (SUS)	50.93	206.85	Passed
Pm+Pl+Q (TOTAL)	76.20	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Circ. Pl (SUS)		-11.3	-11.3	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.1	19.1	6.1	-6.1	-44.9	44.9	22.0	-22.0
Long. Pm (SUS)		56.7	56.7	56.7	56.7	56.7	56.7	56.7	56.7
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.7	29.7	5.8	-5.8	-23.2	23.2	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Pm+Pl (SUS)		102.0	104.3	117.3	119.6	107.8	110.1	113.5	115.8
Pm+Pl+Q (Total)		83.0	123.6	123.4	113.4	62.9	155.0	135.5	93.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.67	137.90	Passed
Pm+Pl (SUS)	119.59	206.85	Passed
Pm+Pl+Q (TOTAL)	155.00	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A3

Noz1: 18 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: A3 From : 20


Pressure for Reinforcement Calculations	P	23.000	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		1200.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	8.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: A3

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23)$$

$$= 7.5487 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23)$$

$$= 0.5839 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684	mm.
Parallel to Vessel Wall, opening length	d	51.0342	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000	mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A3

Noz1: 18 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.954	1.483	NA
Area in Shell	A1	0.721	1.658	NA
Area in Nozzle Wall	A2	1.563	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.547	0.547	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	7.840	8.890	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 69.6847 12.0000 mm.
 Based on given Pad Diameter: 160.3250 2.6906 mm.
 Based on Shell or Nozzle Thickness: 75.0158 7.6454 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 \cdot 7.549 \cdot 1 + 2 \cdot 4.645 \cdot 7.549 \cdot 1 \cdot (1 - 0.855))$$

$$= 3.954 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 51.03 \cdot (1 \cdot 9 - 1 \cdot 7.549) - 2 \cdot 4.645 \cdot (1 \cdot 9 - 1 \cdot 7.549) \cdot (1 - 0.855)$$

$$= 0.721 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 22.5) \cdot (4.645 - 0.584) \cdot 0.855$$

$$= 1.563 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 8^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.547 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (102.1 - 60.33) \cdot 12 \cdot 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $ta = 3.5839 \text{ mm.}$
 Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$
 Wall Thickness, shell/head, internal pressure $trb1 = 10.5487 \text{ mm.}$
 Wall Thickness $tb1 = \max(trb1, tr16b) = 10.5487 \text{ mm.}$
 Wall Thickness, shell/head, external pressure $trb2 = 3.3576 \text{ mm.}$
 Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A3 Noz1: 18 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.55, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.0,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification -46 °C

Calculated Minimum Design Metal Temperature -104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification -46 °C

Calculated Minimum Design Metal Temperature -104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

Min Metal Temp. at Required thickness (UCS 66.1) -104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.549, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.839, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A3 Noz1: 18 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.00 / 51.10 = 0.450$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: A3

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * tmin.$	$5.6560 = 0.7 * Wo$ mm.
Pad Weld	$4.5000 = 0.5 * TminPad$	$7.0700 = 0.7 * Wp$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.954 - 0.721 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 7.549))) 137.9) \\
 &= 46.17 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv \\
 &= (1.563 + 5.009 + 0.547 - 0 * 0.855) * 137.9 \\
 &= 98.16 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.563 + 0 + 0.547 + (0.715)) * 137.9 \\
 &= 38.95 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.563 + 0 + 0.547 + 5.009 + (0.715)) * 137.9 \\
 &= 108.02 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 60.33 * 8 * 0.49 * 117.9 \\
 &= 44. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: A3

Noz1: 18 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (43.79 + 116 + 87.02 + 0) = 246.8 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (170.2 + 87.02 + 0) = 257.2 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 98 kN
 Path 2-2 = 246 kN , must exceed W = 46 kN or W2 = 38 kN
 Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 108 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.329 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

Input Echo, WRC107/537 Item 1, Description: A3 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: A3 Nozl: 18 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.325	mm.
Design Internal Pressure	Dp	23.000	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	Vl	2.0	kN
Circumferential Shear (SUS)	Vc	2.0	kN
Circumferential Moment (SUS)	Mc	400.0	N-m
Longitudinal Moment (SUS)	Ml	400.0	N-m
Torsional Moment (SUS)	Mt	500.0	N-m

Use Interactive Control	No
WRC107 Version	Version March 1979
Include Pressure Stress Indices per Div. 2	No
Compute Pressure Stress per WRC-368	No
Local Loads applied at end of Nozzle/Attachment	No

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: A3 Noz1: 18 11:52pm Dec 24,2021

N(x) / (P/Rm)	0.058	4C	4.229	(C,D)
M(x) / (P)	0.058	1C1	0.207	(A,B)
M(x) / (P)	0.058	2C	0.166	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at								
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl	
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	0.4	0.4	0.4	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4	
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0	
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0	
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4	
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5	
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	0.5	0.5	0.5	
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9	
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0	
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0	
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8	
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0	
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0	
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2	
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0	

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.575	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.538	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.077	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.450	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.538	(A,B)
N(x) / (P/Rm)	0.155	4C	7.575	(C,D)
M(x) / (P)	0.155	1C1	0.080	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.512	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: A3 Noz1: 18 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.955 (A,B,C,D)
 M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl

Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.4	33.4	33.4	-33.4
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.6	12.6	12.6	-12.6	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.5	7.8	10.0	-2.2	-50.5	39.3	22.1	-21.8

Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.7	16.7	16.7	-16.7
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.7	17.7	17.7	-17.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.1	24.2	5.8	-5.8	-31.8	14.6	11.5	-9.1

Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3

Str. Int.		36.0	24.5	10.1	5.9	50.5	39.3	22.6	22.2

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl

Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9

Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4

Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Pm+Pl (SUS)	45.6	47.9	48.6	50.9	46.7	49.0	47.5	49.8
Pm+Pl+Q (Total)	33.7	66.2	56.9	43.4	20.4	76.2	64.2	35.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.25	137.90	Passed
Pm+Pl (SUS)	50.93	206.85	Passed
Pm+Pl+Q (TOTAL)	76.20	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Circ. Pl (SUS)		-11.3	-11.3	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.1	19.1	6.1	-6.1	-44.9	44.9	22.0	-22.0
Long. Pm (SUS)		56.7	56.7	56.7	56.7	56.7	56.7	56.7	56.7
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.7	29.7	5.8	-5.8	-23.2	23.2	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Pm+Pl (SUS)		102.0	104.3	117.3	119.6	107.8	110.1	113.5	115.8
Pm+Pl+Q (Total)		83.0	123.6	123.4	113.4	62.9	155.0	135.5	93.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.67	137.90	Passed
Pm+Pl (SUS)	119.59	206.85	Passed
Pm+Pl+Q (TOTAL)	155.00	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT1

Noz1: 19 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: LT1 From : 20


Pressure for Reinforcement Calculations	P	23.040	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		3700.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		180.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: LT1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23.04 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23.04)$$

$$= 7.5621 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.04 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23.04)$$

$$= 0.5849 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684 mm.
Parallel to Vessel Wall, opening length	d	51.0342 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

Nozzle Calcs.: LT1 Nozl: 19 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.961	1.483	NA
Area in Shell	A1	0.714	1.658	NA
Area in Nozzle Wall	A2	1.562	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.141	9.198	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	67.2364	12.0000 mm.
Based on given Pad Diameter:	160.3250	1.9868 mm.
Based on Shell or Nozzle Thickness:	71.1729	7.6454 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 * 7.562 * 1 + 2 * 4.645 * 7.562 * 1 * (1 - 0.855))$$

$$= 3.961 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 51.03 (1 * 9 - 1 * 7.562) - 2 * 4.645 (1 * 9 - 1 * 7.562) * (1 - 0.855)$$

$$= 0.714 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 22.5) * (4.645 - 0.585) * 0.855$$

$$= 1.562 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (102.1 - 60.33) * 12 * 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5849 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 10.5621 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 10.5621 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.3576 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT1

Noz1: 19 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.56, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.585, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:
This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:
This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.562, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.84$, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Governing MDMT of the Nozzle	: -104 °C
Governing MDMT of the Reinforcement Pad	: -48 °C
Governing MDMT of all the sub-joints of this Junction	: -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT1

Noz1: 19 11:52pm Dec 24,2021

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i) (2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i) (3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :
 Design Pressure/Ambient Rating = 23.04/51.10 = 0.451

Note:
 Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: LT1

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	3.2518 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.
Pad Weld	4.5000 = 0.5*TminPad	7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:
 $= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$
 $= \max(0, (3.961 - 0.714 + 2 * 4.645 * 0.855 * (1 * 9 - 7.562)) 137.9)$
 $= 46.34 \text{ kN}$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:
 $= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv$
 $= (1.562 + 5.009 + 0.855 - 0 * 0.855) * 137.9$
 $= 102.40 \text{ kN}$

Weld Load [W2]:
 $= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$
 $= (1.562 + 0 + 0.855 + (0.715)) * 137.9$
 $= 43.19 \text{ kN}$

Weld Load [W3]:
 $= (A2+A3+A4+A5+(2*tn*t*fr1))*S$
 $= (1.562 + 0 + 0.855 + 5.009 + (0.715)) * 137.9$
 $= 112.26 \text{ kN}$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:
 $= (\pi/2) * Dlo * Wo * 0.49 * Snw$
 $= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9$
 $= 55. \text{ kN}$

Shear, Pad Element Weld [Spew]:
 $= (\pi/2) * DP * WP * 0.49 * SEW$
 $= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$
 $= 170. \text{ kN}$

Shear, Nozzle Wall [Snw]:
 $= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$
 $= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$
 $= 34. \text{ kN}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0
Nozzle Calcs.: LTI

Noz1: 19 11:52pm Dec 24,2021

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned} &= (\pi/2) * D_{lo} * W_{gpn} * 0.74 * S_{eg} \\ &= (3.142/2) * 60.33 * 12 * 0.74 * 137.9 \\ &= 116. \text{ kN} \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned} &= (\pi/2) * D_{lo} * (W_{gnvi-Cas}) * 0.74 * S_{ng} \\ &= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9 \\ &= 87. \text{ kN} \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned} \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN} \\ \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\ &= (54.74 + 116 + 87.02 + 0) = 257.8 \text{ kN} \\ \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\ &= (170.2 + 87.02 + 0) = 257.2 \text{ kN} \end{aligned}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 102 kN
Path 2-2 = 257 kN , must exceed W = 46 kN or W2 = 43 kN
Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.369 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT2

Noz1: 20 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: LT2 From : 20

Pressure for Reinforcement Calculations	P	23.000	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		3700.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT2

Noz1: 20 11:52pm Dec 24,2021

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: LT2

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (23 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23) \\
 &= 7.5487 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23) \\
 &= 0.5839 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684 mm.
Parallel to Vessel Wall, opening length	d	51.0342 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr4]:

$$\begin{aligned}
 &= \min(1, S_p / S_v) \\
 &= \min(1, 137.9 / 137.9) \\
 &= 1.000
 \end{aligned}$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: LT2

Noz1: 20 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.954	1.483	NA
Area in Shell	A1	0.721	1.658	NA
Area in Nozzle Wall	A2	1.563	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.148	9.198	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.

The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness

Based on given Pad Thickness: 67.1197 12.0000 mm.

Based on given Pad Diameter: 160.3250 1.9533 mm.

Based on Shell or Nozzle Thickness: 70.9898 7.6454 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 \cdot 7.549 \cdot 1 + 2 \cdot 4.645 \cdot 7.549 \cdot 1 \cdot (1 - 0.855))$$

$$= 3.954 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 51.03 \cdot (1 \cdot 9 - 1 \cdot 7.549) - 2 \cdot 4.645 \cdot (1 \cdot 9 - 1 \cdot 7.549) \cdot (1 - 0.855)$$

$$= 0.721 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 22.5) \cdot (4.645 - 0.584) \cdot 0.855$$

$$= 1.563 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 10^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (102.1 - 60.33) \cdot 12 \cdot 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $ta = 3.5839 \text{ mm.}$

Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$

Wall Thickness, shell/head, internal pressure $trb1 = 10.5487 \text{ mm.}$

Wall Thickness $tb1 = \max(trb1, tr16b) = 10.5487 \text{ mm.}$

Wall Thickness, shell/head, external pressure $trb2 = 3.3576 \text{ mm.}$

Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT2

Noz1: 20 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.55, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.0,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.549, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.839, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT2

Noz1: 20 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.00 / 51.10 = 0.450$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: LT2

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * tmin.$	$7.0700 = 0.7 * Wo$ mm.
Pad Weld	$4.5000 = 0.5 * TminPad$	$7.0700 = 0.7 * Wp$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.954 - 0.721 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 7.549)) 137.9) \\
 &= 46.17 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv \\
 &= (1.563 + 5.009 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 102.41 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.563 + 0 + 0.855 + (0.715)) * 137.9 \\
 &= 43.19 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.563 + 0 + 0.855 + 5.009 + (0.715)) * 137.9 \\
 &= 112.27 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9 \\
 &= 55. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LT2

Noz1: 20 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (54.74 + 116 + 87.02 + 0) = 257.8 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (170.2 + 87.02 + 0) = 257.2 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 102 kN
 Path 2-2 = 257 kN , must exceed W = 46 kN or W2 = 43 kN
 Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.329 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

Input Echo, WRC107/537 Item 1, Description: LT2 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: LT2 Nozl: 20 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.325	mm.
Design Internal Pressure	Dp	23.000	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load	(SUS)	P	2.0	kN
Longitudinal Shear	(SUS)	Vl	2.0	kN
Circumferential Shear	(SUS)	Vc	2.0	kN
Circumferential Moment	(SUS)	Mc	400.0	N-m
Longitudinal Moment	(SUS)	Ml	400.0	N-m
Torsional Moment	(SUS)	Mt	500.0	N-m

Use Interactive Control		No
WRC107 Version	Version	March 1979
Include Pressure Stress Indices per Div. 2		No
Compute Pressure Stress per WRC-368		No
Local Loads applied at end of Nozzle/Attachment		No

Note:
 WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:
 = NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: LT2 Noz1: 20 11:52pm Dec 24,2021

N(x)	/ (P/Rm)	0.058	4C	4.229	(C,D)
M(x)	/ (P)	0.058	1C1	0.207	(A,B)
M(x)	/ (P)	0.058	2C	0.166	(C,D)
N(x)	/ (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x)	/ (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x)	/ (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x)	/ (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	-0.5	0.5	0.5
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.575	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.538	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.077	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.450	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.538	(A,B)
N(x) / (P/Rm)	0.155	4C	7.575	(C,D)
M(x) / (P)	0.155	1C1	0.080	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.512	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: LT2 Noz1: 20 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.955 (A,B,C,D)
 M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.4	33.4	33.4	-33.4
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.6	12.6	12.6	-12.6	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.5	7.8	10.0	-2.2	-50.5	39.3	22.1	-21.8
Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.7	16.7	16.7	-16.7
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.7	17.7	17.7	-17.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.1	24.2	5.8	-5.8	-31.8	14.6	11.5	-9.1
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3
Str. Int.		36.0	24.5	10.1	5.9	50.5	39.3	22.6	22.2

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Pm+Pl (SUS)	45.6	47.9	48.6	50.9	46.7	49.0	47.5	49.8
Pm+Pl+Q (Total)	33.7	66.2	56.9	43.4	20.4	76.2	64.2	35.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.25	137.90	Passed
Pm+Pl (SUS)	50.93	206.85	Passed
Pm+Pl+Q (TOTAL)	76.20	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Circ. Pl (SUS)		-11.3	-11.3	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.1	19.1	6.1	-6.1	-44.9	44.9	22.0	-22.0
Long. Pm (SUS)		56.7	56.7	56.7	56.7	56.7	56.7	56.7	56.7
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.7	29.7	5.8	-5.8	-23.2	23.2	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Pm+Pl (SUS)		102.0	104.3	117.3	119.6	107.8	110.1	113.5	115.8
Pm+Pl+Q (Total)		83.0	123.6	123.4	113.4	62.9	155.0	135.5	93.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.67	137.90	Passed
Pm+Pl (SUS)	119.59	206.85	Passed
Pm+Pl+Q (TOTAL)	155.00	413.70	Passed

Noz1: 21 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: D From : 20


Pressure for Reinforcement Calculations	P	23.040	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		300.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		180.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.0000	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		49.8375	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: D

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23.04 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23.04)$$

$$= 7.5621 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.04 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23.04)$$

$$= 0.5849 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684 mm.
Parallel to Vessel Wall, opening length	d	51.0342 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: D Nozl: 21 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.961	1.483	NA
Area in Shell	A1	0.714	1.658	NA
Area in Nozzle Wall	A2	1.562	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.141	9.198	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS: Diameter Thickness
 Based on given Pad Thickness: 67.2364 12.0000 mm.
 Based on given Pad Diameter: 160.0000 1.9868 mm.
 Based on Shell or Nozzle Thickness: 71.1729 7.6454 mm.

Area Required [A]:

$$= (d \cdot tr \cdot F + 2 \cdot tn \cdot tr \cdot F \cdot (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 \cdot 7.562 \cdot 1 + 2 \cdot 4.645 \cdot 7.562 \cdot 1 \cdot (1 - 0.855))$$

$$= 3.961 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d \cdot (E1 \cdot t - F \cdot tr) - 2 \cdot tn \cdot (E1 \cdot t - F \cdot tr) \cdot (1 - fr1)$$

$$= 51.03 \cdot (1 \cdot 9 - 1 \cdot 7.562) - 2 \cdot 4.645 \cdot (1 \cdot 9 - 1 \cdot 7.562) \cdot (1 - 0.855)$$

$$= 0.714 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 \cdot Tlwp) \cdot (tn - trn) \cdot fr2$$

$$= (2 \cdot 22.5) \cdot (4.645 - 0.585) \cdot 0.855$$

$$= 1.562 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 \cdot fr3 + (Wi - can/0.707)^2 \cdot fr2 + Wp^2 \cdot fr4$$

$$= 10^2 \cdot 0.855 + (0)^2 \cdot 0.855 + 0^2 \cdot 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - \text{Nozzle OD}) \cdot (\min(tp, Tlwp, te)) \cdot fr4$$

$$= (102.1 - 60.33) \cdot 12 \cdot 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures $ta = 3.5849 \text{ mm.}$
 Wall Thickness per UG16(b), $tr16b = 4.5000 \text{ mm.}$
 Wall Thickness, shell/head, internal pressure $trb1 = 10.5621 \text{ mm.}$
 Wall Thickness $tb1 = \max(trb1, tr16b) = 10.5621 \text{ mm.}$
 Wall Thickness, shell/head, external pressure $trb2 = 3.3576 \text{ mm.}$
 Wall Thickness $tb2 = \max(trb2, tr16b) = 4.5000 \text{ mm.}$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: D Noz1: 21 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.56, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.585, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.1,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.562, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.84, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: D Noz1: 21 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.04 / 51.10 = 0.451$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: D

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * tmin.$	$7.0700 = 0.7 * Wo$ mm.
Pad Weld	$4.5000 = 0.5 * TminPad$	$7.0700 = 0.7 * Wp$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv)$$

$$= \max(0, (3.961 - 0.714 + 2 * 4.645 * 0.855 * (1 * 9 - 7.562)) 137.9)$$

$$= 46.34 \text{ kN}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv$$

$$= (1.562 + 5.009 + 0.855 - 0 * 0.855) * 137.9$$

$$= 102.40 \text{ kN}$$

Weld Load [W2]:

$$= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv$$

$$= (1.562 + 0 + 0.855 + (0.715)) * 137.9$$

$$= 43.19 \text{ kN}$$

Weld Load [W3]:

$$= (A2+A3+A4+A5+(2*tn*t*fr1))*S$$

$$= (1.562 + 0 + 0.855 + 5.009 + (0.715)) * 137.9$$

$$= 112.26 \text{ kN}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$= (\pi/2) * Dlo * Wo * 0.49 * Snw$$

$$= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9$$

$$= 55. \text{ kN}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: D

Noz1: 21 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160 * 10 * 0.49 * 137.9$$

$$= 170. kN$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. kN$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. kN$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. kN$$

Strength of Failure Paths:

$$PATH11 = (SPEW + SNW) = (169.8 + 33.53) = 203.3 kN$$

$$PATH22 = (Sonw + Tpgw + Tngw + Sinw)$$

$$= (54.74 + 116 + 87.02 + 0) = 257.8 kN$$

$$PATH33 = (Spew + Tngw + Sinw)$$

$$= (169.8 + 87.02 + 0) = 256.8 kN$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 102 kN
 Path 2-2 = 257 kN , must exceed W = 46 kN or W2 = 43 kN
 Path 3-3 = 256 kN , must exceed W = 46 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.369 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.
 The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

Input Echo, WRC107/537 Item 1, Description: D :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: D Nozl: 21 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.000	mm.
Design Internal Pressure	Dp	23.040	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	Vl	2.0	kN
Circumferential Shear (SUS)	Vc	2.0	kN
Circumferential Moment (SUS)	Mc	400.0	N-m
Longitudinal Moment (SUS)	Ml	400.0	N-m
Torsional Moment (SUS)	Mt	500.0	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: D Noz1: 21 11:52pm Dec 24,2021

N(x) / (P/Rm)	0.058	4C	4.229	(C,D)
M(x) / (P)	0.058	1C1	0.207	(A,B)
M(x) / (P)	0.058	2C	0.166	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at								
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl	
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4	
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0	
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0	
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4	
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5	
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	-0.5	0.5	0.5	
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9	
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0	
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0	
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8	
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0	
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0	
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2	
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0	

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.581	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.549	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.078	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.454	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.549	(A,B)
N(x) / (P/Rm)	0.155	4C	7.581	(C,D)
M(x) / (P)	0.155	1C1	0.081	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.507	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: D Noz1: 21 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.954 (A,B,C,D)
 M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.9	-2.9	2.9	2.9
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.5	33.5	33.5	-33.5
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.7	12.7	12.7	-12.7	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.6	7.8	10.1	-2.2	-50.6	39.4	22.2	-21.9
Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.8	16.8	16.8	-16.8
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.8	17.8	17.8	-17.8	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.2	24.3	5.9	-5.9	-31.9	14.6	11.5	-9.1
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3
Str. Int.		36.1	24.6	10.1	5.9	50.6	39.4	22.6	22.3

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Nozzle Calcs.: D Noz1: 21 11:52pm Dec 24,2021

Pm+Pl (SUS)	45.7	48.0	48.7	51.0	46.8	49.1	47.6	49.9
Pm+Pl+Q (Total)	33.7	66.3	57.0	43.5	20.5	76.3	64.3	35.3

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.34	137.90	Passed
Pm+Pl (SUS)	51.02	206.85	Passed
Pm+Pl+Q (TOTAL)	76.29	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.6	115.9	113.6	115.9	113.6	115.9	113.6	115.9
Circ. Pl (SUS)		-11.4	-11.4	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.2	19.2	6.2	-6.2	-45.0	45.0	22.0	-22.0
Long. Pm (SUS)		56.8	56.8	56.8	56.8	56.8	56.8	56.8	56.8
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.8	29.8	5.9	-5.9	-23.3	23.3	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.6	115.9	113.6	115.9	113.6	115.9	113.6	115.9
Pm+Pl (SUS)		102.2	104.5	117.5	119.8	108.0	110.3	113.7	116.0
Pm+Pl+Q (Total)		83.1	123.8	123.7	113.6	63.0	155.3	135.8	94.1

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.87	137.90	Passed
Pm+Pl (SUS)	119.81	206.85	Passed
Pm+Pl+Q (TOTAL)	155.31	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG1

Noz1: 22 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: LG1 From : 20


Pressure for Reinforcement Calculations	P	23.040	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		2500.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		180.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: LG1

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation 2.375 in.
 Actual Thickness Used in Calculation 0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)}$$

$$= (23.04 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23.04)$$

$$= 7.5621 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.04 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23.04)$$

$$= 0.5849 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684	mm.
Parallel to Vessel Wall, opening length	d	51.0342	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000	mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr2]:

$$= \min(1, S_n / S_v)$$

$$= \min(1, 117.9 / 137.9)$$

$$= 0.855$$

Weld Strength Reduction Factor [fr4]:

$$= \min(1, S_p / S_v)$$

$$= \min(1, 137.9 / 137.9)$$

$$= 1.000$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

Nozzle Calcs.: LG1 Nozl: 22 11:52pm Dec 24,2021

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.961	1.483	NA
Area in Shell	A1	0.714	1.658	NA
Area in Nozzle Wall	A2	1.562	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.141	9.198	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	67.2364	12.0000 mm.
Based on given Pad Diameter:	160.3250	1.9868 mm.
Based on Shell or Nozzle Thickness:	71.1729	7.6454 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 * 7.562 * 1 + 2 * 4.645 * 7.562 * 1 * (1 - 0.855))$$

$$= 3.961 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 51.03 (1 * 9 - 1 * 7.562) - 2 * 4.645 (1 * 9 - 1 * 7.562) * (1 - 0.855)$$

$$= 0.714 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 22.5) * (4.645 - 0.585) * 0.855$$

$$= 1.562 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (102.1 - 60.33) * 12 * 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5849 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 10.5621 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 10.5621 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.3576 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: LG1 Noz1: 22 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.56, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.585, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.1,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.562, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.84, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: LG1 Noz1: 22 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C
Governing MDMT of the Nozzle	: -104 °C
Governing MDMT of the Reinforcement Pad	: -48 °C
Governing MDMT of all the sub-joints of this Junction	: -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification	-46 °C
Flange MDMT with Temp reduction per UCS-66(i)(2)	-48 °C
Flange MDMT with Temp reduction per UCS-66(i)(3)	-104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.04 / 51.10 = 0.451$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: LG1

Intermediate Calc. for nozzle/shell Welds	Tmin	4.6454 mm.
Intermediate Calc. for pad/shell Welds	TminPad	9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * tmin.$	$7.0700 = 0.7 * Wo$ mm.
Pad Weld	$4.5000 = 0.5 * TminPad$	$7.0700 = 0.7 * Wp$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.961 - 0.714 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 7.562)) 137.9) \\
 &= 46.34 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv \\
 &= (1.562 + 5.009 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 102.40 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.562 + 0 + 0.855 + (0.715)) * 137.9 \\
 &= 43.19 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.562 + 0 + 0.855 + 5.009 + (0.715)) * 137.9 \\
 &= 112.26 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9 \\
 &= 55. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG1

Noz1: 22 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (54.74 + 116 + 87.02 + 0) = 257.8 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (170.2 + 87.02 + 0) = 257.2 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 102 kN
 Path 2-2 = 257 kN , must exceed W = 46 kN or W2 = 43 kN
 Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.369 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

Input Echo, WRC107/537 Item 1, Description: LG1 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: LG1 Nozl: 22 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.325	mm.
Design Internal Pressure	Dp	23.040	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	Vl	2.0	kN
Circumferential Shear (SUS)	Vc	2.0	kN
Circumferential Moment (SUS)	Mc	400.0	N-m
Longitudinal Moment (SUS)	Ml	400.0	N-m
Torsional Moment (SUS)	Mt	500.0	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: LGL Nozl: 22 11:52pm Dec 24,2021

N(x) / (P/Rm)	0.058	4C	4.229	(C,D)
M(x) / (P)	0.058	1C1	0.207	(A,B)
M(x) / (P)	0.058	2C	0.166	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x) / (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x) / (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at								
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl	
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4	
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0	
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0	
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4	
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5	
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	-0.5	0.5	0.5	
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9	
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0	
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0	
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8	
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0	
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0	
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2	
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0	

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.575	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.538	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.077	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.450	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.538	(A,B)
N(x) / (P/Rm)	0.155	4C	7.575	(C,D)
M(x) / (P)	0.155	1C1	0.080	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.512	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: LG1 Noz1: 22 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.955 (A,B,C,D)
M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.4	33.4	33.4	-33.4
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.6	12.6	12.6	-12.6	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.5	7.8	10.0	-2.2	-50.5	39.3	22.1	-21.8
Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.7	16.7	16.7	-16.7
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.7	17.7	17.7	-17.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.1	24.2	5.8	-5.8	-31.8	14.6	11.5	-9.1
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3
Str. Int.		36.0	24.5	10.1	5.9	50.5	39.3	22.6	22.2

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Pm+Pl (SUS)	45.7	48.0	48.7	51.0	46.8	49.1	47.6	49.9
Pm+Pl+Q (Total)	33.7	66.3	57.0	43.5	20.5	76.3	64.3	35.3

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.34	137.90	Passed
Pm+Pl (SUS)	51.02	206.85	Passed
Pm+Pl+Q (TOTAL)	76.29	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.6	115.9	113.6	115.9	113.6	115.9	113.6	115.9
Circ. Pl (SUS)		-11.3	-11.3	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.1	19.1	6.1	-6.1	-44.9	44.9	22.0	-22.0
Long. Pm (SUS)		56.8	56.8	56.8	56.8	56.8	56.8	56.8	56.8
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.7	29.7	5.8	-5.8	-23.2	23.2	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.6	115.9	113.6	115.9	113.6	115.9	113.6	115.9
Pm+Pl (SUS)		102.2	104.5	117.5	119.8	108.0	110.3	113.7	116.0
Pm+Pl+Q (Total)		83.2	123.8	123.6	113.6	63.1	155.2	135.7	94.1

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.87	137.90	Passed
Pm+Pl (SUS)	119.79	206.85	Passed
Pm+Pl+Q (TOTAL)	155.20	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG2

Noz1: 23 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: LG2 From : 20

Pressure for Reinforcement Calculations	P	23.000	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Cylindrical Shell	D	890.00	mm.
Design Length of Section	L	4148.3335	mm.
Shell Finished (Minimum) Thickness	t	12.0000	mm.
Shell Internal Corrosion Allowance	c	3.0000	mm.
Shell External Corrosion Allowance	co	0.0000	mm.
Distance from Bottom/Left Tangent		2500.00	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle


Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		0.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG2

Noz1: 23 11:52pm Dec 24,2021

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Reinforcement CALCULATION, Description: LG2

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Cylindrical Shell, Tr [Int. Press]

$$\begin{aligned}
 &= (P \cdot R) / (S_v \cdot E - 0.6 \cdot P) \text{ per UG-27 (c) (1)} \\
 &= (23 \cdot 448) / (137.9 \cdot 1 - 0.6 \cdot 23) \\
 &= 7.5487 \text{ mm.}
 \end{aligned}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$\begin{aligned}
 &= (P \cdot R_o) / (S_n \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)} \\
 &= (23 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23) \\
 &= 0.5839 \text{ mm.}
 \end{aligned}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	102.0684 mm.
Parallel to Vessel Wall, opening length	d	51.0342 mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr2]:

$$\begin{aligned}
 &= \min(1, S_n / S_v) \\
 &= \min(1, 117.9 / 137.9) \\
 &= 0.855
 \end{aligned}$$

Weld Strength Reduction Factor [fr4]:

$$\begin{aligned}
 &= \min(1, S_p / S_v) \\
 &= \min(1, 137.9 / 137.9) \\
 &= 1.000
 \end{aligned}$$

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.954	1.483	NA
Area in Shell	A1	0.721	1.658	NA
Area in Nozzle Wall	A2	1.563	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.148	9.198	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	67.1197	12.0000 mm.
Based on given Pad Diameter:	160.3250	1.9533 mm.
Based on Shell or Nozzle Thickness:	70.9898	7.6454 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) \text{ UG-37(c)}$$

$$= (51.03 * 7.549 * 1 + 2 * 4.645 * 7.549 * 1 * (1 - 0.855))$$

$$= 3.954 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d * (E1 * t - F * tr) - 2 * tn * (E1 * t - F * tr) * (1 - fr1)$$

$$= 51.03 * (1 * 9 - 1 * 7.549) - 2 * 4.645 * (1 * 9 - 1 * 7.549) * (1 - 0.855)$$

$$= 0.721 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 22.5) * (4.645 - 0.584) * 0.855$$

$$= 1.563 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (\text{Nozzle OD})) * (\min(tp, Tlwp, te)) * fr4$$

$$= (102.1 - 60.33) * 12 * 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5839 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 10.5487 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 10.5487 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.3576 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG2

Noz1: 23 11:52pm Dec 24,2021

Wall Thickness per table UG-45 tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:
 = min[tb3, max(tb1,tb2)]
 = min[6.42, max(10.55, 4.5)]
 = 6.4200 mm.

Minimum Wall Thickness of Nozzle Necks [tUG-45]:
 = max(ta, tb)
 = max(3.584, 6.42)
 = 6.4200 mm.

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

**Stresses on Nozzle due to External and Pressure Loads per the ASME
 B31.3 Piping Code (see 319.4.4 and 302.3.5):**

Sustained	:	62.0,	Allowable	:	117.9 N./mm ²	Passed
Expansion	:	0.0,	Allowable	:	232.7 N./mm ²	Passed
Occasional	:	5.8,	Allowable	:	156.8 N./mm ²	Passed
Shear	:	33.9,	Allowable	:	82.5 N./mm ²	Passed

Note : The number of cycles on this nozzle was assumed to be 7000 or less for the determination of the expansion stress allowable.

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.126, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

Govrn. thk, tg = 12, tr = 7.549, c = 3 mm., E* = 1
 Thickness Ratio = tr * (E*)/(tg - c) = 0.839, Temp. Reduction = 9 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

Govrn. thk, tg = 7.645, tr = 0.584, c = 3 mm., E* = 1

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG2

Noz1: 23 11:52pm Dec 24,2021

Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D -48 °C
 Min Metal Temp. at Required thickness (UCS 66.1) -104 °C
 Governing MDMT of the Nozzle : -104 °C
 Governing MDMT of the Reinforcement Pad : -48 °C
 Governing MDMT of all the sub-joints of this Junction : -48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification -46 °C
 Flange MDMT with Temp reduction per UCS-66(i)(2) -48 °C
 Flange MDMT with Temp reduction per UCS-66(i)(3) -104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.00 / 51.10 = 0.450$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: LG2

Intermediate Calc. for nozzle/shell Welds Tmin 4.6454 mm.
 Intermediate Calc. for pad/shell Welds TminPad 9.0000 mm.

Results Per UW-16.1:

	Required Thickness	Actual Thickness
Nozzle Weld	$3.2518 = 0.7 * t_{min}$	$7.0700 = 0.7 * W_o$ mm.
Pad Weld	$4.5000 = 0.5 * T_{minPad}$	$7.0700 = 0.7 * W_p$ mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.954 - 0.721 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 7.549)) 137.9) \\
 &= 46.17 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4 - (Wi-Can/.707)^2*fr2) * Sv \\
 &= (1.563 + 5.009 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 102.41 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.563 + 0 + 0.855 + (0.715)) * 137.9 \\
 &= 43.19 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.563 + 0 + 0.855 + 5.009 + (0.715)) * 137.9 \\
 &= 112.27 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * D_{lo} * W_o * 0.49 * S_{nw} \\
 &= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9 \\
 &= 55. \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: LG2

Noz1: 23 11:52pm Dec 24,2021

Shear, Pad Element Weld [Spew]:

$$= (\pi/2) * DP * WP * 0.49 * SEW$$

$$= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9$$

$$= 170. \text{ kN}$$

Shear, Nozzle Wall [Snw]:

$$= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn$$

$$= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9$$

$$= 34. \text{ kN}$$

Tension, Pad Groove Weld [Tpgw]:

$$= (\pi/2) * Dlo * Wgpn * 0.74 * Seg$$

$$= (3.142/2) * 60.33 * 12 * 0.74 * 137.9$$

$$= 116. \text{ kN}$$

Tension, Shell Groove Weld [Tngw]:

$$= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng$$

$$= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9$$

$$= 87. \text{ kN}$$

Strength of Failure Paths:

$$\text{PATH11} = (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN}$$

$$\text{PATH22} = (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw})$$

$$= (54.74 + 116 + 87.02 + 0) = 257.8 \text{ kN}$$

$$\text{PATH33} = (\text{Spew} + \text{Tngw} + \text{Sinw})$$

$$= (170.2 + 87.02 + 0) = 257.2 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 46 kN or W1 = 102 kN
 Path 2-2 = 257 kN , must exceed W = 46 kN or W2 = 43 kN
 Path 3-3 = 257 kN , must exceed W = 46 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.329 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 1.0234 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 163.0234 mm.

Input Echo, WRC107/537 Item 1, Description: LG2 :

Diameter Basis for Vessel	Vbasis	ID	
Cylindrical or Spherical Vessel	Cylsph	Cylindrical	
Internal Corrosion Allowance	Cas	3.0000	mm.
Vessel Diameter	Dv	890.000	mm.
Vessel Thickness	Tv	12.000	mm.
Design Temperature		135.00	°C
Vessel Material		SA-516 70	
Vessel Cold S.I. Allowable	Smc	137.90	N./mm ²
Vessel Hot S.I. Allowable	Smh	137.90	N./mm ²
Attachment Type	Type	Round	
Diameter Basis for Nozzle	Nbasis	OD	
Corrosion Allowance for Nozzle	Can	3.0000	mm.
Nozzle Diameter	Dn	60.325	mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: LG2 Nozl: 23 11:52pm Dec 24,2021

Nozzle Thickness	Tn	7.645	mm.
Nozzle Material		SA-333 6	
Nozzle Cold S.I. Allowable	SNmc	117.90	N./mm ²
Nozzle Hot S.I. Allowable	SNmh	117.90	N./mm ²
Thickness of Reinforcing Pad	Tpad	12.000	mm.
Diameter of Reinforcing Pad	Dpad	160.325	mm.
Design Internal Pressure	Dp	23.000	bar
Include Pressure Thrust		No	

External Forces and Moments in WRC 107/537 Convention:

Radial Load (SUS)	P	2.0	kN
Longitudinal Shear (SUS)	Vl	2.0	kN
Circumferential Shear (SUS)	Vc	2.0	kN
Circumferential Moment (SUS)	Mc	400.0	N-m
Longitudinal Moment (SUS)	Ml	400.0	N-m
Torsional Moment (SUS)	Mt	500.0	N-m

Use Interactive Control		No	
WRC107 Version	Version	March	1979
Include Pressure Stress Indices per Div. 2		No	
Compute Pressure Stress per WRC-368		No	
Local Loads applied at end of Nozzle/Attachment		No	

Note:

WRC Bulletin 537 provides equations for the dimensionless curves found in bulletin 107. As noted in the foreword to bulletin 537, "537 is equivalent to WRC 107". Where 107 is printed in the results below, "537" can be interchanged with "107".

Stress Attenuation Diameter (for Insert Plates) per WRC 297:

= NozzleOD + 2 * 1.65 * sqrt(Rmean(t - ca))
 = 60.325 + 2 * 1.65 * sqrt(452.5 (12.0 - 3.0))
 = 270.918 mm.

WRC 107 Stress Calculation for SUSTained loads:

Radial Load	P	2.0	kN
Circumferential Shear	VC	2.0	kN
Longitudinal Shear	VL	2.0	kN
Circumferential Moment	MC	400.0	N-m
Longitudinal Moment	ML	400.0	N-m
Torsional Moment	MT	500.0	N-m

Dimensionless Parameters used : Gamma = 21.83

Dimensionless Loads for Cylindrical Shells at Attachment Junction:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.058	4C	4.229	(A,B)
N(PHI) / (P/Rm)	0.058	3C	4.165	(C,D)
M(PHI) / (P)	0.058	2C1	0.168	(A,B)
M(PHI) / (P)	0.058	1C	0.202	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.058	3A	0.246	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.058	1A	0.104	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.058	3B	0.967	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.058	1B	0.060	(A,B,C,D)
N(x) / (P/Rm)	0.058	3C	4.165	(A,B)

Nozzle Calcs.: LG2 Noz1: 23 11:52pm Dec 24,2021

N(x)	/ (P/Rm)	0.058	4C	4.229	(C,D)
M(x)	/ (P)	0.058	1C1	0.207	(A,B)
M(x)	/ (P)	0.058	2C	0.166	(C,D)
N(x)	/ (MC/(Rm**2 * Beta))	0.058	4A	0.309	(A,B,C,D)
M(x)	/ (MC/(Rm * Beta))	0.058	2A	0.063	(A,B,C,D)
N(x)	/ (ML/(Rm**2 * Beta))	0.058	4B	0.238	(A,B,C,D)
M(x)	/ (ML/(Rm * Beta))	0.058	2B	0.099	(A,B,C,D)

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Attachment Junction (N./mm^2)

Type of Stress	Load	Stress Intensity Values at								
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl	
Circ. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Circ. Bend. P		-4.6	4.6	-4.6	4.6	-5.5	5.5	-5.5	5.5	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-0.4	-0.4	0.4	0.4	
Circ. Memb. MC		0.0	0.0	0.0	0.0	-21.4	21.4	21.4	-21.4	
Circ. Memb. ML		-1.5	-1.5	1.5	1.5	0.0	0.0	0.0	0.0	
Circ. Bend. ML		-12.3	12.3	12.3	-12.3	0.0	0.0	0.0	0.0	
Tot. Circ. Str.		-19.3	14.5	8.4	-7.1	-28.2	25.7	15.4	-16.4	
Long. Memb. P		-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	-0.9	
Long. Bend. P		-5.6	5.6	-5.6	5.6	-4.5	4.5	-4.5	4.5	
Long. Memb. MC		0.0	0.0	0.0	0.0	-0.5	-0.5	0.5	0.5	
Long. Bend. MC		0.0	0.0	0.0	0.0	-12.9	12.9	12.9	-12.9	
Long. Memb. ML		-0.4	-0.4	0.4	0.4	0.0	0.0	0.0	0.0	
Long. Bend. ML		-20.5	20.5	20.5	-20.5	0.0	0.0	0.0	0.0	
Tot. Long. Str.		-27.4	24.9	14.3	-15.3	-18.8	16.1	8.0	-8.8	
Shear VC		1.0	1.0	-1.0	-1.0	0.0	0.0	0.0	0.0	
Shear VL		0.0	0.0	0.0	0.0	-1.0	-1.0	1.0	1.0	
Shear MT		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2	
Tot. Shear		5.2	5.2	3.2	3.2	3.2	3.2	5.2	5.2	
Str. Int.		29.9	27.0	15.7	16.4	29.1	26.6	18.1	19.0	

Dimensionless Parameters used : Gamma = 50.28

Dimensionless Loads for Cylindrical Shells at Pad edge:

Curves read for 1979	Beta	Figure	Value	Location
N(PHI) / (P/Rm)	0.155	4C	7.575	(A,B)
N(PHI) / (P/Rm)	0.155	3C	5.538	(C,D)
M(PHI) / (P)	0.155	2C1	0.044	(A,B)
M(PHI) / (P)	0.155	1C !	0.077	(C,D)
N(PHI) / (MC/(Rm**2 * Beta))	0.155	3A	2.036	(A,B,C,D)
M(PHI) / (MC/(Rm * Beta))	0.155	1A	0.079	(A,B,C,D)
N(PHI) / (ML/(Rm**2 * Beta))	0.155	3B	5.450	(A,B,C,D)
M(PHI) / (ML/(Rm * Beta))	0.155	1B	0.030	(A,B,C,D)
N(x) / (P/Rm)	0.155	3C	5.538	(A,B)
N(x) / (P/Rm)	0.155	4C	7.575	(C,D)
M(x) / (P)	0.155	1C1	0.080	(A,B)
M(x) / (P)	0.155	2C !	0.044	(C,D)
N(x) / (MC/(Rm**2 * Beta))	0.155	4A	3.512	(A,B,C,D)
M(x) / (MC/(Rm * Beta))	0.155	2A	0.040	(A,B,C,D)

Nozzle Calcs.: LG2 Noz1: 23 11:52pm Dec 24,2021

N(x) / (ML/(Rm**2 * Beta)) 0.155 4B 1.955 (A,B,C,D)
 M(x) / (ML/(Rm * Beta)) 0.155 2B 0.042 (A,B,C,D)

Note - The ! mark next to the figure name denotes curve value exceeded.

Stress Concentration Factors: Kn = 1.00, Kb = 1.00

Stresses in the Vessel at the Edge of Reinforcing Pad (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Memb. P		-3.7	-3.7	-3.7	-3.7	-2.7	-2.7	-2.7	-2.7
Circ. Bend. P		-6.5	6.5	-6.5	6.5	-11.5	11.5	-11.5	11.5
Circ. Memb. MC		0.0	0.0	0.0	0.0	-2.8	-2.8	2.8	2.8
Circ. Memb. MC		0.0	0.0	0.0	0.0	-33.4	33.4	33.4	-33.4
Circ. Memb. ML		-7.6	-7.6	7.6	7.6	0.0	0.0	0.0	0.0
Circ. Bend. ML		-12.6	12.6	12.6	-12.6	0.0	0.0	0.0	0.0
Tot. Circ. Str.		-30.5	7.8	10.0	-2.2	-50.5	39.3	22.1	-21.8
Long. Memb. P		-2.7	-2.7	-2.7	-2.7	-3.7	-3.7	-3.7	-3.7
Long. Bend. P		-11.9	11.9	-11.9	11.9	-6.5	6.5	-6.5	6.5
Long. Memb. MC		0.0	0.0	0.0	0.0	-4.9	-4.9	4.9	4.9
Long. Bend. MC		0.0	0.0	0.0	0.0	-16.7	16.7	16.7	-16.7
Long. Memb. ML		-2.7	-2.7	2.7	2.7	0.0	0.0	0.0	0.0
Long. Bend. ML		-17.7	17.7	17.7	-17.7	0.0	0.0	0.0	0.0
Tot. Long. Str.		-35.1	24.2	5.8	-5.8	-31.8	14.6	11.5	-9.1
Shear VC		0.9	0.9	-0.9	-0.9	0.0	0.0	0.0	0.0
Shear VL		0.0	0.0	0.0	0.0	-0.9	-0.9	0.9	0.9
Shear MT		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Tot. Shear		2.3	2.3	0.5	0.5	0.5	0.5	2.3	2.3
Str. Int.		36.0	24.5	10.1	5.9	50.5	39.3	22.6	22.2

WRC 107/537 Stress Summations:

Vessel Stress Summation at Attachment Junction (N./mm²)

		Stress Intensity Values at							
Type of Stress	Load	Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3
Circ. Pl (SUS)		-2.4	-2.4	0.6	0.6	-1.3	-1.3	-0.5	-0.5
Circ. Q (SUS)		-16.9	16.9	7.7	-7.7	-26.9	26.9	15.9	-15.9
Long. Pm (SUS)		24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0
Long. Pl (SUS)		-1.2	-1.2	-0.5	-0.5	-1.4	-1.4	-0.4	-0.4
Long. Q (SUS)		-26.1	26.1	14.8	-14.8	-17.4	17.4	8.4	-8.4
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		1.0	1.0	-1.0	-1.0	-1.0	-1.0	1.0	1.0
Shear Q (SUS)		4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2
Pm (SUS)		48.0	50.3	48.0	50.3	48.0	50.3	48.0	50.3

Pm+Pl (SUS)	45.6	47.9	48.6	50.9	46.7	49.0	47.5	49.8
Pm+Pl+Q (Total)	33.7	66.2	56.9	43.4	20.4	76.2	64.2	35.2

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	50.25	137.90	Passed
Pm+Pl (SUS)	50.93	206.85	Passed
Pm+Pl+Q (TOTAL)	76.20	413.70	Passed

WRC 107/537 Stress Summations:

Vessel Stress Summation at Reinforcing Pad Edge (N./mm²)

Type of Stress	Load	Stress Intensity Values at							
		Au	Al	Bu	Bl	Cu	Cl	Du	Dl
Circ. Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Circ. Pl (SUS)		-11.3	-11.3	3.9	3.9	-5.6	-5.6	0.1	0.1
Circ. Q (SUS)		-19.1	19.1	6.1	-6.1	-44.9	44.9	22.0	-22.0
Long. Pm (SUS)		56.7	56.7	56.7	56.7	56.7	56.7	56.7	56.7
Long. Pl (SUS)		-5.5	-5.5	0.0	0.0	-8.6	-8.6	1.2	1.2
Long. Q (SUS)		-29.7	29.7	5.8	-5.8	-23.2	23.2	10.3	-10.3
Shear Pm (SUS)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Shear Pl (SUS)		0.9	0.9	-0.9	-0.9	-0.9	-0.9	0.9	0.9
Shear Q (SUS)		1.4	1.4	1.4	1.4	1.4	1.4	1.4	1.4
Pm (SUS)		113.4	115.7	113.4	115.7	113.4	115.7	113.4	115.7
Pm+Pl (SUS)		102.0	104.3	117.3	119.6	107.8	110.1	113.5	115.8
Pm+Pl+Q (Total)		83.0	123.6	123.4	113.4	62.9	155.0	135.5	93.9

Stress Summation Comparison (N./mm²):

Type of Stress Int.	Max. S.I.	S.I. Allowable	Result
Pm (SUS)	115.67	137.90	Passed
Pm+Pl (SUS)	119.59	206.85	Passed
Pm+Pl+Q (TOTAL)	155.00	413.70	Passed

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: TI

Noz1: 24 11:52pm Dec 24,2021

INPUT VALUES, Nozzle Description: TI From : 30


Pressure for Reinforcement Calculations	P	23.034	bar
Temperature for Internal Pressure	Temp	135	°C
Design External Pressure	Pext	1.10	bar
Temperature for External Pressure	Tempex	100	°C
Shell Material [Normalized]		SA-516 70	
Shell Allowable Stress at Temperature	Sv	137.90	N./mm ²
Shell Allowable Stress At Ambient	Sva	137.90	N./mm ²
Inside Diameter of Elliptical Head	D	890.00	mm.
Aspect Ratio of Elliptical Head	Ar	2.00	
Head Finished (Minimum) Thickness	t	12.0000	mm.
Head Internal Corrosion Allowance	c	3.0000	mm.
Head External Corrosion Allowance	co	0.0000	mm.
Distance from Head Centerline	L1	300.0000	mm.
User Entered Minimum Design Metal Temperature		-45.00	°C

Type of Element Connected to the Shell : Nozzle

Material [Impact Tested]		SA-333 6	
Material UNS Number		K03006	
Material Specification/Type	Smls. & wld. pipe		
Allowable Stress at Temperature	Sn	117.90	N./mm ²
Allowable Stress At Ambient	Sna	117.90	N./mm ²
Diameter Basis (for tr calc only)		OD	
Layout Angle		180.00	deg
Diameter		2.0000	in.
Size and Thickness Basis		Minimum	
Nominal Thickness	tn	160	
Flange Material		SA-350 LF2	
Flange Type		Weld Neck Flange	
Corrosion Allowance	can	3.0000	mm.
Joint Efficiency of Shell Seam at Nozzle	E1	1.00	
Joint Efficiency of Nozzle Neck	En	1.00	
Outside Projection	ho	150.0000	mm.
Weld leg size between Nozzle and Pad/Shell	Wo	10.0000	mm.
Groove weld depth between Nozzle and Vessel	Wgnv	12.0000	mm.
Inside Projection	h	0.0000	mm.
Weld leg size, Inside Element to Shell	Wi	0.0000	mm.
Pad Material [Normalized]		SA-516 70	
Pad Allowable Stress at Temperature	Sp	137.90	N./mm ²
Pad Allowable Stress At Ambient	Spa	137.90	N./mm ²
Diameter of Pad along vessel surface	Dp	160.3250	mm.
Thickness of Pad	te	12.0000	mm.
Weld leg size between Pad and Shell	Wp	10.0000	mm.
Groove weld depth between Pad and Nozzle	Wgpn	12.0000	mm.
Reinforcing Pad Width		50.0000	mm.
Class of attached Flange		300	
Grade of attached Flange		GR 1.1	

The Pressure Design option was Design Pressure + static head.

Nozzle Sketch (may not represent actual weld type/configuration)



Insert/Set-in Nozzle With Pad, no Inside projection

Note : Checking Nozzle in the Meridional direction.

Reinforcement CALCULATION, Description: TI

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation	2.375 in.
Actual Thickness Used in Calculation	0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Elliptical Head, Tr [Int. Press]
 $= (P \cdot K1 \cdot D) / (2 \cdot Sv \cdot E - 0.2 \cdot P)$ per UG-37(a) (3)
 $= (23.03 \cdot 0.894 \cdot 896) / (2 \cdot 117.9 \cdot 1 - 0.2 \cdot 23.03)$
 $= 6.7041 \text{ mm.}$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]
 $= (P \cdot Ro) / (Sn \cdot E + 0.4 \cdot P)$ per Appendix 1-1 (a) (1)
 $= (23.03 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23.03)$
 $= 0.5848 \text{ mm.}$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit)	D1	112.1259	mm.
Parallel to Vessel Wall, opening length	d	56.0629	mm.
Normal to Vessel Wall (Thickness Limit), pad side Tlwp		22.5000	mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Weld Strength Reduction Factor [fr1]:
 $= \min(1, Sn/Sv)$
 $= \min(1, 117.9/137.9)$
 $= 0.855$

Weld Strength Reduction Factor [fr2]:
 $= \min(1, Sn/Sv)$
 $= \min(1, 117.9/137.9)$
 $= 0.855$

Weld Strength Reduction Factor [fr4]:
 $= \min(1, Sp/Sv)$
 $= \min(1, 137.9/137.9)$
 $= 1.000$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: TI

Noz1: 24 11:52pm Dec 24,2021

Weld Strength Reduction Factor [fr3]:

$$= \min(fr2, fr4)$$

$$= \min(0.855, 1)$$

$$= 0.855$$

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.849	0.701	NA
Area in Shell	A1	1.256	3.589	NA
Area in Nozzle Wall	A2	1.669	1.790	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds	A41+A42+A43	0.855	0.855	NA
Area in Element	A5	5.503	5.503	NA
TOTAL AREA AVAILABLE	Atot	9.283	11.737	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 65.55 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	60.8978	12.0000 mm.
Based on given Pad Diameter:	160.3250	0.1499 mm.
Based on Shell or Nozzle Thickness:	67.1682	7.6454 mm.

Area Required [A]:

$$= (d * tr * F + 2 * tn * tr * F * (1 - fr1)) UG-37(c)$$

$$= (56.06 * 6.704 * 1 + 2 * 4.645 * 6.704 * 1 * (1 - 0.855))$$

$$= 3.849 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d (E1 * t - F * tr) - 2 * tn (E1 * t - F * tr) * (1 - fr1)$$

$$= 56.06 (1 * 9 - 1 * 6.704) - 2 * 4.645$$

$$(1 * 9 - 1 * 6.704) * (1 - 0.855)$$

$$= 1.256 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2 / \sin(alpha3)$$

$$= (2 * 22.5) * (4.645 - 0.585) * 0.855 / \sin(69.41)$$

$$= 1.669 \text{ cm}^2$$

Note: See ASME VIII-1 2011(a) Appendix L, L-7.7.7(b) for more information.

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi - can / 0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp, DL) - (Nozzle OD)) * (\min(tp, Tlwp, te)) * fr4$$

$$= (112.1 - 66.27) * 12 * 1$$

$$= 5.503 \text{ cm}^2$$

Nozzle Junction Minimum Design Metal Temperature (MDMT) Calculations:

Nozzle Neck to Flange Weld (Impact tested) :

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: TI

Noz1: 24 11:52pm Dec 24,2021

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for the Nozzle (Impact tested) :

Note:

This Material was specified as being an Impact Tested (Low Temperature) Material.

Impact Test Temperature provided per Specification	-46 °C
Calculated Minimum Design Metal Temperature	-104 °C

Nozzle Neck to Pad Weld for Reinforcement pad, Curve: D

 Govern. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Shell to Pad Weld Junction at Pad OD, Curve: D

 Govern. thk, tg = 12, tr = 6.704, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.745$, Temp. Reduction = 14 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
--	--------

Nozzle-Shell/Head Weld (UCS-66(a)1(b)), Curve: D

 Govern. thk, tg = 7.645, tr = 0.585, c = 3 mm., E* = 1
 Thickness Ratio = $tr * (E^*) / (tg - c) = 0.126$, Temp. Reduction = 78 °C

Min Metal Temp. w/o impact per UCS-66, Curve D	-48 °C
Min Metal Temp. at Required thickness (UCS 66.1)	-104 °C

Governing MDMT of the Nozzle	:	-104 °C
Governing MDMT of the Reinforcement Pad	:	-48 °C
Governing MDMT of all the sub-joints of this Junction	:	-48 °C

ANSI Flange MDMT including Temperature reduction per UCS-66.1:

MDMT of ANSI B16.5/47 flange per Matl. Specification	-46 °C
Flange MDMT with Temp reduction per UCS-66(i)(2)	-48 °C
Flange MDMT with Temp reduction per UCS-66(i)(3)	-104 °C

Where the Stress Reduction Ratio per UCS-66(i)(2) is :

Design Pressure/Ambient Rating = $23.03/51.10 = 0.451$

Note:

Using the min value from (i)(2) and (i)(3) above as the computed nozzle flange MDMT.

Weld Size Calculations, Description: TI

Intermediate Calc. for nozzle/shell Welds	Tmin	4.6454 mm.
Intermediate Calc. for pad/shell Welds	TminPad	12.0000 mm.

Results Per UW-16.1:

Nozzle Calcs.: TI Noz1: 24 11:52pm Dec 24,2021

	Required Thickness	Actual Thickness
Nozzle Weld	3.2518 = 0.7 * tmin.	7.0700 = 0.7 * Wo mm.
Pad Weld	6.0000 = 0.5*TminPad	7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.849 - 1.256 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 6.704)) 137.9) \\
 &= 38.26 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (1.669 + 5.503 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 110.68 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.669 + 0 + 0.855 + (0.715)) * 137.9 \\
 &= 44.66 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.669 + 0 + 0.855 + 5.503 + (0.715)) * 137.9 \\
 &= 120.54 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 66.27 * 10 * 0.49 * 117.9 \\
 &= 60. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.142 * 30.58) * (7.645 - 3) * 0.7 * 117.9 \\
 &= 37. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wgpn * 0.74 * Seg \\
 &= (3.142/2) * 66.27 * 12 * 0.74 * 137.9 \\
 &= 127. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.142/2.0) * 66.27 * (12 - 3) * 0.74 * 137.9 \\
 &= 96. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170.2 + 36.83) = 207 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (60.13 + 127.5 + 95.59 + 0) = 283.2 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw})
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0
 Nozzle Calcs.: TI

Noz1: 24 11:52pm Dec 24,2021

$$= (170.2 + 95.59 + 0) = 265.7 \text{ kN}$$

Summary of Failure Path Calculations:

Path 1-1 = 206 kN , must exceed W = 38 kN or W1 = 110 kN
 Path 2-2 = 283 kN , must exceed W = 38 kN or W2 = 44 kN
 Path 3-3 = 265 kN , must exceed W = 38 kN or W3 = 120 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.883 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

Note : Checking Nozzle in the Latitudinal direction.

Reinforcement CALCULATION, Description: TI

ASME Code, Section VIII, Div. 1, 2017, UG-37 to UG-45

Actual Outside Diameter Used in Calculation 2.375 in.
 Actual Thickness Used in Calculation 0.301 in.

Nozzle input data check completed without errors.

Reqd thk per UG-37(a)of Elliptical Head, Tr [Int. Press]

$$= (P \cdot K1 \cdot D) / (2 \cdot Sv \cdot E - 0.2 \cdot P) \text{ per UG-37(a) (3)}$$

$$= (23.03 \cdot 0.894 \cdot 896) / (2 \cdot 137.9 \cdot 1 - 0.2 \cdot 23.03)$$

$$= 6.7041 \text{ mm.}$$

Reqd thk per UG-37(a)of Nozzle Wall, Trn [Int. Press]

$$= (P \cdot Ro) / (Sn \cdot E + 0.4 \cdot P) \text{ per Appendix 1-1 (a) (1)}$$

$$= (23.03 \cdot 30.16) / (117.9 \cdot 1 + 0.4 \cdot 23.03)$$

$$= 0.5848 \text{ mm.}$$

Required Nozzle thickness under External Pressure per UG-28 : 0.2901 mm.

UG-40, Limits of Reinforcement : [Internal Pressure]

Parallel to Vessel Wall (Diameter Limit) D1 102.0684 mm.
 Parallel to Vessel Wall, opening length d 51.0342 mm.
 Normal to Vessel Wall (Thickness Limit), pad side Tlwp 22.5000 mm.

Note: The Pad diameter is greater than the Diameter Limit. The excess will not be considered.

Results of Nozzle Reinforcement Area Calculations: (cm²)

AREA AVAILABLE, A1 to A5		Design	External	Mapnc
Area Required	Ar	3.512	0.639	NA
Area in Shell	A1	1.141	3.259	NA
Area in Nozzle Wall	A2	1.562	1.676	NA
Area in Inward Nozzle	A3	0.000	0.000	NA
Area in Welds A41+A42+A43		0.855	0.855	NA
Area in Element	A5	5.009	5.009	NA
TOTAL AREA AVAILABLE	Atot	8.567	10.799	NA

The Internal Pressure Case Governs the Analysis.

Nozzle Angle Used in Area Calculations 90.00 Degs.

The area available without a pad is Insufficient.
 The area available with the given pad is Sufficient.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: TI Nozl: 24 11:52pm Dec 24,2021

SELECTION OF POSSIBLE REINFORCING PADS:	Diameter	Thickness
Based on given Pad Thickness:	60.3250	12.0000 mm.
Based on given Pad Diameter:	160.3250	0.0000 mm.
Based on Shell or Nozzle Thickness:	60.3250	7.6454 mm.

Area Required [A]:

$$= (d * tr*F + 2 * tn * tr*F * (1-fr1)) \text{ UG-37(c)}$$

$$= (51.03*6.704*1+2*4.645*6.704*1*(1-0.855))$$

$$= 3.512 \text{ cm}^2$$

Reinforcement Areas per Figure UG-37.1

Area Available in Shell [A1]:

$$= d(E1*t - F*tr) - 2 * tn(E1*t - F*tr) * (1 - fr1)$$

$$= 51.03 (1 * 9 - 1 * 6.704) - 2 * 4.645$$

$$(1 * 9 - 1 * 6.704) * (1 - 0.855)$$

$$= 1.141 \text{ cm}^2$$

Area Available in Nozzle Wall Projecting Outward [A2]:

$$= (2 * Tlwp) * (tn - trn) * fr2$$

$$= (2 * 22.5) * (4.645 - 0.585) * 0.855$$

$$= 1.562 \text{ cm}^2$$

Area Available in Welds [A41 + A42 + A43]:

$$= Wo^2 * fr3 + (Wi-can/0.707)^2 * fr2 + Wp^2 * fr4$$

$$= 10^2 * 0.855 + (0)^2 * 0.855 + 0^2 * 1$$

$$= 0.855 \text{ cm}^2$$

Area Available in Element [A5]:

$$= (\min(Dp,DL) - (Nozzle OD)) * (\min(tp,Tlwp,te)) * fr4$$

$$= (102.1 - 60.33) * 12 * 1$$

$$= 5.009 \text{ cm}^2$$

UG-45 Minimum Nozzle Neck Thickness Requirement: [Int. Press.]

Wall Thickness for Internal/External pressures	ta = 3.5848 mm.
Wall Thickness per UG16(b),	tr16b = 4.5000 mm.
Wall Thickness, shell/head, internal pressure	trb1 = 10.4304 mm.
Wall Thickness	tb1 = max(trb1, tr16b) = 10.4304 mm.
Wall Thickness, shell/head, external pressure	trb2 = 3.3543 mm.
Wall Thickness	tb2 = max(trb2, tr16b) = 4.5000 mm.
Wall Thickness per table UG-45	tb3 = 6.4200 mm.

Determine Nozzle Thickness candidate [tb]:

$$= \min[tb3, \max(tb1, tb2)]$$

$$= \min[6.42, \max(10.43, 4.5)]$$

$$= 6.4200 \text{ mm.}$$

Minimum Wall Thickness of Nozzle Necks [tUG-45]:

$$= \max(ta, tb)$$

$$= \max(3.585, 6.42)$$

$$= 6.4200 \text{ mm.}$$

Available Nozzle Neck Thickness = 7.6454 mm. --> OK

Weld Size Calculations, Description: TI

Intermediate Calc. for nozzle/shell Welds	Tmin	4.6454 mm.
Intermediate Calc. for pad/shell Welds	TminPad	12.0000 mm.

Results Per UW-16.1:

Required Thickness	Actual Thickness
--------------------	------------------

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Calcs.: TI Noz1: 24 11:52pm Dec 24,2021

Nozzle Weld 3.2518 = 0.7 * tmin. 7.0700 = 0.7 * Wo mm.
 Pad Weld 6.0000 = 0.5*TminPad 7.0700 = 0.7 * Wp mm.

Weld Strength and Weld Loads per UG-41.1, Sketch (a) or (b)

Weld Load [W]:

$$\begin{aligned}
 &= \max(0, (A-A1+2*tn*fr1*(E1*t-tr))Sv) \\
 &= \max(0, (3.512 - 1.141 + 2 * 4.645 * 0.855 * \\
 &\quad (1 * 9 - 6.704)) 137.9) \\
 &= 35.21 \text{ kN}
 \end{aligned}$$

Note: F is always set to 1.0 throughout the calculation.

Weld Load [W1]:

$$\begin{aligned}
 &= (A2+A5+A4-(Wi-Can/.707)^2*fr2)*Sv \\
 &= (1.562 + 5.009 + 0.855 - 0 * 0.855) * 137.9 \\
 &= 102.40 \text{ kN}
 \end{aligned}$$

Weld Load [W2]:

$$\begin{aligned}
 &= (A2 + A3 + A4 + (2 * tn * t * fr1)) * Sv \\
 &= (1.562 + 0 + 0.855 + (0.715)) * 137.9 \\
 &= 43.19 \text{ kN}
 \end{aligned}$$

Weld Load [W3]:

$$\begin{aligned}
 &= (A2+A3+A4+A5+(2*tn*t*fr1))*S \\
 &= (1.562 + 0 + 0.855 + 5.009 + (0.715)) * 137.9 \\
 &= 112.26 \text{ kN}
 \end{aligned}$$

Strength of Connection Elements for Failure Path Analysis

Shear, Outward Nozzle Weld [Sonw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wo * 0.49 * Snw \\
 &= (3.142/2.0) * 60.33 * 10 * 0.49 * 117.9 \\
 &= 55. \text{ kN}
 \end{aligned}$$

Shear, Pad Element Weld [Spew]:

$$\begin{aligned}
 &= (\pi/2) * DP * WP * 0.49 * SEW \\
 &= (3.142/2.0) * 160.3 * 10 * 0.49 * 137.9 \\
 &= 170. \text{ kN}
 \end{aligned}$$

Shear, Nozzle Wall [Snw]:

$$\begin{aligned}
 &= (\pi * (Dlr + Dlo) / 4) * (Thk - Can) * 0.7 * Sn \\
 &= (3.142 * 27.84) * (7.645 - 3) * 0.7 * 117.9 \\
 &= 34. \text{ kN}
 \end{aligned}$$

Tension, Pad Groove Weld [Tpgw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * Wgpn * 0.74 * Seg \\
 &= (3.142/2) * 60.33 * 12 * 0.74 * 137.9 \\
 &= 116. \text{ kN}
 \end{aligned}$$

Tension, Shell Groove Weld [Tngw]:

$$\begin{aligned}
 &= (\pi/2) * Dlo * (Wgnvi-Cas) * 0.74 * Sng \\
 &= (3.142/2.0) * 60.33 * (12 - 3) * 0.74 * 137.9 \\
 &= 87. \text{ kN}
 \end{aligned}$$

Strength of Failure Paths:

$$\begin{aligned}
 \text{PATH11} &= (\text{SPEW} + \text{SNW}) = (170.2 + 33.53) = 203.7 \text{ kN} \\
 \text{PATH22} &= (\text{Sonw} + \text{Tpgw} + \text{Tngw} + \text{Sinw}) \\
 &= (54.74 + 116 + 87.02 + 0) = 257.8 \text{ kN} \\
 \text{PATH33} &= (\text{Spew} + \text{Tngw} + \text{Sinw}) \\
 &= (170.2 + 87.02 + 0) = 257.2 \text{ kN}
 \end{aligned}$$

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0
Nozzle Calcs.: TI

Noz1: 24 11:52pm Dec 24,2021

Summary of Failure Path Calculations:

Path 1-1 = 203 kN , must exceed W = 35 kN or W1 = 102 kN
Path 2-2 = 257 kN , must exceed W = 35 kN or W2 = 43 kN
Path 3-3 = 257 kN , must exceed W = 35 kN or W3 = 112 kN

Maximum Allowable Pressure for this Nozzle at this Location:

Converged Max. Allow. Pressure in Operating case 27.883 bar

Note: The MAWP of this junction was limited by the parent Shell/Head.

Nozzle is O.K. for the External Pressure 1.100 bar

The Drop for this Nozzle is : 12.7279 mm.

The Cut Length for this Nozzle is, Drop + Ho + H + T : 175.6302 mm.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Nozzle Schedule: Step: 24 11:52pm Dec 24,2021

Nozzle Schedule:

Flg	Nominal or	Schd	Flg	Nozzle	Wall	Reinforcing Pad	Cut
Class	Actual	or FVC	Type	O/Dia	Thk	Diameter	Thk
Description	Size	Type		in	mm.	mm.	mm.

A2	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							213.02
PT	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							163.02
A3	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							163.02
LT1	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							163.02
LT2	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							163.02
D	2.000 in	160	WNF	2.375	8.738	160.00	12.00
300							163.02
LG1	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							163.02
LG2	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							163.02
TI	2.000 in	160	WNF	2.375	8.738	160.32	12.00
300							175.63
A1	8.000 in	80	WNF	8.625	12.700	379.08	12.00
300							812.00
B	8.000 in	80	WNF	8.625	12.700	379.08	12.00
300							225.69
M	20.000 in	Actual	WNF	20.000	15.000	738.00	15.00
							252.82
							300

General Notes for the above table:

The Cut Length is the Outside Projection + Inside Projection + Drop + In Plane Shell Thickness. This value does not include weld gaps, nor does it account for shrinkage.

In the case of Oblique Nozzles, the Outside Diameter must be increased. The Re-Pad WIDTH around the nozzle is calculated as follows:
 Width of Pad = (Pad Outside Dia. (per above) - Nozzle Outside Dia.)/2

For hub nozzles, the thickness and diameter shown are those of the smaller and thinner section.

Nozzle Material and Weld Fillet Leg Size Details (mm.):

Description	Material	Shl Grve	Noz Shl/Pad	Pad OD	Pad Grve	Inside
		Weld	Weld	Weld	Weld	Weld
A2	SA-333 6	12.000	10.000	10.000	12.000	...
PT	SA-333 6	12.000	8.000	10.000	12.000	...
A3	SA-333 6	12.000	8.000	10.000	12.000	...
LT1	SA-333 6	12.000	10.000	10.000	12.000	...
LT2	SA-333 6	12.000	10.000	10.000	12.000	...
D	SA-333 6	12.000	10.000	10.000	12.000	...
LG1	SA-333 6	12.000	10.000	10.000	12.000	...
LG2	SA-333 6	12.000	10.000	10.000	12.000	...

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Nozzle Schedule: Step: 24 11:52pm Dec 24,2021

TI	SA-333 6	12.000	10.000	10.000	12.000	...
A1	SA-333 6	12.000	10.000	10.000	12.000	...
B	SA-333 6	12.000	10.000	10.000	12.000	...
M	SA-516 70	12.000	10.000	9.000	15.000	...

Note: The Outside projections below do not include the flange thickness.

Nozzle Miscellaneous Data:

Description	Elev/Distance From Datum mm.	Layout Angle deg	Proj Outside mm.	Proj Inside mm.	Installed in Component
A2	2800.000	0.0	200.00	0.00	shell 001
PT	1800.000	0.0	150.00	0.00	shell 001
A3	1200.000	0.0	150.00	0.00	shell 001
LT1	3700.000	180.0	150.00	0.00	shell 001
LT2	3700.000	0.0	150.00	0.00	shell 001
D	300.000	180.0	150.00	0.00	shell 001
LG1	2500.000	180.0	150.00	0.00	shell 001
LG2	2500.000	0.0	150.00	0.00	shell 001
TI	...	180.0	150.00	0.00	head 002
A1	500.000	0.0	200.00	600.00	shell 001
B	2000.000	180.0	200.00	0.00	shell 001
M	...	0.0	200.00	0.00	head 001

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

MDMT Summary: Step: 26 11:52pm Dec 24,2021

Minimum Design Metal Temperature Results Summary :

Description	Notes	Curve	Basic MDMT °C	Reduced MDMT °C	UG-20 (f) MDMT °C	Thickness ratio	Gov Thk mm.	E*	PWHT reqd
head 001	[10]	D	-48	-48	-29	0.860	12.000	1.00	No
head 001	[7]	D	-47	-48	-29	0.656	15.000	1.00	No
shell 001	[8]	D	-48	-48	-29	0.875	12.000	1.00	No
head 002	[10]	D	-48	-48	-29	0.860	12.000	1.00	No
head 002	[7]	D	-47	-48	-29	0.656	15.000	1.00	No
M	[1]	D	-47	-48		0.351	15.000	1.00	No
Nozzle Flg	[4]	!	-46	-48					
A1	[1]	D	-48	-48	-29	0.839	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
B	[1]	D	-48	-48	-29	0.840	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
A2	[1]	D	-48	-48	-29	0.839	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
PT	[1]	D	-48	-48	-29	0.839	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
A3	[1]	D	-48	-48	-29	0.839	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
LT1	[1]	D	-48	-48	-29	0.840	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
LT2	[1]	D	-48	-48	-29	0.839	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
D	[1]	D	-48	-48	-29	0.840	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
LG1	[1]	D	-48	-48	-29	0.840	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
LG2	[1]	D	-48	-48	-29	0.839	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
TI	[1]	D	-48	-48	-29	0.745	12.000	1.00	No
Nozzle Flg	[4]	!	-46	-104					
Warmest MDMT:			-46	-48					
Required Minimum Design Metal Temperature						-45	°C		
Warmest Computed Minimum Design Metal Temperature						-48	°C		

Notes:

- [!] - This was an impact tested material.
- [1] - Governing Nozzle Weld.
- [4] - ANSI Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-c).
- [5] - ANSI Flange MDMT Calcs; Thickness ratio per UCS-66(b)(1)(-b).
- [6] - MDMT Calculations at the Shell/Head Joint.
- [7] - MDMT Calculations for the Straight Flange.
- [8] - Cylinder/Cone/Flange Junction MDMT.
- [9] - Calculations in the Spherical Portion of the Head.
- [10] - Calculations in the Knuckle Portion of the Head.
- [11] - Calculated (Body Flange) Flange MDMT.
- [12] - Calculated Flat Head MDMT per UCS-66.3
- [13] - Tubesheet MDMT, shell side, if applicable
- [14] - Tubesheet MDMT, tube side, if applicable
- [15] - Nozzle Material
- [16] - Shell or Head Material
- [17] - Impact Testing required
- [18] - Impact Testing not required, see UCS-66(b)(3)

UG-84(b)(2) was not considered.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
Tag no:Liquid Receiver (D-PK6101-2)
PV Elite 2018 SP2 Licensee: SPLM Licensed User
FileName : LIQID RECEIVER-Rev.D0

MDMT Summary: Step: 26 11:52pm Dec 24,2021

UCS-66(g) was not considered.

UCS-66(i) was not considered.

Notes:

Impact test temps were not entered in and not considered in the analysis.

UCS-66(i) applies to impact tested materials not by specification and

UCS-66(g) applies to materials impact tested per UG-84.1 General Note (c).

The Basic MDMT includes the (30F) PWHT credit if applicable.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018

Vessel Design Summary: Step: 27 11:52pm Dec 24,2021

ASME Code, Section VIII Division 1, 2017

Diameter Spec : 914.000 mm. OD
 Vessel Design Length, Tangent to Tangent 4000.00 mm.
 Specified Datum Line Distance 0.00 mm.
 Shell Material SA-516 70 [Normalized]
 Nozzle Material SA-333 6 [Impact Tested]
 Re-Pad Material SA-516 70 [Normalized]
 Internal Design Temperature 135 °C
 Internal Design Pressure 23.000 bar
 External Design Temperature 100 °C
 External Design Pressure 1.100 bar
 Maximum Allowable Working Pressure 23.873 bar
 External Max. Allowable Working Pressure 3.413 bar
 Hydrostatic Test Pressure 29.900 bar
 Required Minimum Design Metal Temperature -45 °C
 Warmest Computed Minimum Design Metal Temperature -48 °C
 Wind Design Code ASCE-2010
 Earthquake Design Code ASCE 7-2010

Element Pressures and MAWP (bar):

Element Description	Design Pres. + Stat. head	External Pressure	M.A.W.P	Corrosion Allowance	Str. Flange Governing
head 001	23.040	1.100	27.849	3.0000	No
shell 001	23.040	1.100	27.329	3.0000	N/A
head 002	23.040	1.100	27.849	3.0000	No

Liquid Level: 890.00 mm. Dens.: 460.789 kg/m³ Sp. Gr.: 0.461

Element Types and Properties:

Element Type	"To" Elev mm.	Length mm.	Element Thk mm.	Reqd Int.	Thk Ext.	Joint Eff Long	Circ
Ellipse	50.0	50.0	15.0	10.5	5.4	1.00	1.00
Cylinder	3950.0	3900.0	12.0	10.6	8.7	1.00	1.00
Ellipse	4000.0	50.0	15.0	10.5	5.4	1.00	1.00

Element thicknesses are shown as Nominal if specified, otherwise are Minimum

Saddle Parameters:


Saddle Width 200.000 mm.
 Saddle Bearing Angle 120.000 deg.
 Centerline Dimension 1000.000 mm.
 Wear Pad Width 250.000 mm.
 Wear Pad Thickness 10.000 mm.
 Wear Pad Bearing Angle 130.000 deg.
 Distance from Saddle to Tangent 680.000 mm.
 Baseplate Length 1200.000 mm.
 Baseplate Thickness 12.000 mm.
 Baseplate Width 250.000 mm.

DEHDASHT PETROCHEMICAL INDUSTRY COMPANY
 DEHDASHT HIGH DENSITY POLYETHYLENE PROJECT
 Tag no:Liquid Receiver (D-PK6101-2)
 PV Elite 2018 SP2 Licensee: SPLM Licensed User
 FileName : LIQID RECEIVER-Rev.D0

Vessel Design Summary: Step: 27 11:52pm Dec 24,2021

Number of Ribs (including outside ribs)	2
Rib Thickness	10.000 mm.
Web Thickness	10.000 mm.
Height of Center Web	530.000 mm.
Number of Bolts in Baseplate	4

Baseplate Sketch



Baseplate Plan View



Baseplate Side View

Maximum Tensile Bolt Load	0. kN
---------------------------	-------

Summary of Maximum Saddle Loads, Operating Case :

Maximum Vertical Saddle Load	38.90 kN
Maximum Transverse Saddle Shear Load	4.32 kN
Maximum Longitudinal Saddle Shear Load	8.63 kN

Summary of Maximum Saddle Loads, Hydrotest Case :

Maximum Vertical Saddle Load	34.14 kN
Maximum Transverse Saddle Shear Load	0.80 kN
Maximum Longitudinal Saddle Shear Load	0.45 kN

Weights:

Fabricated - Bare W/O Removable Internals	2523.9 kg.
Shop Test - Fabricated + Water (Full)	5195.7 kg.
Shipping - Fab. + Rem. Intls.+ Shipping App.	2523.9 kg.
Erected - Fab. + Rem. Intls.+ Insul. (etc)	2711.0 kg.
Empty - Fab. + Intls. + Details + Wghts.	2711.0 kg.
Operating - Empty + Operating Liquid (No CA)	3942.8 kg.
Field Test - Empty Weight + Water (Full)	5083.0 kg.

PV Elite is a trademark of Intergraph CADWorx & Analysis Solutions, Inc. 2018