







OWNER:  شرکت سست و سویی توهمه ایران لیان (سهامی عامه)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	<b>AFTER COOLER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER</b>								
MC :  شرکت سست و سویی توهمه ایران لیان (سهامی عامه)	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-11B	BU	20	VD	303	ME	DSH	0017	Rev.:	Page
								01	1 of 3





Title and content of document shall be same. AIRPACK is expected to check the document carefully before issuing.

## AFTER COOLER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER

 		BUSHEHR PETROCHEMICAL COMPANY MEG PLANT
<b>Document Review</b>		
Issue Purpose:	IFA	
Result Code: AP,AN,CM,RE,NC	CM	
Next Status : IFC,IFA,IFI,AFC,AB	IFA	
Responsible Department	MECHANICAL	
Commented Date	Oct /02/2021	
<b>Approval or review hereunder shall not be construed to relieve Vendor / Subcontractor of his responsibilities and liability under the contract.</b>		

01	14/09/2021	For approval	KP	PW	JR	
00	11/12/2020	For approval	KP	PW	JR	
<b>Rev.</b>	<b>Date</b>	<b>Purpose of Issue</b>	<b>Prepared</b>	<b>Checked</b>	<b>Approved</b>	<b>AC Code</b>
					Class: 1	Phase: P



VENDOR		<b>Aftercooler mechanical datasheet</b>				P.O. No.		52-98/445																																																																																																																																																																																																																																									
						Document No.		17811-11B																																																																																																																																																																																																																																									
						Sheet No.		3																																																																																																																																																																																																																																									
						Rev.No		01																																																																																																																																																																																																																																									
CONTRACTOR / END USER			<b>BUSHEHR PETROCHEMICAL COMPANY MEG PLANT</b>			Service		Nitrogen or Instrument air compressor 20-C-7080																																																																																																																																																																																																																																									
  																																																																																																																																																																																																																																																	
<div style="border: 1px solid red; padding: 2px; display: inline-block; margin-bottom: 5px;">Discrepancy with PID. In PID 180 oC</div> <div style="border: 1px solid red; padding: 2px; display: inline-block; margin-left: 20px;">AEC-7080-1</div> <div style="border: 1px solid red; padding: 2px; display: inline-block; margin-left: 20px;">Nitrogen or Instrument air compressor, which one is correct?</div>																																																																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4" style="text-align: left;">SHELL SIDE (HUMID AIR)</th> <th colspan="4" style="text-align: left;">TUBE SIDE (WATER)</th> <th colspan="2" style="text-align: left;">GENERAL</th> </tr> </thead> <tbody> <tr> <td>3 SHELL OPERATING PRESS.</td> <td>bar(a)</td> <td>21</td> <td></td> <td>TUBE OPERATING PRESS.</td> <td>bar(g)</td> <td>4,5</td> <td></td> <td>MANUFACTURER</td> <td>Monje</td> </tr> <tr> <td>4 SHELL DESIGN PRESS.</td> <td>bar(g)</td> <td>25</td> <td></td> <td>TUBE DESIGN PRESS.</td> <td>bar(g)</td> <td>10</td> <td></td> <td>INLET SIZE</td> <td>2" 300#</td> </tr> <tr> <td>5 SHELL OPERATING TEMP.</td> <td>°C</td> <td>195</td> <td></td> <td>TUBE OPERATING TEMP.</td> <td>°C</td> <td>35</td> <td></td> <td>OUTLET SIZE</td> <td>2" 300#</td> </tr> <tr> <td>6 SHELL DESIGN TEMP.</td> <td>°C</td> <td>210</td> <td></td> <td>TUBE DESIGN TEMP.</td> <td>°C</td> <td>95</td> <td></td> <td>WATER INLET</td> <td>1 1/2" SAE</td> </tr> <tr> <td>7 SHELL DIFF PRESSURE</td> <td>mbar</td> <td>0,4195</td> <td></td> <td>TUBE DIFF PRESSURE</td> <td>mbar</td> <td>11,12</td> <td></td> <td>WATER OUTLET</td> <td>1 1/2" SAE</td> </tr> <tr> <td>8 DISCHARGE TEMP.</td> <td>°C</td> <td>40</td> <td></td> <td>DISCHARGE TEMP.</td> <td>°C</td> <td>45</td> <td></td> <td>CORROSION ALL.</td> <td>0</td> </tr> <tr> <td>9 AIR FLOW</td> <td>Nm3/hr</td> <td>173</td> <td></td> <td>WATER FLOW</td> <td>m3/hr</td> <td>1,699</td> <td></td> <td>DIM. LxWxH</td> <td>1500 X 140 X 140</td> </tr> <tr> <td>10 SHELL MATERIAL</td> <td></td> <td>SS316</td> <td></td> <td>TUBE MATERIAL</td> <td></td> <td><del>SS316</del></td> <td></td> <td>WEIGHT</td> <td>TBC</td> </tr> <tr> <td>11 DESIGN CODE</td> <td></td> <td>TEMA C, ASME VIII</td> <td></td> <td>DESIGN CODE</td> <td></td> <td>TEMA C, ASME VIII</td> <td></td> <td></td> <td></td> </tr> <tr> <td>12 SHELL ID</td> <td></td> <td>133,3</td> <td></td> <td>TUBE SHEET TYPE</td> <td></td> <td>STRAIGHT TUBES WITH FIXED TUBESHEETS</td> <td></td> <td></td> <td></td> </tr> <tr> <td>13 SHELL OD</td> <td></td> <td>139,7</td> <td></td> <td>TUBE NO.</td> <td></td> <td>72</td> <td></td> <td></td> <td></td> </tr> <tr> <td>14 FLOATING HEAD COVER MAT.</td> <td></td> <td>SS316</td> <td></td> <td>TOBE OD.</td> <td>mm</td> <td>8</td> <td></td> <td></td> <td>As per clause 6.14.2.3 of API 618, minimum tube O.D shall be 16 mm.</td> </tr> <tr> <td>15 GASKET SHELL SIDE TYPE</td> <td></td> <td>Viton</td> <td></td> <td>TUBE LENGTH</td> <td>mm</td> <td>1200</td> <td></td> <td></td> <td></td> </tr> <tr> <td>16 HEAT EXCHANGER TYPE</td> <td></td> <td>Shell and Tube/fin</td> <td></td> <td>TUBE THICKNESS (AVG)</td> <td>mm</td> <td>0,5</td> <td></td> <td></td> <td></td> </tr> <tr> <td>17 SHELL THICKNESS</td> <td></td> <td>3,2</td> <td></td> <td>TUBE PITCH</td> <td>mm</td> <td>11,5</td> <td></td> <td></td> <td>As per clause 6.14.2.3 of API 618, minimum tube thickness shall be 1.2mm.</td> </tr> <tr> <td>18 SURF/UNIT (EFF)</td> <td></td> <td>11,29</td> <td></td> <td>TUBESHEET FLOATING MATERIAL</td> <td></td> <td>N/A</td> <td></td> <td></td> <td></td> </tr> <tr> <td>19 SURF/SHELL (EFF)</td> <td></td> <td>N/A</td> <td></td> <td>TUBESHEET FIXED MATERIAL</td> <td></td> <td><del>SS304</del></td> <td></td> <td></td> <td></td> </tr> <tr> <td>20</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>21</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>22</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>23</td> <td colspan="9"><b>NOTES :</b></td> </tr> <tr> <td>24</td> <td colspan="9" rowspan="3" style="border: 1px solid red; padding: 5px;"> 1- TEMA type shall be specified (For example BEM, AES and etc.).  2- TEMA sheet shall be sent.  3- As per clause 6.14.2.3 of API 618, tube sheets shall be brass; and tubes shall be of a copper/zinc/tin non-ferrous material such as UNS C44300.  4- In next revision, calculation of heat exchanger shall be sent officially. </td> </tr> <tr> <td>25</td> </tr> <tr> <td>26</td> </tr> </tbody> </table>										SHELL SIDE (HUMID AIR)				TUBE SIDE (WATER)				GENERAL		3 SHELL OPERATING PRESS.	bar(a)	21		TUBE OPERATING PRESS.	bar(g)	4,5		MANUFACTURER	Monje	4 SHELL DESIGN PRESS.	bar(g)	25		TUBE DESIGN PRESS.	bar(g)	10		INLET SIZE	2" 300#	5 SHELL OPERATING TEMP.	°C	195		TUBE OPERATING TEMP.	°C	35		OUTLET SIZE	2" 300#	6 SHELL DESIGN TEMP.	°C	210		TUBE DESIGN TEMP.	°C	95		WATER INLET	1 1/2" SAE	7 SHELL DIFF PRESSURE	mbar	0,4195		TUBE DIFF PRESSURE	mbar	11,12		WATER OUTLET	1 1/2" SAE	8 DISCHARGE TEMP.	°C	40		DISCHARGE TEMP.	°C	45		CORROSION ALL.	0	9 AIR FLOW	Nm3/hr	173		WATER FLOW	m3/hr	1,699		DIM. LxWxH	1500 X 140 X 140	10 SHELL MATERIAL		SS316		TUBE MATERIAL		<del>SS316</del>		WEIGHT	TBC	11 DESIGN CODE		TEMA C, ASME VIII		DESIGN CODE		TEMA C, ASME VIII				12 SHELL ID		133,3		TUBE SHEET TYPE		STRAIGHT TUBES WITH FIXED TUBESHEETS				13 SHELL OD		139,7		TUBE NO.		72				14 FLOATING HEAD COVER MAT.		SS316		TOBE OD.	mm	8			As per clause 6.14.2.3 of API 618, minimum tube O.D shall be 16 mm.	15 GASKET SHELL SIDE TYPE		Viton		TUBE LENGTH	mm	1200				16 HEAT EXCHANGER TYPE		Shell and Tube/fin		TUBE THICKNESS (AVG)	mm	0,5				17 SHELL THICKNESS		3,2		TUBE PITCH	mm	11,5			As per clause 6.14.2.3 of API 618, minimum tube thickness shall be 1.2mm.	18 SURF/UNIT (EFF)		11,29		TUBESHEET FLOATING MATERIAL		N/A				19 SURF/SHELL (EFF)		N/A		TUBESHEET FIXED MATERIAL		<del>SS304</del>				20										21										22										23	<b>NOTES :</b>									24	1- TEMA type shall be specified (For example BEM, AES and etc.). 2- TEMA sheet shall be sent. 3- As per clause 6.14.2.3 of API 618, tube sheets shall be brass; and tubes shall be of a copper/zinc/tin non-ferrous material such as UNS C44300. 4- In next revision, calculation of heat exchanger shall be sent officially.									25	26
SHELL SIDE (HUMID AIR)				TUBE SIDE (WATER)				GENERAL																																																																																																																																																																																																																																									
3 SHELL OPERATING PRESS.	bar(a)	21		TUBE OPERATING PRESS.	bar(g)	4,5		MANUFACTURER	Monje																																																																																																																																																																																																																																								
4 SHELL DESIGN PRESS.	bar(g)	25		TUBE DESIGN PRESS.	bar(g)	10		INLET SIZE	2" 300#																																																																																																																																																																																																																																								
5 SHELL OPERATING TEMP.	°C	195		TUBE OPERATING TEMP.	°C	35		OUTLET SIZE	2" 300#																																																																																																																																																																																																																																								
6 SHELL DESIGN TEMP.	°C	210		TUBE DESIGN TEMP.	°C	95		WATER INLET	1 1/2" SAE																																																																																																																																																																																																																																								
7 SHELL DIFF PRESSURE	mbar	0,4195		TUBE DIFF PRESSURE	mbar	11,12		WATER OUTLET	1 1/2" SAE																																																																																																																																																																																																																																								
8 DISCHARGE TEMP.	°C	40		DISCHARGE TEMP.	°C	45		CORROSION ALL.	0																																																																																																																																																																																																																																								
9 AIR FLOW	Nm3/hr	173		WATER FLOW	m3/hr	1,699		DIM. LxWxH	1500 X 140 X 140																																																																																																																																																																																																																																								
10 SHELL MATERIAL		SS316		TUBE MATERIAL		<del>SS316</del>		WEIGHT	TBC																																																																																																																																																																																																																																								
11 DESIGN CODE		TEMA C, ASME VIII		DESIGN CODE		TEMA C, ASME VIII																																																																																																																																																																																																																																											
12 SHELL ID		133,3		TUBE SHEET TYPE		STRAIGHT TUBES WITH FIXED TUBESHEETS																																																																																																																																																																																																																																											
13 SHELL OD		139,7		TUBE NO.		72																																																																																																																																																																																																																																											
14 FLOATING HEAD COVER MAT.		SS316		TOBE OD.	mm	8			As per clause 6.14.2.3 of API 618, minimum tube O.D shall be 16 mm.																																																																																																																																																																																																																																								
15 GASKET SHELL SIDE TYPE		Viton		TUBE LENGTH	mm	1200																																																																																																																																																																																																																																											
16 HEAT EXCHANGER TYPE		Shell and Tube/fin		TUBE THICKNESS (AVG)	mm	0,5																																																																																																																																																																																																																																											
17 SHELL THICKNESS		3,2		TUBE PITCH	mm	11,5			As per clause 6.14.2.3 of API 618, minimum tube thickness shall be 1.2mm.																																																																																																																																																																																																																																								
18 SURF/UNIT (EFF)		11,29		TUBESHEET FLOATING MATERIAL		N/A																																																																																																																																																																																																																																											
19 SURF/SHELL (EFF)		N/A		TUBESHEET FIXED MATERIAL		<del>SS304</del>																																																																																																																																																																																																																																											
20																																																																																																																																																																																																																																																	
21																																																																																																																																																																																																																																																	
22																																																																																																																																																																																																																																																	
23	<b>NOTES :</b>																																																																																																																																																																																																																																																
24	1- TEMA type shall be specified (For example BEM, AES and etc.). 2- TEMA sheet shall be sent. 3- As per clause 6.14.2.3 of API 618, tube sheets shall be brass; and tubes shall be of a copper/zinc/tin non-ferrous material such as UNS C44300. 4- In next revision, calculation of heat exchanger shall be sent officially.																																																																																																																																																																																																																																																
25																																																																																																																																																																																																																																																	
26																																																																																																																																																																																																																																																	