











OWNER:  شرکت سست موبلی آوند ایرانیان (سهامی خاص)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	MC :  شرکت سست موبلی آوند ایرانیان اصفهان	<b>PULSATION DAMPER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER</b>							
Owner Document Number: 17811-11C	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
	BU	20	VD	303	ME	DSH	0027	Rev.: 07	Page 1 of 4

## PULSATION DAMPER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER

 شرکت سست موبلی آوند ایرانیان اصفهان	 Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT
<b>Document Review</b>		
Issue Purpose:	AFC	
Result Code: AP,AN,CM,RE,NC	AP	
Next Status : IFC,IFA,IFI,AFC,AB	AB	
Responsible Department	MECHANICAL	
Commented Date	8/17/2022	
<b>Approval or review hereunder shall not be construed to relieve Vendor / Subcontractor of his responsibilities and liability under the contract.</b>		






07	16/08/2022	Approved for Construction	KP	CL	JR	
06	14/07/2022	Approved for Construction	KP	CL	JR	
05	06/05/2022	Approved for Construction	KP	CL	JR	
04	25/04/2022	Approved for Construction	KP	CL	JR	
03	13/04/2022	For approval	KP	CL	JR	
02	10/03/2022	For approval	KP	CL	JR	
01	28/02/2022	For approval	KP	CL	JR	
00	11/12/2020	For approval	KP	KP	KP	
Rev	Date	Purpose of Issue	Prepared	Checked	Approved	AC Code
					Class: 1	Phase: P



OWNER:  شرکت سست موبه‌ئی آوند ایرانیان (سه‌لی نغصه‌ر)	<b>BUSHEHR PETROCHEMICAL COMPANY MEG PLANT</b>						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	<b>PULSATION DAMPER MECHANICAL DATA SHEET FOR NITROGEN GAS BOOSTER</b>						 Netherlands		
MC :  شرکت سست موبه‌ئی آوند ایرانیان امدی نغصه‌ر	<b>Project</b>	<b>Area</b>	<b>Phase</b>	<b>Unit</b>	<b>Dis.</b>	<b>Doc.</b>	<b>Seq.</b>	<b>Contract No : 52-98/445</b>	
<b>Owner Document Number: 17811-11C</b>	<b>BU</b>	<b>20</b>	<b>VD</b>	<b>303</b>	<b>ME</b>	<b>DSH</b>	<b>0027</b>	<b>Rev.:</b>	<b>Page</b>
								07	2 of 4

### TABULATION OF REVISED PAGES

Page	D00	D01	D02	D03	D04
1.	X	X	X	X	X
2.	X	X	X	X	X
3.	X	X	X	X	
4.		X	X	X	
5.					

Page	D05	D06	D07		
1.	X	X	X		
2.	X	X	X		
3.		X	X		
4.		X	X		
5.					

		<b>Pulsation damper mechanical datasheet</b>		P.O. No.	52-98/445
				Document No.	17811-11C
				Sheet No.	3
				Rev.No	7
   			<b>BUSHEHR PETROCHEMICAL COMPANY MEG PLANT</b>		
CONTRACTOR / END USER شرکت سیمت و سوی توسعه ایرانیان توسعه ایرانیان			Service nitrogen compressor package		
<b>1st stage inlet pulsation damper (20-DC-1002-1)</b>					
2	OPERATING PRESSURE	Bar(a)			<b>9 bar(a)</b>
3	DESIGN PRESSURE	Bar(a)			<b>13,5 bar(a)</b>
4	HYDROTEST PRESSURE				<b>1.3 X MAWP as per ASME VIII</b>
5	OPERATING TEMPERATURE	°C			<b>5-52</b>
6	DESIGN TEMPERATURE	°C			<b>0-85</b>
7	DESIGN CODE				<b>ASME VIII Div. 1 Ed. 2021</b>
8	MATERIAL CERTIFICATE				<b>3.1</b>
9	MATERIAL OF CONSTRUCTION				<b>Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105</b>
10	NOZZLE SIZE INLET/OUTLET				<b>2" 150# for inlet and outlet, 1/2 NPT-F for drain</b>
11	DIMENSIONS	DIAX TT			<b>12" X 1100 mm</b>
12	WEIGHT EMPTY	kg			<b>120</b>
13	WEIGHT FILLED WITH WATER	kg			<b>210</b>
14	CAPACITY	Liters			<b>96</b>
15	TESTING AS PER CODE				<b>ASME VIII Div. 1 Ed. 2021</b>
16	CORROSION ALLOWANCE	mm			<b>3</b>
17	PWHT	Yes/No			<b>No</b>
18	THICKNESS	mm			<b>9,52</b>
19	Design aproach				<b>API 618 Design approach 2</b>
20	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.				<b>6,64%</b>
21	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar			<b>0,18</b>
23	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar			<b>0,536</b>
<b>1st stage outlet pulsation damper (20-DC-1002-2)</b>					
25	OPERATING PRESSURE	Bar(a)			<b>14,5 bar(a)</b>
26	DESIGN PRESSURE	Bar(a)			<b>25 bar(a)</b>
27	HYDROTEST PRESSURE				<b>1.3 X MAWP as per ASME VIII</b>
28	OPERATING TEMPERATURE	°C			<b>134</b>
29	DESIGN TEMPERATURE	°C			<b>0-170</b>
30	DESIGN CODE				<b>ASME VIII Div. 1 Ed. 2021</b>
31	MATERIAL CERTIFICATE				<b>3.1</b>
32	MATERIAL OF CONSTRUCTION				<b>Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105</b>
33	NOZZLE SIZE INLET/OUTLET				<b>2" 300# for inlet and outlet, 1/2 NPT-F for drain</b>
34	DIMENSIONS	DIAX TT			<b>12" X 1100 mm</b>
35	WEIGHT EMPTY	kg			<b>110</b>
36	WEIGHT FILLED WITH WATER	kg			<b>190</b>
37	CAPACITY	Liters			<b>96</b>
38	TESTING AS PER CODE				<b>ASME VIII Div. 1 Ed. 2021</b>
39	CORROSION ALLOWANCE	mm			<b>3</b>
40	PWHT	Yes/No			<b>No</b>
41	THICKNESS	mm			<b>9,52</b>
43	Design aproach				<b>API 618 Design approach 2</b>
44	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.	Bar			<b>6,64%</b>
45	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar			<b>0,15</b>
46	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar			<b>1,433</b>
47					
48					
49	<b>NOTES:</b>				
50					
51					
52					

		<b>Pulsation damper mechanical datasheet</b>		P.O. No.	52-98/445
				Document No.	17811-11C
				Sheet No.	4
				Rev.No	7
			<b>BUSHEHR PETROCHEMICAL COMPANY MEG PLANT</b>		
			Service		nitrogen compressor package
<b>2nd stage inlet pulsation damper (20-DC-1002-3)</b>					
2	OPERATING PRESSURE	Bar(a)	<b>14,5 bar(a)</b>		
3	DESIGN PRESSURE	Bar(a)	<b>25 bar(a)</b>		
4	HYDROTEST PRESSURE		<b>1.3 X MAWP as per ASME VIII</b>		
5	OPERATING TEMPERATURE	°C	<b>50</b>		
6	DESIGN TEMPERATURE	°C	<b>0-85</b>		
7	DESIGN CODE		<b>ASME VIII Div. 1 Ed. 2021</b>		
8	MATERIAL CERTIFICATE		<b>3.1</b>		
9	MATERIAL OF CONSTRUCTION		<b>Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105</b>		
10	NOZZLE SIZE INLET/OUTLET		<b>2" 300# for inlet and outlet, 1/2 NPT-F for drain</b>		
11	DIMENSIONS	DIxT	<b>10" X 600 mm</b>		
12	WEIGHT EMPTY	kg	<b>75</b>		
13	WEIGHT FILLED WITH WATER	kg	<b>115</b>		
14	CAPACITY	Liters	<b>38</b>		
15	TESTING AS PER CODE		<b>ASME VIII Div. 1 Ed. 2021</b>		
16	CORROSION ALLOWANCE	mm	<b>3</b>		
17	PWHT	Yes/No	<b>No</b>		
18	THICKNESS	mm	<b>9,27</b>		
20	Design approach		<b>API 618 Design approach 2</b>		
21	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.		<b>4,54%</b>		
22	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar	<b>0,0636</b>		
23	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar	<b>0,739</b>		
<b>2nd stage outlet pulsation damper (20-DC-1002-4)</b>					
26	OPERATING PRESSURE	Bar(a)	<b>23,5 bar(a)</b>		
27	DESIGN PRESSURE	Bar(a)	<b>26 bar(a)</b>		
28	HYDROTEST PRESSURE		<b>1.3 X MAWP as per ASME VIII</b>		
29	OPERATING TEMPERATURE	°C	<b>83</b>		
30	DESIGN TEMPERATURE	°C	<b>0-100</b>		
31	DESIGN CODE		<b>ASME VIII Div. 1 Ed. 2021</b>		
32	MATERIAL CERTIFICATE		<b>3.1</b>		
33	MATERIAL OF CONSTRUCTION		<b>Shell /pipes : SA106 gr B, Heads : SA234 WPB, flanges : SA105</b>		
34	NOZZLE SIZE INLET/OUTLET		<b>2" 300# for inlet and outlet, 1/2 NPT-F for drain</b>		
35	DIMENSIONS	DIxT	<b>10" X 800 mm</b>		
36	WEIGHT EMPTY	kg	<b>85</b>		
37	WEIGHT FILLED WITH WATER	kg	<b>130</b>		
38	CAPACITY	Liters	<b>48</b>		
39	TESTING AS PER CODE		<b>ASME VIII Div. 1 Ed. 2021</b>		
40	CORROSION ALLOWANCE	mm	<b>3</b>		
41	PWHT	Yes/No	<b>No</b>		
42	THICKNESS	mm	<b>9,27</b>		
44	Design approach		<b>API 618 Design approach 2</b>		
45	Maximum Allowable Compressor Cylinder Flange Pressure Pulsation as per clause 7.9.4.2.5.2.1 of API618.	Bar	<b>4,54%</b>		
46	Maximum Allowable Pressure Drop as per clause 7.9.4.2.5.3.1 of API 618.	Bar	<b>0,0603</b>		
47	Maximum Allowable Pulsation Limits at and Beyond Line-side Nozzles of Pulsation Suppression Devices as per clause 7.9.4.2.5.2.2.1 of API 618.	bar	<b>0,9</b>		
45					
46					
47					
48	<b>NOTES:</b>				
49					
50					
51					