








OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT							CONTRACTOR  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 	
MC:  شرکت سست و سازه های صنعتی	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							Contract No :	
Owner Document Number :	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	rev 02	Page: 1 OF 20
	BU	20	VD	303	ME	DSH	0075		

MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)

Rev.	Date	Description	Prepared By	Checked By	Approved	AC code.
02	9-12-2021	Approved for Construction	KP	KP	JR	
01	4-11-2021	for approval	KP	KP	JR	
00	12-8-2021	for approval	KP	KP	JR	

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							
	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445





Owner Document Number :	BU	20	VD	303	ME	DSH	75	Rev : 02	Page: 4 OF 20
-------------------------	----	----	----	-----	----	-----	----	----------	---------------

	GAS ANALYSIS AT OPERATING CONDITIONS MOLE PERCENT					REMARKS
3	● SERVICE/ITEM NO.					
4	● STAGE					
5	○ NORMAL OR ALT					
6		M.W.	NORMAL			
7	AIR	28.966	100			
8	NITROGEN	28.016				
9	WATER H ₂ O	18.016				
10	CARBON MONOXIDE CO	28.010				
11	CARBON DIOXIDE CO ₂	44.010				
12	HYDROGEN H ₂	2.016				
13	METHANE CH ₄	16.042				
14	ETHANE	30.068				
15	PROPANE	44.094				
16	i-BUTANE	58,12				
17	n-BUTANE	58,12				
18	i-PENTANE	72,146				
19	OXYGEN O ₂	32.00				
20	HYDRO. SULFIDE	34,076				
21	ETHYLENE	28,052				
22	PROPYLENE	42,078				
23	n-PENTANE	72,146				● API-618-RECIPROCATING COMPRESSORS FOR PETROLEUM, CHEMICAL AND GAS INDUSTRY SERVICES
24	HEXANE PLUS					
25	AMMONIA	17,031				
26	HYDRO. CHLORIDE	36,461				
27	CHLORINE	70,914				● Doc. No. 1216-DE-00-RE-MSS-302
28						
29						
30						
31	TOTAL:					
32	<input type="checkbox"/> CALCULATED MOL WT.		28,97			
33	<input type="checkbox"/> Cp/Cv (K) @ 65° OR	Suction temperature °C	45			
34	NOTE: IF WATER VAPOR AND/OR CHLORIDES ARE PRESENT, EVEN MINUTE TRACES, IN THE GAS BEING COMPRESSED, IT MUST BE INCLUDED ABOVE.					

SITE CONDITION (SEE PROJECT SITE CONDITION FOR MORE DETAIL)

ELEVATION	8,5 m	BAROMETER	1,013 (BARA)	AMBIENT TEMPS: MAX	55 °C	MIN	5 °C
		○ MIN DESIGN METAL TEMP		5 °C (2.14.8)	RELATIVE HUMIDITY: MAX	76%	MIN 74% %
COMPRESSOR LOCATION:		○ INDOOR	HEATED	● UNHEATED	● AT GRADE LEVEL	○ ELEVATED:	M
		● OUTDOOR	NO ROOF	● UNDER ROOF	○ PARTIAL SIDES	○ PLATFORM:	● ON-SHORE
		○ OFF-SHORE	● WEATHER PROTECTION REQ.		● TROPICALIZATION REQ.		
UNUSUAL CONDITIONS:		○ WINTERIZATION REQUIRED					
		○ CORROSIVES	● DUST	● FUMES	● OTHER	Sand storm , Thunder & Lightening, Sea Breeze	

ELECTRICAL CLASSIFICATIONS							
HAZARDOUS				NON-HAZARDOUS			
MAIN UNIT	● ZONE	2	GROUP	IIB	TEMP CLASS	T3	○
L.O. CONSOLE	● ZONE	2	GROUP	IIB	TEMP CLASS	T3	○
CW CONSOLE	○ ZONE		GROUP		TEMP CLASS		○

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 							
MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)								
Owner Document Number :	BU	20	VD	303	ME	DSH	75	Rev : 02	Page: 5 OF 20

PART LOAD OPERATING CONDITIONS

CAPACITY CONTROL BY: MFG'S CAP. CONTROL PURCHASERS BY-PASS BOTH OTHER _____

FOR: PART LOAD COND. START-UP ONLY BOTH

WITH: AUTO LOADING DELAY INTERLOCK AUTO IMMEDIATE UNLOADING

USING: FIXED VOLUME POCK. SUCTION VALVE UNLOADERS: FINGER PLUG OTHER

ACTION: DIRECT (AIR-TO-UNLOAD) REVERSE (AIR-TO-LOAD/FAIL SAFE)

NUMBER OF STEPS: ONE THREE FIVE OTHER _____

RAIN COVER REQUIRED OVER UNLOADERS

ALL UNLOADING STEPS BASIS MANUFACTURERS CAPACITY SHOWN ON PAGE 1.

<p>INLET AND DISCHARGE PRESSURE ARE</p> <p><input type="radio"/> AT CYLINDER FLANGES <input checked="" type="radio"/> PULSATION SUPPRESSOR FLANGES</p> <p><input type="radio"/> SERVICE OR ITEM NO.</p> <p><input type="radio"/> STAGE</p> <p><input type="radio"/> NORMAL OR ALTERNATE CONDITION</p> <p><input type="radio"/> PERCENT CAPACITY</p> <p><input type="radio"/> WEIGHT FLOW, kg/h</p> <p><input type="radio"/> m³/h (760 mm HG & 0°C)</p> <p><input type="checkbox"/> POCKETS/VALVES OPERATION *</p> <p><input type="checkbox"/> POCKET CLEARANCE ADDED %</p> <p><input type="checkbox"/> TYPE UNLOADERS, PLUG/FINGER</p> <p><input type="radio"/> INLET TEMPERATURE, °C</p> <p><input type="radio"/> INLET PRESSURE, (BARA)</p> <p><input type="radio"/> DISCHARGE PRESSURE, (BARA)</p> <p><input type="checkbox"/> DISCHARGE TEMP., ADIABATIC °C</p> <p><input type="checkbox"/> DISCHARGE TEMP., PREDICTED °C</p> <p><input type="checkbox"/> VOLUMETRIC EFF., %HE/%CE(AVER)</p> <p><input type="checkbox"/> CALC. GAS ROD LOAD, KN, C **</p> <p><input type="checkbox"/> CALC. GAS ROD LOAD, KN, T **</p> <p><input type="checkbox"/> COMB. ROD LOAD, KN C (GAS & INERTIA)</p> <p><input type="checkbox"/> COMB. ROD LOAD, KN T (GAS & INERTIA)</p> <p><input type="checkbox"/> ROD REV., DEGREES MIN @ X-HD PIN ***</p> <p><input type="checkbox"/> BkW/STAGE</p> <p><input type="checkbox"/> TOTAL kW @ COMPRESSOR SHAFT</p> <p><input type="checkbox"/> TOTAL kW INCL. V-BELT & GEAR LOSSES</p>	<table border="1" style="width:100%; border-collapse: collapse;"> <tr><td>1</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Normal</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>100</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>223</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>173</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Valves</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>NA</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Plug</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>45</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>8 (Min.:7, Max:8.5)</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>21,5</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>180</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>164</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>75</td><td>/</td><td>/</td><td>/</td><td>/</td><td>/</td></tr> <tr><td>11,06</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>0,36</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>10,83</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>0,2</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>195</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>12</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>12</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>13</td><td></td><td></td><td></td><td></td><td></td></tr> </table>	1						Normal						100						223						173						Valves						NA						Plug						45						8 (Min.:7, Max:8.5)						21,5						180						164						75	/	/	/	/	/	11,06						0,36						10,83						0,2						195						12						12						13					
1																																																																																																																																					
Normal																																																																																																																																					
100																																																																																																																																					
223																																																																																																																																					
173																																																																																																																																					
Valves																																																																																																																																					
NA																																																																																																																																					
Plug																																																																																																																																					
45																																																																																																																																					
8 (Min.:7, Max:8.5)																																																																																																																																					
21,5																																																																																																																																					
180																																																																																																																																					
164																																																																																																																																					
75	/	/	/	/	/																																																																																																																																
11,06																																																																																																																																					
0,36																																																																																																																																					
10,83																																																																																																																																					
0,2																																																																																																																																					
195																																																																																																																																					
12																																																																																																																																					
12																																																																																																																																					
13																																																																																																																																					

* SHOW OPERATION WITH THE FOLLOWING SYMBOLS:

HEAD END = HE OR CRANK END = CE	} PLUS	{	SUCTION VALVE(S) UNLOADED = S OR FIXED POCKET OPEN = F OR VARIABLE POCKET OPEN = V
---------------------------------------	--------	---	--

** C = COMPRESSION T = TENSION *** X - HD = CROSSHEAD

MINIMUM PRESSURE REQUIRED TO OPERATE CYLINDER UNLOADING DEVICES, 6 _____ (BARG)

CYLINDER UNLOADING MEDIUM: AIR NITROGEN OTHER _____

PRESSURE AVAILABLE FOR CYLINDER UNLOADING DEVICES, MAX/MIN 8,0 / 6,0 (BARG)

SPECIAL REMARK:

OWNER:



شرکت پتروشیمی بوشهر
BUPC

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**



CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT



MC:




**MECHANICAL DATA SHEET FOR EMERGENCY
INSTRUMENT AIR COMPRESSOR (20-C-7080)**

Project	Area	Phase	Unit	Dis.	Doc.	Seq.
BU	20	VD	303	ME	DSH	75

Contract No : 52-98/445
Rev : 02 **Page: 6 OF 20**

Owner Document Number :

SCOPE OF BASIC SUPPLY

PURCHASER TO FILL IN () **AFTER COMMODITY TO INDICATE:** **BY COMPR. MFR.** **BY PURCH.** **BY OTHERS**

DRIVER (): **VARIABLE SPEED** **SPEED RANGE** **NOT APPLICABLE** **RPM TO** **NOT APPLICABLE RPM**

INDUCTION MOTOR **SYNCHRONOUS MOTOR** **STEAM TURBINE** **ENGINE** **OTHER** _____

API-541 **API-546** **API-611** **API-612**

OUTBOARD BEARING **PROVISION FOR DRY AIR PURGE FOR OUTBOARD BEARING.**

SLIDE BASE FOR DRIVER () **SOLE PLATE FOR DRIVER** ()

MOTOR STARTING EQUIPMENT (); **DEFINE** _____ **Local power distribution board**

GEAR (): **BASEPLATE FOR GEAR** **API-613** **API-677**

COUPLING(S) (): **LOW SPD.** **HI-SPD.** **QUILL SHAFT** **KEY-LESS DRV.** **KEY'D DRV.** **OTHER** _____

API 671

V-BELT DRIVE (): **SHEAVES & V-BELTS** () **STATIC CONDUCTING V-BELTS** **BANDED V-BELTS**

DRIVE GUARD(S) (): **MANUFACTURER'S STD.** **NON-SPARKING** **CALIF CODE** **API-671 APPENDIX C**

OTHER _____

PULSATION SUPPRESSORS WITH INTERNALS (): **INITIAL INLET & FINAL DISCHARGE** **SUPPORTS** ()

INTERSTAGE **SUPPORTS** ()

PULSATION SUPPRESSORS WITHOUT INTRNL (): **INITIAL INLET & FINAL DISCHARGE** **SUPPORTS** ()

INTERSTAGE **SUPPORTS** ()

SUPPRESSOR(S) TO HAVE MOISTURE REMOVAL SECTION: **INITIAL INLET ONLY** **ALL INLET SUPPRESSORS**

ACOUSTICAL SIMUL. STUDY (): **DESIGN APPROACH** **1, EMPRICAL PULSATION SUPPRESSION DEVICE SIZING**

DIGITAL **ANALOG** **2, ACOUSTIC SIMULATION AND PIPING RESTRAINT ANALYSIS**

3, ACOUSTIC SIMULATION AND PIPING RESTRAINT ANALYSIS PLUS MECHANICAL ANALYSIS

STUDY TO CONSIDER: **ALL SPECIFIED LOAD COND., INCL.** **SINGLE ACT., PLUS**

COMP. OPER. IN PARALLEL **ALTERNATE GASES**

WITH EXISTING COMP. AND PIPING SYSTEMS

COMPRESSOR VALVE DYNAMIC RESPONSE

STUDY TO BE WITNESSED **PULSATION SUPPRESSEN DEVICE LOW CYCLE FATIGUE ANALYSIS**

VENDOR REVIEW OF PURCHASER'S PIPING ARRANGEMENT **PIPING SYSTEM FLEXIBILITY**

PACKAGED: **NO** **YES** () **DEFINE BASIC SCOPE OF PACKAGING IN REMARKS SECTION**

SKID **SOLEPLT.** **BASEPLT.** **BOLTS OR STUDS FOR SOLEPLT. TO FRAME** **RAILS** **CHOKE BLOCKS** **SHIMS**

SUITABLE FOR COLUMN MOUNTING (UNDER SKID AND/OR BASEPLATE)

LEVELING SCREWS **NON-SKID DECKING** **SUB SOLEPLATES**

DIRECT GROUTED **CEMENTED/MORTAR GROUT** **EPOXY GROUT; MFG/TYPE** _____ / _____

INTERCOOLER(S) () **SEPARATOR(S)** () **AFTERCOOLER(S)** ()

INTERCOOLERS:

INTERSTAGE PIPE () **PIPING MATCHMARKED** **SHOP FITTED** **MACHINE MTD.**

CONDENSATE SEPARATION & COLLECTION FACILITY SYSTEM PER 3.8.12 **OFF MOUNTED**

INLET STRAINER(S) (): **INITIAL INLET** **SIDESTREAM INLET** **SPOOL PIECE FOR INLET STRAINERS**

MANIFOLD PIPING; **DRAINS** **VENTS** **RELIEF VALVES** **AIR/GAS SUPPLY** **FLANGE FINISH**

RELIEF VALVE(S) (): **INITIAL INLET** **INTERSTAGE** **FINAL DISCHARGE** **API-618 FLANGE FINISH**

RUPTURE DISC(S) () **THRU STUDS IN PIPING FLANGES**

CRANKCASE RAPID PRESSURE RELIEF DEVICE(S) () **FLANGE FINISH PER ANSI 16.5**

SPECIAL PIPING REQUIREMENTS **SPECIAL FINISH**

INITIAL INLET, **INTERSTAGE SUCTION PIPING ARR'D FOR:** **INSULATION (PP)** () **HEAT TRACING** ()

FOR ATMOSPHERIC INLET AIR COMPR. ONLY: **INLET AIR FILTER** () **INLET FILTER -SILENCER** ()

PREFERRED TYPE OF CYLINDER COOLING (): **FORCED** **THERMOSYPHON** _____ **STAGE CYL(S)**

STATIC (STAND-PIPE) _____ **STAGE CYL(S)**

NOTE: MANUFACTURER SHALL RECOMMENDBEST TYPE OF COOLING AFTERFINAL ENGINEERING REVIEW OF ALLOPERATING CONDITIONS



CYL. COOLING WATER PIPING () **MATCH M'RKED**


SINGLE INLET/OUTLET MANIFOLD & VALVES **SIGHT GL'S(S)**

INDIVIDUAL INLET/ OUTLET PER CYL. **VALVE(S)**

CLOSED SYS. WITH WATER PUMP, COOLER, SURGE TANK, & PIPING

SHOP RUN **ARR'D FOR HEATING JACKET AS WELL AS COOLING**

OWNER:  شریکت پتروشیمی بوشهر BUPC	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
--	--	--

MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)	Contract No : 52-98/445														
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:12.5%;">Project</th> <th style="width:12.5%;">Area</th> <th style="width:12.5%;">Phase</th> <th style="width:12.5%;">Unit</th> <th style="width:12.5%;">Dis.</th> <th style="width:12.5%;">Doc.</th> <th style="width:12.5%;">Seq.</th> </tr> <tr> <td style="text-align: center;">BU</td> <td style="text-align: center;">20</td> <td style="text-align: center;">VD</td> <td style="text-align: center;">303</td> <td style="text-align: center;">ME</td> <td style="text-align: center;">DSH</td> <td style="text-align: center;">75</td> </tr> </table>	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	BU	20	VD	303	ME	DSH	75	Rev : 02 Page: 7 OF 20	
Project	Area	Phase	Unit	Dis.	Doc.	Seq.										
BU	20	VD	303	ME	DSH	75										

Owner Document Number BU 20 VD 303 ME DSH 75 Rev : 02 Page: 7 OF 20

1 **SCOPE OF BASIC SUPPLY (Con't)**

2 SEPARATE COOLING CONSOLE (): ONE FOR EA. UNIT ONE CMMN TO ALL UNITS DUAL PUMPS (AUX. & MAIN)

3 ARRANGED FOR HEATING JACKET WATER AS WELL AS COOLING

4 ROD PRESS. PACKING COOLING SYSTEM () SEPARATE CONSOLE COMBINE WITH JKT SYSTEM FILTERS

5 FRAME LUBE OIL SYSTEM (): AUX. PUMP DUAL FILTERS WITH TRANSFER VALVE SHOP RUN

6 CONTINUOUS FLOW IN SENSING LINE TO PRESSURE SWITCHES

7 SEPARATE LUBE OIL CONSOLE (): EXTENDED TO MOTOR OUTBOARD BEARING SHOP RUN

8 API 614 APPLIES NO YES

9 **NOTE: PIPING BETWEEN ALL CONSOLES AND COMPRESSOR UNIT BY PURCHASER**

10 CAPACITY CONTROL (): SEE DATA SHEET PAGE 5 FOR DETAILS INSTRUMENT & CONTROL PANEL

11 SEPARATE MACHINE MOUNTED PANEL SEPARATE FREE STANDING PANEL

12 PNEUMATIC ELECTRIC ELECTRONIC HYDRAULIC

13 PROGRAMMABLE CONTROLLER

14 INSTRUMENT & CONTROL PANEL (): ONE FOR EACH UNIT ONE COMMON TO ALL UNITS

15 MACHINE MOUNTED FREE STANDING (OFF UNIT)

16

17 BUFFER GAS CONTROL PANEL () = ONE FOR EACH UNIT ONE COMMON TO ALL UNITS

18 MACHINE MOUNTED FREE STANDING (OFF UNIT)

19 **SEE INSTRUMENTATION DATA SHEETS FOR DETAILS OF PANEL, ADDITIONAL REMARKS, AND INSTRUMENTATION**

20 **NOTE: ALL TUBING, WIRING, & CONNECTIONS BETWEEN OFF-UNIT FREE STANDING PANELS AND COMPRESSOR UNIT BY PURCHASER**

21

22

23 HEATERS (): FRAME LUBE OIL CYL. LUBRICATORS COOLING WATER DRIVER(S) GEAR OIL

24 ELECTRIC STEAM

25

26 BARRING DEVICE (): MANUAL PNEUMATIC ELECTRIC FLYWHEEL LOCKING DEVICE ()

27 ROD PRESSURE PACKING COOLING SYSTEM (): SEPARATE CONSOLE FILTERS

28 SPECIAL CORROSION PROTECTION: NO YES MFR'S STANDARD OTHER _____

29 HYDRAULIC TENSIONING TOOLS NO YES

30 MECHANICAL RUN TEST: NO YES MFG'S STANDARD OTHER Approved test procedure

31 COMPLETE SHOP RUN TEST OF ALL MACHINE MOUNTED EQUIPMENT, PIPING & APPURT.(S)

32

33 PAINTING: MANUFACTURER'S STANDARD SPECIAL Project specification for color

34 NAMEPLATES: U.S. CUSTOMARY UNITS SI UNITS

35 SHIPMENT: DOMESTIC EXPORT EXPORT BOXING REQUIRED ()

36 STANDARD 6 MONTH STORAGE PREPARATION (), PER SPEC _____

37 OUTDOOR STORAGE FOR OVER 12 MONTHS (), PER SPEC _____

38 INITIAL INSTALLATION AND OPERATING TEMP ALIGNMENT CHECK AT JOBSITE BY VENDOR REPRESENTATIVE

39

40 COMPRESSOR MANUFACTURER'S USER'S LIST FOR SIMILAR SERVICE

41 PERFORMANCE DATA REQUIRED PER 9.3.3: BkW VS. SUCTION PRESSURE CURVES

42 ROD LOAD/GAS LOAD CHARTS

43 VALVE FAILURE DATA CHARTED

44 SPEED/TORQUE CURVE DATA

45 BkW VS. CAPACITY PERFORMANCE CURVES OR TABLES REQUIRED FOR UNLOADING STEPS AND/OR VARIABLE

46 SUCTION/DISCHARGE PRESSURES



**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**



**MECHANICAL DATA SHEET FOR EMERGENCY
INSTRUMENT AIR COMPRESSOR (20-C-7080)**



Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445
BU	20	VD	303	ME	DSH	75	Rev : 02 Page: 9 OF 20

Owner Document Number

<input checked="" type="checkbox"/> CYLINDER DATA AT FULL LOAD CONDITION							
1							
2	SERVICE/ITEM NO.	Air					
3	STAGE	1					
4	INLET PRESSURE, (BARA)	8,0					
5	DISCHARGE PRESSURE, (BARA)	21,0					
6	CYLINDERS PER STAGE	2					
7	SINGLE OR DOUBLE ACTING (SA OR DA)	SA					
8	BORE, mm	90					
9	STROKE, mm	140					
10	RPM:	RATED / MAX ALLOW		400/690			
11	PISTON SPEED, m/s:	RATED / MAX ALLOW		<3,5			
12	CYLINDER LINER, YES/NO	yes					
13	LINER NOMINAL THICKNESS, mm	12,5					
14	PISTON DISPLACEMENT, m³/h	36,9					
15	CYLINDER DESIGN CLEARANCE, % AVERAGE						
16	VOLUMETRIC EFFICIENCY, % AVERAGE	73					
17	VALVES, INLET/DISCHARGE, QTY PER CYL.	1/1		/	/	/	/
18	TYPE OF VALVES	plate					
19	VALVE LIFT, INLET/DISCHARGE, mm	0,8 / 0,8		/	/	/	/
20	VALVE VELOCITY, API 4TH EDITION, m/s	19,9					
21	SUCTION VALVE(S)	16,65					
22	DISCHARGE VALVE(S)	16,65					
23	ROD DIAMETER, (mm)	30					
24	MAX ALLOW. COMBINED ROD LOADING, kN, C *	17,5					
25	MAX ALLOW. COMBINED ROD LOADING, kN, T *	17,5					
26	CALCULATED GAS ROD LOAD, kN, C *	11,06					
27	CALCULATED GAS ROD LOAD, kN, T *	0,36					
28	COMBINED ROD LOAD (GAS + INERTIA), kN, C *	10,83					
29	COMBINED ROD LOAD (GAS + INERTIA), kN, T *	0,20					
30	ROD REV., DEGREES MIN @ X-HD PIN**	195,00					
31	RECIP WT. (PISTON, ROD, X-HD & NUTS), kg**	10,74					
32	MAX ALLOW. WORKING PRESSURE, (BARG)	24					
33	MAX ALLOW. WORKING TEMPERATURE, °C	230					
34	HYDROSTATIC TEST PRESSURE, (BARG)	36					
35	HELIUM TEST PRESSURE, (BARG)	3					
36	INLET FLANGE SIZE/RATING at CYLINDER			/	/	/	/
37	FACING at CYLINDER	RF					
38	DISCHARGE FLANGE SIZE/RATING at CYLINDER			/	/	/	/
39	FACING at CYLINDER	RF					
40	DISCHARGE RELIEF VALVE SETTING DATA AT INLET PRESSURES GIVEN ABOVE:						
41	RECOMMENDED SETTING, (BARG)	-25					
42	GAS ROD LOAD, kN, C *	17,5					
43	GAS ROD LOAD, kN, T *	17,5					
44	COMBINED ROD LOAD, kN, C *	13,13					
45	COMBINED ROD LOAD, kN, T *	12,6					
46	ROD REVERSAL, °MIN @ X-HD PIN**	195					
47	NOTE: CALCULATED AT INLET PRESSURES						
48	GIVEN ABOVE & RECOMMENDED SETTING.						
49	<input type="checkbox"/> SETTLE-OUT GAS PRESSURE	8,5 - 9,5					
50	(DATA REQUIRED FOR STARTING)						
51	* C = COMPRESSION * T = TENSION			**X-HD = CROSSHEAD			
52	NOTES/REMARKS:						
53							

OWNER:



شرکت پتروشیمی بوشهر
BUPC

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**



CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT



MC:

**MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR
COMPRESSOR (20-C-7080)**

Project	Area	Phase	Unit	Dis.	Doc.	Seq.
BU	20	VD	303	ME	DSH	75

Contract No : 52-98/445

Owner Document Number :

BU 20 VD 303 ME DSH 75

Rev : 02 Page: 10 OF 20

1	<input type="checkbox"/> CONSTRUCTION FEATURES					
2	SERVICE ITEM NO.					
3	STAGE					
4	CYLINDER SIZE (BORE DIA), mm					
5	ROD RUN-OUT: NORMAL COLD VERTICAL					
6	(per appendix C)					

MATERIALS OF CONSTRUCTION	
8	CYLINDER(S) DUCTILE CAST IRON
9	CYLINDER LINER(S) EN-GJL-250 (SLG)
10	PISTON(S) AlCu4PbMgMn T3
11	PISTON RINGS PTFE compaund
12	WEAR BANDS <input type="radio"/> REQUIRED
13	PISTON ROD(S): MATERIAL/YIELD, N/mm ²
14	THREAD ROOT STRESS @ MACRL * @ X-HD END
15	PISTON ROD HARDNESS, BASE MATERIAL, Rc
16	PISTON ROD COATING <input type="radio"/> REQUIRED
17	COATING HARDNESS, Rc
18	VALVE SEATS / SEAT PLATE SS/SS
19	VALVE SEAT MIN HARDNESS, Rc
20	VALVE GUARDS (STOPS) 79RL
21	VALVE DISCS 79RL
22	VALVE SPRINGS 79RLX
23	ROD PRESSURE PACKING RINGS NBR, 70-ShA
24	ROD PRESSURE PACKING CASE Niro (1.4305)
25	ROD PRESSURE PACKING SPRINGS -
26	SEAL / BUFFER PACKING, DISTANCE PIECE SK703 E
27	SEAL / BUFFER PACKING, INTERMEDIATE SK703 E
28	WIPER PACKING RINGS SK703 E
29	MAIN JOURNAL BEARINGS, CRANKSHAFT -
30	CONNECTING ROD BEARING, CRANKPIN -
31	CONNECTING ROD BUSHING, X-HD END G-Cu Sn 12
32	CROSSHEAD (X-HD) PIN BUSHING -
33	CROSSHEAD PIN 17Cr3 (1.7016)
34	CROSSHEAD EN-GJS-400-15
35	CROSSHEAD SHOES EN-GJS-400-15
36	CYLINDER INDICATOR VALVES (X)
37	INDICATOR CONNECTIONS ABOVE 5000 PSI
38	FLUOROCARBON SPRAYED CYLINDER (X)
39	INSTRUMENTATION IN (X) COLD SIDE
40	CONTACT W/PROCESS GAS (X) HOT SIDE
41	* MAXIMUM ALLOWABLE COMBINED ROD LOAD

USE (X) IN APPROPRIATE COLUMN WHERE APPLICABLE

COMPRESSOR CYLINDER ROD PACKING

FULL FLOATING PACKING

VENTED TO: FLARE @ _____ ATM

SUCTION PRESSURE @ _____ (BARG)

FORCED LUBRICATED NON-LUBE TFE

WATER COOLED, _____ STAGE(S), _____ m³/h REQ'D

OIL COOLED, _____ STAGE(S), _____ m³/h REQ'D

WATER FILTER PROV.FUTURE WATER/OIL COOLING

VENT/BUFFER GAS SEAL PACKING ARR. (Ref: Appndx I FIG I-1)

CONSTANT OR VARIABLE DISPOSAL SYSTEM

BUFFER GAS PRESSURE, _____ (BARG)

SPLASH GUARDS FOR WIPER PACKING

DISTANCE PIECE(S): TYPE A TYPE B TYPE C TYPE D

Ref: Appendix G, Fig. G-3

COVERS: SOLID METAL SCREEN LOUVERED

CYLINDER COMPARTMENT: VENTED TO amb _____ (BARG)

(Outboard Distance Piece) PURGED AT _____ (BARG)

PRESSURIZED TO _____ (BARG)

WITH RELIEF VALVE

FRAME COMPARTMENT: VENTED TO _____ (BARG)

(Inboard Distance Piece) PURGED AT _____ (BARG)

PRESSURIZED TO _____ (BARG)

WITH RELIEF VALVE

DISTANCE PIECE MAWP 0 _____ (BARG)

OWNER:



شرکت پتروشیمی بوشهر

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**

CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT

MC:



موسسه مهندسی مشاوران

**MECHANICAL DATA SHEET FOR EMERGENCY
INSTRUMENT AIR COMPRESSOR (20-C-7080)**



Contract No : 52-98/445

Owner Document Number :

Project	Area	Phase	Unit	Dis.	Doc.	Seq.
BU	20	VD	303	ME	DSH	75

Rev : 02 Page: 12 OF 20

UTILITY CONSUMPTION

ELECTRIC MOTORS

	NAMEPLATE HP (kW)	LOCKED ROTOR AMPS	FULL LOAD AMPS
◆ MAIN DRIVER	15	239	28,5
◇ MAIN LUBE OIL PUMP			
◇ AUX LUBE OIL PUMP			
◇ MAIN COOLING WATER PUMP			
◇ AUX COOLING WATER PUMP			
◇ ROD PACKING COOLING PUMP			
◇ CYLINDER LUBRICATOR			

ELECTRIC HEATERS

	WATTS	VOLTS	HERTZ
◆ FRAME OIL HEATER(S)	75	230	50
◇ COOLING WATER HEATER(S)			
◇ CYL. LUBRICATOR HEATER(S)			
◇ MAIN DRIVER SPACE HEATER(S)			

STEAM-NOT APPLICABLE

	FLOW	PRESSURE	TEMPERATURE	BACK PRESSURE
◇ MAIN DRIVER	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
◇ FRAME OIL HEATER(S)	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
◇ CYL. LUB. HEATER(S)	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)

COOLING WATER REQUIREMENTS-(NOTE 9)

	FLOW m³/h	INLET TEMP °C	OUTLET TEMP °C	INLET PRESS (BARG)	OUTLET PRESS (BARG)	MAX PRESS (BARG)
□ CYLINDER JACKETS						
◆ INTERCOOLER(S)	1,7	35	45	4,5	3,5	6
◇ AFTERCOOLER						
◇ FRAME LUBE OIL COOLER						
◇ ROD PRESSURE PACKING*						
◆ CYLINDER COOLANT CONSOLE	0,90	35	45	4,5	3,5	6
◆ TOTAL QUANTITY, m³/h	2,6					

49
50
51



**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**



**MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT
AIR COMPRESSOR (20-C-7080)**



Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Rev : 02	Page: 13 OF 20
BU	20	VD	303	ME	DSH	75		

Owner Document Number : BU 20 VD 303 ME DSH 75 Rev : 02 Page: 13 OF 20

FRAME LUBE OIL SYSTEM

BASIC LUBE OIL SYSTEM FOR FRAME:

REF: TYPE MAIN BEARINGS: SPLASH (TBA) PRESSURE (FORCED) HEATERS REQUIRED:

TAPER ROLLER PRECISION SLEEVE ELEC. W/THERMOSTAT(S) STEAM

PRESSURE SYSTEM: MAIN OIL PUMP DRIVEN BY: COMP. CRANKSHAFT ELEC. MOTOR OTHER _____

AUX OIL PUMP DRIVEN BY: ELEC. MOTOR OTHER _____

HAND OPERATED PRE-LUBE PUMP FOR STARTING OPERATIONAL TEST & 4 HOUR MECH RUN TEST

API-614 LUBE SYSTEM: NO YES CHECK VALVE ON MAIN PUMP

CONTINUOUS FLOW THROUGH OIL (7.7.2.5)

SEP. CONSOLE FOR PRESS. LUBE SYS: ONE CONSOLE FOR EA. COMP. ONE CONSOLE FOR _____ COMPRESSORS

CONSOLE TO BE OF DECK PLATE TYPE CONSTRUCTION SUITABLE FOR MULTI-POINT SUPPORT AND GROUTING WITH GROUT & VENT HOLES.

ELECTRICAL CLASSIFICATION : ZONE 2 , GROUP IIB CLASS _____ T3 NON-HAZARDOUS

BASIC SYS. REQ'MTS (NORM. OIL FLOWS & VOLUMES)

LUBE OIL	FLOW m³/h	PRESSURE (BARG)	VISCOSITY cst @ 40°C	SUMP VOLUME m³
<input type="checkbox"/> COMPRESSOR FRAME	_____	_____	_____	_____
<input type="checkbox"/> DRIVER	_____	_____	_____	_____
<input type="checkbox"/> GEAR	_____	_____	_____	_____

SYSTEM PRESSURES: DESIGN _____ (BARG) HYDROTEST _____ (BARG)

PRESSURE CONTROL VALVE SETTING _____ VTS (BARG) PUMP RELIEF VALVE(S) SET _____ (BAR)

PIPING MATERIALS:

	CARBON STEEL	STAINLESS STEEL WITH SS FLANGES	STAINLESS STEEL WITH CARBON STEEL FLANGES
<input checked="" type="checkbox"/> UPSTREAM OF PUMPS & FILTERS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/> DOWNSTREAM OF FILTERS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PUMPS

	RATED FLOW	PRESSURE (BARG)	COLD START REQ'D KW	DRIVER KW	SPEED RPM	COUPLING REQ'D	MECH. SEAL REQ'D
MAIN	NA	2,0	NA	SHAFT DRIVEN	NA	<input type="checkbox"/>	<input type="checkbox"/>
AUXILIARY	_____	_____	_____	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>

PUMP CASING MATERIAL MAIN PUMP _____ AUX PUMP _____

GUARD(S) REQ. FOR COUPLING(S): MAIN PUMP AUX PUMP GUARD TYPE OR CODE _____

AUXILIARY PUMP CONTROL: MANUAL AUTOMATIC ON-OFF-AUTO SEL. SWITCH: BY PURCH. BY MFR.

WIRING TO TERMINAL BOX: BY PURCH. BY MFR.

SWITCHES RTD'S/THERMOCOUPLES

COOLERS:

SHELL & TUBE SINGLE DUAL W/TRANSFER VALVE MFG'S STD. TEMA C TEMA R

REMOVABLE BUNDLE WATER COOLED AIR COOLED W/AUTO TEMP CONTROL

W/BYPASS & TEMP CONTROL VALVE: MANUAL AUTO SEE SEPARATE HEAT EXCHANGER DATA SHTEET

FILTER(S)

SINGLE DUAL W/TRANSFER VALVE ASME CODE DESIGN ASME CODE STAMPED

DESIGN PRESSURE, _____ (BARG) ΔP CLEAN, _____ (BARG) ΔP COLLAPSE, _____ (BARG)


MICRON RATING, _____ CARTRIDGE MATERIAL, _____ CARTRIDGE P/N _____

BONNET MATERIAL, _____ CASING MATERIAL, _____ FURN.SPARE CARTR.,QTY _____

SYS. COMPONENT SUPP.

	MANUFACTURER	MODEL	MANUFACTURER	MODEL
<input checked="" type="checkbox"/> MAIN PUMP	Airpack	_____	<input type="checkbox"/> OIL COOLER(S)	_____
<input type="checkbox"/> AUXILIARY PUMP	_____	_____	<input type="checkbox"/> TRANSFER VALVE(S)	_____
<input checked="" type="checkbox"/> MECHANICAL SEALS	Airpack	_____	<input type="checkbox"/> PUMP COUPLING(S)	_____
<input checked="" type="checkbox"/> ELECTRIC MOTORS	WEG	_____	<input checked="" type="checkbox"/> SUCTION STRAINER(S)	TBC
<input type="checkbox"/> STEAM TURBINES	_____	_____	<input checked="" type="checkbox"/> CHECK VALVE(S)	TBC
<input checked="" type="checkbox"/> OIL FILTER(S)	Airpack	_____		

OWNER:



شرکت پتروشیمی بوشهر
BUPC

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**

CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT

MC:



شرکت سست و سیستم های مکانیک
SST

**MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT
AIR COMPRESSOR (20-C-7080)**



Contract No : 52-98/445

Owner Document Number :	BU	20	VD	303	ME	DSH	75	Rev : 02	Page: 14 OF 20
--------------------------------	-----------	-----------	-----------	------------	-----------	------------	-----------	-----------------	-----------------------

COOLING WATER SYSTEM

BASIC COOLING SYS. FOR: COMPRESSOR CYL.(S) INTERCOOLER(S) AFTERCOOLER OIL COOLER(S)

HEATERS REQ'D FOR PRE-HEATING: ELEC.,W/ THERMOSTAT(S) STEAM

PRESSURE FORCED CIRCULATING SYS: OPEN, PIPING BY: PURCH MFR CLOSED, PIPING BY MFR.

MAIN WATER PUMP DRIVEN BY: ELEC. MOTOR STEAM TURBINE OTHER

AUX WATER PUMP DRIVEN BY: ELEC. MOTOR STEAM TURBINE OTHER

SEP. CONSOLE FOR COOLING WATER SYS.: ONE CONSOLE FOR EA. COMP. ONE CONSOLE FOR _____ COMP'RS

CONSOLE TO BE OF DECK PLATE TYPE CONSTRUCTION SUITABLE FOR MULTI-POINT SUPPORT AND GROUTING WITH GROUT & VENT HOLES.

ELECTRICAL CLASSIFICATION ZONE 2 IIB T3 NON-HAZARDOUS

BASIC SYS. REQ'MTS (NORM. COOLING WATER FLOW DATA) COOL'G WATER TO BE _____ % ETHYL'NE GLYCL SITE

	FORCED COOL'G	THERMO SYPHON	STAND PIPE	FLOW m³/h	PRESSURE (BARG)	INLET TEMP °C	OUTLET TEMP °C	FLOW IND'TR
CYLINDER(S), _____ STAGE	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	0,9	4,5	35	45	<input checked="" type="radio"/>
CYLINDER(S), _____ STAGE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>					<input type="radio"/>
CYLINDER(S), _____ STAGE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>					<input type="radio"/>
CYLINDER(S), _____ STAGE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>					<input type="radio"/>
CYLINDER(S), _____ STAGE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>					<input type="radio"/>
CYLINDER(S), _____ STAGE	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>					<input type="radio"/>
PISTON ROD PACK'G TOTAL	<input type="radio"/>							<input type="radio"/>
INTERCOOLER(S) TOTAL	<input type="radio"/>							<input type="radio"/>
AFTERCOOLER	<input type="radio"/>							<input type="radio"/>
OIL COOLER(S)	<input type="radio"/>							<input type="radio"/>
JACKET COOLER	<input type="radio"/>							<input type="radio"/>
TOTAL FLOW								

SYS. PRESSURES: DESIGN, _____ (BARG) HYDROTEST, _____ (BARG) RELIEF VALVE(S), SETTING _____ PSIG

WATER RESERVOIR: SIZE, _____ mm DIA X _____ mm HT. CAPACITY _____ m @ Normal Operating Level

RESERVOIR MATERI/ c.s INTERNAL COATING, TYPE _____

LEVEL GAUGE LEVEL SWITCH DRAIN VALVE INSPECTION & CLEAN-OUT OPENINGS

PUMPS: (Centrifugal Only) RAT'D FL'W m³/h PRESS. (BARG) REQ'D kW DRIVER kW SPEED RPM COUPLING REQ'D MECH. SEAL REQ'D

MAIN _____ _____ _____ _____ _____ _____ _____ _____

AUXILIARY _____ _____ _____ _____ _____ _____ _____ _____

PUMP CASING MATERIAL (Ref 6.14.2.1.5): MAIN PUMP _____ AUX PUMP _____

GUARD(S) REQ'D FOR COUP'G(S) MAIN PUMP AUX PUMP GUARD TYPE OR CODE _____

AUX.PUMP CONTROL: MANUAL AUTO ON-OFF-AUTO SEL. SWITCH: BY PURCH. BY MANUFACTURER

WIRING TO TERMINAL BOX: BY PURCH. BY MANUFACTURER

COOLING WATER HEAT EXCH.: SHELL & TUBE SINGLE DUAL W/TRANSFER VALVE TEMA C TEMA R(API-660)

AIR COOLED EXCHANGER W/AUTO TEMP CONTROL (API-661 Data Sheets Attached)

W/BYPASS & TEM. CONTROL VALVE MANUAL AUTO LOUVERS FOR AIR EXCH.

SEE SEPARATE COOLER DATA SHEET FOR DETAILS; SPECIFY % GLYCOL ON BOTH SIDES OF SHELL & TUBE

SYS. COMPONENT SUPP.	MANUFACTURER	MODEL	MANUFACTURER	MODEL
<input type="checkbox"/> MAIN PUMP			<input type="checkbox"/> TEMP CONTROL VALVE(S)	
<input type="checkbox"/> AUXILIARY PUMP			<input type="checkbox"/> TRANSFER VALVE(S)	
<input type="checkbox"/> MECHANICAL SEALS			<input type="checkbox"/> PUMP COUPLING(S)	
<input type="checkbox"/> ELECTRIC MOTORS				
<input type="checkbox"/> STEAM TURBINES				

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC:   شرکت پتروشیمی بوشهر	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)
---	--

Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445
BU	20	VD	303	ME	DSH	75	Rev : 02 Page: 15 OF 20

PULSATION SUPPRESSION DEVICES FOR RECIPROCATING COMPRESSORS
 THESE SHEETS TO BE FILLED OUT FOR EACH SERVICE AND/OR STAGE OF COMPRESSION

3 **APPLICABLE TO:** PROPOSALS PURCHASE AS BUILT

4 **FOR/USER** BUSHEHR PETROCHEMICAL COMPANY (BUPC)

5 **SITE/LOCATION** ASSALUYE **AMBIENT TEMPERATURE MIN/MAX** 5 / 55 °C

6 **COMPRESSOR SERVICE** EMERGENCY INSTRUMENT AIR COMP **NUMBER OF COMPRESSORS** 1 SET

7 **COMPRESSOR MFG.** **MODEL/TYPE**

8 **SUPPRESSOR MFG.**

9 **NOTE:** Ind.Data Comp.'d Purch. By Compr/Supp.Mfg.w/Proposal By Mfg(s) after order By Mfg(s)/Purchaser as Applicable

GENERAL INFORMATION APPLICABLE TO ALL SUPPRESSORS

11 **TOTAL NUMBER OF SERVICES AND/OR STAGES**

12 **TOTAL NUMBER OF COMPRESSOR CYL.** 2 **TOTAL NUMBER OF CRANKTHROWS** 1 **STROKE** mm **RPM**

13 ASME CODE DESIGN GOVERNMENTAL CODES OF CODE REGULATIONS APPLY

14 OTHER APPLICABLE PRESSURE VESSEL SPEC. OR CODE

15 LUBE SERVICE NON-LUBE SERV. NO OIL ALLOWED INTERNALLY **DRY TYPE INTER.CORR.COATING** YES NO

16 RADIOGRAPHY (X-RAY OF WELDS): NONE SPOT 100% IMPACT TEST SPECIAL WELDING REQUIREMENTS

17 SHOP INSPECTION WITNESS HYDROTEST OUTDOOR STORAGE OVER 12 MONTHS SPECIAL PAINT SPEC: BU-20-D-000-PI-SPC-409

18 WITNESSED OBSERVED

CYLINDER, GAS, OPERATING, AND SUPPRESSOR DESIGN DATA

	SERVICE EMERGENCY INSTRUMENT AIR COMP STAGE NO. 2																				
<input type="checkbox"/> COMPRESSOR MANUFACTURER'S RATED CAPACITY	LBS/HR SCFM MMSCFD																				
<input type="checkbox"/> LINE SIDE OPERATING PRESSURE	INLET, (BARA) DISCHARGE, (BARA)																				
<input type="checkbox"/> OPERATING TEMP. WITHIN SUPPRESSORS	INLET, °C DISCHARGE, °C																				
<input type="checkbox"/> ALLOWABLE PRESSURE DROP THROUGH SUPPRESSORS	Δ P (BAR) / % Δ P (BAR) / %																				
	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:50%; color: blue;">INLET SUPPRESSOR</th> <th style="width:50%; color: blue;">DISCHARGE SUPPRESSOR</th> </tr> <tr> <td style="text-align: center;">20-DC-7080-1</td> <td style="text-align: center;">20-DC-7080-2</td> </tr> <tr> <td style="text-align: center;"><input type="radio"/> YES <input checked="" type="radio"/> NO</td> <td style="text-align: center;"><input type="radio"/> YES <input checked="" type="radio"/> NO</td> </tr> <tr> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> </tr> <tr> <td style="text-align: center;">(BAR) / %</td> <td style="text-align: center;">(BAR) / %</td> </tr> <tr> <td style="text-align: center;">(BAR) / %</td> <td style="text-align: center;">(BAR) / %</td> </tr> <tr> <td style="text-align: center;"><input type="radio"/> YES <input checked="" type="radio"/> NO</td> <td style="text-align: center;"><input type="radio"/> YES <input checked="" type="radio"/> NO</td> </tr> <tr> <td style="text-align: center;">(BARA) 13,5 @ 85 °C</td> <td style="text-align: center;">(BARA) 25 @ 210 °C</td> </tr> <tr> <td style="text-align: center;">0,3 m³</td> <td style="text-align: center;">0,3 m³</td> </tr> <tr> <td style="text-align: center;">m³</td> <td style="text-align: center;">m³</td> </tr> </table>	INLET SUPPRESSOR	DISCHARGE SUPPRESSOR	20-DC-7080-1	20-DC-7080-2	<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO	1	1	(BAR) / %	(BAR) / %	(BAR) / %	(BAR) / %	<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO	(BARA) 13,5 @ 85 °C	(BARA) 25 @ 210 °C	0,3 m³	0,3 m³	m³	m³
INLET SUPPRESSOR	DISCHARGE SUPPRESSOR																				
20-DC-7080-1	20-DC-7080-2																				
<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO																				
1	1																				
(BAR) / %	(BAR) / %																				
(BAR) / %	(BAR) / %																				
<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO																				
(BARA) 13,5 @ 85 °C	(BARA) 25 @ 210 °C																				
0,3 m³	0,3 m³																				
m³	m³																				
<input checked="" type="radio"/> SUPPRESSOR TAG NUMBER <input checked="" type="radio"/> COMBINATION INLET SUPP SEPARATOR/INTERNALS <input type="checkbox"/> NO. (QTY) OF INLET & DISCH. SUPP. PER STAGE <input type="radio"/> ALLOWABLE PEAK-PEAK PULSE @ LINE SIDE NOZZLE <input type="radio"/> ALLOWABLE PEAK-PEAK PULSE @ CYL FLANGE NOZZLE <input checked="" type="radio"/> DESIGN FOR FULL VACUUM CAPABILITY <input checked="" type="radio"/> MIN. REQ'D WORKING PRESSURE & TEMPERATURE NOTE: AFTER DESIGN, THE ACTUAL MAWP & TEMP ARE TO BE DETERMINED BASED ON THE WEAKEST COMPONENT AND STAMPED ON THE VESSEL, THE ACTUAL MAWP IS TO BE SHOWN ON PG. 14 LINE 12 AND ON THE U1A FORMS <input checked="" type="radio"/> INITIAL SIZING VOL. PER FORMULA OF 7.9.3.2 NOTE: This is a Reference																					
<input checked="" type="checkbox"/> AS BUILT VOLUME (m³)																					

42 **#2 : PULSATION DAMPING FOR INLET AND OUTLET OF EACH CYLINDER, BY VOLUME BOTTLES.**

43

44

45

46

47

48



49

50

51

52

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC:   شرکت پتروشیمی بوشهر	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)	Contract No : 52-98/445
---	--	-------------------------

Owner Document Number :	BU	20	VD	303	ME	DSH	75	Rev : 02	Page: 16 OF 20
-------------------------	----	----	----	-----	----	-----	----	----------	----------------

1 **PULSATION SUPPRESSION DEVICES FOR RECIPROCATING COMPRESSORS (CONT'D)** SERVICE _____
 2 THESE SHEETS TO BE FILLED OUT FOR EACH SERVICE AND/OR STAGE OF COMPRESSION STAGE NO. _____

	INLET SUPPRESSOR	DISCHARGE SUPPRESSOR
3 CONSTRUCTION REQUIREMENTS & DATA		
4 ● SUPPRESSOR TAG NUMBER		
5 ● BASIC MATERIAL REQUIRED, CS, SS, ETC.	Carbon Steel	Carbon Steel
6 ◇ ACTUAL MATERIAL DESIGNINATION	/	/
7 ○ SPECIAL HARDNESS LIMITATIONS, Rc	SHELL & HEADS	SHELL & HEADS
8 ● CORROSION ALLOWANCE., mm	WELDS	WELDS
9 ◆ WALL THICKNESS, mm	3 mm	3 mm
10 □ NOM. SHELL DIA X OVERALL LGTH. (mm/m ³)	mm/ mm	mm. mm
11 □ PIPE OR ROLLED PLATE CONSTRUCTION	mm/ mm ³	mm. mm ³
12 ◆ ACT. MAX ALLOW. WORKING PRESS. AND TEMPERATURE	<input type="checkbox"/> PIPE <input type="checkbox"/> ROLLED PLATE	<input type="checkbox"/> PIPE <input type="checkbox"/> ROLLED PLATE
13 ● MINIMUM DESIGN METAL TEMP (2.14.8)	(BAR) @ °C	(BAR) @ °C
14 ○ INLET SUPPRESS. TO BE SAME MAWP AS DISCH'RG SUPPRESS.	°C	°C
15 ◇ MAX EXPECTED PRESSURE DROP(Δ P, %) LINE PRESS	<input type="radio"/> YES <input type="radio"/> NO	<input type="radio"/> YES <input type="radio"/> NO
16 ◇ WEIGHT (EACH)	Δ P (BAR) / %	Δ P (BAR) / %
17 ○ INSUL CLIP	kg	kg
18 ◇ EXPECTED P-P PULSE @ LINE SIDE/CYL FLG, % LINE PRESS BASED ON FINAL SUPPRESSOR DESIGN	VTS	VTS
19	%/ %	%/ %
20		

	INLET SUPPRESSOR	DISCHARGE SUPPRESSOR
21 CONNECTION REQUIREMENTS & DATA		
22 ● LINE SIDE FLANGE. SIZE/RATING/FACING/TYPE	VTS/VTS/RF/WN	VTS/VTS/RF/WN
23 ● COMP CYL FLANGE(S), QTY/SIZE/RATING/FACING/TYPE	VTS	VTS
24 ○ FLANGE FINISH, ○ PER 3.9.3.15 >3.2 <6.4 ○ SPECIAL (SPECIFY) ● PER ANSI 16.5		
26 ● INSPECTION OPENINGS REQUIRED	<input type="radio"/> YES <input checked="" type="radio"/> NO <input type="radio"/> BLINDED	<input type="radio"/> YES <input checked="" type="radio"/> NO <input type="radio"/> BLINDED
27 ● SPEC. QTY. SIZE, /FLG TYPE & RATING		
28 ◇ * QTY. SIZE, /FLG TYPE & RATING		
29 ● VENT CONNECTIONS REQUIRED	<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO
30 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING		
31 ◇ * QTY. SIZE, /FLG TYPE & RATING		
32 ● DRAIN CONNECTIONS REQUIRED	<input checked="" type="radio"/> YES <input type="radio"/> NO	<input checked="" type="radio"/> YES <input type="radio"/> NO
33 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING		
34 ◇ * QTY. SIZE, /FLG TYPE & RATING		
35 ● PRESSURE CONNECTIONS REQUIRED	<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO
36 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING		
37 ◇ * QTY. SIZE, /FLG TYPE & RATING		
38 ● TEMPERATURE CONNECTIONS REQUIRED	<input type="radio"/> YES <input checked="" type="radio"/> NO	<input type="radio"/> YES <input checked="" type="radio"/> NO
39 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING		
40 ○ CYL NOZZLE ○ MAIN BODY		
41 ◇ * QTY. SIZE, /FLG TYPE & RATING		
42		
43		
44		
45		

46 **OTHER DATA AND NOTES**

47 ◆ COMPRESSOR MFG'S SUPP. OUTLINE OR DRAWING NO.

48 ◇ SUPP. MFG'S OUTLINE OR DRAWING NO.

49

50

51

52

OWNER:



شرکت پتروشیمی بوشهر
BUPC

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**

CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT

MC:



شرکت مهندسی پارس پارس
Pars Pars Engineering Company

**MECHANICAL DATA SHEET FOR EMERGENCY
INSTRUMENT AIR COMPRESSOR (20-C-7080)**



Owner Document Number :	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445
	BU	20	VD	303	ME	DSH	75	Rev : 02 Page: 17 OF 20

INSTRUMENTATION

PURCHASER TO FILL IN () **AFTER COMMODITY TO INDICATE:** **BY COMP. MFR.** **BY PURCH.** **BY OTHERS**

INSTRUMENT & CONTROL PANEL ():

ONE FOR EA. UNIT ONE COMMON TO ALL UNITS

MACHINE M'TED FREE STANDING (OFF UNIT) / LOCAL REMOTE INDOORS

PNEUMATIC ELEC. ELECTRONIC HYDRAULIC PROGRAMMABLE CONTR'L'R

NEMA 7, CLASS _____, GROUP IIB _____, DIVISION _____ INTRINSICALLY SAFE (Exi)

I/S BARRIERS ()

NEMA 4, WATERTIGHT & DUSTTIGHT PURGED TO NFPA 496 TYPE X Y Z

OTHER NEMA IP42 _____ LOW PURGE PRESS. ALARM SHUTDOWN

VIB, ISOLATORS STRIP HEATERS PURGE CONN. EXTRA CUTOUTS

ANNUNCIATOR W/FIRST-OUT INDICATION LOCATED ON CONTROL PANEL

PURCHASER'S CONN. BROUGHT OUT TO TERMINAL BOX BY VENDOR

IP PROTECTION : IP 65 FOR LOCAL PANEL , IP 42 FOR CONTROL INDOOR PANEL.

BUFFER GAS CONTROL PANE ONE FOR EA. UNIT ONE COMMON TO ALL UNITS

INSTRUMENTATION SUITABLE FOR: INDOORS OUTDOORS IP PROTECTION: IP-65 OTHER

PREFERRED INSTRUMENT SUPPLIERS, (TO BE COMPLETED BY PURCHASER), OTHERWISE MFR'S STANDARD APPLIES

PRESSURE GAUGES	MFR	as per instrument data sheets	SIZE & TYPE	as per instrument data sheets	MTL
TEMPERATURE GAUGES	MFR	as per instrument data sheets	SIZE & TYPE	as per instrument data sheets	MTL
LIQUID LEVEL GAUGES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
DIFF. PRESSURE GAUGES	MFR	as per instrument data sheets	SIZE & TYPE	as per instrument data sheets	MTL
PRESS. TRANSMITTERS	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
LIQUID LEV. TRANSMITTER	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
PRESSURE SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
TEMPERATURE SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
LIQUID LEVEL SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
DIFF. PRESSURE SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
CONTROL VALVES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
PRESSURE SAFETY VALVES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
SIGHT FLOW INDICATORS	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
VIBRATION MONITORS & EQUIP.	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
THERMOCOUPLES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
RTD'S	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
SOLENOID VALVES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
ANNUNCIATOR	MFR		MODEL & (QTY SPARE POINTS)		()
PROGRAMMABLE CONTROLLER	MFR		TYPE		MTL
	MFR		TYPE		MTL
	MFR		TYPE		MTL

PRESSURE GAUGE REQUIREMENTS LIQUID FILLED PRESSURE GAUGES: YES NO

FUNCTION	LOCALLY MOUNTED		PANEL MOUNTED		PROCESS GAS: INLET PRESS.	LOCALLY MOUNTED		PANEL MOUNTED	
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LUBE OIL MAIN PUMP DISCHAR.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LUBE OIL AUX. PUMP DISCHARG.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	@ EA. STAGE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LUBE OIL PRESS. AT FRAME HEADER (<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LUBE OIL FILTER Δ P	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	DISCH. PRESS. @ EA. STAGE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COOLING H ₂ O INLET HEADER	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REMARKS: _____

OWNER: شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR: Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT
--	--	--

MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)
----------------	--

Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445
BU	20	VD	303	ME	DSH	75	Rev : 02 Page: 18 OF 20

Owner Document Number BU 20 VD 303 ME DSH 75 Rev : 02 Page: 18 OF 20

INSTRUMENTATION (CONT'D)									
FUNCTION				LOCALLY MOUNTED	PANEL MOUNTED	GAUGE W/ CAPIL'RY	THERMO CPL SYS	RTD SYS	I/S SYS
LUBE OIL	<input type="radio"/> INLET	<input type="radio"/> OUT OF	FRAME	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LUBE OIL	<input type="radio"/> INLET	<input type="radio"/> OUT OF	COOLER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
MAIN JRNL BEARINGS	(THERMOCOUPLES OR RTD'S ONLY)			(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
MOTOR BEARING(S)	(THERMOCOUPLES OR RTD'S ONLY)			(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COOLING WATER HEADER:	<input checked="" type="radio"/> INLET	<input checked="" type="radio"/> OUTLET		(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CYL. COOLING WATER:	<input type="radio"/> INLET	<input checked="" type="radio"/> OUTLET	<input checked="" type="radio"/> EA. CYL	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PROCESS GAS:	<input checked="" type="radio"/> INLET	<input checked="" type="radio"/> DISCH.	<input type="radio"/> EACH CYL	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
PROCESS GAS:	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
INTERCOOLER(S)	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
AFTERCOOLER:	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COOLING WATER	<input type="radio"/> INLET	<input type="radio"/> OUTLET/COOLED PKG CASE(S)		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRESS. PGK CASE, CYL PIST ROD	(THRM/CPLS OR RTD'S ONLY)			(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COMPRESSOR VALVES	<input type="radio"/> SUCT.	<input type="radio"/> DISCH.	TC'S OR RTD'S ONLY	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ALARM & SHUTDOWN SWITCH REQ'MTS NOTE: ALARM & SHUTDOWN SWITCHES SHALL BE INDIVIDUALLY SEPARATE

ALARM DEVICES TRANSMITTER
 SHUTDOWN DEVICES TRANSMITTER

FUNCTION	ALARM		SHUT DOWN		ANNUNCIATION POINTS				
					ALARM		SHUTDOWN		TOTAL NO. OF POINTS
					IN PNL BY MFR	IN CTL ROOM PANEL OTH'RS	IN PNL BY MFR	IN CTL ROOM PANEL OTH'RS	
LOW LUBE OIL PRESS. @ BEARING HEADER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1
HIGH LUBE OIL Δ P ACROSS FILTER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
LOW LUBE OIL LEVEL, FRAME	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
AUX LUBE OIL PUMP, FAIL TO START	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
CYL LUBE SYSTEM PROTECTION	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
COMPR. VIBRATION, SHUTDOWN ONLY			(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
VIBRATION, W/ CONTINUOUS MONITORING	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
ROD DROP DETECTOR, CONTACT TYPE(1/CYL)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
ROD DROP PROXIMITY PROBE (1/CYL)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
OIL TEMP OUT OF FRAME	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HIGH GAS DISCH. TEMP EACH CYLINDER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HIGH JACKET WATER TEMP., EA. CYL	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
LOW SUCTION PRESS., FIRST STG INLET	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HI DISCH. PRESS. <input type="radio"/> FINAL <input checked="" type="radio"/> EA STG	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
HI CYL. GAS Δ P, EACH STAGE	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HI LIQ. LEV., SEPARATOR	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
LOW PURGE GAS PRESS, DISTANCE PIECE(S)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
HI X-HD PIN TEMP	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
PRESS PKG CASE (PISTON ROD TEMP)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
LOW PRESSURE COOLING WATER INLET	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
TOTAL NUMBER OF ANNUNCIATION POINTS									

SWITCH CONTACT OPERATION NOTE: EACH SWITCH SHALL BE MINIMUM SPDT ARRANGEMENT

ALARM CONTACTS SHALL: OPEN (DE-ENER.) TO SOUND ALARM & BE ENERGIZED WHEN COMPR. IS IN OPERATION(NORMALLY CLOSE)
 CLOSE (ENERGIZE) TO SOUND ALARM & BE DE-ENERGIZED WHEN COMPR. IS IN OPERATION(NORMALLY OPEN)

SHUTDOWN CONTACTS SHALL: OPEN (DE-ENERGIZED) TO SHUTDOWN & BE ENERGIZE WHEN COMPR. IS IN OPERATION(NORMALLY CLOSE)
 CLOSE (ENERGIZE) TO SHUTDOWN & BE DE-ENERGIZE WHEN COMPR. IS IN OPERATION(NORMALLY OPEN)

REF: 7.6.6.2 FOR MINIMUM RECOMMENDED PROTECTION REQUIREMENTS

OWNER:



شرکت پترو شیمی یوشهر
BUPC

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**

CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT

MC:



شرکت سست و سیستم های پتروشیمی
SST

**MECHANICAL DATA SHEET FOR EMERGENCY
INSTRUMENT AIR COMPRESSOR (20-C-7080)**

Contract No : 52-98/445



Owner Document Number :

Project	Area	Phase	Unit	Dis.	Doc.	Seq.
BU	20	VD	303	ME	DSH	75

Rev : 02 Page: 19 OF 20

INSTRUMENTATION (CONT'D)

MISCELLANEOUS INSTRUMENTATION

2	SIGHT FLOW IND. (COOLING H ₂ O ONLY)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	<input type="checkbox"/> INTERCLR(S)	<input type="checkbox"/> AFTERCLR	<input type="checkbox"/> OIL CLR	<input type="checkbox"/> H ₂ O CLR
3	PNEUMATIC PRESSURE TRANSMITTERS	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	<input type="checkbox"/> CYL JACKET WATER	<input type="checkbox"/> ROD PRESS. PKG CASES		
4	PRESSURE TRANSMITTERS (ELEC. OUTP.)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:				
5	PNEUMATIC LEVEL TRANSMITTERS	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)					
6	ALARM HORN & ACKN'LMT TEST BUTTON	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)					
7	CONDUIT & WIRING W/JUNCT. BOXES (CON-SOLES)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)					
8	TEST VALVES	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:				
9	DRAIN VALVES	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	Coolers			
10	GAUGE GLASS(ES)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	Recirculating Oil,			
11	TACHOMETER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			SPEED RANGE _____ TO _____ RPM		
12	CRANKSHAFT KEY PHASER AND TRANSDUCER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:				
13	LEVEL GAUGE ON SUCTION SUPPRESSOR	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)					
14	OIL LEVEL SWITCH ON CRAKCASE	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)					

SEPARATE LUBE OIL CONSOLE INSTRUMENTATION: PURCH. TO LIST REQ'MTS IN ADDITION TO ANY ABOVE REQ'MTS

17	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
18	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
19	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
20	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
21	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
22	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
23	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	

SEPARATE COOLING WATER CONSOLE INSTRUMENT: PURCH. TO LIST REQ'MTS IN ADDITION TO ANY ABOVE REQ'MTS





24	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
25	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
26	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
27	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
28	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
29	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	
30	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	

RELIEF VALVES

	LOCATION	BY	MANUFACTURER	TYPE	SIZE	SETTING
32	EACH STAGE DISCHARGE	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	TBC		1" / 11/2"	26 barg
33	COOLING WATER OUTLET	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
34	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
35	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
36	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
37	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
38	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
39	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
40	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
41	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				
42	_____	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)				

NOTES:
#1 SEE MOTOR DATA SHEET FOR ADDITIONAL MOTOR INSTRUMENTATION REQUIREMENTS

43
44
45
46
47
48
49
50

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:   Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT						
MC:  شرکت سست درستی شش	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)						Contract No : 52-98/445	
Owner Document Number :	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	Rev : 02 Page: 20 OF 20

GENERAL NOTES

- (1) COMPRESSOR STARTS BY MEANS OF A LOW-PRESSURE SWITCH ON DELIVERY PIPE AND STOPS WHEN HIGH PRESSURE IS REACHED . THE REQUIRED LOW/HIGH PRESSURE TRANSMITTER TO MAINTAIN THE REQUIRED DELIVERY PRESSURE WILL BE SUPPLIED BY VENDOR . THE OPERATION IS INTERMITTENT.
- (2) DELETED, VENDOR SHALL PROVIDE AFTER-COOLER .AFTERCOOLER OUTLET GAS TEMPERATURE TO BE 40 DEG C.
- (3) DELETED
- (4) DELETED
- (5) FOR UTILITIES SUPPLY CONDITION AND CLIMATE CONDITION REFER TO "AMBIENT ,SITE CONDITION & UTILITY DATA" , (BU-20-B-000-PR-SPC-111)
- (6) MINIMUM METAL TEMPRATURE = 0 DEG C
- (7) DELETED
- (8) DEW POINT AT INLET -170 DEG C, DEW POINT AT ATM. -194.6 DEG C
- 9) TYPE OF COMPRESSOR : VERTICAL
- (10) VENDOR ALSO SHALL PROVIDE BELOW ITEMS:
 SPARE PARTS
 TEMPORARY STRAINER
- (11)GENERAL NOTES :
- A. PROVIDE CONTACTS OPEN FOR CUMULATIVE ALARM AND CUMULATIVE SHUTDOWN .
 - B. PROVIDE SAFETY VALVE ON COMPRESSOR DISCHARGE ,WITH LOCKED OPEN ISOLATING VALVE .
 - C. PROVIDE SEPARATE INSTRUMENT FOR ALARM AND SHUTDOWN.
 - D. THE VENDOR TOGETHER WITH THE INSTRUMENT DOCUMENTATION MUST SUPPLY. A COMPLETE LIST OF ALL THE ALARMS AND INTERLOCKS WITH ALL SET VALUES.
 - E. PROVIDE A VISUAL FLOWMETER ON COOLING WATER RETURN LINE.
 - F. NOISE PRESSURE LEVEL AT 1 M. SHALL BE LESS THAN 80 DB(A)
- (12)VENDOR SHOULD FOLLOW DOC NO.: BU-20-D-000-IN-SPC-676 FOR SPECIFICATION OF APPLICABLE INSTRUMENT.
- (13)PLC PACKAGE SYSTEM (UCP) WILL BE INSTALLED IN CONTROL/AUXILIARY ROOM.
 LOCAL PANEL INCLUDING START/STOP PUSH BUTTONS ,LAMPS AND INDICATORS, TRIP RESET PUSH BUTTON ,AMMETER AND ETC (AS PER PROJECT REQUIREMENTS) WILL BE INSTALLED IN FIELD.
 INSTRUMENT WILL BE INSTALLED ON MACHINE OR FREE STANDING.
- (14) DELETED
- (15) THE CAPACITY TO BE SUPPLIED CONSIDERING NO NEGATIVE TOLERANCE. THE REQUIRED CAPACITY (NNT) IS 1.1*50=55 KG/H.
- (16) COMPRESSOR TYPE IS RECIPROCATING