









OWNER:  شرکت پترو شیمی دوشهر BUPC	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT							CONTRACTOR  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 	
MC:  شرکت مهندسی و پیمانکاری ماسپان MASPAN	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							Contract No : 52-98/445	
17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 0075	rev 04	Page: 1 OF 20

MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)

04	06/Apr	Approved for Construction	KP	KP	JR	
03	11/03/2022	Approved for Construction	KP	KP	JR	
02	09/12/2021	Approved for Construction	KP	KP	JR	
01	04/11/2021	for approval	KP	KP	JR	
00	12/08/2021	for approval	KP	KP	JR	
Rev.	Date	Description	Prepared By	Checked By	Approved	AC code.

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 								
MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							Contract No : 52-98/445		
17811-11G	BU	20	VD	303	ME	DSH	75		rev 04	Page: 4 OF 20
GAS ANALYSIS AT OPERATING CONDITIONS								REMARKS		
MOLE PERCENT										
		<input checked="" type="radio"/> SERVICE/ITEM NO.								
		<input checked="" type="radio"/> STAGE								
		<input type="radio"/> NORMAL OR ALT								
		M.W.	NORMAL							
7	AIR	28.966	100							
8	NITROGEN	28.016								
9	WATER H ₂ O	18.016								
10	CARBON MONOXIDE CO	28.010								
11	CARBON DIOXIDE CO ₂	44.010								
12	HYDROGEN H ₂	2.016								
13	METHANE CH ₄	16.042								
14	ETHANE	30.068								
15	PROPANE	44.094								
16	i-BUTANE	58,12								
17	n-BUTANE	58,12								
18	i-PENTANE	72,146								
19	OXYGEN O ₂	32.00								
20	HYDRO. SULFIDE	34,076								
21	ETHYLENE	28,052								
22	PROPYLENE	42,078							APPLICABLE SPECIFICATIONS	
23	n-PENTANE	72,146							<input checked="" type="radio"/> API-618-RECIPROCATING COMPRESSORS FOR PETROLEUM, CHEMICAL AND GAS INDUSTRY SERVICES	
24	HEXANE PLUS								<input checked="" type="radio"/> Doc. No. 1216-DE-00-RE-MSS-302	
25	AMMONIA	17,031								
26	HYDRO. CHLORIDE	36,461								
27	CHLORINE	70,914								
28										
29										
30										
31	TOTAL:									
32	<input type="checkbox"/> CALCULATED MOL WT.		28,97							
33	<input type="checkbox"/> Cp/Cv (K) @ 65° OR	Suction temperature °C	45							
34	NOTE: IF WATER VAPOR AND/OR CHLORIDES ARE PRESENT, EVEN MINUTE									
35	TRACES, IN THE GAS BEING COMPRESSED, IT MUST BE INCLUDED ABOVE.									
36	SITE CONDITION (SEE PROJECT SITE CONDITION FOR MORE DETAIL)									
37	ELEVATION	8,5 m	BAROMETER	1,013 (BARA)	AMBIENT TEMPS: MAX	55 °C	MIN	5 °C		
38			<input type="radio"/> MIN DESIGN METAL TEMP		5 °C (2.14.8)	RELATIVE HUMIDITY: MAX	76%	MIN	74%	%
39	COMPRESSOR LOCATION:	<input type="radio"/> INDOOR	HEATED	<input checked="" type="radio"/> UNHEATED	<input checked="" type="radio"/> AT GRADE LEVEL	<input type="radio"/> ELEVATED:				M
40		<input checked="" type="radio"/> OUTDOOR	NO ROOF	<input checked="" type="radio"/> UNDER ROOF	<input type="radio"/> PARTIAL SIDES	<input type="radio"/> PLATFORM:			<input checked="" type="radio"/> ON-SHORE	
41		<input type="radio"/> OFF-SHORE	<input checked="" type="radio"/> WEATHER PROTECTION REQ.		<input checked="" type="radio"/> TROPICALIZATION REQ.					
42		<input type="radio"/> WINTERIZATION REQUIRED								
43	UNUSUAL CONDITIONS:	<input type="radio"/> CORROSIVES	<input checked="" type="radio"/> DUST	<input checked="" type="radio"/> FUMES	<input checked="" type="radio"/> OTHER	Sand storm , Thunder & Lightening, Sea Breeze				
44	ELECTRICAL CLASSIFICATIONS									
45	HAZARDOUS									
46	NON-HAZARDOUS									
47	MAIN UNIT	<input checked="" type="radio"/> ZONE	2	GROUP	IIB	TEMP CLASS	T3			<input type="radio"/>
48	L.O. CONSOLE	<input checked="" type="radio"/> ZONE	2	GROUP	IIB	TEMP CLASS	T3			<input type="radio"/>
49	CW CONSOLE	<input type="radio"/> ZONE		GROUP		TEMP CLASS				<input type="radio"/>
50										
51										
52										

OWNER: شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR: Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 							
MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)								
17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	Contract No : 52-98/445 rev 04	Page : 5 OF 20

PART LOAD OPERATING CONDITIONS

CAPACITY CONTROL BY: MFG'S CAP. CONTROL PURCHASERS BY-PASS BOTH OTHER _____

FOR: PART LOAD COND. START-UP ONLY BOTH

WITH: AUTO LOADING DELAY INTERLOCK AUTO IMMEDIATE UNLOADING

USING: FIXED VOLUME POCK. SUCTION VALVE UNLOADERS: FINGER PLUG OTHER

ACTION: DIRECT (AIR-TO-UNLOAD) REVERSE (AIR-TO-LOAD/FAIL SAFE)

NUMBER OF STEPS: ONE THREE FIVE OTHER _____

RAIN COVER REQUIRED OVER UNLOADERS

ALL UNLOADING STEPS BASIS MANUFACTURERS CAPACITY SHOWN ON PAGE 1.

INLET AND DISCHARGE PRESSURE ARE	<input type="radio"/> AT CYLINDER FLANGES <input checked="" type="radio"/> PULSATION SUPPRESSOR FLANGES	
<input type="radio"/> SERVICE OR ITEM NO.		
<input type="radio"/> STAGE	1	
<input type="radio"/> NORMAL OR ALTERNATE CONDITION	Normal	
<input type="radio"/> PERCENT CAPACITY	100	
<input type="radio"/> WEIGHT FLOW, kg/h	223	
<input type="radio"/> m ³ /h (760 mm HG & 0°C)	173	
<input type="checkbox"/> POCKETS/VALVES OPERATION *	Valves	
<input type="checkbox"/> POCKET CLEARANCE ADDED %	NA	
<input type="checkbox"/> TYPE UNLOADERS, PLUG/FINGER	Plug	
<input type="radio"/> INLET TEMPERATURE, °C	45	
<input type="radio"/> INLET PRESSURE, (BARA)	8 (Min.:7, Max:8.5)	
<input type="radio"/> DISCHARGE PRESSURE, (BARA)	21,5	
<input type="checkbox"/> DISCHARGE TEMP., ADIABATIC °C	180	
<input type="checkbox"/> DISCHARGE TEMP., PREDICTED °C	164	
<input type="checkbox"/> VOLUMETRIC EFF., %HE/%CE(AVER)	75	/ / / /
<input type="checkbox"/> CALC. GAS ROD LOAD, kN, C **	11,06	
<input type="checkbox"/> CALC. GAS ROD LOAD, kN, T **	0,36	
<input type="checkbox"/> COMB. ROD LOAD, kN C (GAS & INERTIA)	10,83	
<input type="checkbox"/> COMB. ROD LOAD, kN T (GAS & INERTIA)	0,2	
<input type="checkbox"/> ROD REV., DEGREES MIN @ X-HD PIN ***	195	
<input type="checkbox"/> BkW/STAGE	12	
<input type="checkbox"/> TOTAL kW @ COMPRESSOR SHAFT	12	
<input type="checkbox"/> TOTAL kW INCL. V-BELT & GEAR LOSSES	13	

* SHOW OPERATION WITH THE FOLLOWING SYMBOLS:

HEAD END = HE OR CRANK END = CE	} PLUS	SUCTION VALVE(S) UNLOADED = S OR FIXED POCKET OPEN = F OR VARIABLE POCKET OPEN = V
---------------------------------------	--------	--

** C = COMPRESSION T = TENSION *** X - HD = CROSSHEAD


MINIMUM PRESSURE REQUIRED TO OPERATE CYLINDER UNLOADING DEVICES, 6 (BARG)

CYLINDER UNLOADING MEDIUM: AIR NITROGEN OTHER _____

PRESSURE AVAILABLE FOR CYLINDER UNLOADING DEVICES, MAX/MIN 8,0 / 6,0 (BARG)

SPECIAL REMARK:

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC:  شرکت پتروشیمی بوشهر	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)	Contract No : 52-98/445					
Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445

17811-11G	BU	20	VD	303	ME	DSH	75	rev 04	Page: 6 OF 20
------------------	-----------	-----------	-----------	------------	-----------	------------	-----------	---------------	----------------------

SCOPE OF BASIC SUPPLY

PURCHASER TO FILL IN () AFTER COMMODITY TO INDICATE: BY COMPR. MFR. BY PURCH. BY OTHERS

DRIVER (): VARIABLE SPEED SPEED RANGE NOT APPLICABLE RPM TO NOT APPLICABLE RPM
 INDUCTION MOTOR SYNCHRONOUS MOTOR STEAM TURBINE ENGINE OTHER _____
 API-541 API-546 API-611 API-612
 OUTBOARD BEARING PROVISION FOR DRY AIR PURGE FOR OUTBOARD BEARING.
 SLIDE BASE FOR DRIVER () SOLE PLATE FOR DRIVER ()
 MOTOR STARTING EQUIPMENT (); DEFINE _____ Local power distribution board
 GEAR (): BASEPLATE FOR GEAR API-613 API-677
 COUPLING(S) (): LOW SPD. HI-SPD. QUILL SHAFT KEY-LESS DRV. KEY'D DRV. OTHER _____
 API 671
 V-BELT DRIVE (): SHEAVES & V-BELTS () STATIC CONDUCTING V-BELTS BANDED V-BELTS
 DRIVE GUARD(S) (): MANUFACTURER'S STD. NON-SPARKING CALIF CODE API-671 APPENDIX C
 OTHER _____






PULSATION SUPPRESSORS WITH INTERNALS (): INITIAL INLET & FINAL DISCHARGE SUPPORTS ()
 INTERSTAGE SUPPORTS ()
 PULSATION SUPPRESSORS WITHOUT INTRNL (): INITIAL INLET & FINAL DISCHARGE SUPPORTS ()
 INTERSTAGE SUPPORTS ()
 SUPPRESSOR(S) TO HAVE MOISTURE REMOVAL SECTION: INITIAL INLET ONLY ALL INLET SUPPRESSORS
 ACOUSTICAL SIMUL. STUDY (): DESIGN APPROACH 1, EMPRICAL PULSATION SUPPRESSION DEVICE SIZING
 DIGITAL ANALOG 2, ACOUSTIC SIMULATION AND PIPING RESTRAINT ANALYSIS
 3, ACOUSTIC SIMULATION AND PIPING RESTRAINT ANALYSIS PLUS MECHANICAL ANALYSIS
 STUDY TO CONSIDER: ALL SPECIFIED LOAD COND., INCL. SINGLE ACT., PLUS
 COMP. OPER. IN PARALLEL ALTERNATE GASES
 WITH EXISTING COMP. AND PIPING SYSTEMS
 COMPRESSOR VALVE DYNAMIC RESPONSE
 PULSATION SUPPRESSOR DEVICE LOW CYCLE FATIGUE ANALYSIS
 PIPING SYSTEM FLEXIBILITY
 STUDY TO BE WITNESSED
 VENDOR REVIEW OF PURCHASER'S PIPING ARRANGEMENT

PACKAGED: NO YES () DEFINE BASIC SCOPE OF PACKAGING IN REMARKS SECTION
 SKID SOLEPLT. BASEPLT. BOLTS OR STUDS FOR SOLEPLT. TO FRAME RAILS CHOKE BLOCKS SHIMS
 SUITABLE FOR COLUMN MOUNTING (UNDER SKID AND/OR BASEPLATE)
 LEVELING SCREWS NON-SKID DECKING SUB SOLEPLATES
 DIRECT GROUTED CEMENTED/MORTAR GROUT EPOXY GROUT; MFG/TYPE _____ / _____
 INTERCOOLER(S) () SEPARATOR(S) () AFTERCOOLER(S) ()

INTERCOOLERS:
 INTERSTAGE PIPE () PIPING MATCHMARKED SHOP FITTED MACHINE MTD.
 CONDENSATE SEPARATION & COLLECTION FACILITY SYSTEM PER 3.8.12 OFF MOUNTED
 INLET STRAINER(S) (): INITIAL INLET SIDESTREAM INLET SPOOL PIECE FOR INLET STRAINERS
 MANIFOLD PIPING; DRAINS VENTS RELIEF VALVES AIR/GAS SUPPLY FLANGE FINISH
 RELIEF VALVE(S) (): INITIAL INLET INTERSTAGE FINAL DISCHARGE API-618 FLANGE FINISH
 RUPTURE DISC(S) () THRU STUDS IN PIPING FLANGES
 CRANKCASE RAPID PRESSURE RELIEF DEVICE(S) () FLANGE FINISH PER ANSI 16.5
 SPECIAL PIPING REQUIREMENTS SPECIAL FINISH _____

INITIAL INLET, INTERSTAGE SUCTION PIPING ARR'D FOR: INSULATION (PP) () HEAT TRACING ()
 FOR ATMOSPHERIC INLET AIR COMPR. ONLY: INLET AIR FILTER () INLET FILTER -SILENCER ()
 PREFERRED TYPE OF CYLINDER COOLING (): FORCED THERMOSYPHON _____ STAGE CYL(S)
 STATIC (STAND-PIPE) _____ STAGE CYL(S)
 CYL. COOLING WATER PIPING () MATCH M'RKED
 SINGLE INLET/OUTLET MANIFOLD & VALVES SIGHT GL'S(S)
 INDIVIDUAL INLET/ OUTLET PER CYL. VALVE(S)
 CLOSED SYS. WITH WATER PUMP, COOLER, SURGE TANK, & PIPING
 SHOP RUN ARR'D FOR HEATING JACKET AS WELL AS COOLING

NOTE: MANUFACTURER SHALL RECOMMEND BEST TYPE OF COOLING AFTER FINAL ENGINEERING REVIEW OF ALLOPERATING CONDITIONS

OWNER:  شرکت پترو شیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 						
MC:  	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							
17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	Contract No : 52-98/445
	rev 04	Page: 7 OF 20						

1 **SCOPE OF BASIC SUPPLY (Con't)**

2 SEPARATE COOLING CONSOLE (): ONE FOR EA. UNIT ONE CMMN TO ALL UNITS DUAL PUMPS (AUX. & MAIN)

3 ARRANGED FOR HEATING JACKET WATER AS WELL AS COOLING

4 ROD PRESS. PACKING COOLING SYSTEM (): SEPARATE CONSOLE COMBINE WITH JKT SYSTEM FILTERS

5 FRAME LUBE OIL SYSTEM (): AUX. PUMP DUAL FILTERS WITH TRANSFER VALVE SHOP RUN

6 CONTINUOUS FLOW IN SENSING LINE TO PRESSURE SWITCHES

7 SEPARATE LUBE OIL CONSOLE (): EXTENDED TO MOTOR OUTBOARD BEARING SHOP RUN

8 API 614 APPLIES NO YES

9 NOTE: PIPING BETWEEN ALL CONSOLES AND COMPRESSOR UNIT BY PURCHASER

10 CAPACITY CONTROL (): SEE DATA SHEET PAGE 5 FOR DETAILS INSTRUMENT & CONTROL PANEL

11 SEPARATE MACHINE MOUNTED PANEL SEPARATE FREE STANDING PANEL

12 PNEUMATIC ELECTRIC ELECTRONIC HYDRAULIC

13 PROGRAMMABLE CONTROLLER

14 INSTRUMENT & CONTROL PANEL (): ONE FOR EACH UNIT ONE COMMON TO ALL UNITS

15 MACHINE MOUNTED FREE STANDING (OFF UNIT)

16

17 BUFFER GAS CONTROL PANEL () = ONE FOR EACH UNIT ONE COMMON TO ALL UNITS

18 MACHINE MOUNTED FREE STANDING (OFF UNIT)

19 SEE INSTRUMENTATION DATA SHEETS FOR DETAILS OF PANEL, ADDITIONAL REMARKS, AND INSTRUMENTATION

20 NOTE: ALL TUBING, WIRING, & CONNECTIONS BETWEEN OFF-UNIT FREE STANDING PANELS AND COMPRESSOR UNIT BY PURCHASER

23 HEATERS (): FRAME LUBE OIL CYL. LUBRICATORS COOLING WATER DRIVER(S) GEAR OIL

24 ELECTRIC STEAM

25

26 BARRING DEVICE (): MANUAL PNEUMATIC ELECTRIC FLYWHEEL LOCKING DEVICE ()

27 ROD PRESSURE PACKING COOLING SYSTEM (): SEPARATE CONSOLE FILTERS

28 SPECIAL CORROSION PROTECTION: NO YES MFR'S STANDARD OTHER _____

29 HYDRAULIC TENSIONING TOOLS NO YES

30 MECHANICAL RUN TEST: NO YES MFG'S STANDARD OTHER Approved test procedure

31 COMPLETE SHOP RUN TEST OF ALL MACHINE MOUNTED EQUIPMENT, PIPING & APPURT.(S)

32

33 PAINTING: MANUFACTURER'S STANDARD SPECIAL Project specification for color

34 NAMEPLATES: U.S. CUSTOMARY UNITS SI UNITS

35 SHIPMENT: DOMESTIC EXPORT EXPORT BOXING REQUIRED ()

36 STANDARD 6 MONTH STORAGE PREPARATION (), PER SPEC _____

37 OUTDOOR STORAGE FOR OVER 12 MONTHS (), PER SPEC _____

38 INITIAL INSTALLATION AND OPERATING TEMP ALIGNMENT CHECK AT JOBSITE BY VENDOR REPRESENTATIVE

39

40 COMPRESSOR MANUFACTURER'S USER'S LIST FOR SIMILAR SERVICE

41 PERFORMANCE DATA REQUIRED PER 9.3.3: BkW VS. SUCTION PRESSURE CURVES


42 ROD LOAD/GAS LOAD CHARTS



43 VALVE FAILURE DATA CHARTED

44 SPEED/TORQUE CURVE DATA

45 BkW VS. CAPACITY PERFORMANCE CURVES OR TABLES REQUIRED FOR UNLOADING STEPS AND/OR VARIABLE

46 SUCTION/DISCHARGE PRESSURES

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC:  	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)	Contract No : 52-98/445																
17811-11G	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:12.5%;">Project</td> <td style="width:12.5%;">Area</td> <td style="width:12.5%;">Phase</td> <td style="width:12.5%;">Unit</td> <td style="width:12.5%;">Dis.</td> <td style="width:12.5%;">Doc.</td> <td style="width:12.5%;">Seq.</td> </tr> <tr> <td style="text-align: center;">BU</td> <td style="text-align: center;">20</td> <td style="text-align: center;">VD</td> <td style="text-align: center;">303</td> <td style="text-align: center;">ME</td> <td style="text-align: center;">DSH</td> <td style="text-align: center;">75</td> </tr> </table>	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	BU	20	VD	303	ME	DSH	75	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">rev 04</td> <td style="width:50%;">Page: 9 OF 20</td> </tr> </table>	rev 04	Page: 9 OF 20
Project	Area	Phase	Unit	Dis.	Doc.	Seq.												
BU	20	VD	303	ME	DSH	75												
rev 04	Page: 9 OF 20																	

1	<input type="checkbox"/> CYLINDER DATA AT FULL LOAD CONDITION						
2	SERVICE/ITEM NO.	Air					
3	STAGE	1					
4	INLET PRESSURE, (BARA) } @ CYLINDER	8,0					
5	DISCHARGE PRESSURE, (BARA) } @ CYLINDER	21,0					
6	CYLINDERS PER STAGE	2					
7	SINGLE OR DOUBLE ACTING (SA OR DA)	SA					
8	BORE, mm	90					
9	STROKE, mm	140					
10	RPM: RATED / MAX ALLOW	400/690					
11	PISTON SPEED, m/s: RATED / MAX ALLOW	<3,5					
12	CYLINDER LINER, YES/NO	yes					
13	LINER NOMINAL THICKNESS, mm	12,5					
14	PISTON DISPLACEMENT, m³/h	36,9					
15	CYLINDER DESIGN CLEARANCE, % AVERAGE						
16	VOLUMETRIC EFFICIENCY, % AVERAGE	73					
17	VALVES, INLET/DISCHARGE, QTY PER CYL.	1/1	/	/	/	/	
18	TYPE OF VALVES	plate					
19	VALVE LIFT, INLET/DISCHARGE, mm	0,8 / 0,8	/	/	/	/	
20	VALVE VELOCITY, API 4TH EDITION, m/s	19,9					
21	SUCTION VALVE(S)	16,65					
22	DISCHARGE VALVE(S)	16,65					
23	ROD DIAMETER, (mm)	30					
24	MAX ALLOW. COMBINED ROD LOADING, kN, C *	17,5					
25	MAX ALLOW. COMBINED ROD LOADING, kN, T *	17,5					
26	CALCULATED GAS ROD LOAD, kN, C *	11,06					
27	CALCULATED GAS ROD LOAD, kN, T *	0,36					
28	COMBINED ROD LOAD (GAS + INERTIA), kN, C *	10,83					
29	COMBINED ROD LOAD (GAS + INERTIA), kN, T *	0,20					
30	ROD REV., DEGREES MIN @ X-HD PIN**	195,00					
31	RECIP WT. (PISTON, ROD, X-HD & NUTS), kg**	10,74					
32	MAX ALLOW. WORKING PRESSURE, (BARG)	24					
33	MAX ALLOW. WORKING TEMPERATURE, °C	230					
34	HYDROSTATIC TEST PRESSURE, (BARG)	36					
35	HELIUM TEST PRESSURE, (BARG)	3					
36	INLET FLANGE SIZE/RATING at CYLINDER	150#	/	/	/	/	
37	FACING at CYLINDER	RF					
38	DISCHARGE FLANGE SIZE/RATING at CYLINDER	300#	/	/	/	/	
39	FACING at CYLINDER	RF					
40	DISCHARGE RELIEF VALVE SETTING DATA AT INLET PRESSURES GIVEN ABOVE:						
41	RECOMMENDED SETTING, (BARG)	-25					
42	GAS ROD LOAD, kN, C *	17,5					
43	GAS ROD LOAD, kN, T *	17,5					
44	COMBINED ROD LOAD, kN, C *	13,13					
45	COMBINED ROD LOAD, kN, T *	12,6					
46	ROD REVERSAL, *MIN @ X-HD PIN**	195					
47	NOTE: CALCULATED AT INLET PRESSURES						
48	GIVEN ABOVE & RECOMMENDED SETTING.						
49	<input type="checkbox"/> SETTLE-OUT GAS PRESSURE	8,5 - 9,5					
50	(DATA REQUIRED FOR STARTING)						
51	* C = COMPRESSION * T = TENSION		**X-HD = CROSSHEAD				

52 **NOTES/REMARKS:**

53

OWNER:



شرکت پتروشیمی بوشهر

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**

CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT



MC:



**MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR
COMPRESSOR (20-C-7080)**

Project	Area	Phase	Unit	Dis.	Doc.	Seq.
BU	20	VD	303	ME	DSH	75

Contract No : 52-98/445
rev 04 Page: 10 OF 20

17811-11G

CONSTRUCTION FEATURES

1	SERVICE ITEM NO.	
2	STAGE	1
3	CYLINDER SIZE (BORE DIA), mm	90
4	ROD RUN-OUT: NORMAL COLD VERTICAL (per appendix C)	

MATERIALS OF CONSTRUCTION

8	CYLINDER(S)	DUCTILE CAST IRON
9	CYLINDER LINER(S)	EN-GJL-250 (SLG)
10	PISTON(S)	AlCu4PbMgMn T3
11	PISTON RINGS	PTFE compound
12	WEAR BANDS <input type="radio"/> REQUIRED	
13	PISTON ROD(S): MATERIAL/YIELD, N/mm ²	1.2316 (X36CrMo17QT) >447
14	THREAD ROOT STRESS @ MACRL * @ X-HD END	
15	PISTON ROD HARDNESS, BASE MATERIAL, Rc	49
16	PISTON ROD COATING <input type="radio"/> REQUIRED	plasma nitrided to = 1000 HV1
17	COATING HARDNESS, Rc	
18	VALVE SEATS / SEAT PLATE	SS/SS
19	VALVE SEAT MIN HARDNESS, Rc	
20	VALVE GUARDS (STOPS)	79RL (Polymer)
21	VALVE DISCS	79RL (Polymer)
22	VALVE SPRINGS	79RLX (Polymer)
23	ROD PRESSURE PACKING RINGS	NBR, 70-ShA
24	ROD PRESSURE PACKING CASE	Niro (1.4305)
25	ROD PRESSURE PACKING SPRINGS	-
26	SEAL / BUFFER PACKING, DISTANCE PIECE	SK703 E (polymer)
27	SEAL / BUFFER PACKING, INTERMEDIATE	SK703 E (polymer)
28	WIPER PACKING RINGS	SK703 E (polymer)
29	MAIN JOURNAL BEARINGS, CRANKSHAFT	-
30	CONNECTING ROD BEARING, CRANKPIN	-
31	CONNECTING ROD BUSHING, X-HD END	G-Cu Sn 12
32	CROSSHEAD (X-HD) PIN BUSHING	-
33	CROSSHEAD PIN	17Cr3 (1.7016)
34	CROSSHEAD	EN-GJS-400-15
35	CROSSHEAD SHOES	EN-GJS-400-15
36	CYLINDER INDICATOR VALVES (X)	
37	INDICATOR CONNECTIONS ABOVE 5000 PSI	
38	FLUOROCARBON SPRAYED CYLINDER (X)	
39	INSTRUMENTATION IN (X) COLD SIDE	
40	CONTACT W/PROCESS GAS (X) HOT SIDE	
41	* MAXIMUM ALLOWABLE COMBINED ROD LOAD	

USE (X) IN APPROPRIATE COLUMN WHERE APPLICABLE

COMPRESSOR CYLINDER ROD PACKING

FULL FLOATING PACKING

VENTED TO: FLARE @ _____ ATM

SUCTION PRESSURE @ _____ (BARG)

FORCED LUBRICATED NON-LUBE TFE

WATER COOLED, _____ STAGE(S), _____ m³/h REQ'D

OIL COOLED, _____ STAGE(S), _____ m³/h REQ'D

WATER FILTER _____ PROV.FUTURE WATER/OIL COOLING

VENT/BUFFER GAS SEAL PACKING ARR. _____ (Ref: Appndx I FIG I-1)

CONSTANT OR VARIABLE DISPOSAL SYSTEM

BUFFER GAS PRESSURE, _____ (BARG)

SPLASH GUARDS FOR WIPER PACKING

DISTANCE PIECE(S): TYPE A TYPE B TYPE C TYPE D
Ref: Appendix G, Fig. G-3

COVERS: SOLID METAL SCREEN LOUVERED

CYLINDER COMPARTMENT: VENTED TO amb _____ (BARG)

(Outboard Distance Piece) PURGED AT _____ (BARG)

PRESSURIZED TO _____ (BARG)

WITH RELIEF VALVE

FRAME COMPARTMENT: VENTED TO _____ (BARG)

(Inboard Distance Piece) PURGED AT _____ (BARG)

PRESSURIZED TO _____ (BARG)

WITH RELIEF VALVE

DISTANCE PIECE MAWP _____ 0 _____ (BARG)

OWNER:  شریکت پترو شیمیایی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
--	--	--

MC:  شرکت سستپ	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)
--	--

17811-11G	BU	20	VD	303	ME	DSH	75	rev 04	Page: 11 OF 20
------------------	-----------	-----------	-----------	------------	-----------	------------	-----------	---------------	-----------------------

<input type="checkbox"/> CONSTRUCTION FEATURES (CONTINUED)	
---	--

FABRICATED CYLINDER, HEADS, & CONNECTION SKETCHES FOR DESIGN REVIEW BY PURCHASER.

BUFFER GAS PACKING ARR. Ref: Appendix I
Figures I-1, I-2 & I-3

OIL WIPER PACKING PURGE

INTERMEDIATE PARTITION PURGE

INERT BUFFER PURGE GAS: N₂ OTHER _____

VENT, DRAIN, PURGE PIPING BY MFG'R NO YES

COUPLING(S) LOW-SPEED HI-SPEED

Between Compressor & Driver or Gear Between Driver & Gear

◆ **BY MANUFACTURER** _____

◆ **MODEL** _____

◆ **TYPE** _____

API-671 APPLIES YES NO

V-BELT DRIVE DRIVEN SHEAVE DRIVE SHEAVE
(Compressor Shaft) (Driver Shaft)

RPM (EXPECTED) 400 1475

PITCH DIA. (Inches) _____

◆ **QTY & GROOVE X-SEC.** 4 _____

POWER TRANSMIT'D 13 15
Incl. Belt Losses

DRIVER NAMEPLATE HP RATING _____

◆ CENTER DISTANCE (INCHES) _____

◆ QTY, TYPE, X-SEC., & LENGTH BELTS _____

◆ BELT SERVICE FACTOR (RELATIVE TO DRIVER NAMEPLATE HP RATING) _____

INSPECTION AND SHOP TESTS

	REQ'D	WITN.	OBSER.
*SHOP INSPECTION	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
ACTUAL RUNNING CLEARANCES AND RECORDS	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
MFG STANDARD SHOP TESTS	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
CYLINDER HYDROSTATIC TEST	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CYLINDER PNEUMATIC TEST	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CYLINDER HELIUM LEAK TEST	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
CYL. JACKET WATER HYDRO TEST	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
*MECHANICAL RUN TEST (4 HR)	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
BAR-OVER TO CHECK ROD RUNOUT	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
*LUBE OIL CONSOLE RUN/TEST (4 HR)	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
*COOLING H ₂ O CONSOLE RUN/TEST	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>
RADIOGRAPHY BUTT WELDS	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
<input type="radio"/> GAS <input type="radio"/> OIL <input type="radio"/> FAB CYLS.	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
MAG PARTICLE/LIQUID PENETRANT OF WELDS	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
SPECIFY ADDITIONAL REQUIREMENTS (4.2.1.3)	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
QC OF INACCESSIBLE WELDS (2.14.5.2.4)	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
SHOP FIT-UP OF PULSATION SUPPL. DEVICES & ALL ASSOCIATED GAS PIPING	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
*CLEANLINESS OF EQUIP., PIPING, & APPURTENANCES	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
*HARDNESS OF PARTS, WELDS & HEAT AFFECTED ZONES	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
*NOTIFICATION TO PURCHASER OF ANY REPAIRS TO MAJOR COMPONENTS	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
SOUND LEVEL TEST	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>
DISMANTLING INSPECTION	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
*SPECIFIC REQUIREMENTS TO BE DEFINED, FOR EXAMPLE, DISMANTLING, AUX EQUIPMENT OPERATIONAL & RUN TESTS.	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
APPENDIX K COMPLIANCE: <input type="radio"/> VENDOR <input type="radio"/> PURCHASER	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
NOTE: - INSPECTION AND TESTING SHALL BE AS PER SCOPE OF APPROVED ITP			

CYLINDER LUBRICATION

NON-LUBE STAGE(S)/SERVICE _____

LUBRICATED STAGE(S)/SERVICE _____

TYPE OF LUBE OIL: SYNTHETIC _____

HYDROCARBON _____

LUBRICATOR COMP. CRANKSHAFT, DIRECT

DRIVE BY: CHAIN, FROM CRANKSHAFT

ELECTRIC MOTOR

OTHER _____

◆ LUBRICATOR MFR _____

◆ MODEL _____

TYPE LUBRICATOR: SINGLE PLUNGER PER POINT

(2.13) DIVIDER BLOCKS _____

◆ COMPARTM'T, TOTAL QTY. _____

◆ PLUNGERS (PUMPS), TOTAL QTY. _____

◆ SPARE PLUNGERS, QTY. _____

◆ SPARE COMPARTM'T W/OUT PLUNGERS _____

HEATERS: ELECTRIC W/THERM.(S) STEAM

ESTIMATED WEIGHTS AND NOMINAL DIMENSIONS

<input type="checkbox"/> TOTAL COMPR. WT, LESS DRIVER & GEAR	_____ kg
◆ WT, OF COMPLETE UNIT, (LESS CONSOLES)	3200 kg
◆ MAXIMUM ERECTION WEIGHT	_____ kg
◆ MAXIMUM MAINTENANCE WEIGHT	211 kg
◆ DRIVER WEIGHT/GEAR WEIGHT	_____ / 211 kg
◆ LUBE OIL/COOLING H ₂ O CONS.	_____ / _____ kg
◆ FREE STANDING PANEL	_____
SPACE REQUIREMENTS-mm: LENGTH WIDTH HEIGHT	
◆ COMPLETE UNIT	_____
◆ LUBE OIL CONSOLE	_____
◆ COOLING H ₂ O CONSOLE	_____
◆ FREE STANDING PANEL	_____
<input type="checkbox"/> PISTON ROD REMOVAL DIST.	_____
OTHER EQUIPMENT SHIPPED LOOSE (DEFINE)	
◆ PULSATION SUPP., WEIGHT	70 kg
◆ PIPING	50 kg
◆ INTERSTAGE EQUIPMENT	_____ kg

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC:  شرکت سست اوی گسترده اصناف تیس	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)	Contract No : 52-98/445
---	--	--------------------------------

17811-11G	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No
	BU	20	VD	303	ME	DSH	75	rev 04 Page: 12 OF 20

UTILITY CONSUMPTION

ELECTRIC MOTORS

	NAMEPLATE HP (kW)	LOCKED ROTOR AMPS	FULL LOAD AMPS	
9 <input checked="" type="checkbox"/> MAIN DRIVER	15	239	28,5	
10 <input type="checkbox"/> MAIN LUBE OIL PUMP				
11 <input type="checkbox"/> AUX LUBE OIL PUMP				
12 <input type="checkbox"/> MAIN COOLING WATER PUMP				
13 <input type="checkbox"/> AUX COOLING WATER PUMP				
14 <input type="checkbox"/> ROD PACKING COOLING PUMP				
15 <input type="checkbox"/> CYLINDER LUBRICATOR				
16				
17				
18				
19				

ELECTRIC HEATERS

	WATTS	VOLTS	HERTZ	
22 <input checked="" type="checkbox"/> FRAME OIL HEATER(S)	75	230	50	
23 <input type="checkbox"/> COOLING WATER HEATER(S)				
24 <input type="checkbox"/> CYL. LUBRICATOR HEATER(S)				
25 <input type="checkbox"/> MAIN DRIVER SPACE HEATER(S)				
26				
27				
28				

STEAM-NOT APPLICABLE

	FLOW	PRESSURE	TEMPERATURE	BACK PRESSURE
31 <input type="checkbox"/> MAIN DRIVER	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
32 <input type="checkbox"/> FRAME OIL HEATER(S)	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
33 <input type="checkbox"/> CYL. LUB. HEATER(S)	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
34	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
35	kg/h @	(BARG) (kPa)	°CTT TO	(BARG) (kPa)
36				

COOLING WATER REQUIREMENTS-(NOTE 9)

	FLOW m³/h	INLET TEMP °C	OUTLET TEMP °C	INLET PRESS (BARG)	OUTLET PRESS (BARG)	MAX PRESS (BARG)
40 <input type="checkbox"/> CYLINDER JACKETS						
41 <input checked="" type="checkbox"/> INTERCOOLER(S)	1,7	35	45	4,5	3,5	6
42 <input type="checkbox"/> AFTERCOOLER						
43 <input type="checkbox"/> FRAME LUBE OIL COOLER						
44 <input type="checkbox"/> ROD PRESSURE PACKING*						
45 <input checked="" type="checkbox"/> CYLINDER COOLANT CONSOLE	0,90	35	45	4,5	3,5	6
46						
47						
48 <input checked="" type="checkbox"/> TOTAL QUANTITY, m³/h	2,6					
49						
50						
51						

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
---	--	--

MC: 	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)
---	--

17811-11G	BU	20	VD	303	ME	DSH	75	rev 04	Page: 13 OF 20
------------------	-----------	-----------	-----------	------------	-----------	------------	-----------	---------------	-----------------------

FRAME LUBE OIL SYSTEM

BASIC LUBE OIL SYSTEM FOR FRAME: **SPLASH (TBA)** **PRESSURE (FORCED)** **HEATERS REQUIRED:**

REF: TYPE MAIN BEARINGS: **TAPERED ROLLER** **PRECISION SLEEVE** **ELEC. W/THERMOSTAT(S)** **STEAM**

PRESSURE SYSTEM: **MAIN OIL PUMP DRIVEN BY:** **COMP. CRANKSHAFT** **ELEC. MOTOR** **OTHER** _____

AUX OIL PUMP DRIVEN BY: **ELEC. MOTOR** **OTHER** _____

HAND OPERATED PRE-LUBE PUMP FOR STARTING **OPERATIONAL TEST & 4 HOUR MECH RUN TEST**

API-614 LUBE SYSTEM: **NO** **YES** **CHECK VALVE ON MAIN PUMP**

CONTINUOUS FLOW THROUGH OIL (7.7.2.5)

SEP. CONSOLE FOR PRESS. LUBE SYS: **ONE CONSOLE FOR EA. COMP.** **ONE CONSOLE FOR** _____ **COMPRESSORS**

CONSOLE TO BE OF DECK PLATE TYPE CONSTRUCTION SUITABLE FOR MULTI-POINT SUPPORT AND GROUTING WITH GROUT & VENT HOLES.

ELECTRICAL CLASSIFICATION : ZONE 2 , **GROUP** IIB **CLASS** _____ **T3** **NON-HAZARDOUS**

BASIC SYS. REQ'MTS (NORM. OIL FLOWS & VOLUMES)

	FLOW m³/h	PRESSURE (BARG)	VISCOSITY cst @ 40°C	VISCOSITY cst @ 100°C	SUMP VOLUME m³
<input type="checkbox"/> COMPRESSOR FRAME	_____	_____	_____	_____	_____
<input type="checkbox"/> DRIVER	_____	_____	_____	_____	_____
<input type="checkbox"/> GEAR	_____	_____	_____	_____	_____

SYSTEM PRESSURES: **DESIGN** _____ (BARG) **HYDROTEST** _____ (BARG)

PRESSURE CONTROL VALVE SETTING _____ **VTS** (BARG) **PUMP RELIEF VALVE(S) SET** _____ (BAR)

PIPING MATERIALS:

	CARBON STEEL	STAINLESS STEEL WITH SS FLANGES	STAINLESS STEEL WITH CARBON STEEL FLANGES
<input checked="" type="checkbox"/> UPSTREAM OF PUMPS & FILTERS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/> DOWNSTREAM OF FILTERS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> _____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> _____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PUMPS

	RATED FLOW	PRESSURE (BARG)	COLD START REQ'D KW	DRIVER KW	SPEED RPM	COUPLING REQ'D	MECH. SEAL REQ'D
MAIN	NA	2.0	NA	SHAFT DRIVEN	NA	<input type="checkbox"/>	<input type="checkbox"/>
AUXILIARY	_____	_____	_____	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>

PUMP CASING MATERIAL **MAIN PUMP** _____ **STEEL** **AUX PUMP** _____

GUARD(S) REQ. FOR COUPLING(S): **MAIN PUMP** **AUX PUMP** **GUARD TYPE OR CODE** _____

AUXILIARY PUMP CONTROL: **MANUAL** **AUTOMATIC** **ON-OFF-AUTO SEL. SWITCH:** **BY PURCH.** **BY MFR.**

WIRING TO TERMINAL BOX: **BY PURCH.** **BY MFR.**

SWITCHES **RTD'S/THERMOCOUPLES**

COOLERS: **SHELL & TUBE** **SINGLE** **DUAL W/TRANSFER VALVE** **MFG'S STD.** **TEMA C** **TEMA R**

REMOVABLE BUNDLE **WATER COOLED** **AIR COOLED W/AUTO TEMP CONTROL**

W/BYPASS & TEMP CONTROL VALVE: **MANUAL** **AUTO** **SEE SEPARATE HEAT EXCHANGER DATA SHEET**

FILTER(S) **SINGLE** **DUAL W/TRANSFER VALVE** **ASME CODE DESIGN** **ASME CODE STAMPED**






DESIGN PRESSURE, _____ (BARG) **ΔP CLEAN,** _____ (BARG) **ΔP COLLAPSE,** _____ (BARG)

MICRON RATING, _____ **CARTRIDGE MATERIAL,** _____ **CARTRIDGE P/N** _____

BONNET MATERIAL, _____ **CASING MATERIAL,** _____ **FURN.SPARE CARTR.,QTY** _____

SYS. COMPONENT SUPP.

	MANUFACTURER	MODEL	MANUFACTURER	MODEL
<input checked="" type="checkbox"/> MAIN PUMP	Airpack	_____	<input type="checkbox"/> OIL COOLER(S)	_____
<input type="checkbox"/> AUXILIARY PUMP	_____	_____	<input type="checkbox"/> TRANSFER VALVE(S)	_____
<input checked="" type="checkbox"/> MECHANICAL SEALS	Airpack	_____	<input type="checkbox"/> PUMP COUPLING(S)	_____
<input checked="" type="checkbox"/> ELECTRIC MOTORS	WEG	_____	<input checked="" type="checkbox"/> SUCTION STRAINER(S)	TBC
<input type="checkbox"/> STEAM TURBINES	_____	_____	<input checked="" type="checkbox"/> CHECK VALVE(S)	TBC
<input checked="" type="checkbox"/> OIL FILTER(S)	Airpack	_____	<input type="checkbox"/> _____	_____

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 						
MC:   شرکت پتروشیمی بوشهر	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							
17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	Contract No : 52-98/445
								rev 04 Page: 14 OF 20

COOLING WATER SYSTEM

BASIC COOLING SYS. FOR:
 COMPRESSOR CYL.(S)
 INTERCOOLER(S)
 AFTERCOOLER
 OIL COOLER(S)

HEATERS REQ.'D FOR PRE-HEATING:
 ELEC.,W/ THERMOSTAT(S)
 STEAM

PRESSURE FORCED CIRCULATING SYS.:
 OPEN, PIPING BY:
 PURCH
 MFR
 CLOSED, PIPING BY MFR.

MAIN WATER PUMP DRIVEN BY:
 ELEC. MOTOR
 STEAM TURBINE
 OTHER

AUX WATER PUMP DRIVEN BY:
 ELEC. MOTOR
 STEAM TURBINE
 OTHER

SEP. CONSOLE FOR COOLING WATER SYS.:
 ONE CONSOLE FOR EA. COMP.
 ONE CONSOLE FOR _____ COMP'RS

CONSOLE TO BE OF DECK PLATE TYPE CONSTRUCTION SUITABLE FOR MULTI-POINT SUPPORT AND GROUTING WITH GROUT & VENT HOLES.

ELECTRICAL CLASSIFICATION: ZONE 2 IIB T3
 NON-HAZARDOUS

	<input type="checkbox"/>	BASIC SYS. REQ'MTS (NORM. COOLING WATER FLOW DATA)			<input type="checkbox"/>	COOL'G WATER TO BE _____ % ETHYL'NE GLYCL		SITE	
		FORCED COOL'G	THERMO SYPHON	STAND PIPE	FLOW m³/h	PRESSURE (BARG)	INLET TEMP °C	OUTLET TEMP °C	FLOW INDTR
14			<input checked="" type="checkbox"/>	<input type="checkbox"/>	0,9	4,5	35	45	<input checked="" type="checkbox"/>
15			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
16			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
17			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
18			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
19			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
20			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
21			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
22			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
23			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
24			<input type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>
25		TOTAL FLOW							

SYS. PRESSURES:
 DESIGN, _____ (BARG)
 HYDROTEST, _____ (BARG)
 RELIEF VALVE(S), SETTING _____ PSIG

WATER RESERVOIR:
 SIZE, _____ mm DIA X _____ mm HT.
 CAPACITY _____ m³

@ Normal Operating Level

RESERVOIR MATERI. c.s _____
 INTERNAL COATING, TYPE _____

LEVEL GAUGE
 LEVEL SWITCH
 DRAIN VALVE
 INSPECTION & CLEAN-OUT OPENINGS

PUMPS: (Centrifugal Only)
 RAT'D FL'W _____ m³/h
 PRESS. _____ (BARG)
 REQ'D _____ kW
 DRIVER _____ kW
 SPEED _____ RPM
 COUPLING REQ'D _____
 MECH. SEAL REQ'D _____

MAIN
 AUXILIARY

PUMP CASING MATERIAL (Ref 6.14.2.1.5):
 MAIN PUMP
 AUX PUMP

GUARD(S) REQ.'D FOR COUP'G(S)
 MAIN PUMP
 AUX PUMP
 GUARD TYPE OR CODE _____

AUX.PUMP CONTROL:
 MANUAL
 AUTO
 ON-OFF-AUTO SEL. SWITCH:
 BY PURCH.
 BY MANUFACTURER

WIRING TO TERMINAL BOX:
 BY PURCH.
 BY MANUFACTURER





COOLING WATER HEAT EXCH.:
 SHELL & TUBE
 SINGLE
 DUAL W/TRANSFER VALVE
 TEMA C
 TEMA R(API-660)

AIR COOLED EXCHANGER W/AUTO TEMP CONTROL (API-661 Data Sheets Attached)

W/BYPASS & TEM. CONTROL VALVE
 MANUAL
 AUTO
 LOUVERS FOR AIR EXCH.

SEE SEPARATE COOLER DATA SHEET FOR DETAILS; SPECIFY % GLYCOL ON BOTH SIDES OF SHELL & TUBE

SYS. COMPONENT SUPP.	MANUFACTURER	MODEL	MANUFACTURER	MODEL
<input type="checkbox"/> MAIN PUMP			<input type="checkbox"/> TEMP CONTROL VALVE(S)	
<input type="checkbox"/> AUXILIARY PUMP			<input type="checkbox"/> TRANSFER VALVE(S)	
<input type="checkbox"/> MECHANICAL SEALS			<input type="checkbox"/> PUMP COUPLING(S)	
<input type="checkbox"/> ELECTRIC MOTORS				
<input type="checkbox"/> STEAM TURBINES				

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 														
MC:  شرکت مهندسی و پیمانکاری	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)															
	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Project</th> <th>Area</th> <th>Phase</th> <th>Unit</th> <th>Dis.</th> <th>Doc.</th> <th>Seq.</th> </tr> <tr> <td style="text-align: center;">BU</td> <td style="text-align: center;">20</td> <td style="text-align: center;">VD</td> <td style="text-align: center;">303</td> <td style="text-align: center;">ME</td> <td style="text-align: center;">DSH</td> <td style="text-align: center;">75</td> </tr> </table>	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	BU	20	VD	303	ME	DSH	75	Contract No : 52-98/445 rev 04 Page: 15 OF 20
Project	Area	Phase	Unit	Dis.	Doc.	Seq.										
BU	20	VD	303	ME	DSH	75										
17811-11G																
PULSATION SUPPRESSION DEVICES FOR RECIPROCATING COMPRESSORS THESE SHEETS TO BE FILLED OUT FOR EACH SERVICE AND/OR STAGE OF COMPRESSION																
3 APPLICABLE TO: <input checked="" type="radio"/> PROPOSALS <input type="radio"/> PURCHASE <input type="radio"/> AS BUILT 4 FOR/USER BUSHEHR PETROCHEMICAL COMPANY (BUPC) 5 SITE/LOCATION ASSALUYE AMBIENT TEMPERATURE MIN/MAX 5 / 55 °C 6 COMPRESSOR SERVICE EMERGENCY INSTRUMENT AIR COMP NUMBER OF COMPRESSORS 1 SET 7 COMPRESSOR MFG. MODEL/TYPE 8 SUPPRESSOR MFG.																
9 NOTE: <input type="radio"/> Ind.Data Comp.'d Purch. <input type="checkbox"/> By Compr/Supp.Mfg.w/Proposal <input checked="" type="checkbox"/> By Mfg(s) after order <input type="checkbox"/> By Mfg(s)/Purchaser as Applicable																
GENERAL INFORMATION APPLICABLE TO ALL SUPPRESSORS																
11 TOTAL NUMBER OF SERVICES AND/OR STAGES 12 TOTAL NUMBER OF COMPRESSOR CYL. 2 TOTAL NUMBER OF CRANKTHROWS 1 STROKE mm RPM 13 <input checked="" type="radio"/> ASME CODE DESIGN <input type="radio"/> GOVERNMENTAL CODES OF CODE REGULATIONS APPLY 14 <input type="radio"/> OTHER APPLICABLE PRESSURE VESSEL SPEC. OR CODE 15 <input type="radio"/> LUBE SERVICE <input checked="" type="radio"/> NON-LUBE SERV. <input type="radio"/> NO OIL ALLOWED INTERNALLY DRY TYPE INTER.CORR.COATING <input type="radio"/> YES <input checked="" type="radio"/> NO 16 <input type="radio"/> RADIOGRAPHY (X-RAY OF WELDS): <input type="radio"/> NONE <input checked="" type="radio"/> SPOT <input type="radio"/> 100% <input type="radio"/> IMPACT TEST <input type="radio"/> SPECIAL WELDING REQUIREMENTS 17 <input checked="" type="radio"/> SHOP INSPECTION <input type="radio"/> WITNESS HYDROTEST <input checked="" type="radio"/> OUTDOOR STORAGE OVER 12 MONTHS <input type="radio"/> SPECIAL PAINT SPEC: BU-20-D-000-PI-SPC-409 18 <input type="radio"/> WITNESSED <input type="radio"/> OBSERVED																
CYLINDER, GAS, OPERATING, AND SUPPRESSOR DESIGN DATA																
				21 SERVICE EMERGENCY INSTRUMENT AIR COMP STAGE NO. 1												
22 <input type="checkbox"/> COMPRESSOR MANUFACTURER'S RATED CAPACITY				LBS/HR SCFM MMSCFD												
23 <input type="checkbox"/> LINE SIDE OPERATING PRESSURE				INLET, 7 to 8,5 (BARA)		DISCHARGE, 21 (BARA)										
24 <input type="checkbox"/> OPERATING TEMP. WITHIN SUPPRESSORS				INLET, 5 to 55 °C		DISCHARGE, 180 °C										
25 <input type="radio"/> ALLOWABLE PRESSURE DROP THROUGH SUPPRESSORS				Δ P 0,169 (BAR) / 2,4 %		Δ P 1,522 (BAR) / 7,23 %										
				INLET SUPPRESSOR		DISCHARGE SUPPRESSOR										
27 <input checked="" type="radio"/> SUPPRESSOR TAG NUMBER				20-DC-7080-1		20-DC-7080-2										
28 <input checked="" type="radio"/> COMBINATION INLET SUPP SEPARATOR/INTERNALS				<input type="radio"/> YES <input checked="" type="radio"/> NO / <input type="radio"/> YES <input checked="" type="radio"/> NO		<input type="radio"/> YES <input checked="" type="radio"/> NO / <input type="radio"/> YES <input checked="" type="radio"/> NO										
29 <input type="checkbox"/> NO. (QTY) OF INLET & DISCH. SUPP. PER STAGE				1		1										
30 <input type="radio"/> ALLOWABLE PEAK-PEAK PULSE @ LINE SIDE NOZZLE				(BAR) / %		(BAR) / %										
31 <input type="radio"/> ALLOWABLE PEAK-PEAK PULSE @ CYL FLANGE NOZZLE				(BAR) 0,245 / 3,5 %		(BAR) 1,02 / 4,9 %										
32 <input checked="" type="radio"/> DESIGN FOR FULL VACUUM CAPABILITY				<input type="radio"/> YES <input checked="" type="radio"/> NO		<input type="radio"/> YES <input checked="" type="radio"/> NO										
33 <input checked="" type="radio"/> MIN. REQ'D WORKING PRESSURE & TEMPERATURE NOTE: AFTER DESIGN, THE ACTUAL MAWP & TEMP ARE TO BE DETERMINED BASED ON THE WEAKEST COMPONENT AND STAMPED ON THE VESSEL, THE ACTUAL MAWP IS TO BE SHOWN ON PG. 14 LINE 12 AND ON THE U1A FORMS				(BARA) 13,5 @ 85 °C		(BARA) 25 @ 210 °C										
38 <input checked="" type="radio"/> INITIAL SIZING VOL. PER FORMULA OF 7.9.3.2 NOTE: This is a Reference				0,3 m ³		0,3 m ³										
41 <input checked="" type="checkbox"/> AS BUILT VOLUME (m ³)				0,3 m ³		0,3 m ³										
43 #2 : PULSATION DAMPING FOR INLET AND OUTLET OF EACH CYLINDER, BY VOLUME BOTTLES.																

OWNER:



شرکت پتروشیمی بوشهر
BUPC

**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**

CONTRACTOR:



Chagalesh-Enerchimi-Steam
Joint Venture
BUPC-MEG PLANT PROJECT

MC:



شرکت مهندسی و پیمانکاری
مکانیک

**MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT
AIR COMPRESSOR (20-C-7080)**



17811-11G	BU	20	VD	303	ME	DSH	75	rev 04	Page: 16 OF 20
								Contract No : 52-98/445	

1 **PULSATION SUPPRESSION DEVICES FOR RECIPROCATING COMPRESSORS (CONT'D)** SERVICE _____
 2 THESE SHEETS TO BE FILLED OUT FOR EACH SERVICE AND/OR STAGE OF COMPRESSION STAGE NO. _____

3 CONSTRUCTION REQUIREMENTS & DATA	4 INLET SUPPRESSOR		5 DISCHARGE SUPPRESSOR	
	6 ● SUPPRESSOR TAG NUMBER	Carbon Steel		Carbon Steel
7 ● BASIC MATERIAL REQUIRED, CS, SS, ETC.	SA106 gr B / SA234		SA106 gr B / SA234	
8 ◇ ACTUAL MATERIAL DESIGNINATION SHELL/HEAD	SHELL & HEADS WELDS		SHELL & HEADS WELDS	
9 ○ SPECIAL HARDNESS LIMITATIONS, Rc ○ YES ● NO	3 mm		3 mm	
10 ● CORROSION ALLOWANCE., mm ● REQUIRED	8,18 mm / 8,18 mm		8,18 mm / 8,18 mm	
11 ◆ WALL THICKNESS, mm SHELL/HEAD	8" X 850 mm / 30 mm ³		8" x 850 mm / 30 mm ³	
12 □ NOM. SHELL DIA X OVERALL LGTH. (mm/m ³)	PIPE		PIPE	
13 □ PIPE OR ROLLED PLATE CONSTRUCTION	ROLLED PLATE		ROLLED PLATE	
14 ◆ ACT. MAX ALLOW. WORKING PRESS. AND TEMPERATURE	(BAR) 18,3 @ 80 °C		(BAR) 38,6 @ 210 °C	
15 ● MINIMUM DESIGN METAL TEMP (2.14.8)	°C		°C	
16 ○ INLET SUPPRESS. TO BE SAME MAWP AS DISCH'RG SUPPRESS.	○ YES ● NO		○ YES ● NO	
17 ◇ MAX EXPECTED PRESSURE DROP (Δ P, %) LINE PRESS	Δ P 0,0926 (BAR) / 1,3 %		Δ P 0,154 (BAR) / 4,5 %	
18 ◇ WEIGHT (EACH)	59 kg		63 kg	
19 ○ INSUL CLIP	NA		NA	
20 ◇ EXPECTED P-P PULSE @ LINE SIDE/CYL FLG, % LINE PRESS BASED ON FINAL SUPPRESSOR DESIGN	% / %		% / %	
21 □ SUPPORTS, TYPE/QUANTITY	YES, saddle 2		YES, saddle 2	

CONNECTION REQUIREMENTS & DATA

22 ● LINE SIDE FLANGE. SIZE/RATING/FACING/TYPE	2" 150# RF WNF	2" 300# RF WNF
23 ● COMP CYL FLANGE(S), QTY/SIZE/RATING/FACING/TYPE	2" 150# RF WNF	2" 300# RF WNF
24 ○ FLANGE FINISH, ○ PER 3.9.3.15 ○ SPECIAL (SPECIFY) >3.2 <6.4 ● PER ANSI 16.5		
26 ● INSPECTION OPENINGS REQUIRED ○ YES ● NO ○ BLINDED	○ YES ● NO ○ BLINDED	○ YES ● NO ○ BLINDED
27 ● SPEC. QTY. SIZE, /FLG TYPE & RATING	NA	NA
28 ◇ * QTY. SIZE, /FLG TYPE & RATING		
29 ● VENT CONNECTIONS REQUIRED ○ YES ● NO	○ YES ● NO	○ YES ● NO
30 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING	NA	NA
31 ◇ * QTY. SIZE, /FLG TYPE & RATING		
32 ● DRAIN CONNECTIONS REQUIRED ● YES ○ NO	● YES ○ NO	● YES ○ NO
33 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING	1/2"NPT	1/2"NPT
34 ◇ * QTY. SIZE, /FLG TYPE & RATING		
35 ● PRESSURE CONNECTIONS REQUIRED ○ YES ● NO	○ YES ● NO	○ YES ● NO
36 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING	NA	BA
37 ◇ * QTY. SIZE, /FLG TYPE & RATING		
38 ● TEMPERATURE CONNECTIONS REQUIRED ○ YES ● NO	○ YES ● NO	○ YES ● NO
39 ○ SPEC. QTY. SIZE, /FLG TYPE & RATING	NA	NA
40 ○ CYL NOZZLE ○ MAIN BODY		
41 ◇ * QTY. SIZE, /FLG TYPE & RATING		

OTHER DATA AND NOTES

47 ◆ COMPRESSOR MFG'S SUPP. OUTLINE OR DRAWING NO.		
48 ◇ SUPP. MFG'S OUTLINE OR DRAWING NO.		
49		
50		
51		
52		

OWNER:  شرکت پترو شیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 
--	--	--

MC:  شرکت پترو شیمی بوشهر	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)	
---	--	---

17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	Contract No : 52-98/445 rev 04	Page: 17 OF 20
------------------	----------------------	-------------------	--------------------	--------------------	-------------------	--------------------	-------------------	--	-----------------------

INSTRUMENTATION

2 PURCHASER TO FILL IN () AFTER COMMODITY TO INDICATE: BY COMP. MFR. BY PURCH. BY OTHERS

3 INSTRUMENT & CONTROL ONE FOR EA. UNIT ONE COMMON TO ALL UNITS

4 PANEL (): MACHINE MT'ED FREE STANDING (OFF UNIT) / LOCAL REMOTE INDOORS

5 PNEUMATIC ELEC. ELECTRONIC HYDRAULIC PROGRAMMABLE CONT'L'R

6 NEMA 7, CLASS _____, GROUP IIB _____, DIVISION _____ INTRINSICALLY SAFE (Exi)

7 I/S BARRIERS ()

8 NEMA 4, WATERTIGHT & DUSTTIGHT PURGED TO NFPA 496 TYPE X Y Z

9 OTHER NEMA IP42 _____ LOW PURGE PRESS. ALARM SHUTDOWN

10 VIB. ISOLATORS STRIP HEATERS PURGE CONN. EXTRA CUTOUTS

11 ANNUNCIATOR W/FIRST-OUT INDICATION LOCATED ON CONTROL PANEL

12 PURCHASER'S CONN. BROUGHT OUT TO TERMINAL BOX BY VENDOR

13 IP PROTECTION : IP 65 FOR LOCAL PANEL , IP 42 FOR CONTROL INDOOR PANEL.

14 BUFFER GAS CONTROL PANE ONE FOR EA. UNIT ONE COMMON TO ALL UNITS

18 INSTRUMENTATION SUITABLE FOR: INDOORS OUTDOORS IP PROTECTION: IP-65 OTHER

19 PREFERRED INSTRUMENT SUPPLIERS, (TO BE COMPLETED BY PURCHASER), OTHERWISE MFR'S STANDARD APPLIES

20 PRESSURE GAUGES	MFR	as per instrument data sheets	SIZE & TYPE	as per instrument data sheets	MTL
21 TEMPERATURE GAUGES	MFR	as per instrument data sheets	SIZE & TYPE	as per instrument data sheets	MTL
22 LIQUID LEVEL GAUGES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
23 DIFF. PRESSURE GAUGES	MFR	as per instrument data sheets	SIZE & TYPE	as per instrument data sheets	MTL
24 PRESS. TRANSMITTERS	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
25 LIQUID LEV. TRANSMITTER	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
26 PRESSURE SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
27 TEMPERATURE SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
28 LIQUID LEVEL SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
29 DIFF. PRESSURE SWITCHES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
30 CONTROL VALVES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
31 PRESSURE SAFETY VALVES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
32 SIGHT FLOW INDICATORS	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
33 VIBRATION MONITORS & EQUIP.	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
34 THERMOCOUPLES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
35 RTD'S	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
36 SOLENOID VALVES	MFR	as per instrument data sheets	TYPE	as per instrument data sheets	MTL
37 ANNUNCIATOR	MFR	_____	MODEL & (QTY SPARE POINTS)	_____	()
38 PROGRAMMABLE CONTROLLER	MFR	_____	TYPE	_____	MTL
39 _____	MFR	_____	TYPE	_____	MTL
40 _____	MFR	_____	TYPE	_____	MTL

42 PRESSURE GAUGE REQUIREMENTS LIQUID FILLED PRESSURE GAUGES: YES NO

44 FUNCTION	43 LOCALLY MOUNTED		43 PANEL MOUNTED		PROCESS GAS: INLET PRESS.	43 LOCALLY MOUNTED		43 PANEL MOUNTED	
	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)		(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
45 LUBE OIL MAIN PUMP DISCHAR.	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)		(<input checked="" type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
46 LUBE OIL AUX. PUMP DISCHARG.	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	@ EA. STAGE	(<input checked="" type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
47 LUBE OIL PRESS. AT FRAME HEADER ((<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)		(<input checked="" type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
48 LUBE OIL FILTER Δ P	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	DISCH. PRESS. @ EA. STAGE	(<input checked="" type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
49 COOLING H ₂ O INLET HEADER	(<input checked="" type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)		(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
50 _____	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)		(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)
51 _____	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)		(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)	(<input type="checkbox"/>)

52 REMARKS: _____

53



**BUSHEHR PETROCHEMICAL COMPANY
MEG PLANT**



**MECHANICAL DATA SHEET FOR EMERGENCY
INSTRUMENT AIR COMPRESSOR (20-C-7080)**







17811-11G	BU	20	VD	303	ME	DSH	75	rev 04	Page: 18 OF 20
------------------	-----------	-----------	-----------	------------	-----------	------------	-----------	---------------	-----------------------

INSTRUMENTATION (CONT'D)									
TEMPERATURE MEASUREMENT REQUIREMENTS				LOCALLY MOUNTED	PANEL MOUNTED	GAUGE W/ CAPIL'RY	THERMO CPL SYS	RTD SYS	I/S SYS
FUNCTION	INLET	OUTLET	FRAME						
LUBE OIL	<input type="radio"/>	<input type="radio"/>		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LUBE OIL	<input type="radio"/>	<input type="radio"/>		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
MAIN JRNL BEARINGS (THERMOCOUPLES OR RTD'S ONLY)				(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
MOTOR BEARING(S) (THERMOCOUPLES OR RTD'S ONLY)				(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COOLING WATER HEADER:	<input checked="" type="radio"/> INLET	<input checked="" type="radio"/> OUTLET		(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CYL. COOLING WATER:	<input type="radio"/> INLET	<input checked="" type="radio"/> OUTLET	<input checked="" type="radio"/> EA. CYL	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PROCESS GAS:	<input checked="" type="radio"/> INLET	<input checked="" type="radio"/> DISCH.	<input type="radio"/> EACH CYL	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
PROCESS GAS:	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
INTERCOOLER(S)	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
AFTERCOOLER:	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="radio"/> INLET	<input type="radio"/> GAS	<input type="radio"/> WATER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COOLING WATER	<input type="radio"/> INLET	<input type="radio"/> OUTLET/COOLED PKG CASE(S)		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PRESS. PGK CASE, CYL PIST ROD (THRM/CPLS OR RTD'S ONLY)				(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COMPRESSOR VALVES	<input type="radio"/> SUCT.	<input type="radio"/> DISCH.	TC'S OR RTD'S ONLY	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
				(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ALARM & SHUTDOWN SWITCH REQ'MTS		NOTE: ALARM & SHUTDOWN SWITCHES SHALL BE INDIVIDUALLY SEPARATE				
ALARM DEVICES	<input checked="" type="radio"/> TRANSMITTER	ANNUNCIATION POINTS				
SHUTDOWN DEVICES	<input checked="" type="radio"/> TRANSMITTER	ALARM		SHUTDOWN		TOTAL NO. OF POINTS
		IN PNL BY MFR	IN CTL ROOM PANEL OTH'RS	IN PNL BY MFR	IN CTL ROOM PANEL OTH'RS	
FUNCTION	ALARM			SHUT DOWN		
LOW LUBE OIL PRESS. @ BEARING HEADER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			1
HIGH LUBE OIL Δ P ACROSS FILTER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
LOW LUBE OIL LEVEL, FRAME	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
AUX LUBE OIL PUMP, FAIL TO START	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
CYL LUBE SYSTEM PROTECTION	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
COMPR. VIBRATION, SHUTDOWN ONLY		(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
VIBRATION, W/ CONTINUOUS MONITORING	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
ROD DROP DETECTOR, CONTACT TYPE(1/CYL)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
ROD DROP PROXIMITY PROBE (1/CYL)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
OIL TEMP OUT OF FRAME	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
HIGH GAS DISCH. TEMP EACH CYLINDER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
HIGH JACKET WATER TEMP., EA. CYL	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
LOW SUCTION PRESS., FIRST STG INLET	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
HI DISCH. PRESS. <input type="radio"/> FINAL <input checked="" type="radio"/> EA STG	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
HI CYL. GAS Δ P, EACH STAGE	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
HI LIQ. LEV., SEPARATOR	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
LOW PURGE GAS PRESS, DISTANCE PIECE(S)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
HI X-HD PIN TEMP	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
PRESS PKG CASE (PISTON ROD TEMP)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
LOW PRESSURE COOLING WATER INLET	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			
TOTAL NUMBER OF ANNUNCIATION POINTS						
SWITCH CONTACT OPERATION		NOTE: EACH SWITCH SHALL BE MINIMUM SPDT ARRANGEMENT				
ALARM CONTACTS SHALL:	<input checked="" type="radio"/> OPEN (DE-ENER.) TO SOUND ALARM & BE ENERGIZED WHEN COMPR. IS IN OPERATION(NORMALLY CLOSE)					
	<input type="radio"/> CLOSE (ENERGIZE) TO SOUND ALARM & BE DE-ENERGIZED WHEN COMPR. IS IN OPERATION(NORMALLY OPEN)					
SHUTDOWN CONTACTS SHALL:	<input checked="" type="radio"/> OPEN (DE-ENERGIZED) TO SHUTDOWN & BE ENERGIZE WHEN COMPR. IS IN OPERATION(NORMALLY CLOSE)					
	<input type="radio"/> CLOSE (ENERGIZE) TO SHUTDOWN & BE DE-ENERGIZE WHEN COMPR. IS IN OPERATION(NORMALLY OPEN)					

REF: 7.6.6.2 FOR MINIMUM RECOMMENDED PROTECTION REQUIREMENTS

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT 						
MC:  شرکت سست و سیستم های انرژی	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							
17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	Contract No : 52-98/445
							rev 04	Page: 19 OF 20






1	<input type="checkbox"/> INSTRUMENTATION (CONT'D)												
2	<input checked="" type="checkbox"/> MISCELLANEOUS INSTRUMENTATION			<input type="checkbox"/>	INTERCLR(S)		<input type="checkbox"/>	AFTERCLR	<input type="checkbox"/>	OIL CLR	<input type="checkbox"/>	H ₂ O CLR	
3	SIGHT FLOW IND. (COOLING H ₂ O ONLY)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	<input type="checkbox"/>	CYL JACKET WATER		<input type="checkbox"/>	ROD PRESS. PKG CASES					
4	PNEUMATIC PRESSURE TRANSMITTERS	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:										
5	PRESSURE TRANSMITTERS (ELEC. OUTP.)	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:										
6	PNEUMATIC LEVEL TRANSMITTERS	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)											
7	ALARM HORN & ACK'N LMT TEST BUTTON	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)											
8	CONDUIT & WIRING W/JUNCT. BOXES	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)											
9	TEST VALVES	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:										
10	DRAIN VALVES	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	Coolers									
11	GAUGE GLASS(ES)	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:	Recirculating Oil,									
12	TACHOMETER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)			SPEED RANGE			TO			RPM		
13	CRANKSHAFT KEY PHASER	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	FOR:										
14	AND TRANSDUCER												
15	LEVEL GAUGE ON SUCTION SUPPRESSOR	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)											
16	OIL LEVEL SWITCH ON CRAKCASE	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)											

17	<input type="checkbox"/> SEPARATE LUBE OIL CONSOLE INSTRUMENTATION:			PURCH. TO LIST REQ'MTS IN ADDITION TO ANY ABOVE REQ'MTS								
18		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
19		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
20		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
21		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
22		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
23		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										

24	<input type="checkbox"/> SEPARATE COOLING WATER CONSOLE INSTRUMENT:			PURCH. TO LIST REQ'MTS IN ADDITION TO ANY ABOVE REQ'MTS								
25		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
26		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
27		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
28		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
29		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
30		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										

31	<input checked="" type="checkbox"/> RELIEF VALVES											
32	LOCATION	BY	MANUFACTURER	TYPE	◇ SIZE	◇ SETTING						
33	EACH STAGE DISCHARGE	(<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)	TBC		1" / 1 1/2"	26 barg						
34	COOLING WATER OUTLET	(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
35		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
36		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
37		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
38		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
39		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
40		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
41		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										
42		(<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>)										

43	NOTES:											
44	#1 SEE MOTOR DATA SHEET FOR ADDITIONAL MOTOR INSTRUMENTATION REQUIREMENTS											
45												
46												
47												
48												
49												
50												

OWNER:  شرکت پتروشیمی بوشهر	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT	CONTRACTOR:   Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT							
MC:   شرکت پتروشیمی بوشهر	MECHANICAL DATA SHEET FOR EMERGENCY INSTRUMENT AIR COMPRESSOR (20-C-7080)							Contract No : 52-98/445	
17811-11G	Project BU	Area 20	Phase VD	Unit 303	Dis. ME	Doc. DSH	Seq. 75	rev 04	Page: 20 OF 20

GENERAL NOTES

- (1) COMPRESSOR STARTS BY MEANS OF A LOW-PRESSURE SWITCH ON DELIVERY PIPE AND STOPS WHEN HIGH PRESSURE IS REACHED .
THE REQUIRED LOW/HIGH PRESSURE TRANSMITTER (PT-71107) TO MAINTAIN THE REQUIRED DELIVERY PRESSURE.
THE OPERATION IS INTERMITTENT.
- (2) VENDOR SHALL PROVIDE AFTER-COOLER .AFTERCOOLER OUTLET GAS TEMPERATURE TO BE 42 DEG C, AS CONFIRMED BY COOLER CALCULATION.
- (3) DELETED
- (4) DELETED
- (5) FOR UTILITIES SUPPLY CONDITION AND CLIMATE CONDITION REFER TO "AMBIENT ,SITE CONDITION & UTILITY DATA" , (BU-20-B-000-PR-SPC-111)
- (6) MINIMUM METAL TEMPRATURE = 0 DEG C
- (7) DELETED
- (8) DEW POINT AT INLET -170 DEG C, DEW POINT AT ATM. -194.6 DEG C
- 9) TYPE OF COMPRESSOR : VERTICAL
- (10) VENDOR ALSO SHALL PROVIDE BELOW ITEMS:
SPARE PARTS
TEMPORARY STRAINER
- (11)GENERAL NOTES :
- A. PROVIDE CONTACTS OPEN FOR CUMULATIVE ALARM AND CUMULATIVE SHUTDOWN .
- B. PROVIDE SAFETY VALVE ON COMPRESSOR DISCHARGE ,WITH LOCKED OPEN ISOLATING VALVE .
- C. PROVIDE SEPARATE INSTRUMENT FOR ALARM AND SHUTDOWN.
- D. THE VENDOR TOGETHER WITH THE INSTRUMENT DOCUMENTATION MUST SUPPLY. A COMPLETE LIST OF ALL THE ALARMS AND INTERLOCKS WITH ALL SET VALUES.
- E. PROVIDE A VISUAL FLOWMETER ON COOLING WATER RETURN LINE.
- F. NOISE PRESSURE LEVEL AT 1 M. SHALL BE LESS THAN 80 DB(A)
- (12)VENDOR SHOULD FOLLOW DOC NO.: BU-20-D-000-IN-SPC-676 FOR SPECIFICATION OF APPLICABLE INSTRUMENT.
- (13)PLC PACKAGE SYSTEM (UCP) WILL BE INSTALLED IN CONTROL/AUXILIARY ROOM.
LOCAL PANEL INCLUDING START/STOP PUSH BUTTONS ,LAMPS AND INDICATORS, TRIP RESET PUSH BUTTON ,AMMETER AND ETC
(AS PER PROJECT REQUIREMENTS) WILL BE INSTALLED IN FIELD.
INSTRUMENT WILL BE INSTALLED ON MACHINE OR FREE STANDING.
- (14) DELETED
- (15) THE CAPACITY TO BE SUPPLIED CONSIDERING NO NEGATIVE TOLERANCE. THE REQUIRED CAPACITY (NNT) IS 1.1*50=55 KG/H.
- (16) COMPRESSOR TYPE IS RECIPROCATING