





OWNER:  شرکت ست و سویی گیس ایران (سهامی خاص)	<b>BUSHEHR PETROCHEMICAL COMPANY MEG PLANT</b>						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
MC :  شرکت ست و سویی گیس ایران (سهامی خاص)	<b>I/O LIST FOR EMERGENCY INSTRUMENT AIR COMPRESSOR</b>								
	<b>Project</b>	<b>Area</b>	<b>Phase</b>	<b>Unit</b>	<b>Dis.</b>	<b>Doc.</b>	<b>Seq.</b>	<b>Contract No : 52-98/445</b>	
<b>Owner Document Number: 17811-06B</b>	<b>BU</b>	<b>20</b>	<b>VD</b>	<b>303</b>	<b>IN</b>	<b>LST</b>	<b>0084</b>	<b>Rev.:</b> 05	<b>Page</b> 1 of 4

## I/O LIST FOR EMERGENCY INSTRUMENT AIR COMPRESSOR

05	07/07/2022	Approved for Construction	KP	RB	JR	
04	09/06/2022	Approved for Construction	KP	RB	JR	
03	10/02/2022	Approved for Construction	KP	RB	JR	
02	06/01/2022	Approved for Construction	WZ	KP	JR	
01	24/11/2021	For approval	WZ	KP	JR	
00	14/10/2021	For approval	WZ	KP	JR	
<b>Rev.</b>	<b>Date</b>	<b>Purpose of Issue</b>	<b>Prepared</b>	<b>Checked</b>	<b>Approved</b>	<b>AC Code</b>
					<b>Class: 1</b>	<b>Phase: P</b>



# Inputs and Outputs List



## 1 LEGEND

SIGNAL TYPE	SIGNAL LEVEL	SCHEDULE total amount *	USED total amount *	SPARE total amount*	SPARE %	NOTES
<b>AI</b> Analog Inputs	4-20 mA	16	7	9	56%	
<b>DI</b> Digital Inputs	24 VDC	32	18	14	44%	
<b>DO</b> Digital Outputs	24 VDC	32	16	16	50%	
<b>AI</b> Analog Inputs	4-20 mA					No IO, only through PID controller

\*Total amount considering redundant IOs. All IO's are redundant

TAG NUMBER	SERVICE DESCRIPTION	INSTRUMENT TYPE	LOCATION	CONTROL SYSTEM	I/O TYPE	SIGNAL TYPE	POWER SUPPLY	IS/NIS	CALIBRATED RANGE	ENG UNIT	STATE 0	STATE 1	SET POINT LL	SET POINT L	SET POINT H	SET POINT HH	PLD NUMBER	PROTOCOL
PIT-71103	Compressor Inlet Air Pressure Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	0...13.5	bar(a)	-	-	-	-	-	8,6	BU-20-VD-303-PR-DWG-0066	HART
PIT-71104	Compressor Oil System Oil Pressure Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	1...5	bar(g)	-	-	6,9	-	-	-	BU-20-VD-303-PR-DWG-0066	HART
PIT-71107	Compressor Outlet Air Pressure Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	1...36	bar(a)	-	-	18,5	19 (load/start)	21 (Unload/Stop)	21,5	BU-20-VD-303-PR-DWG-0066	HART
TIT-71101	Compressor Inlet Air Temperature Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	0...80	°C	-	-	-	-	56	-	BU-20-VD-303-PR-DWG-0066	HART
TIT-71102	Compressor Upstream After-Cooler Air Temperature Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	0...200	°C	-	-	-	-	-	195	BU-20-VD-303-PR-DWG-0066	HART
FT-71103	Compressor Cooling Water Outlet Water Flow Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	0...5	m <sup>3</sup> /hr	-	-	-	2,3	-	-	BU-20-VD-303-PR-DWG-0066	HART
VT-71101	Compressor Vibration Level Transmitter	TRANSMITTER	FIELD	PLC	AI 4-20 mA (redundant)	ANALOG	LOOP POWERED	IS	0...25	mm/s	-	-	-	-	-	8	BU-20-VD-303-PR-DWG-0066	HART
PV-71101	PV-71101 I/P Actuator	I/P CONVERTER	FIELD	PID CONTROLLER	AO 4-20 mA (redundant)	ANALOG	LOOP POWERED	NIS	0...100	%	-	-	-	-	-	-	BU-20-VD-303-PR-DWG-0066	HART
XY-71101	Compressor Inlet Solenoid Valve	SOLENOID VALVE	FIELD	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Open	Closed	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XY-71102	Compressor Cooling Water Inlet Solenoid Valve	SOLENOID VALVE	FIELD	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Open	Closed	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71101	Compressor Start Pushbutton	PUSHBUTTON	LP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	-	-	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71102	Compressor Stop Pushbutton	PUSHBUTTON	LP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Stop	-	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71103	Compressor Emergency Stop Button	ESD PUSHBUTTON	LP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Emergency Stop	Normal	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71104	Compressor Lamptest Pushbutton	PUSHBUTTON	LP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Lampstest	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71105	Compressor Start Pushbutton	PUSHBUTTON	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	-	Start	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71106	Compressor Stop Pushbutton	PUSHBUTTON	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Stop	-	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71107	Compressor Emergency Stop Button	ESD PUSHBUTTON	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Emergency Stop	Normal	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71108	Compressor Lamptest Pushbutton	PUSHBUTTON	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Lampstest	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71109	Compressor Accept Pushbutton	PUSHBUTTON	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Not Accept	Accept	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
PB-71170	Compressor Reset Pushbutton	PUSHBUTTON	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Not Reset	Reset	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
HS-71101	Compressor Local/Off/Remote Switch	SWITCH	LP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off/Local	Remote	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71101	Compressor Operational Lamp	LAMP	LP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Operational	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71102	Compressor Running Lamp	LAMP	LP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Running	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71103	Compressor Common Alarm Lamp	LAMP	LP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Common Alarm	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71104	Compressor Common Trip Lamp	LAMP	LP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Common Trip	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71106	Compressor Operational Lamp	LAMP	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Operational	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71107	Compressor Running Lamp	LAMP	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Running	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71108	Compressor Common Alarm Lamp	LAMP	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Common Alarm	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71109	Compressor Common Trip Lamp	LAMP	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Common Trip	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
HM-71101	Compressor Hourmeter	HOURMETER	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	Hourmeter	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
HS-71120-R	Compressor Reset ESD Relay	ESD RESET RELAY	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	-	Reset	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
HS-71121-SO	Compressor Forced Shutdown	INTERFACE RELAY	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Normal	Forced Shutdown	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XS-71122-SF/SP	Compressor Main Motor Start/Stop	INTERFACE RELAY	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Stop	Start	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XS-71123-SF/SP	Compressor Oil Heater ON/OFF	INTERFACE RELAY	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	On	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XS-71128-FID	PID control active	INTERFACE RELAY	UCP	PLC	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Off	On	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71124	Compressor Main Motor Running	CONTACT	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Not_Running	Running	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71125	Compressor Main Motor Fault	CONTACT	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Fault	Healthy	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XL-71126	Heater Running	CONTACT	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Not_Running	Running	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
VAL-71127	Heater Fault	CONTACT	UCP	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Fault	Healthy	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
KCS-715	Time Synchronization	CONTACT	FCS	PLC	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	-	-	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
HS-715-SO-1	Emergency Shutdown Command	SIGNAL TO/FROM ESD	UCP	ESD	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	ESD	Healthy	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
MAI-715-2	VD Status	SIGNAL TO/FROM ESD	UCP	ESD	DO 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Alarm	Healthy	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-
XS-715	Interlock Switch Stop Compressor	SIGNAL TO/FROM FCS	UCP	FCS	DI 24VDC (redundant)	DIGITAL	24 VDC	NIS	-	-	Stop	Not Stop	-	-	-	-	BU-20-VD-303-PR-DWG-0066	-