









OWNER:  شرکت سست و سویی توستر ایرانیاان (سهامی خاص)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
MC :  شرکت سست و سویی توستر ایرانیاان (سهامی خاص)	INSTRUMENT DATA SHEET FOR NITROGEN GAS BOOSTER								
	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-12A	BU	20	VD	303	IN	DSH	0040	Rev.: 08	Page 1 of 38

INSTRUMENT DATA SHEET FOR NITROGEN GAS BOOSTER

08	18/10/2022	Approve For Construction	TvT	KP	JR	
07	05/09/2022	For approval	TvT	KP	JR	
06	07/07/2022	For approval	KP	TvT	JR	
05	31/05/2022	For approval	TvT	KP	LdM	
04	05/01/2022	For approval	TvT	KP	LdM	
03	19/11/2021	For approval	TvT	KP	LdM	
02	27/10/2021	For approval	TvT	KP	LdM	
01	21/09/2021	For approval	TvT	KP	LdM	
00	19/11/2020	For approval	TvT	KP	LdM	
Rev	Date	Purpose of Issue	Prepared	Checked	Approved	AC Code
					Class: 1	Phase: P


OWNER:  شرکت سست، موبلی توهر ایرانیا (سهایی بنیادی)	BUSHEHR PETROCHEMICAL COMPANY MEG PLANT						EPC CONTRACTOR:  Chagalesh-Enerchimi-Steam Joint Venture BUPC-MEG PLANT PROJECT		
	INSTRUMENT DATA SHEET FOR NITROGEN GAS BOOSTER						 Netherlands		
MC : 	Project	Area	Phase	Unit	Dis.	Doc.	Seq.	Contract No : 52-98/445	
Owner Document Number: 17811-12A	BU	20	VD	303	IN	DSH	0040	Rev.:	Page
								08	2 of 38

TABULATION OF REVISED PAGES

Page	D00	D01	D02	D03	D04	D05	D06	D07	D08		
1.	X	X	X	X	X	X	X	X	X		
2.	X	X	X	X	X	X	X	X	X		
3.	X	X	X	X	X	X	X	X			
4.	X	X	X	X	X	X	X	X			
5.	X	X	X	X	X	X	X	X			
6.	X	X	X	X	X	X	X	X			
7.	X	X	X	X	X	X	X	X			
8.	X	X	X	X	X	X	X	X			
9.	X	X	X	X	X	X	X	X			
10.	X	X	X	X	X	X	X	X			
11.	X	X	X	X	X	X	X	X			
12.	X	X	X	X	X	X	X	X			
13.	X	X	X	X	X	X	X	X			
14.	X	X	X	X	X	X	X	X			
15.	X	X	X	X	X	X	X	X			
16.	X	X	X	X	X	X	X	X			
17.	X	X	X	X	X	X	X	X			
18.	X	X	X	X	X	X	X	X			
19.	X	X	X	X	X	X	X	X			
20.	X	X	X	X	X	X	X	X			
21.	X	X	X	X	X	X	X	X			
22.	X	X	X	X	X	X	X	X			
23.	X	X	X	X	X	X	X	X			
24.	X	X	X	X	X	X	X	X			
25.	X			X	X	X	X	X			
26.	X			X	X	X	X	X			
27.	X			X	X	X	X	X			
28.	X			X	X	X	X	X			
29.	X			X	X	X	X	X			
30.	X			X	X	X	X	X			
31.	X			X	X	X	X	X			
32.	X			X	X	X	X	X			
33.	X			X	X	X	X	X			
Till 46	X			X	X	X	X	X			
Till 37						X	X	X			
Till 38						X	X	X			


INDEX			
No.	Device	Tag Number	Page
1	Diff. Pressure Gauge	PDG-10151	4
2	Pressure Gauge	PG-10152	5
3	Pressure Gauge	PG-10155	6
4	Pressure Gauge	PG-10161	7
5	Pressure Gauge	PG-10160	8
6	Temperature Gauge	TG-10157	9
7	Thermowell	TW-10157	10
8	Temperature Gauge	TG-10158	11
9	Thermowell	TW-10158	12
10	Temperature Gauge	TG-10156	13
11	Thermowell	TW-10156	14
12	Sight glass	LG-10151	15
13	Pressure Transmitter	PIT-10153	16
14	Pressure Transmitter	PIT-10154	17
15	Pressure Transmitter	PIT-10158	18
16	Pressure Transmitter	PIT-10159	19
17	Pressure Transmitter	PIT-10156	20
18	Pressure Transmitter	PIT-10157	21
19	Temperature Transmitter	TIT-10151	22
20	Thermowell + Element	TW-10151	23
21	Temperature Transmitter	TIT-10152	24
22	Thermowell + Element	TW-10152	25
23	Temperature Transmitter	TIT-10153	26
24	Thermowell + Element	TW-10153	27
25	Temperature Transmitter	TIT-10154	28
26	Thermowell + Element	TW-10154	29
27	Temperature Transmitter	TIT-10155	30
28	Thermowell + Element	TW-10155	31
29	Flow Transmitter	FT-10151	32
30	Vibration Transmitter	VT-10151	33
31	Solenoid Valve	XY-10151, XY-10152	34
32	Orifice	FO-10151	35
33	Orifice	FO-10152	36
34	Orifice	FO-10153	37
35	Orifice	FO-10154	38
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			

Notes:

08	TT	18/10/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Index 	Sheet 3 of 38 Based on P&ID Rev.04
07	TT	05/09/2022	For Approval		
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PDG-10151	
	2	Service		Differential Pressure	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		Compressor Inlet strainer	
	5	Ingress Protection		IP65	
	6	Line/equipment number		2"-NL-1001-511C(N)	
	7				
PROCESS CONDITIONS	8	Fluid	State	Nitrogen	Dry Gas
	9	Pressure	Norm. Max.	8 Bar(a)	9 Bar(a)
	10	Temperature	Norm. Max.	55°C	65°C
	11	Design	Press. Temp.	13.5 Bar(a)	85°C
	12	Ambient Temp.	Min. Max.	5 °C	52 °C
	13				
	14				
GAUGE	15	Type		Diaphragm type	
	16	Range	Unit	-200 ... 200	mbar
	17	Mounting		Panel mounted	
	18	Dial Size	Dial Color	160 mm	White. Black numbers
	19	Case Material		SS 316	
	20	Ring Construction	Ring Material	Bayonet	SS 316
	21	Blow-Out Protection		Yes @ back	
	22	Lens Material		Shatterproof laminated safety glass	
	23	Pressure Element Type		Diaphragm	
	24	Pressure Element Material		SS 316	
	25	Socket Material		SS 316	
	26	Connection Size		2 x 1/4" NPT-F	
	27	Connection Location		Back	
	28	Movement Material		SS 316	
	29	Nominal Accuracy		±1.0% of full scale	
	30	Gauge Filling		Glycerine	
	31	Over Range Protection		1,3 x full scale value	
	32	Zero stop pin		Yes	
	33	Zero mechanism		Adjustable	
	34				
	35				
	36				
	37				
38					
39					
40					
41					
42					
OPTIONS	43	Snubber	Material	Yes	SS316
	44	Gauge Savers	Material	N/A	N/A
	45	Manifold (Block & Bleed)		1/2" NPTF, 5-way B&B manifold	SS316 (Airpack Scope)
	46	Block valve (Hand ball valve)		Yes SS316 (Airpack scope)	
	47				
CERTIFICATES	49	Calibration certificate		Yes	
	50	3.1 Material certificate		Yes	
	51	IP certificate		No	
	52				
	53				
PURCHASE	54	Manufacturer		WIKA	
	55	Model		733.51	
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Diff. Pressure Gauge 	Sheet 4 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PG-10152	
	2	Service		Nitrogen pressure	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		Compressor Inlet	
	5	Ingress Protection		IP65	
	6	Line/equipment number		2"-NL-1001-511C(N)	
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	8 Bar(a)	9 Bar(a)
	11	Temperature	Norm. Max.	55°C	65°C
	12	Design	Press. Temp.	13.5 Bar(a)	85°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14				
	15				
	16				
GAUGE	19	Type		Bourdon tube	
	20	Range	Unit	0 ...16	bar(a)
	21	Mounting		Panel mounted	
	22	Dial Size	Dial Color	160 mm	White. Black numbers
	23	Case Material		SS 316	
	24	Ring Construction	Ring Material	Bayonet	SS 316
	25	Blow-Out Protection		Yes @ Back	
	26	Lens Material		Shatterproof laminated safety glass	
	27	Pressure Element Material		SS 316	
	28	Socket Material		SS 316	
	29	Connection Size		1/2" NPT-M	
	30	Connection Location		Back-bottom	
	31	Movement Material		SS 316	
	32	Nominal Accuracy		±1,0 % of span	
	33	Gauge Filling		Glycerine	
	34	Over Range Protection		1,3 x full scale value	
	35	Zero stop pin		Yes	
	36	Zero mechanism		Adjustable	
OPTIONS	38	Snubber	Material	Yes	SS316
	39	Gauge Savers	Material	N/A	N/A
	40	Manifold (Block & Bleed)		1/2" NPTF, 2-way B&B manifold	SS316 (Airpack Scope)
	41	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)	
	42				
	43				
CERTIFICATES	45	Calibration certificate		Yes	
	46	3.1 Material certificate		Yes	
	47	IP certificate		No	
	48				
	49				
PURCHASE	51	Manufacturer		WIKA	
	52	Model		233.50	
	53				
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Gauge 	Sheet 5 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PG-10155	
	2	Service		Nitrogen pressure	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		Compressor Upstream Inter-Cooler	
	5	Ingress Protection		IP65	
	6	Line/equipment number		2"-NL-1002-539D(N)	
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm. Max.	160°C	170°C
	12	Design	Press. Temp.	26 Bar(a)	200°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14				
	15				
	16				
	17				
GAUGE	19	Type		Bourdon tube	
	20	Range	Unit	0 ...30	bar(a)
	21	Mounting		Panel mounted	
	22	Dial Size	Dial Color	160 mm	White, Black numbers
	23	Case Material		SS 316	
	24	Ring Construction	Ring Material	Bayonet	SS 316
	25	Blow-Out Protection		Yes @ Back, solid front	
	26	Lens Material		Shatterproof laminated safety glass	
	27	Pressure Element Material		SS 316	
	28	Socket Material		SS 316	
	29	Connection Size		1/2" NPT-M	
	30	Connection Location		Back-bottom	
	31	Movement Material		SS 316	
	32	Nominal Accuracy		±1,0 % of span	
	33	Gauge Filling		Glycerine	
	34	Over Range Protection		1,3 x full scale value	
	35	Zero stop pin		Yes	
	36	Zero mechanism		Adjustable	
OPTIONS	38	Snubber	Material	Yes	SS316
	39	Gauge Savers	Material	N/A	N/A
	40	Manifold (Block & Bleed)		1/2" NPTF, 2-way B&B manifold	SS316 (Airpack Scope)
	41	Block valve (Hand ball valve)		Yes	SS316 (Airpack supply)
	42				
CERTIFICATES	45	Calibration certificate		Yes	
	46	3.1 Material certificate		Yes	
	47	IP certificate		No	
	48				
PURCHASE	51	Manufacturer		WIKA	
	52	Model		233.50	
	53				
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Gauge 	Sheet 6 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PG-10161	
	2	Service		Nitrogen pressure	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		Compressor Outlet	
	5	Ingress Protection		IP65	
	6	Line/equipment number		2"-NL-1003-539D(N)	
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	23,5 Bar(a)	26 Bar(a)
	11	Temperature	Norm. Max.	40°C	52°C
	12	Design	Press. Temp.	26 Bar(a)	85°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14				
	15				
	16				
GAUGE	19	Type		Bourdon tube	
	20	Range	Unit	0 ...40	bar(a)
	21	Mounting		Panel mounted	
	22	Dial Size	Dial Color	160 mm	White, Black numbers
	23	Case Material		SS 316	
	24	Ring Construction	Ring Material	Bayonet	SS 316
	25	Blow-Out Protection		Yes @ Back, solid front	
	26	Lens Material		Shatterproof laminated safety glass	
	27	Pressure Element Material		SS 316	
	28	Socket Material		SS 316	
	29	Connection Size		1/2" NPT-M	
	30	Connection Location		Back-bottom	
	31	Movement Material		SS 316	
	32	Nominal Accuracy		±1,0 % of span	
	33	Gauge Filling		Glycerine	
	34	Over Range Protection		1,3 x full scale value	
	35	Zero stop pin		Yes	
	36	Zero mechanism		Adjustable	
OPTIONS	38	Snubber	Material	Yes	SS316
	39	Gauge Savers	Material	N/A	N/A
	40	Manifold (Block & Bleed)		1/2" NPTF, 2-way B&B manifold	SS316 (Airpack Scope)
	41	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)	
	42				
	43				
CERTIFICATES	45	Calibration certificate		Yes	
	46	3.1 Material certificate		Yes	
	47	IP certificate		No	
	48				
	49				
PURCHASE	51	Manufacturer		WIKA	
	52	Model		233.50	
	53				
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Gauge 	Sheet 7 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PG-10160	
	2	Service		Water pressure	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		Compressor Cooling water Inlet	
	5	Ingress Protection		IP65	
	6	Line/equipment number		2"-CWS-1004-501C(N)	
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Water	Liquid
	10	Pressure	Norm. Max.	4,5 Bar(g)	5 Bar(g)
	11	Temperature	Norm. Max.	35°C	45°C
	12	Design	Press. Temp.	10 Bar(g)	95°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14				
	15				
	16				
GAUGE	19	Type		Bourdon tube	
	20	Range	Unit	0 ...10	bar(g)
	21	Mounting		Panel mounted	
	22	Dial Size	Dial Color	160 mm	White. Black numbers
	23	Case Material		SS 316	
	24	Ring Construction	Ring Material	Bayonet	SS 316
	25	Blow-Out Protection		Yes @ Back	
	26	Lens Material		Shatterproof laminated safety glass	
	27	Pressure Element Material		SS 316	
	28	Socket Material		SS 316	
	29	Connection Size		1/2" NPT-M	
	30	Connection Location		Back-bottom	
	31	Movement Material		SS 316	
	32	Nominal Accuracy		±1,0 % of span	
	33	Gauge Filling		Glycerine	
	34	Over Range Protection		1,3 x full scale value	
	35	Zero stop pin		Yes	
	36	Zero mechanism		Adjustable	
OPTIONS	38	Snubber	Material	No	N/A
	39	Gauge Savers	Material	N/A	N/A
	40	Manifold (Block & Bleed)		1/2" NPTF, 2-way B&B manifold	SS316 (Airpack Scope)
	41	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)	
	42				
	43				
CERTIFICATES	45	Calibration certificate		Yes	
	46	3.1 Material certificate		Yes	
	47	IP certificate		No	
	48				
	49				
PURCHASE	51	Manufacturer		WIKA	
	52	Model		233.50	
	53				
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Gauge 	Sheet 8 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TG-10157		
	2	Service		Water temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Cooling water Inlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-CWS-1004-501C(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Water	Liquid	
	10	Pressure	Norm. Max.	4,5 Bar(g)	5 Bar(g)	
	11	Temperature	Norm. Max.	35°C	45°C	
	12	Design	Press. Temp.	10 Bar(g)	95°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14					
	15					
	16					
GAUGE	19	Type		Bi-metal		
	20	Range	Unit	0...60	°C	
	21	Dial Size	Dial Color	160 mm	White. Black numbers	
	22	Case material		SS 316		
	23	Stem Material		SS 316		
	24	Mounting		Panel mounted		
	25	Lens Material		Shatterproof laminated safety glass		
	26	Stem length	Stem Diameter	To fit in TW	6 mm	
	27	External Calibrator		Yes		
	28	Nominal Accuracy		±1.0% of full scale		
	29	Connection		1/2" NPT-M x 6 mm OD compression fitting, sliding on stem		
	30	Liquid filling		Glycerine		
	31	Element case		Hermetically sealed		
	32					
	33	FILLED SYSTEM	Compensation		-	
	34		Capillary Length		5 meter	
	35		Capillary Material		SS 316	
	36		Armor Material		SS 316	
	37					
	38					
39						
40						
41						
42						
43						
44						
CERTIFICATES	45	Calibration certificate		Yes		
	46	3.1 Material certificate		Yes		
	47	IP certificate		No		
	48					
	49					
PURCHASE	51	Manufacturer		WIKA		
	52	Model		F73		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Gauge 	Sheet 9 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TW-10157	
	2	Service		Water temperature	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TG-10157	
	5				
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Water	Liquid
	10	Pressure	Norm. Max.	4,5 Bar(g)	5 Bar(g)
	11	Temperature	Norm. Max.	35°C	45°C
	12	Design	Press. Temp.	10 Bar(g)	95°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		0,4 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
	29	Make		Rodax	
	30	Model		BFT	
	31				
	32				
	33				
	34				
	35				
	36				
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
CERTIFICATES	49	3.1 Material certificate		Yes	
	50				
	51				
	52				
CALCULATIONS	53	Wake frequency calculation		No	
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET 	Sheet 10 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TG-10158		
	2	Service		Water temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Cooling water Outlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-CWR-1011-501C(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Water	Liquid	
	10	Pressure	Norm. Max.	2,5 Bar(g)	3 Bar(g)	
	11	Temperature	Norm. Max.	45°C	55°C	
	12	Design	Press. Temp.	10 Bar(g)	95°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14					
	15					
	16					
GAUGE	19	Type		Bi-metal		
	20	Range	Unit	0...60	°C	
	21	Dial Size	Dial Color	160 mm	White. Black numbers	
	22	Case material		SS 316		
	23	Stem Material		SS 316		
	24	Mounting		Panel mounted		
	25	Lens Material		Shatterproof laminated safety glass		
	26	Stem length	Stem Diameter	To fit in TW	6 mm	
	27	External Calibrator		Yes		
	28	Nominal Accuracy		±1.0% of full scale		
	29	Connection		1/2" NPT-M x 6 mm OD compression fitting, sliding on stem		
	30	Liquid filling		Glycerine		
	31	Element case		Hermetically sealed		
	32					
	33	FILLED SYSTEM	Compensation		-	
	34		Capillary Length		5 meter	
	35		Capillary Material		SS 316	
	36		Armor Material		SS 316	
	37					
	38					
39						
40						
41						
42						
43						
44						
CERTIFICATES	45	Calibration certificate		Yes		
	46	3.1 Material certificate		Yes		
	47	IP certificate		No		
	48					
	49					
PURCHASE	51	Manufacturer		WIKA		
	52	Model		F73		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Gauge 	Sheet 11 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TW-10158	
	2	Service		Water temperature	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TG-10158	
	5				
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Water	Liquid
	10	Pressure	Norm. Max.	2,5 Bar(g)	3 Bar(g)
	11	Temperature	Norm. Max.	45°C	55°C
	12	Design	Press. Temp.	10 Bar(g)	95°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		0,4 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
	29	Make		Rodax	
	30	Model		BFT	
	31				
	32				
	33				
	34				
	35				
	36				
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
CERTIFICATES	49	3.1 Material certificate		Yes	
	50				
	51				
	52				
CALCULATIONS	53	Wake frequency calculation		No	
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET	
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		
				Sheet	12 of 38
				Based on P&ID	Rev.04


GENERAL	1	Tag Number		TG-10156		
	2	Service		Nitrogen temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Outlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1003-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	23,5 Bar(a)	25 Bar(a)	
	11	Temperature	Norm. Max.	35°C	52°C	
	12	Design	Press. Temp.	25 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14					
	15					
	16					
	17					
GAUGE	19	Type		Bi-metal		
	20	Range	Unit	0...60	°C	
	21	Dial Size	Dial Color	160 mm	White. Black numbers	
	22	Case material		SS 316		
	23	Stem Material		SS 316		
	24	Mounting		Panel mounted		
	25	Lens Material		Shatterproof laminated safety glass		
	26	Stem length	Stem Diameter	To fit in TW	6 mm	
	27	External Calibrator		Yes		
	28	Nominal Accuracy		±1.0% of full scale		
	29	Connection		1/2" NPT-M x 6 mm OD compression fitting, sliding on stem		
	30	Liquid filling		Glycerine		
	31	Element case		Hermetically sealed		
	32					
	33	FILLED SYSTEM	Compensation		-	
	34		Capillary Length		5 meter	
	35		Capillary Material		SS 316	
	36		Armor Material		SS 316	
	37					
	38					
	39					
	40					
	41					
	42					
43						
44						
CERTIFICATES	45	Calibration certificate		Yes		
	46	3.1 Material certificate		Yes		
	47	IP certificate		No		
	48					
	49					
	50					
PURCHASE	51	Manufacturer		WIKA		
	52	Model		F73		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Gauge 	Sheet 13 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number			TW-10156	
	2	Service			Nitrogen temperature	
	3	P&ID No.			BU-20-VD-303-PR-WG-0013	
	4	Location			TG-10156	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Nitrogen	Dry Gas
	10	Pressure	Norm.	Max.	23,5 Bar(a)	25 Bar(a)
	11	Temperature	Norm.	Max.	35°C	52°C
	12	Design	Press.	Temp.	25 Bar(a)	85°C
	13	Ambient Temp.	Min.	Max.	5 °C	52 °C
	14	Velocity			0,9 m/s	
	15					
	16					
THERMOWELL	19	Material			SS 316	
	20	Construction			Solid bar stock	
	21	Process Connection			1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection			1/2" NPT-F	
	23	Root diameter			16 mm	
	24	Tip diameter			12 mm	
	25	Tip thickness			6 mm	
	26	Bore diameter			6,5 mm	
	27	Nozzle projection			110 mm	
	28	U-length			160 mm (4" pipe)	
	29	Make			Rodax	
	30	Model			BFT	
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
39						
40						
41						
42						
43						
44						
45						
46						
47						
48						
CERTIFICATES	49	3.1 Material certificate			Yes	
	50					
	51					
	52					
CALCULATIONS	53	Wake frequency calculation			No	
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET	
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		Sheet 14 of 38 Based on P&ID Rev.04
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number			LG-10151	
	2	Service			Oil level	
	3	P&ID No.			BU-20-VD-303-PR-WG-0013	
	4	Location			Compressor oil sump	
	5	Ingress Protection			IP65	
	6	Line/equipment number			20-C-1002	
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Oil	Liquid
	10	Pressure	Norm.	Max.	Ambient	-
	11	Temperature	Norm.	Max.	45°C	65°C
	12	Design	Press.	Temp.	5 Bar(g)	80°C
	13	Ambient Temp.	Min.	Max.	5 °C	52 °C
	14					
	15					
	16					
GAUGE	19	Type			Bull-Eye	
	20					
	21	Mounting			Locally	
	22	Case Material			SS316	
	23	Lens Material			Pyrex glass	
	24					
	25					
	26					
	27					
	28					
	29					
OPTIONS	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
CERTIFICATES	38					
	39					
	40					
	41					
	42					
PURCHASE	43					
	44					
	45	3.1 Material certificate			No	
	46					
	47					
PURCHASE	48					
	49					
	50					
	51	Manufacturer			Compressor supplier	
	52					
53						
54						
55						
56						
57						

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Sight glass 	Sheet 15 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PIT-10153		
	2	Service		Nitrogen Pressure		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Inlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1001-511C(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	8 Bar(a)	9 Bar(a)	
	11	Temperature	Norm. Max.	52°C	65°C	
	12	Design	Press. Temp.	13.5 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L	6,5 Bar(a)	
	15		H	HH		9,5 Bar(a)
	16					
17						
TRANSMITTER	19	Function		Field mounted Transmitter		
	20	Element Type		Diaphragm		
	21	Element Material		SS 316L		
	22	Housing Material		Aluminium, epoxy coated		
	23	Power Supply		24 VDC, 2-wire, loop powered		
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5	
	25	Accuracy		± 0.1% of span		
	26	Calibrated Range	Unit	0...13,5	bar(a)	
	27	Adjustable Range	Unit	0...55	bar(a)	
	28	Allow. Press.	Allow. Temp.	110 bar	85°C	
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4 - 20 mA		
	32	Sensor Fill Fluid		silicone		
	33					
34						
35						
36						
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(a)	
	38	Lightning And Surge Protection		N/A		
	39	Mounting facilities		Bracket		
	40	Manifold (Block & Bleed)		1/2" NPTF, 3-way B&B manifold	SS316 (Airpack Scope)	
	41	Housing ground connection		Yes, external (tightened with screws)		
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	43	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)		
CERTIFICATES	44	Calibration certificate		Yes		
	45	3.1 Material certificate		Yes		
	46	ATEX		No		
	47	SIL certificate		No		
	48	IP certificate		No		
	49					
PURCHASE	51	Manufacturer		Emerson/Rosemount		
	52	Model		2051TA		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Transmitter 	Sheet 16 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PIT-10154		
	2	Service		Oil Pressure		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Oil system		
	5	Ingress Protection		IP65		
	6	Line/equipment number		20-C-1002		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Oil	Liquid	
	10	Pressure	Norm. Max.	3 Bar(g)	3,5 Bar(g)	
	11	Temperature	Norm. Max.	45°C	65°C	
	12	Design	Press. Temp.	5 Bar(g)	80°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L	1,5 Bar(g)	
	15		H	HH		
	16					
17						
TRANSMITTER	19	Function		Field mounted Transmitter		
	20	Element Type		Diaphragm		
	21	Element Material		SS 316L		
	22	Housing Material		Aluminium, epoxy coated		
	23	Power Supply		24 VDC, 2-wire, loop powered		
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5	
	25	Accuracy		± 0.1% of span		
	26	Calibrated Range	Unit	-1...5	bar(g)	
	27	Adjustable Range	Unit	-1...10,3	bar(g)	
	28	Allow. Press.	Allow. Temp.	51 bar	85°C	
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4 - 20 mA		
	32	Sensor Fill Fluid		silicone		
	33					
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(a)	
	38	Lightning And Surge Protection		N/A		
	39	Mounting facilities		Bracket		
	40	Manifold (Block & Bleed)		1/2" NPTF, 3-way B&B manifold, lock. SS316 (Airpack Scope)		
	41	Housing ground connection		Yes, external (tightened with screws)		
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	43	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)		
	44	Calibration certificate		Yes		
CERTIFICATES	45	3.1 Material certificate		Yes		
	46	ATEX		No		
	47	SIL certificate		No		
	48	IP certificate		No		
	49					
	50					
PURCHASE	51	Manufacturer		Emerson/Rosemount		
	52	Model		2051TG		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Transmitter 	Sheet 17 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PIT-10158		
	2	Service		Nitrogen Pressure		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Outlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1003-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	23,5 Bar(a)	26 Bar(a)	
	11	Temperature	Norm. Max.	35°C	52°C	
	12	Design	Press. Temp.	26 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L	22 Bar(a) load	
	15		H	HH	23,5 Bar(a) unload	
	16					
TRANSMITTER	19	Function		Field mounted Transmitter		
	20	Element Type		Diaphragm		
	21	Element Material		SS 316L		
	22	Housing Material		Aluminium, epoxy coated		
	23	Power Supply		24 VDC, 2-wire, loop powered		
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5	
	25	Accuracy		± 0.1% of span		
	26	Calibrated Range	Unit	1...36	bar(a)	
	27	Adjustable Range	Unit	0...55	bar(a)	
	28	Allow. Press.	Allow. Temp.	110 bar	85°C	
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4 - 20 mA		
	32	Sensor Fill Fluid		silicone		
	OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(a)
38		Lightning And Surge Protection		N/A		
39		Mounting facilities		Bracket		
40		Manifold (Block & Bleed)		1/2" NPTF, 3-way B&B manifold SS316 (Airpack Scope)		
41		Housing ground connection		Yes, external (tightened with screws)		
42		Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
43		Block valve (Hand ball valve)		Yes SS316 (Airpack supply)		
44		Calibration certificate		Yes		
CERTIFICATES	45	3.1 Material certificate		Yes		
	46	ATEX		No		
	47	SIL certificate		No		
	48	IP certificate		No		
	49					
	50					
PURCHASE	51	Manufacturer		Emerson/Rosemount		
	52	Model		2051TA		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Transmitter 	Sheet 18 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PIT-10159		
	2	Service		Nitrogen Pressure		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Outlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1003-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	23,5 Bar(a)	26 Bar(a)	
	11	Temperature	Norm. Max.	35°C	52°C	
	12	Design	Press. Temp.	26 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L	21 Bar(a)	
	15		H	HH		24 Bar(a)
	16					
17						
TRANSMITTER	19	Function		Field mounted Transmitter		
	20	Element Type		Diaphragm		
	21	Element Material		SS 316L		
	22	Housing Material		Aluminium, epoxy coated		
	23	Power Supply		24 VDC, 2-wire, loop powered		
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5	
	25	Accuracy		± 0.1% of span		
	26	Calibrated Range	Unit	1...36	bar(a)	
	27	Adjustable Range	Unit	0...55	bar(a)	
	28	Allow. Press.	Allow. Temp.	110 bar	85°C	
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4 - 20 mA		
	32	Sensor Fill Fluid		silicone		
	33					
34						
35						
36						
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(a)	
	38	Lightning And Surge Protection		N/A		
	39	Mounting facilities		Bracket		
	40	Manifold (Block & Bleed)		1/2" NPTF,	3-way B&B manifold SS316 (Airpack Scope)	
	41	Housing ground connection		Yes, external (tightened with screws)		
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	43	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)		
CERTIFICATES	44	Calibration certificate		Yes		
	45	3.1 Material certificate		Yes		
	46	ATEX		No		
	47	SIL certificate		No		
	48	IP certificate		No		
	49					
PURCHASE	51	Manufacturer		Emerson/Rosemount		
	52	Model		2051TA		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Transmitter 	Sheet 19 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PIT-10156		
	2	Service		Nitrogen Pressure		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor 1st downstream intercooler		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1003-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)	
	11	Temperature	Norm. Max.	45°C	50°C	
	12	Design	Press. Temp.	26 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L		
	15		H	HH	16 bar(a)	
	16					
17						
TRANSMITTER	19	Function		Field mounted Transmitter		
	20	Element Type		Diaphragm		
	21	Element Material		SS 316L		
	22	Housing Material		Aluminium, epoxy coated		
	23	Power Supply		24 VDC, 2-wire, loop powered		
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5	
	25	Accuracy		± 0.1% of span		
	26	Calibrated Range	Unit	1...36	bar(a)	
	27	Adjustable Range	Unit	0...55	bar(a)	
	28	Allow. Press.	Allow. Temp.	110 bar	85°C	
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4 - 20 mA		
	32	Sensor Fill Fluid		silicone		
	33					
34						
35						
36						
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(a)	
	38	Lightning And Surge Protection		N/A		
	39	Mounting facilities		Bracket		
	40	Manifold (Block & Bleed)		1/2" NPTF, 3-way B&B manifold SS316 (Airpack Scope)		
	41	Housing ground connection		Yes, external (tightened with screws)		
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	43	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)		
CERTIFICATES	44	Calibration certificate		Yes		
	45	3.1 Material certificate		Yes		
	46	ATEX		No		
	47	SIL certificate		No		
	48	IP certificate		No		
	49					
PURCHASE	51	Manufacturer		Emerson/Rosemount		
	52	Model		2051TA		
	53					
	54					
	55					
	56					
	57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Transmitter 	Sheet 20 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		PIT-10157		
	2	Service		Nitrogen Pressure		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor 1st downstream intercooler		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1003-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	14,5 Bar(a)	26 Bar(a)	
	11	Temperature	Norm. Max.	45°C	50°C	
	12	Design	Press. Temp.	26 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L	15,5 bar(a)	
	15		H	HH		
	16					
17						
TRANSMITTER	19	Function		Field mounted Transmitter		
	20	Element Type		Diaphragm		
	21	Element Material		SS 316L		
	22	Housing Material		Aluminium, epoxy coated		
	23	Power Supply		24 VDC, 2-wire, loop powered		
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5	
	25	Accuracy		± 0.1% of span		
	26	Calibrated Range	Unit	1...36	bar(a)	
	27	Adjustable Range	Unit	0...55	bar(a)	
	28	Allow. Press.	Allow. Temp.	110 bar	85°C	
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4 - 20 mA		
	32	Sensor Fill Fluid		silicone		
	33					
34						
35						
36						
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(a)	
	38	Lightning And Surge Protection		N/A		
	39	Mounting facilities		Bracket		
	40	Manifold (Block & Bleed)		1/2" NPTF, 3-way B&B manifold SS316 (Airpack Scope)		
	41	Housing ground connection		Yes, external (tightened with screws)		
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	43	Block valve (Hand ball valve)		Yes SS316 (Airpack supply)		
CERTIFICATES	44	Calibration certificate		Yes		
	45	3.1 Material certificate		Yes		
	46	ATEX		No		
	47	SIL certificate		No		
	48	IP certificate		No		
	49					
PURCHASE	51	Manufacturer		Emerson/Rosemount		
	52	Model		2051TA		
	53					
	54					
	55					
	56					
	57					

NOTES :


07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Pressure Transmitter 	Sheet 21 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		

GENERAL	1	Tag Number		TIT-10151		
	2	Service		Nitrogen Temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor Inlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1001-511C(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	8 Bar(a)	9 Bar(a)	
	11	Temperature	Norm. Max.	52°C	65°C	
	12	Design	Press. Temp.	13.5 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L		
	15		H	HH	56 °C	
16						
TRANSMITTER	17	Function		Field mounted Transmitter		
	18	Transmitter Type		Temperature		
	19	RTD Types Supported		N/A		
	20	Thermocouples Types Supported		Yes, TC type 'K'		
	21	MV Type Supported		N/A		
	22	Cold Junction Compensation		Internal compensation		
	23	Housing Material		Aluminium, epoxy coated		
	24	Power supply		24 VDC, 2 wire, loop powered		
	25	Electric Conn.		ISO M20 x 1,5		
	26	Accuracy		± 0.1% of span		
	27	Calibrated Range	Unit	0...80		°C
	28	Burn-out Protection/Loss of Input		Overrange		
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4-20 mA		
	32	Adjustable Range		Yes		
	33					
34						
35						
36						
37						
38						
39						
40						
41						
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C	
	43	Lightning And Surge Protection		N/A		
	44	Mounting facilities		Bracket		
	45	Housing ground connection		Yes, external (tightened with screws)		
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
CERTIFICATES	47	Calibration certificate		Yes		
	48	ATEX		No		
	49	IP certificate		No		
	50	SIL certificate	Level	No		
	51					
52						
PURCHASE	53	Manufacturer		Emerson/Rosemount		
	54	Model		644H		
	55					
	56					
	57					

Notes:


07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Transmitter 	Sheet 22 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		

GENERAL	1	ThermowellTag Number		TW-10151	
	2	Service		Temperature Transmitter	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TIT-10001	
	5				
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	8 Bar(a)	9 Bar(a)
	11	Temperature	Norm. Max.	55°C	65°C
	12	Design	Press. Temp.	13.5 Bar(a)	85°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		2,6 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
ELEMENT	30	ElementTag Number		TE-10151	
	31	Construction		Sensor with lead wire, transition and relief spring	
	32	Type Of Element		TC type 'K / Simplex	
	33	Accuracy Class		DIN - IEC-EN 60584 Class 1	
	34	Outside Diameter Sensor		6 mm	
	35	Connection		1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	36	Element Length		To fit in Thermowell	
	37	Type Of Cable		Armoured	
	38	Cable Length		5 m	
	39	Special construction		No	
	40	Sheat Material		SS 316	
	41	Element case		Hermetically sealed	
	42				
	43				
	OPTIONS	44	Make TW and TE		Rodax
45		Model TE and TW		BFT + KWA	
46					
47					
CERTIFICATES	48				
	49	3.1 Material certificate		Yes	
	50	Functional test report (up-down) for elem		Yes	
	51	Calibration certificate		Yes	
CALCULATIONS	52				
	53	Wake frequency calculation		No	
	54				
	55				
	56				
NOTES :					

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Thermowell + Element 	Sheet 23 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TIT-10152		
	2	Service		Nitrogen Temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor 1st stage		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1002-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)	
	11	Temperature	Norm. Max.	160°C	170°C	
	12	Design	Press. Temp.	26 Bar(a)	200°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L		
	15		H	HH	160°C	
TRANSMITTER	16					
	17	Function		Field mounted Transmitter		
	18	Transmitter Type		Temperature		
	19	RTD Types Supported		N/A		
	20	Thermocouples Types Supported		Yes, TC type 'K'		
	21	MV Type Supported		N/A		
	22	Cold Junction Compensation		Internal compensation		
	23	Housing Material		Aluminium, epoxy coated		
	24	Power supply		24 VDC, 2 wire, loop powered		
	25	Electric Conn.		ISO M20 x 1,5		
	26	Accuracy		± 0.1% of span		
	27	Calibrated Range	Unit	0...200	°C	
	28	Burn-out Protection/Loss of Input		Overrange		
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4-20 mA		
	32	Adjustable Range		Yes		
	33					
	34					
	35					
36						
37						
38						
39						
40						
OPTIONS	41					
	42	Integral Meter	Scale	Yes, LCD	°C	
	43	Lightning And Surge Protection		N/A		
	44	Mounting facilities		Bracket		
	45	Housing ground connection		Yes, external (tightened with screws)		
CERTIFICATES	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	47	Calibration certificate		Yes		
	48	ATEX		No		
	49	IP certificate		No		
	50	SIL certificate	Level	No		
	51					
PURCHASE	52					
	53	Manufacturer		Emerson/Rosemount		
	54	Model		644H		
	55					
	56					
57						

Notes:

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Transmitter 	Sheet 24 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	ThermowellTag Number		TW-10152	
	2	Service		Temperature Transmitter	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TIT-10152	
	5				
	6	Line/equipment number			
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm. Max.	160°C	170°C
	12	Design	Press. Temp.	26 Bar(a)	200°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		1,9 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
ELEMENT	30	ElementTag Number		TE-10152	
	31	Construction		Sensor with lead wire, transition and relief spring	
	32	Type Of Element		TC type 'K / Simplex	
	33	Accuracy Class		DIN - IEC-EN 60584 Class 1	
	34	Outside Diameter Sensor		6 mm	
	35	Connection		1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	36	Element Length		To fit in Thermowell	
	37	Type Of Cable		Armoured	
	38	Cable Length		5 m	
	39	Special construction		No	
	40	Sheat Material		SS 316	
	41	Element case		Hermetically sealed	
	42				
	43				
	OPTIONS	44	Make TW and TE		Rodax
45		Model TE and TW		BFT + KWA	
46					
CERTIFICATES	47				
	48				
	49	3.1 Material certificate		Yes	
CALCULATIONS	50	Functional test report (up-down) for element		Yes	
	51	Calibration certificate		Yes	
	52				
NOTES :	53	Wake frequency calculation		No	
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Thermowell + Element 	Sheet 25 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TIT-10153		
	2	Service		Nitrogen Temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor 1st stage		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1002-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)	
	11	Temperature	Norm. Max.	160°C	170°C	
	12	Design	Press. Temp.	26 Bar(a)	200°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L		
	15		H	HH		170°C
TRANSMITTER	16					
	17	Function		Field mounted Transmitter		
	18	Transmitter Type		Temperature		
	19	RTD Types Supported		N/A		
	20	Thermocouples Types Supported		Yes, TC type 'K'		
	21	MV Type Supported		N/A		
	22	Cold Junction Compensation		Internal compensation		
	23	Housing Material		Aluminium, epoxy coated		
	24	Power supply		24 VDC, 2 wire, loop powered		
	25	Electric Conn.		ISO M20 x 1,5		
	26	Accuracy		± 0.1% of span		
	27	Calibrated Range	Unit	0...200		°C
	28	Burn-out Protection/Loss of Input		Overrange		
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4-20 mA		
	32	Adjustable Range		Yes		
	33					
	34					
	35					
36						
37						
38						
39						
40						
OPTIONS	41					
	42	Integral Meter	Scale	Yes, LCD	°C	
	43	Lightning And Surge Protection		N/A		
	44	Mounting facilities		Bracket		
	45	Housing ground connection		Yes, external (tightened with screws)		
CERTIFICATES	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
	47	Calibration certificate		Yes		
	48	ATEX		No		
	49	IP certificate		No		
	50	SIL certificate	Level	No		
PURCHASE	51					
	52					
	53	Manufacturer		Emerson/Rosemount		
	54	Model		644H		
	55					
56						
57						

Notes:

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Transmitter 	Sheet 26 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	ThermowellTag Number		TW-10153	
	2	Service		Temperature Transmitter	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TIT-10153	
	5				
	6	Line/equipment number			
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm. Max.	160°C	170°C
	12	Design	Press. Temp.	26 Bar(a)	200°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		1,9 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
ELEMENT	30	ElementTag Number		TE-10153	
	31	Construction		Sensor with lead wire, transition and relief spring	
	32	Type Of Element		TC type 'K / Simplex	
	33	Accuracy Class		DIN - IEC-EN 60584 Class 1	
	34	Outside Diameter Sensor		6 mm	
	35	Connection		1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	36	Element Length		To fit in Thermowell	
	37	Type Of Cable		Armoured	
	38	Cable Length		5 m	
	39	Special construction		No	
	40	Sheat Material		SS 316	
	41	Element case		Hermetically sealed	
	42				
	43				
	OPTIONS	44	Make TW and TE		Rodax
45		Model TE and TW		BFT + KWA	
46					
CERTIFICATES	47				
	48				
	49	3.1 Material certificate		Yes	
CALCULATIONS	50	Functional test report (up-down) for element		Yes	
	51	Calibration certificate		Yes	
	52				
NOTES :	53	Wake frequency calculation		No	
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Thermowell + Element 	Sheet 27 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TIT-10154		
	2	Service		Nitrogen Temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor 1st downstream inter-cooler		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1002-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)	
	11	Temperature	Norm. Max.	45°C	50°C	
	12	Design	Press. Temp.	26 Bar(a)	85°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L		
	15		H	HH	50°C	
	16					
TRANSMITTER	17	Function		Field mounted Transmitter		
	18	Transmitter Type		Temperature		
	19	RTD Types Supported		N/A		
	20	Thermocouples Types Supported		Yes, TC type 'K'		
	21	MV Type Supported		N/A		
	22	Cold Junction Compensation		Internal compensation		
	23	Housing Material		Aluminium, epoxy coated		
	24	Power supply		24 VDC, 2 wire, loop powered		
	25	Electric Conn.		ISO M20 x 1,5		
	26	Accuracy		± 0.1% of span		
	27	Calibrated Range	Unit	0...80	°C	
	28	Burn-out Protection/Loss of Input		Overrange		
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4-20 mA		
	32	Adjustable Range		Yes		
	33					
34						
35						
36						
37						
38						
39						
40						
41						
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C	
	43	Lightning And Surge Protection		N/A		
	44	Mounting facilities		Bracket		
	45	Housing ground connection		Yes, external (tightened with screws)		
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
CERTIFICATES	47	Calibration certificate		Yes		
	48	ATEX		No		
	49	IP certificate		No		
	50	SIL certificate	Level	No		
	51					
52						
PURCHASE	53	Manufacturer		Emerson/Rosemount		
	54	Model		644H		
	55					
	56					
	57					

Notes:

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Transmitter 	Sheet 28 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	ThermowellTag Number		TW-10154	
	2	Service		Temperature Transmitter	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TIT-10154	
	5				
	6	Line/equipment number			
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	14,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm. Max.	45°C	50°C
	12	Design	Press. Temp.	26 Bar(a)	85°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		1,4 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
ELEMENT	30	ElementTag Number		TE-10154	
	31	Construction		Sensor with lead wire, transition and relief spring	
	32	Type Of Element		TC type 'K / Simplex	
	33	Accuracy Class		DIN - IEC-EN 60584 Class 1	
	34	Outside Diameter Sensor		6 mm	
	35	Connection		1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	36	Element Length		To fit in Thermowell	
	37	Type Of Cable		Armoured	
	38	Cable Length		5 m	
	39	Special construction		No	
	40	Sheat Material		SS 316	
	41	Element case		Hermetically sealed	
	42				
	43				
	OPTIONS	44	Make TW and TE		Rodax
45		Model TE and TW		BFT + KWA	
46					
CERTIFICATES	47				
	48				
	49	3.1 Material certificate		Yes	
CALCULATIONS	50	Functional test report (up-down) for element		Yes	
	51	Calibration certificate		Yes	
	52				
CALCULATIONS	53	Wake frequency calculation		No	
	54				
	55				
56					
57					

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Thermowell + Element 	Sheet 29 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		TIT-10155		
	2	Service		Nitrogen Temperature		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor 2nd upstream intercooler		
	5	Ingress Protection		IP65		
	6	Line/equipment number		2"-NL-1003-539D(N)		
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas	
	10	Pressure	Norm. Max.	23,5 Bar(a)	26 Bar(a)	
	11	Temperature	Norm. Max.	70°C	83°C	
	12	Design	Press. Temp.	26 Bar(a)	200°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Setpoint	LL	L		
	15		H	HH		100°C
16						
TRANSMITTER	17	Function		Field mounted Transmitter		
	18	Transmitter Type		Temperature		
	19	RTD Types Supported		N/A		
	20	Thermocouples Types Supported		Yes, TC type 'K'		
	21	MV Type Supported		N/A		
	22	Cold Junction Compensation		Internal compensation		
	23	Housing Material		Aluminium, epoxy coated		
	24	Power supply		24 VDC, 2 wire, loop powered		
	25	Electric Conn.		ISO M20 x 1,5		
	26	Accuracy		± 0.1% of span		
	27	Calibrated Range	Unit	0...200		°C
	28	Burn-out Protection/Loss of Input		Overrange		
	29	Area Classification		Zone 2, Eex'ia		
	30	Communication Protocol		Smart , HART 5		
	31	Output Signal		4-20 mA		
	32	Adjustable Range		Yes		
	33					
	34					
	35					
	36					
37						
38						
39						
40						
41						
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C	
	43	Lightning And Surge Protection		N/A		
	44	Mounting facilities		Bracket		
	45	Housing ground connection		Yes, external (tightened with screws)		
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
CERTIFICATES	47	Calibration certificate		Yes		
	48	ATEX		No		
	49	IP certificate		No		
	50	SIL certificate	Level	No		
	51					
52						
PURCHASE	53	Manufacturer		Emerson/Rosemount		
	54	Model		644H		
	55					
	56					
	57					

Notes:

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Temperature Transmitter 	Sheet 30 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	ThermowellTag Number		TW-10155	
	2	Service		Temperature Transmitter	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		TIT-10155	
	5				
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Nitrogen	Dry Gas
	10	Pressure	Norm. Max.	23,5 Bar(a)	26 Bar(a)
	11	Temperature	Norm. Max.	70°C	83°C
	12	Design	Press. Temp.	26 Bar(a)	200°C
	13	Ambient Temp.	Min. Max.	5 °C	52 °C
	14	Velocity		1,4 m/s	
	15				
	16				
THERMOWELL	19	Material		SS 316	
	20	Construction		Solid bar stock	
	21	Process Connection		1 1/2" ANSI RF #300 (Ra 125-250 AARH)	
	22	Instrument Connection		1/2" NPT-F	
	23	Root diameter		16 mm	
	24	Tip diameter		12 mm	
	25	Tip thickness		6 mm	
	26	Bore diameter		6,5 mm	
	27	Nozzle projection		110 mm	
	28	U-length		160 mm (4" pipe)	
ELEMENT	30	ElementTag Number		TE-10155	
	31	Construction		Sensor with lead wire, transition and relief spring	
	32	Type Of Element		TC type 'K / Simplex	
	33	Accuracy Class		DIN - IEC-EN 60584 Class 1	
	34	Outside Diameter Sensor		6 mm	
	35	Connection		1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	36	Element Length		To fit in Thermowell	
	37	Type Of Cable		Armoured	
	38	Cable Length		5 m	
	39	Special construction		No	
	40	Sheat Material		SS 316	
	41	Element case		Hermetically sealed	
	42				
	43				
	OPTIONS	44	Make TW and TE		Rodax
45		Model TE and TW		BFT + KWA	
46					
CERTIFICATES	47				
	48				
	49	3.1 Material certificate		Yes	
CALCULATIONS	50	Functional test report (up-down) for element		Yes	
	51	Calibration certificate		Yes	
	52				
NOTES :	53	Wake frequency calculation		No	
	54				
	55				
	56				
	57				

NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Thermowell + Element 	Sheet 31 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number		FT-10151		
	2	Service		Water Flow		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor cooling water outlet		
	5	Ingress Protection		IP65		
	6	Line/equipment number		11/2"-CWR-1011-501C(N)		
PROCESS CONDITIONS	7	Fluid	State	Water	Liquid	
	8	Pressure	Norm. Max.	2,5 Bar(g)	3 Bar(g)	
	9	Temperature	Norm. Max.	45°C	55°C	
	10	Flow		14,5 m³/hr		
	11	Density	Viscosity	990 kg/m³	0.597 Cp	
	12	Design	Press. Temp.	10 Bar(g)	95°C	
	13	Ambient Temp.	Min. Max.	5 °C	52 °C	
	14	Set Point	LL	L	-	13 m3/hr
	15		H	HH	-	-
	16					
TRANSMITTER	17	Function		Transmitter		
	18	Transmitter Type		Flow		
	19	Calibrated Range	Unit	0...20	m³/hr	
	20	Instrument Range	Unit	0...20	m³/hr	
	21	Transmitter Housing		Integral		
	22	Cable Entry		ISO M20 x 1.5		
	23	Power Supply		24 VDC, 2 wire, loop powered		
	24	Enclosure Material		Aluminium, epoxy coated		
	25	Meter To Transmitter Cable		N/A,		
	26	Internal Compensation		Yes, pressure & temperature		
	27	Accuracy		±1.0% of span		
	28	Area Classification		Zone 2, Eex'ia		
	29	Communication Protocol		Smart , HART 5		
	30	Output Signal		4-20 mA		
	31					
	32					
METER	33	Type		Variable Area		
	34	Meter Size		2"		
	35	Size & Rating		ANSI 150# RF		
	36	Body Material		SS 316 / SS 316L		
	37	Flange Material		SS 316 / SS 316L		
	38	Bluff Body Material		SS 316 / SS 316L		
	39	O-ring Material		-		
	40	Other Wetted Parts		SS 316 / SS 316L		
	41	Permanent Pressure Loss		220 mbar		
	42	Mounting/ direction		horizontal		
OPTIONS	43	Integral Meter	Scale	Yes,	m³/hr	
	44	Lightning And Surge Protection		N/A		
	45	Mounting facilities		N/A		
	46	Block Valve		N/A		
	47	Housing ground connection		Yes, external (tightened with screws)		
	48	Cable Gland		Yes, Eex 'd' certified (Airpack scope)		
CERTIFICATES	49	Calibration certificate		Yes		
	50	3.1 Material certificate		Yes		
	51	ATEX		No		
	52	SIL certificate	Level	No		
	53	IP certificate		No		
	54					
PURCHASE	55	Manufacturer		Krohne		
	56	Model		H250H		
	57					

NOTES :

				INSTRUMENT AND VALVE DATASHEET	
				Flow Transmitter	
					
00	XX	06/03/2015	For Approval	Sheet	32 of 38
Rev	By	Date	Description	Based on P&ID Rev.XX	

GENERAL	1	Tag Number		VT-10151		
	2	Service		Vibration level		
	3	P&ID No.		BU-20-VD-303-PR-WG-0013		
	4	Location		Compressor		
	5	Ingress Protection		IP65		
	6	Line/equipment number		20-C-1002		
PROCESS CONDITIONS	7	Fluid	State		Air	Wet Air
	8	Pressure	Norm.	Max.	Atmospheric	Atmospheric
	9	Temperature	Norm.	Max.	190°C	195°C
	10	Design	Press.	Temp.	Atmospheric	200°C
	11	Ambient Temp.	Min.	Max.	5 °C	52 °C
	12	Set Point	LL	L	-	-
	13		H	HH	-	8 mm/sec
TRANSMITTER	14					
	15	Function		Compressir vibration transmitter		
	16	Case Material		SS 316L		
	17	Calibrated Range	Unit		0...25,4	mm/sec
	18	Frequency Response		10 Hz to 1000 Hz (600 to 60,000 cpm) RMS		
	19	Area Classification		Zone 2, Eex'ia		
	20	Communication Protocol		N/A		
	21	Output Signal		4-20 mA		
	22					
	23					
	24					
	25					
	26					
	27					
	28					
	29					
	30					
	31					
	32					
	33					
OPTIONS	34					
	35					
	36					
	37					
	38					
CERTIFICATES	39					
	40	Integral Meter	Scale		No	N/A
	41	Lightning And Surge Protection		N/A		
	42	Mounting facilities		Plate Stud 1/4-28 to M8x1.25		
	43	Housing ground connection		Yes, external (tightened with screws)		
PURCHASE	44	Cable Gland		Yes, Eex' d' certified (Airpack scope)		
	45					
	46	Calibration certificate		No		
	47	3.1 Material certificate		No		
	48	ATEX		No		
NOTES :	49	SIL certificate	Level		No	
	50	IP certificate		No		
	51					
	52					
	53					
PURCHASE	54	Manufacturer		PCB		
	55	Model		EX641B71		
	56					
	57					


NOTES :

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Vibration Transmitter 	Sheet 33 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		

GENERAL	1	Tag Number		XY-10151, XY-10152	
	2	Service		Solenoid Valve	
	3	P&ID No.		BU-20-VD-303-PR-WG-0013	
	4	Location		Compressor inlet	
	5	Ingress Protection		IP65	
	6	Line/equipment number		Instrument airline	
	7				
	8				
	9				
PROCESS CONDITIONS	10	Fluid	State	Nitrogen	Dry Gas
	11	Pressure	Norm. Max.	8 Bar(a)	9 Bar(a)
	12	Temperature	Norm. Max.	55°C	65°C
	13	Design	Press. Temp.	13,5 Bar(a)	85°C
	14	Ambient Temp.	Min. Max.	5 °C	52 °C
	15				
	16				
VALVE BODY	18	Type		Direct acting	
	19	Configuration		3 way 2 position	
	20	Fail position		To be used as FO (Fail open)	
	21	Ports		1/4" NPT-F	
	22	Body Material		SS316	
	23	Seat Sealing Material		Nitrile	
	24				
	25				
	26				
	27				
	28				
	29				
ELECTRICAL	33	Voltage		24 VDC	
	34	Power consumption		< 3W	
	35	Class of Coil Insulation		H	
	36	Connection		ISO M20 x 1.5	
	37	Lightning and Surge Protection		No	
	38	Cable Gland		Yes, Eex 'de' certified (Airpack scope)	
	39	Housing material		SS316	
	40	Area Classification		Zone 2, Exd	
	41				
	42				
	43				
	CERTIFICATES	44	3.1 Material certificate		Yes
45		ATEX		Yes	
46		SIL certificate	Level	No	
47		IP certificate		No	
48					
PURCHASE	50	Manufacturer		Maxseal	
	51	Model		ICO3S	
	52				
	53				
	54				


NOTES:

1. This solenoid valve is an universal 3/2 way, direct operated valve, also suitable for 2/2 way operation.

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Solenoid Valve 	Sheet 34 of 38 Based on P&ID Rev.04
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number			FO-10151	
	2	Service			Flow Orifice	
	3	P&ID No.			BU-20-VD-303-PR-WG-0013	
	4	Line Size / Item Number			2" / upstream 20-DC-1002-2	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Nitrogen	Dry Gas
	10	Pressure	Norm.	Max.	15,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm.	Max.	160°C	170°C
	12	Design	Press.	Temp.	26 Bar(a)	200°C
	13	Ambient Temp.	Min.	Max.	5 °C	52 °C
	14	Oper. Flow			565 Nm³/hr / 707 kg/hr	
	15					
	16					
	17					
BODY	20	Type Of Body			Flow Orifice	
	21	Connection			2", RF 150#	
	22	Sizing standard			API618	
	23	Type of bore			concentric square	
	24	orifice bore diameter			39 mm	
	25	Beta ratio			0,68	
	26	Plate thickness			7,5 mm	
	27	Plate material			ASTM A694 F52	
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
CERTIFICATES	47	3.1 Material certificate			No	
	48					
	49					
	50					
	51					
PURCHASE	53	Manufacturer			Airpack	
	54	Model			FO	
	55					
	56					
	57					

--	--	--	--	--	--	--

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Orifice 	Sheet 35 of 38 Based on P&ID Rev.05
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		


GENERAL	1	Tag Number			FO-10152	
	2	Service			Flow Orifice	
	3	P&ID No.			BU-20-VD-303-PR-WG-0013	
	4	Line Size / Item Number			2" / upstream 20-DC-1002-3	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Nitrogen	Dry Gas
	10	Pressure	Norm.	Max.	15,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm.	Max.	45°C	50°C
	12	Design	Press.	Temp.	26 Bar(a)	85°C
	13	Ambient Temp.	Min.	Max.	5 °C	52 °C
	14	Oper. Flow			565 Nm³/hr / 707 kg/hr	
	15					
	16					
	17					
BODY	20	Type Of Body			Flow Orifice	
	21	Connection			2", RF 150#	
	22	Sizing standard			API618	
	23	Type of bore			concentric square	
	24	orifice bore diameter			42 mm	
	25	Beta ratio			0,67	
	26	Plate thickness			7,5 mm	
	27	Plate material			ASTM A694 F52	
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
39						
40						
41						
42						
43						
44						
45						
46						
CERTIFICATES	47	3.1 Material certificate			No	
	48					
	49					
	50					
	51					
	52					
PURCHASE	53	Manufacturer			Airpack	
	54	Model			FO	
	55					
	56					
	57					

--	--	--	--	--	--	--


07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Orifice 	Sheet 36 of 38 Based on P&ID Rev.05
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		

GENERAL	1	Tag Number			FO-10153	
	2	Service			Flow Orifice	
	3	P&ID No.			BU-20-VD-303-PR-WG-0013	
	4	Line Size / Item Number			2" / downstream 20-DC-1002-3	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Nitrogen	Dry Gas
	10	Pressure	Norm.	Max.	15,5 Bar(a)	18 Bar(a)
	11	Temperature	Norm.	Max.	45°C	50°C
	12	Design	Press.	Temp.	26 Bar(a)	85°C
	13	Ambient Temp.	Min.	Max.	5 °C	52 °C
	14	Oper. Flow			565 Nm³/hr / 707 kg/hr	
	15					
	16					
	17					
BODY	20	Type Of Body			Flow Orifice	
	21	Connection			2", RF 150#	
	22	Sizing standard			API618	
	23	Type of bore			concentric square	
	24	orifice bore diameter			39 mm	
	25	Beta ratio			0,68	
	26	Plate thickness			7,5 mm	
	27	Plate material			ASTM A694 F52	
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
39						
40						
41						
42						
43						
44						
45						
46						
CERTIFICATES	47	3.1 Material certificate			No	
	48					
	49					
	50					
	51					
	52					
PURCHASE	53	Manufacturer			Airpack	
	54	Model			FO	
	55					
	56					
	57					

--	--	--	--	--	--	--

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Orifice 	Sheet 37 of 38 Based on P&ID Rev.05
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		

GENERAL	1	Tag Number			FO-10154	
	2	Service			Flow Orifice	
	3	P&ID No.			BU-20-VD-303-PR-WG-0013	
	4	Line Size / Item Number			2" / upstream 20-DC-1002-4	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Nitrogen	Dry Gas
	10	Pressure	Norm.	Max.	23,5 Bar(a)	26 Bar(a)
	11	Temperature	Norm.	Max.	160°C	170°C
	12	Design	Press.	Temp.	26 Bar(a)	200°C
	13	Ambient Temp.	Min.	Max.	5 °C	52 °C
	14	Oper. Flow			565 Nm³/hr / 707 kg/hr	
	15					
	16					
	17					
BODY	20	Type Of Body			Flow Orifice	
	21	Connection			2", RF 150#	
	22	Sizing standard			API618	
	23	Type of bore			concentric square	
	24	orifice bore diameter			39 mm	
	25	Beta ratio			0,68	
	26	Plate thickness			7,5 mm	
	27	Plate material			ASTM A694 F52	
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
	CERTIFICATES	47	3.1 Material certificate			No
48						
49						
50						
51						
PURCHASE	53	Manufacturer			Airpack	
	54	Model			FO	
	55					
	56					
	57					

07	TT	05/09/2022	For Approval	INSTRUMENT AND VALVE DATASHEET Orifice 	Sheet 38 of 38 Based on P&ID Rev.05
06	KP	07/07/2022	For Approval		
05	TT	31/05/2022	Approved for Construction		
04	TT	05/01/2022	For Approval		
03	TT	19/11/2021	For Approval		
02	TT	27/10/2021	For Approval		
Rev	By	Date	Description		