



Vendor	<b>ABT 360 KT/Y PP PLANT Project</b>			Owner
	Valve data sheet			
	Vendor's Doc. No.: 2 3 2 4 9 - 2 7	Rev.: 01		
	PPEC Doc. No.: L03-RE037-IN-DSH-003			

**PPEC REQ. NO. : L03-RE037-IN-DSH-003**

**ITEM NO. :**

**TOTAL PAGES : 13**

**COMMENTED**

- **NO COMMENTS** : Documents/Drawings Were Checked By PPEC And Further Step Can Be Followed.
- **COMMENTED AS MARKED:** Documents/Drawings Were Checked By PPEC And Marked Comments Must Be Considered By Vendor. Vendor Shall Revise Documents/Drawing As Per Comments And The New Revision Of Documents/Drawings Must Be Revised Prior To Fabrication.
- **REJECTED:** Documents/Drawings Were Checked And It Is Not In Comply With Purchase Requisition Requirements.
- **ACCEPTABLE WITH COMMENTS:** Documents/Drawings Were Checked By PPEC And Comments Must Be Considered By Vendor. Fabrication Can Proceed Accordingly. Revised Document To Be Issued Either For Review Or As Final Certified. However PPEC Will Check The Revised Document For Proper Incorporation Of Comments.
- **NOT RETURNED:** Document Was Received For Information And Not Returned To The Vendor.



Name :  
Signature:  
Date :

Req. No. :

Seq. No.:

PPEC review & comments does not absolve the vendor of the responsibility for the corrected design, manufacturing and operation of the equipment

01	12-06-2025	Issue for Engineering	L.K.	S.K.	J.J.	
00	02-05-2025	Issue for Engineering	L.K.	S.K.	J.J.	
REV.	DATE	Description	Prepared by	Checked by	Approved by	Authorized by

Vendor	ABT 360 KT/Y PP PLANT		Contractor (DEC)	Owner
	Valve data sheet			
	Vendor's Doc. No.: 2 3 2 4 9 - 2 7	Rev.: 01		
	PPEC Doc. No.: L03-RE037-IN-DSH-003			
				 سراج گستران رجال SERAJ GOSTARAN REJAL (سهایی خانی)

PAGE NO.		CHANGE INDEX DURING FORMAL ISSUE						REASON OF LATEST CHANGE
		FIRST ISSUE	SECOND ISSUE	THIRTH ISSUE	FOURTH ISSUE	FIFTH ISSUE	SIXTH ISSUE	
		REV.00	REV.01	REV.02	REV.03	REV.04	REV.05	
1		X	X					
2		X	X					
3		X	X					
4		X	X					
5		X	X					
6		X	X					
7		X	X					
8		X	X					
9		X	X					
10		X	X					
11		X	X					
12		X	X					
13		X	X					
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
32								
33								
34								
35								
36								
37								
38								
39								
61								

Doc. No : 23249-12

Rev. No. : 01



Page : 2

of

12

INDEX			
No.	Device	Tag Number	Page
1	Solenoid Valve	XY-PK6801-01	3
2	Hand Ball Valve	V-6801-01	4
3	Hand Ball Valve	V-6801-02	5
4	Hand Ball Valve	V-6801-05, V-6801-06	6
5	Hand Ball Valve	V-6801-07, V-6801-08	7
6	Hand Ball Valve	V-6801-09, V-6801-10	8
7	Hand Globe Valve	V6801-03, V-6801-04	9
8	Check Valve	CV-6801-01	10
9	Y-Strainer	Y-6801-01	11
10	Y-Strainer	No tag, 1pc	12
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			


**Notes:**

				<b>INSTRUMENT AND VALVE DATASHEET Index</b>  	
01	LK	12-6-2025	For Approval		Sheet 2 of 12 Based on P&ID Rev.00
00	LK	2-5-2025	For Approval		
Rev	By	Date	Description		

GENERAL	1	Tag Number			XY-PK6801-01	
	2	Service			Solenoid Valve	
	3	P&ID No.			23249-03	
	4	Location			Instrument air inlet	
	5	Ingress Protection			IP65	
	6					
	7					
	8					
	9					
PROCESS CONDITIONS	10	Fluid	State	Instrument air	Dry Gas	
	11	Pressure	Norm. Max.	5,5 bar(g)		
	12	Temperature	Norm. Max.			
	13	Design	Press. Temp.	9 bar(g)	60 °C	
	14	Ambient Temp.	Min. Max.	2 °C	48 °C	
	15					
	16					
VALVE BODY	18	Type			Direct acting	
	19	Configuration			3 way 2 position	
	20	Fail position			To be used as FC (Fail-close)	
	21	Ports			1/2" NPT-F	
	22	Body Material			SS316	
	23	Seat Sealing Material			To be advised by the manufacturer	
	24					
	25					
	26					
	27					
	28					
	29					
ELECTRICAL	33	Voltage			24 VDC	
	34	Power consumption			<10W	
	35	Class of Coil Insulation			H / F	
	36	Connection			ISO M20 x 1.5	
	37	Lightning and Surge Protection			No	
	38	Cable Gland			Yes, Eex 'de' certified (Airpack scope)	
	39	Housing material			SS316	
	40	Area Classification			Zone 1, Ex'd' IIC	
	41					
	42					
	43					
	CERTIFICATES	44	3.1 Material certificate			Yes
45		ATEX			Yes	
46		SIL certificate	Level	No	N/A	
47		IP certificate			No	
48						
PURCHASE	50	Manufacturer			According to approved vendor list	
	51	Model			Supplier to advise	
	52					
	53					
	54					
	54					

**NOTES:**

1. This solenoid valve is an universal 3/2 way, direct operated valve, also suitable for 2/2 way operation.

				INSTRUMENT AND VALVE DATASHEET			
				Solenoid Valve			
							
01	LK	12-6-2025	For Approval				
00	LK	2-5-2025	For Approval				
Rev	By	Date	Description			Sheet	3 of 12
						Based on P&ID Rev.00	

GENERAL	1	Tag Number		V-6801-01	
	2	Service		Hand Ball valve	
	3	P&ID No.		23249-03	
	4	Location		Compressor Air Inlet	
	5				
	6				
	7				
PROCESS CONDITIONS	8	Fluid	State	Mixed gas	Dry Gas
	9	Pressure	Norm. Max.	2,8...3,5 bar(g)	
	10	Temperature	Norm. Max.	0...60	
	11	Design	Press. Temp.	5 bar(g)	75 °C
	12	Ambient Temp.	Min. Max.	1 °C	55 °C
	13	Oper. Flow		1100-1200 kg/h	
	14				
BODY	15				
	16	Body Type		Ball valve, wafer type	
	17	Body Size	Bore	3"	Full bore
	18	Guiding	No. Of Ports	-	2
	19	Conn. Type	End Conn. Rat.	RF	150#
	20	Body Material		Carbon steel	
	21	Packing Material		PTFE / Graphite	
	22	Bonnet Type		Screwed / Bolted	
	23	Trim	Form	Floating ball	
	24		Seat Mat.	PTFE / Graphite	
	25		Ball Mat. Shaft Mat.	SS316	SS316
	26	Actuation	Material	Lever handle	CS
	27	Threaded connections		Metric	
	28				
	29				
	30				
	31				
	32				
	33				
	34				
35					
36					
37					
38					
39					
40					
41					
42					
43					
OPTIONS	44				
	45				
	46				
CERTIFICATES	47	3.1 Material certificate		Yes	
	48	Hydrotest certificate		No	
	49				
	50				
PURCHASE	51				
	52	Manufacturer		According to approved vendor list	
	53	Model		Supplier to advise	
	54				
	55				
	56				
	57				

GRADE?


**Notes:**

**Case 1:**

- 77% propylene
- 23% propane

**Case 2:**


- 70,2% propylene
- 26,2% propane
- 3,3% ethylene
- 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET		
				Hand Ball Valve		
						
01	LK	12-6-2025	For Approval			
00	LK	2-5-2025	For Approval			
Rev	By	Date	Description	Sheet 4 of 12		
				Based on P&ID Rev.00		

GENERAL	1	Tag Number		V-6801-02	
	2	Service		Hand Ball valve	
	3	P&ID No.		23249-03	
	4	Location		Compressor Air Outlet	
	5				
	6				
	7				
PROCESS CONDITIONS	8	Fluid	State	Mixed gas	Dry Gas
	9	Pressure	Norm. Max.	21 bar(g)	
	10	Temperature	Norm. Max.	85...97 °C	
	11	Design	Press. Temp.	30 bar(g)	120 °C
	12	Ambient Temp.	Min. Max.	1 °C	55 °C
	13	Oper. Flow		1100-1200 kg/h	
	14				
BODY	15				
	16	Body Type		Ball valve, wafer type	
	17	Body Size	Bore	2"	Full bore
	18	Guiding	No. Of Ports	-	2
	19	Conn. Type	End Conn. Rat.	RF	150#
	20	Body Material		Carbon steel	
	21	Packing Material		PTFE / Graphite	
	22	Bonnet Type		Screwed / Bolted	
	23	Trim	Form	Floating ball	
	24		Seat Mat.	PTFE / Graphite	
	25		Ball Mat. Shaft Mat.	SS316	SS316
	26	Actuation	Material	Lever handle	CS
	27	Threaded connections		Metric	
	28				
	29				
	30				
	31				
	32				
	33				
	34				
	35				
	36				
	37				
	38				
	39				
40					
41					
42					
43					
OPTIONS	44				
	45				
	46				
CERTIFICATES	47	3.1 Material certificate		Yes	
	48	Hydrotest certificate		No	
	49				
	50				
PURCHASE	51				
	52	Manufacturer		According to approved vendor list	
	53	Model		Supplier to advise	
	54				
	55				
	56				
	57				

**Note**  
**Case 1:**  
 - 77% propylene  
 - 23% propane


**Case 2:**  
 - 70,2% propylene  
 - 26,2% propane  
 - 3,3% ethylene  
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET				
				Hand Ball Valve				
								
01	LK	12-6-2025	For Approval					
00	LK	2-5-2025	For Approval					
Rev	By	Date	Description		Based on P&ID		Rev.00	

GENERAL	1	Tag Number		V-6801-05, V-6801-06	
	2	Service		Hand Ball valve	
	3	P&ID No.		23249-03	
	4	Location		Pulsation dampener 1st stage inlet	
	5				
	6				
	7				
PROCESS CONDITIONS	8	Fluid	State	Mixed gas	Dry Gas
	9	Pressure	Norm. Max.	2,8...3,5 bar(g)	
	10	Temperature	Norm. Max.	0...60°C	
	11	Design	Press. Temp.	5 bar(g)	75 °C
	12	Ambient Temp.	Min. Max.	1 °C	55 °C
	13				
	14				
BODY	15				
	16	Body Type		Ball valve, wafer type	
	17	Body Size	Bore	1"	Full bore
	18	Guiding	No. Of Ports	-	2
	19	Conn. Type	End Conn. Rat.	RF	300#
	20	Body Material		Carbon steel	
	21	Packing Material		PTFE / Graphite	
	22	Bonnet Type		Screwed / Bolted	
	23	Trim	Form	Floating ball	
	24		Seat Mat.	PTFE / Graphite	
	25		Ball Mat. Shaft Mat.	SS316	SS316
	26	Actuation	Material	Lever handle	CS
	27	Threaded connections		Metric	
	28				
	29				
	30				
	31				
	32				
	33				
	34				
	35				
	36				
	37				
	38				
	39				
40					
41					
42					
43					
OPTIONS	44	Interlock valve		Yes	
	45				
	46				
CERTIFICATES	47	3.1 Material certificate		Yes	
	48	Hydrotest certificate		No	
	49				
	50				
PURCHASE	51				
	52	Manufacturer		According to approved vendor list	
	53	Model		Supplier to advise	
	54				
	55				
	56				
	57				

**Note**  
**Case 1:**  
 - 77% propylene  
 - 23% propane


**Case 2:**  
 - 70,2% propylene  
 - 26,2% propane  
 - 3,3% ethylene  
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET		
				Hand Ball Valve		
						
01	LK	12-6-2025	For Approval			
00	LK	2-5-2025	For Approval			
Rev	By	Date	Description	Sheet 6 of 12 Based on P&ID Rev.00		

GENERAL	1	Tag Number		V-6801-07, V-6801-08	
	2	Service		Hand Ball valve	
	3	P&ID No.		23249-03	
	4	Location		Pulsation dampener 1st stage outlet	
	5				
	6				
	7				
PROCESS CONDITIONS	8	Fluid	State	Mixed gas	Dry Gas
	9	Pressure	Norm. Max.	10,5 bar(g)	
	10	Temperature	Norm. Max.	45...99 °C	
	11	Design	Press. Temp.	16 bar(g)	120 °C
	12	Ambient Temp.	Min. Max.	1 °C	55 °C
	13				
	14				
BODY	16	Body Type		Ball valve, wafer type	
	17	Body Size	Bore	1"	Full bore
	18	Guiding	No. Of Ports	-	2
	19	Conn. Type	End Conn. Rat.	RF	300#
	20	Body Material		Carbon steel	
	21	Packing Material		PTFE / Graphite	
	22	Bonnet Type		Screwed / Bolted	
	23	Trim	Form	Floating ball	
	24		Seat Mat.	PTFE / Graphite	
	25		Ball Mat. Shaft Mat.	SS316	SS316
	26	Actuation	Material	Lever handle	CS
	27	Threaded connections		Metric	
	28				
	29				
	30				
	31				
	32				
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
41					
42					
43					
OPTIONS	44	Interlock valve		Yes	
	45				
	46				
CERTIFICATES	47	3.1 Material certificate		Yes	
	48	Hydrotest certificate		No	
	49				
	50				
PURCHASE	51				
	52	Manufacturer		According to approved vendor list	
	53	Model		Supplier to advise	
	54				
	55				
	56				
	57				

**Note**  
**Case 1:**  
 - 77% propylene  
 - 23% propane

**Case 2:**  
 - 70,2% propylene  
 - 26,2% propane  
 - 3,3% ethylene  
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET		
				Hand Ball Valve		
						
01	LK	12-6-2025	For Approval			
00	LK	2-5-2025	For Approval			
Rev	By	Date	Description			
				Sheet 7 of 12		
				Based on P&ID Rev.00		



GENERAL	1	Tag Number		V-6801-09, V-6801-10	
	2	Service		Hand Ball valve	
	3	P&ID No.		23249-03	
	4	Location		Pulsation dampener 2nd stage outlet	
	5				
	6				
	7				
PROCESS CONDITIONS	8	Fluid	State	Mixed gas	Dry Gas
	9	Pressure	Norm. Max.	2,8...3,5 bar(g)	
	10	Temperature	Norm. Max.	0...60°C	
	11	Design	Press. Temp.	5 bar(g)	75 °C
	12	Ambient Temp.	Min. Max.	1 °C	55 °C
	13				
	14				
BODY	15				
	16	Body Type		Ball valve, wafer type	
	17	Body Size	Bore	1"	Full bore
	18	Guiding	No. Of Ports	-	2
	19	Conn. Type	End Conn. Rat.	RF	600#
	20	Body Material		Carbon steel	
	21	Packing Material		PTFE / Graphite	
	22	Bonnet Type		Screwed / Bolted	
	23	Trim	Form	Floating ball	
	24		Seat Mat.	PTFE / Graphite	
	25		Ball Mat. Shaft Mat.	SS316	SS316
	26	Actuation	Material	Lever handle	CS
	27	Threaded connections		Metric	
	28				
	29				
	30				
	31				
	32				
	33				
	34				
	35				
	36				
	37				
	38				
	39				
40					
41					
42					
43					
OPTIONS	44	Interlock valve		Yes	
	45				
	46				
CERTIFICATES	47	3.1 Material certificate		Yes	
	48	Hydrotest certificate		No	
	49				
	50				
PURCHASE	51				
	52	Manufacturer		According to approved vendor list	
	53	Model		Supplier to advise	
	54				
	55				
	56				
	57				


**Note**

**Case 1:** (1200kg/h)

- 77% propylene  
 - 23% propane

**Case 2:** (1100kg/h)


- 70,2% propylene  
 - 26,2% propane  
 - 3,3% ethylene  
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET		
				Hand Ball Valve		
						
01	LK	12-6-2025	For Approval			
00	LK	2-5-2025	For Approval			
Rev	By	Date	Description	Sheet 8 of 12		
				Based on P&ID Rev.00		

GENERAL	1	Tag Number			V6801-03, V-6801-04	
	2	Service			Globe valve	
	3	P&ID No.			23249-03	
	4	Location			Cooling water supply / return	
	5					
	6					
	7					
PROCESS CONDITIONS	8	Fluid	State		Cooling water	Liquid
	9	Pressure	Norm.	Max.	6,5...8 bar(g)	
	10	Temperature	Norm.	Max.	42...52 °C	
	11	Design	Press.	Temp.	TBA	TBA
	12	Ambient Temp.	Min.	Max.	1 °C	55 °C
	13	Oper. Flow			TBD	
BODY	14					
	15	Body Type			Globe valve type	
	16	Body Size			1 1/2"	
	17	Guiding	No. Of Ports		-	2
	18	Conn. Type	End Conn. Rat.		RF	150#
	19	Body Material			Carbon steel	
	20	Packing Material			PTFE / Graphite	
	21	Bonnet Type			Screwed / Bolted	
	22	Trim	Form		Disc	
	23		Seat Mat.		PTFE / Graphite	
	24		Disc Mat.	Shaft Mat.	SS316	SS316
	25					
	26					
	27					
	28					
	29					
	30					
	31					
	32					
	33					
34						
35						
36						
37						
38						
39						
40						
41						
42						
43						
OPTIONS	44					
	45					
	46					
CERTIFICATES	47	3.1 Material certificate			Yes	
	48	Hydrotest certificate			No	
	49					
	50					
	51					
PURCHASE	52	Manufacturer			According to approved vendor list	
	53	Model			Supplier to advise	
	54					
	55					
	56					
	57					

GRADE?


**NOTES :**

				<b>INSTRUMENT AND VALVE DATASHEET</b>			
				<b>Hand Globe Valve</b>			
							
01	LK	12-6-2025	For Approval				
00	LK	2-5-2025	For Approval				
Rev	By	Date	Description	Sheet 9 of 12 Based on P&ID Rev.00			

GENERAL	1	Tag Number			CV-6801-01	
	2	Service			Check Valve	
	3	P&ID No.			23249-03	
	4	Location			Compressor outlet	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Mixed gas (see notes)	Dry gas
	10	Pressure	Norm.	Max.	21 bar(g)	
	11	Temperature	Norm.	Max.	85 °C	97 °C
	12	Design	Press.	Temp.	30 bar(g)	120 °C
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14	Oper. Flow			1100-1200 kg/h (See notes)	
	15					
	16					
	17					
	18					
BODY	20	Type Of Body			Wafer type	
	21	Type Of valve			Plate type	
	22	Body Size			DN 50 ( Process line = 2" ANSI 600# RF)	
	23	Body Material			Carbon steel	
	24	Cracking Pressure			To be stated by supplier	
	25	Inlet Connection	Outlet Conn.		RF	RF
	26	Inlet Rating	Outlet Rating		600#	600#
	27	Threaded connections			Metric	
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	OPTIONS	37				
38						
39						
40						
41						
42						
43						
CERTIFICATES	44	3.1 Material certificate			Yes, EN10204 type 3.1	
	45					
	46					
	47					
	48					
PURCHASE	49					
	50	Manufacturer			According to approved vendor list	
	51	Model			Supplier to advise	
	52					
	53					
	54					

**Note**


<b>Case 1:</b> (1200kg/h) - 77% propylene - 23% propane	<b>Case 2:</b> (1100kg/h) - 70,2% propylene - 26,2% propane - 3,3% ethylene - 0,3% ethane
---	---

				<b>INSTRUMENT AND VALVE DATASHEET</b>			
				<b>Check Valve</b>			
							
01	LK	12-6-2025	For Approval				
00	LK	2-5-2025	For Approval				
Rev	By	Date	Description			Sheet 10 of 12 Based on P&ID Rev.00	

GENERAL	1	Tag Number			Y-6801-01	
	2	Service			Y-strainer	
	3	P&ID No.			23249-03	
	4	Location			Compressor inlet	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Mixed gas	Dry gas
	10	Pressure	Norm.	Max.	2,8...3,5 bar(g)	
	11	Temperature	Norm.	Max.	0...60 °C	
	12	Design	Press.	Temp.	5 bar(g)	120 °C
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14	Oper. Flow			1100-1200 kg/h	
	15					
	16					
	17					
	18					
BODY	20	Type Of Body			Y-strainer	
	21	Connection			3" ANSI 150# RF	
	22	Body Material			Carbon steel	
	23	Mesh Material			SS316	
	24	Mesh Size			0,5 mm (Supplier to advise)	
	25					
	26					
	27					
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
	39					
	40					
CERTIFICATES	44	3.1 Material certificate			Yes	
	45					
	46					
	47					
	48					
PURCHASE	50	Manufacturer			According to approved vendor list	
	51	Model			Supplier to advise	
	52					
	53					
	54					


**Note**

<b>Case 1:</b> - 77% propylene - 23% propane	<b>Case 2:</b> - 70,2% propylene - 26,2% propane - 3,3% ethylene - 0,3% ethane
--	--

				INSTRUMENT AND VALVE DATASHEET			
				Y-Strainer			
							
01	LK	12-6-2025	For Approval				
00	LK	2-5-2025	For Approval				
Rev	By	Date	Description			Sheet 11 of 12	Based on P&ID Rev.00

GENERAL	1	Tag Number			No tag, 1pc	
	2	Service			Y-strainer	
	3	P&ID No.			23249-03	
	4	Location			Cooling water supply	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Cooling water	Liquid
	10	Pressure	Norm.	Max.	8 bar(g)	
	11	Temperature	Norm.	Max.	42°C	
	12	Design	Press.	Temp.	TBA	TBA
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14	Oper. Flow			TBD	
	15					
	16					
	17					
	18					
BODY	20	Type Of Body			Y-strainer	
	21	Connection			1 1/2" ANSI 150# RF	
	22	Body Material			Carbon steel	
	23	Mesh Material			SS316	
	24	Mesh Size			0,5 mm (Supplier to advise)	
	25					
	26					
	27					
	28					
	29					
	30					
	31					
	32					
	33					
	34					
	35					
	36					
	37					
	38					
	CERTIFICATES	44	3.1 Material certificate			Yes
45						
46						
47						
48						
49						
PURCHASE	50	Manufacturer			According to approved vendor list	
	51	Model			Supplier to advise	
	52					
	53					
	54					

**Note**

				INSTRUMENT AND VALVE DATASHEET			
				Y-Strainer			
							
01	LK	12-6-2025	For Approval				
00	LK	2-5-2025	For Approval				
Rev	By	Date	Description			Sheet 12 of 12 Based on P&ID Rev.00	