



Vendor	ABT 360 KT/Y PP PLANT Project			Owner
	Instrument data sheet			 سراج گستران رچال SERAJ GOSTARAN REJAL (بهایی خانی)
	Vendor's Doc. No.: 23249-12	Rev.: 01		
	PPEC Doc. No.: L03-RE037-IN-DSH-003			

PPEC REQ. NO. : L03-RE037-IN-DSH-003

ITEM NO. :

TOTAL PAGES : 19

- **NO COMMENTS** : Documents/Drawings Were Checked By PPEC And Further Step Can Be Followed.
- **COMMENTED AS MARKED:** Documents/Drawings Were Checked By PPEC And Marked Comments Must Be Considered By Vendor. Vendor Shall Revise Documents/Drawing As Per Comments And The New Revision Of Documents/Drawings Must Be Revised Prior To Fabrication.
- **REJECTED:** Documents/Drawings Were Checked And It Is Not In Comply With Purchase Requisition Requirements.
- **ACCEPTABLE WITH COMMENTS:** Documents/Drawings Were Checked By PPEC And Comments Must Be Considered By Vendor. Fabrication Can Proceed Accordingly. Revised Document To Be Issued Either For Review Or As Final Certified. However PPEC Will Check The Revised Document For Proper Incorporation Of Comments.
- **NOT RETURNED:** Document Was Received For Information And Not Returned To The Vendor.



Name :
Signature:
Date :

Req. No. :

Seq. No.:

PPEC review & comments does not absolve the vendor of the responsibility for the corrected design, manufacturing and operation of the equipment



01	16-06-2025	Issue for Engineering	L.K	S.K.	J.J.	
00	23-04-2025	Issue for Engineering	L.K	S.K.	J.J.	
REV.	DATE	Description	Prepared by	Checked by	Approved by	Authorized by

Vendor 	ABT 360 KT/Y PP PLANT		Contractor (DEC)	Owner  سراج گستران رجال SERAJ GOSTARAN REJAL (سهایی خانی)
	Instrument data sheet			
	Vendor's Doc. No.: 2 3 2 4 9 - 1 2 PPEC Doc. No.: L03-RE037-IN-DSH-003	Rev.: 01		

PAGE NO.		CHANGE INDEX DURING FORMAL ISSUE						REASON OF LATEST CHANGE
		FIRST ISSUE	SECOND ISSUE	THIRTH ISSUE	FOURTH ISSUE	FIFTH ISSUE	SIXTH ISSUE	
		REV.00	REV.01	REV.02	REV.03	REV.04	REV.05	
1		X						
2		X						
3		X						
4		X						
5		X						
6		X						
7		X						
8		X						
9		X						
10		X						
11		X						
12		X						
13		X						
14		X						
15		X						
16		X						
17		X						
18		X						
19		X						
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
32								
33								
34								
35								
36								
37								
38								
39								
54								


INDEX			
No.	Device	Tag Number	Page
1	Pressure Gauge	PG-PK6801-01	3
2	Pressure Gauge	PG-PK6801-02	4
3	Pressure Gauge	PG-PK6801-03, PG-PK6801-04	5
4	Flow Gauge	FG-PK6801-01, FG-PK6801-02	6
5	Diff. Pressure Transmitter	PDT-PK6801-01	7
6	Pressure Transmitter	PT-PK6801-01	8
7	Pressure Transmitter	PT-PK6801-02	9
8	Temperature Transmitter	TT-PK6801-01	10
9	Temperature Transmitter	TT-PK6801-02	11
10	Thermowell + Element	TW-PK6801-01, TW-PK6801-02	12
11	Temperature Transmitter	TT-PK6801-03	13
12	Temperature Transmitter	TT-PK6801-04	14
13	Thermowell + Element	TW-PK6801-03, TW-PK6801-04	15
14	Temperature Transmitter	TT-PK6801-05	16
15	Temperature Transmitter	TT-PK6801-06	17
16	Thermowell + Element	TW-PK6801-05, TW-PK6801-06	18
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			
51			
52			
53			
54			
55			

Notes:

				INSTRUMENT AND VALVE DATASHEET Index 	
01	LK	16-6-2025	For Approval		Sheet 2 of 18 Based on P&ID Rev.01
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description		

GENERAL	1	Tag Number			PG-PK6801-01	
	2	Service			Oil pressure	
	3	P&ID No.			23249-03	
	4	Location			Downstream oil filter	
	5	Ingress Protection			IP65	
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Oil	Liquid
	10	Pressure	Norm.	Max.	2 bar(g)	
	11	Temperature	Norm.	Max.	15 °C	68 °C
	12	Design	Press.	Temp.	5,5 bar(g)	70 °C
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14					
	15					
	16					
	17					
	18					
GAUGE	19	Type			Bourdon tube	
	20	Range	Unit		-1...5	bar(g)
	21	Mounting			Locally mounted	
	22	Dial Size	Dial Color		100 mm	White, Black numbers
	23	Case Material			SS 316	
	24	Ring Construction	Ring Material		Bayonet	SS 316
	25	Blow-Out Protection			Yes @ Back	
	26	Lens Material			Shatterproof laminated safety glass	
	27	Pressure Element Material			SS 316	
	28	Socket Material			SS 316	
	29	Connection Size			1/2" NPT-M	
	30	Connection Location			Bottom back	
	31	Movement Material			SS316	
	32	Nominal Accuracy			±1,0 % of span	
	33	Gauge Filling			Glycerine / Silicone oil	
	34	Over Range Protection			1,3 x full scale value	
	35					
	36					
37						
OPTIONS	38	Snubber	Material		N/A	N/A
	39	Gauge Savers	Material		N/A	N/A
	40	Manifold (Block & Bleed)			No	N/A
	41	Block valve (Hand ball valve)			No	N/A
	42					
	43					
CERTIFICATES	44					
	45	Calibration certificate			Yes	
	46	3.1 Material certificate			Yes	
	47					
	48					
	49					
PURCHASE	50					
	51	Manufacturer			According to approved vendor list	
	52	Model			Supplier to advise	
	53					
	54					
	55					
	56					
	57					

NOTES :


				INSTRUMENT AND VALVE DATASHEET			
				Pressure Gauge			
							
01	LK	16-6-2025	For Approval				
00	LK	23-4-2025	For Approval				
Rev	By	Date	Description			Sheet	3 of 18
						Based on P&ID Rev.01	

GENERAL	1	Tag Number		PG-PK6801-02	
	2	Service		Gas pressure	
	3	P&ID No.		23249-03	
	4	Location		Second stage inlet pulsation damper	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Mixed gas	Dry Gas
	10	Pressure	Norm. Max.	10,5 bar(g)	
	11	Temperature	Norm. Max.	52 °C	
	12	Design	Press. Temp.	16 bar(g)	75 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14				
	15				
	16				
GAUGE	17				
	18				
	19	Type		Bourdon tube	
	20	Range	Unit	0...16	bar(g)
	21	Mounting		Locally mounted	
	22	Dial Size	Dial Color	100 mm	White. Black numbers
	23	Case Material		SS 316	
	24	Ring Construction	Ring Material	Bayonet	SS 316
	25	Blow-Out Protection		Yes @ Back	
	26	Lens Material		Shatterproof laminated safety glass	
	27	Pressure Element Material		SS 316	
	28	Socket Material		SS 316	
	29	Connection Size		1/2" NPT-M	
	30	Connection Location		Bottom back	
	31	Movement Material		SS316	
	32	Nominal Accuracy		±1,0 % of span	
	33	Gauge Filling		Glycerine / Silicon Oil	
	34	Over Range Protection		1,3 x full scale value	
35					
36					
37					
OPTIONS	38	Snubber	Material	N/A	N/A
	39	Gauge Savers	Material	N/A	N/A
	40	Manifold (Block & Bleed)		No	N/A
	41	Block valve (Hand ball valve)		No	N/A
	42				
	43				
CERTIFICATES	44				
	45	Calibration certificate		Yes	
	46	3.1 Material certificate		Yes	
	47				
	48				
	49				
PURCHASE	50				
	51	Manufacturer		According to approved vendor list	
	52	Model		Supplier to advise	
	53				
	54				
	55				
	56				
	57				

NOTES :


Case 1:
 - 77% propylene
 - 23% propane

Case 2:
 - 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Pressure Gauge	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 4 of 18 Based on P&ID Rev.01	


GENERAL	1	Tag Number		PG-PK6801-03, PG-PK6801-04	
	2	Service		Cooling water pressure	
	3	P&ID No.		23249-03	
	4	Location		Cooling water supply / return	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Cooling water	Liquid
	10	Pressure	Norm. Max.	6,5...8 bar(g)	
	11	Temperature	Norm. Max.	42...52 °C	
	12	Design	Press. Temp.	12 bar(g)	70 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14				
	15				
	16				
GAUGE	17				
	18				
	19	Type		Bourdon tube	
	20	Range	Unit	0...12	bar(g)
	21	Mounting		Locally mounted	
	22	Dial Size	Dial Color	100 mm	White. Black numbers
	23	Case Material		SS 316	
	24	Ring Construction	Ring Material	Bayonet	SS 316
	25	Blow-Out Protection		Yes @ Back	
	26	Lens Material		Shatterproof laminated safety glass	
	27	Pressure Element Material		SS 316	
	28	Socket Material		SS 316	
	29	Connection Size		1/2" NPT-M	
	30	Connection Location		Bottom back	
	31	Movement Material		SS316	
	32	Nominal Accuracy		±1,0 % of span	
	33	Gauge Filling		Glycerine / Silicon Oil	
	34	Over Range Protection		1,3 x full scale value	
35					
36					
37					
OPTIONS	38	Snubber	Material	N/A	N/A
	39	Gauge Savers	Material	N/A	N/A
	40	Manifold (Block & Bleed)		Yes, 2-way B&B manifold	SS316 (Airpack Scope)
	41	Block valve (Hand ball valve)		No	
	42				
	43				
CERTIFICATES	44				
	45	Calibration certificate		Yes	
	46	3.1 Material certificate		Yes	
	47				
	48				
	49				
PURCHASE	50				
	51	Manufacturer		According to approved vendor list	
	52	Model		Supplier to advise	
	53				
	54				
	55				
	56				
	57				

NOTES :

				INSTRUMENT AND VALVE DATASHEET			
				Pressure Gauge			
							
01	LK	16-6-2025	For Approval				
00	LK	23-4-2025	For Approval				
Rev	By	Date	Description	Sheet 5 of 18 Based on P&ID Rev.01			

GENERAL	1	Tag Number			FG-PK6801-01, FG-PK6801-02	
	2	Service			Cooling water flow	
	3	P&ID No.			23249-03	
	4	Location			Cooling water supply / return	
	5	Ingress Protection			IP65	
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Cooling water	Liquid
	10	Pressure	Norm.	Max.	6.5...8 bar(g)	
	11	Temperature	Norm.	Max.	42...52	
	12	Design	Press.	Temp.	12 bar(g)	70 °C
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14	Operating Flow			7 m³/hr	
	15					
	16					
	17					
	18					
	19					
	20					
	21					
GAUGE	22	Type			Variable area	
	23	Range	Unit		0...10	m³/hr
	24	Mounting			Locally mounted	
	25	Case Material			SS316	
	26	Material Flow Tube			To be advised by supplier	
	27	Material Flow Float			To be advised by supplier	
	28	Normal Accuracy			±10% of full scale	
	29	Process Connection			1 1/2" NPT-F	
	30	Process Connection Orientation			Side-side	
	31	Adjustable Orifice			No	
	32					
	33					
	34					
	35					
	36					
	37					
	38					
	39					
	40					
	OPTIONS	42				
43						
44						
45						
46						
47		Calibration certificate			Yes	
CERTIFICATES	48	3.1 Material certificate			Yes	
	49					
	50					
	51					
	52					
PURCHASE	53	Manufacturer			According to approved vendor list	
	54	Model			Supplier to advise	
	55					
	56					
	57					

NOTES :

				INSTRUMENT AND VALVE DATASHEET			
				Flow Gauge			
							
01	LK	16-6-2025	For Approval				
00	LK	23-4-2025	For Approval				
Rev	By	Date	Description	Sheet 6 of 18 Based on P&ID Rev.01			

GENERAL	1	Tag Number		PDT-PK6801-01	
	2	Service		Differential pressure over inlet filter	
	3	P&ID No.		23249-03	
	4	Location		Compressor inlet	
	5	Ingress Protection		IP65	
	6				
PROCESS CONDITIONS	7	Fluid	State	Mixed gas (see notes)	Dry gas
	8	Pressure	Norm. Max.	2.8...3,5 bar(g)	
	9	Temperature	Norm. Max.	0...60	
	10	Design	Press. Temp.	5 bar(g)	75 °C
	11	Ambient Temp.	Min. Max.	1 °C	55 °C
	12	Set Point	LL L	-	-
	13		H HH	0,2 bar	-
	14				
	15				
TRANSMITTER	16	Function		Field mounted Transmitter	
	17	Element Type		Diaphragm	
	18	Element Material		SS 316	
	19	Housing Material		SS316	
	20	Power Supply		24 VDC, 2-wire, loop powered	
	21	Process Conn.	Electric Conn.	1/2" NPT-F	ISO M20x1.5
	22	Accuracy		±0.1% of span	
	23	Max. Static Pressure		VTA	
	24	Calibrated Range	Unit	-1...1	bar
	25	Adjustable Range	Unit	VTA	bar
	26	Allow. Temp.		VTA	
	27	Area Classification		Zone 1, Ex't	
	28	Communication Protocol		Smart , HART	
	29	Output Signal		4 - 20 mA	
	30	Sensor Fill Fluid		To be informed by supplier	
	31				
	32				
	33				
	34				
	35				
DIAPHRAGM SEAL	36	Process Connection & Rating		N/A	
	37	Diaphragm Material		N/A	
	38	Capillary Material		N/A	
	39	Fill Fluid		N/A	
OPTIONS	40	Integral Meter	Scale	Yes, LCD	bar(g)
	41	Lightning And Surge Protection		N/A	
	42	Mounting facilities		Bracket	
	43	Housing ground connection		Yes, external (tightened with screws)	
	44	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
	45	Manifold (Block & Bleed)		Yes, 5-way B&B manifold	SS316 (Airpack Scope)
	46	Block valve (Hand ball valve)		No	
	47	Calibration certificate		Yes	
CERTIFICATES	48	3.1 Material certificate		Yes	
	49	ATEX		Yes	
	50	SIL certificate	Level	No	
	51	IP certificate		No	
	52				
	53				
PURCHASE	54	Manufacturer		According to approved vendor list	
	55	Model		Supplier to advise	
	56				
	57				


NOTES :

Case 1:

- 77% propylene
 - 23% propane


Case 2:

- 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Diff. Pressure Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 7 of 18 Based on P&ID Rev.01	


GENERAL	1	Tag Number		PT-PK6801-01	
	2	Service		Oil pressure	
	3	P&ID No.		23249-03	
	4	Location		Downstream oil filter	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Oil	Liquid
	10	Pressure	Norm. Max.	2 bar(g)	
	11	Temperature	Norm. Max.	15 °C	68 °C
	12	Design	Press. Temp.	5,5 bar(g)	70 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL	L	
	15		H	HH	
	16				
TRANSMITTER	19	Function		Field mounted Transmitter	
	20	Element Type		Diaphragm	
	21	Element Material		SS 316L	
	22	Housing Material		SS316	
	23	Power Supply		24 VDC, 2-wire, loop powered	
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5
	25	Accuracy		± 0.1% of span	
	26	Calibrated Range	Unit	-1...5	bar(g)
	27	Adjustable Range	Unit	VTA	bar(g)
	28	Allow. Press.	Allow. Temp.	To be informed by supplier	To be informed by supplier
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Sensor Fill Fluid		To be informed by supplier	
	33				
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(g)
	38	Lightning And Surge Protection		N/A	
	39	Mounting facilities		Bracket	
	40	Manifold (Block & Bleed)		No	N/A
	41	Housing ground connection		Yes, external (tightened with screws)	
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
	43	Block valve (Hand ball valve)		No	
CERTIFICATES	44	Calibration certificate		Yes	
	45	3.1 Material certificate		Yes	
	46	ATEX		Yes	
	47	SIL certificate		No	
	48	IP certificate		No	
	49				
PURCHASE	51	Manufacturer		According to approved vendor list	
	52	Model		Supplier to advise	
	53				
	54				
	55				
	56				
	57				

NOTES :

				INSTRUMENT AND VALVE DATASHEET	
				Pressure Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 8 of 18 Based on P&ID Rev.01	

GENERAL	1	Tag Number		PT-PK6801-02	
	2	Service		Gas pressure	
	3	P&ID No.		23249-03	
	4	Location		Compressor outlet	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Mixed gas	Dry gas
	10	Pressure	Norm. Max.	21 bar(g)	
	11	Temperature	Norm. Max.	85...97	
	12	Design	Press. Temp.	30 bar(g)	120 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL L		
	15		H HH		30 bar(g)
	16				
TRANSMITTER	19	Function		Field mounted Transmitter	
	20	Element Type		Diaphragm	
	21	Element Material		SS 316L	
	22	Housing Material		SS316	
	23	Power Supply		24 VDC, 2-wire, loop powered	
	24	Process Conn.	Electric Conn.	½" NPTM	ISO M20 x 1,5
	25	Accuracy		± 0.1% of span	
	26	Calibrated Range	Unit	0...30	bar(g)
	27	Adjustable Range	Unit	VTA	bar(g)
	28	Allow. Press.	Allow. Temp.	To be informed by supplier	To be informed by supplier
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Sensor Fill Fluid		To be informed by supplier	
	33				
	34				
	35				
	36				
OPTIONS	37	Integral Meter	Scale	Yes, LCD	bar(g)
	38	Lightning And Surge Protection		N/A	
	39	Mounting facilities		Bracket	
	40	Manifold (Block & Bleed)		No	N/A N/A
	41	Housing ground connection		Yes, external (tightened with screws)	
	42	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
	43	Block valve (Hand ball valve)		No	
CERTIFICATES	44	Calibration certificate		Yes	
	45	3.1 Material certificate		Yes	
	46	ATEX		Yes	
	47	SIL certificate		No	
	48	IP certificate		No	
	49				
PURCHASE	51	Manufacturer		According to approved vendor list	
	52	Model		Supplier to advise	
	53				
	54				
	55				
	56				
	57				

NOTES :		Case 2:	
Case 1:		- 70,2% propylene	
- 77% propylene		- 26,2% propane	
- 23% propane		- 3,3% ethylene	
		- 0,3% ethane	

				INSTRUMENT AND VALVE DATASHEET	
				Pressure Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 9 of 18 Based on P&ID Rev.01	

GENERAL	1	Tag Number		TT-PK6801-01	
	2	Service		Gas temperature	
	3	P&ID No.		23249-03	
	4	Location		First stage outlet pulsation dampener	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Mixed gas	Wet Gas
	10	Pressure	Norm. Max.	10,5 bar(g)	
	11	Temperature	Norm. Max.	45 °C	99 °C
	12	Design	Press. Temp.	16 bar(g)	120 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL L		
	15		H HH	110 °C	
	16				
TRANSMITTER	17	Function		Field mounted Transmitter	
	18	Transmitter Type		Temperature	
	19	RTD Types Supported		N/A	
	20	Thermocouples Types Supported		Yes, TC type 'K'	
	21	MV Type Supported		N/A	
	22	Cold Junction Compensation		Internal compensation	
	23	Housing Material		SS316	
	24	Power supply		24 VDC, 2 wire, loop powered	
	25	Electric Conn.		ISO M20 x 1,5	
	26	Accuracy		± 0.1% of span	
	27	Calibrated Range	Unit	0...150	°C
	28	Burn-out Protection/Loss of Input		Overrange	
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Adjustable Range		Yes	
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
	41				
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C
	43	Lightning And Surge Protection		N/A	
	44	Mounting facilities		Bracket	
	45	Housing ground connection		Yes, external (tightened with screws)	
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
CERTIFICATES	47	Calibration certificate		Yes	
	48	ATEX		Yes	
	49	IP certificate		No	
	50	SIL certificate	Level	No	N/A
	51				
PURCHASE	52				
	53	Manufacturer		According to approved vendor list	
	54	Model		Supplier to advise	
	55				
	56				
	57				


NOTES :

Case 1:

- 77% propylene
- 23% propane

Case 2:

- 70,2% propylene
- 26,2% propane
- 3,3% ethylene
- 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Temperature Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval	Sheet 10 of 18	
Rev	By	Date	Description	Based on P&ID Rev.01	

GENERAL	1	Tag Number		TT-PK6801-02	
	2	Service		Gas temperature	
	3	P&ID No.		23249-03	
	4	Location		First stage outlet pulsation dampener	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Mixed gas	Wet Gas
	10	Pressure	Norm. Max.	10,5 bar(g)	
	11	Temperature	Norm. Max.	45 °C	99 °C
	12	Design	Press. Temp.	16 bar(g)	120 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL	L	
	15		H	HH	120 °C
	16				
TRANSMITTER	17	Function		Field mounted Transmitter	
	18	Transmitter Type		Temperature	
	19	RTD Types Supported		N/A	
	20	Thermocouples Types Supported		Yes, TC type 'K'	
	21	MV Type Supported		N/A	
	22	Cold Junction Compensation		Internal compensation	
	23	Housing Material		SS316	
	24	Power supply		24 VDC, 2 wire, loop powered	
	25	Electric Conn.		ISO M20 x 1,5	
	26	Accuracy		± 0.1% of span	
	27	Calibrated Range	Unit	0...150	°C
	28	Burn-out Protection/Loss of Input		Overrange	
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Adjustable Range		Yes	
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
	41				
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C
	43	Lightning And Surge Protection		N/A	
	44	Mounting facilities		Bracket	
	45	Housing ground connection		Yes, external (tightened with screws)	
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
CERTIFICATES	47	Calibration certificate		Yes	
	48	ATEX		Yes	
	49	IP certificate		No	
	50	SIL certificate	Level	No	N/A
	51				
PURCHASE	52				
	53	Manufacturer		According to approved vendor list	
	54	Model		Supplier to advise	
	55				
	56				
	57				


NOTES :

Case 1:

- 77% propylene
 - 23% propane

Case 2:

- 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Temperature Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval	Sheet 11 of 18	
Rev	By	Date	Description	Based on P&ID Rev.01	

GENERAL	1	Thermowell Tag Number			TW-PK6801-01, TW-PK6801-02	
	2	Service			Gas temperature	
	3	P&ID No.			23249-03	
	4	Location			Correspondent transmitter	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Mixed gas	Dry Gas
	10	Pressure	Norm.	Max.	10,5 bar(g)	
	11	Temperature	Norm.	Max.	45 °C	99 °C
	12	Design	Press.	Temp.	16 bar(g)	120 °C
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14					
	15					
	16					
THERMOWELL	17					
	18					
	19	Material			SS 316	
	20	Construction			Solid bar stock	
	21	Process Connection			3/4" NPT-M	
	22	Instrument Connection			1/2" NPT-F	
	23	Stem Diameter			Tapered, 22...16 mm	
	24	Bore Diameter			6,6 mm	
ELEMENT	25	U-length			150 mm	
	26					
	27					
	28					
	29					
	30	Element Tag Number			TE-PK6801-01, TE-PK6801-02	
	31	Construction			Sensor with lead wire, transition and relief spring	
	32	Type Of Element			Thermocouple type 'K'	
OPTIONS	33	Type Of Element			Simplex	
	34	Accuracy Class			DIN - IEC-EN 60584 Class 1	
	35	Outside Diameter Sensor			6 mm	
	36	Connection			1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	37	Element Length			To fit in Thermowell	
	38	Type Of Cable			Armoured	
	39	Cable Length			10 m (default)	
	40	Sheat Material			SS 316	
CERTIFICATES	41					
	42					
	43					
	44					
	45					
	46					
	47					
	48					
CALCULATIONS	49	3.1 Material certificate			Yes	
	50	Functional test report (up-down) for elem			No	
	51	Calibration certificate			No	
	52					
	53	Wake frequency calculation			No	
	54					
	55					
	56					
	57					


NOTES :

Case 1:

- 77% propylene
 - 23% propane

Case 2:

- 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Thermowell + Element	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 12 of 18 Based on P&ID Rev.01	

GENERAL	1	Tag Number		TT-PK6801-03	
	2	Service		Gas temperature	
	3	P&ID No.		23249-03	
	4	Location		1st stage compressor	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Mixed gas	Dry gas
	10	Pressure	Norm. Max.	21 bar(g)	
	11	Temperature	Norm. Max.	85 °C	97 °C
	12	Design	Press. Temp.	30 bar(g)	120 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL L		
	15		H HH	110 °C	
	16				
TRANSMITTER	17	Function		Field mounted Transmitter	
	18	Transmitter Type		Temperature	
	19	RTD Types Supported		N/A	
	20	Thermocouples Types Supported		Yes, TC type 'K'	
	21	MV Type Supported		N/A	
	22	Cold Junction Compensation		Internal compensation	
	23	Housing Material		SS316	
	24	Power supply		24 VDC, 2 wire, loop powered	
	25	Electric Conn.		ISO M20 x 1,5	
	26	Accuracy		± 0.1% of span	
	27	Calibrated Range	Unit	0...150	°C
	28	Burn-out Protection/Loss of Input		Overrange	
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Adjustable Range		Yes	
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
	41				
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C
	43	Lightning And Surge Protection		N/A	
	44	Mounting facilities		Bracket	
	45	Housing ground connection		Yes, external (tightened with screws)	
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
CERTIFICATES	47	Calibration certificate		Yes	
	48	ATEX		Yes	
	49	IP certificate		No	
	50	SIL certificate	Level	No	N/A
	51				
PURCHASE	52				
	53	Manufacturer		According to approved vendor list	
	54	Model		Supplier to advise	
	55				
	56				
	57				


NOTES :

Case 1:

- 77% propylene
 - 23% propane

Case 2:

- 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Temperature Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval	Sheet 13 of 18	
Rev	By	Date	Description	Based on P&ID Rev.01	

GENERAL	1	Tag Number		TT-PK6801-04	
	2	Service		Gas temperature	
	3	P&ID No.		23249-03	
	4	Location		1st stage compressor	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Mixed gas	Dry gas
	10	Pressure	Norm. Max.	21 bar(g)	
	11	Temperature	Norm. Max.	85 °C	97 °C
	12	Design	Press. Temp.	30 bar(g)	120 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL L		
	15		H HH		120 °C
	16				
TRANSMITTER	17	Function		Field mounted Transmitter	
	18	Transmitter Type		Temperature	
	19	RTD Types Supported		N/A	
	20	Thermocouples Types Supported		Yes, TC type 'K'	
	21	MV Type Supported		N/A	
	22	Cold Junction Compensation		Internal compensation	
	23	Housing Material		SS316	
	24	Power supply		24 VDC, 2 wire, loop powered	
	25	Electric Conn.		ISO M20 x 1,5	
	26	Accuracy		± 0.1% of span	
	27	Calibrated Range	Unit	0...150	°C
	28	Burn-out Protection/Loss of Input		Overrange	
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Adjustable Range		Yes	
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
	41				
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C
	43	Lightning And Surge Protection		N/A	
	44	Mounting facilities		Bracket	
	45	Housing ground connection		Yes, external (tightened with screws)	
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
CERTIFICATES	47	Calibration certificate		Yes	
	48	ATEX		Yes	
	49	IP certificate		No	
	50	SIL certificate	Level	No	N/A
	51				
PURCHASE	52				
	53	Manufacturer		According to approved vendor list	
	54	Model		Supplier to advise	
	55				
	56				
	57				


NOTES :

Case 1:

- 77% propylene
 - 23% propane

Case 2:

- 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Temperature Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval	Sheet 14 of 18	
Rev	By	Date	Description	Based on P&ID Rev.01	

GENERAL	1	Thermowell Tag Number			TW-PK6801-03, TW-PK6801-04	
	2	Service			Gas temperature	
	3	P&ID No.			23249-03	
	4	Location			Correspondent transmitter	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State		Mixed gas	Dry Gas
	10	Pressure	Norm.	Max.	21 bar(g)	
	11	Temperature	Norm.	Max.	85 °C	97 °C
	12	Design	Press.	Temp.	30 bar(g)	120 °C
	13	Ambient Temp.	Min.	Max.	1 °C	55 °C
	14					
	15					
	16					
THERMOWELL	17					
	18					
	19	Material			SS 316	
	20	Construction			Solid bar stock	
	21	Process Connection			3/4" NPT-M	
	22	Instrument Connection			1/2" NPT-F	
	23	Stem Diameter			Tapered, 22...16 mm	
	24	Bore Diameter			6,6 mm	
	25	U-length			150 mm	
	26					
	27					
	28					
	29					
ELEMENT	30	Element Tag Number			TE-PK6801-03, TE-PK6801-04	
	31	Construction			Sensor with lead wire, transition and relief spring	
	32	Type Of Element			Thermocouple type 'K'	
	33	Type Of Element			Simplex	
	34	Accuracy Class			DIN - IEC-EN 60584 Class 1	
	35	Outside Diameter Sensor			6 mm	
	36	Connection			1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	37	Element Length			To fit in Thermowell	
	38	Type Of Cable			Armoured	
	39	Cable Length			10 m (default)	
	40	Sheat Material			SS 316	
	41					
	42					
	43					
	44					
	45					
OPTIONS	46					
	47					
	48					
CERTIFICATES	49	3.1 Material certificate			Yes	
	50	Functional test report (up-down) for elem			No	
	51	Calibration certificate			No	
	52					
CALCULATIONS	53	Wake frequency calculation			No	
	54					
	55					
	56					
	57					


NOTES :

Case 1:

- 77% propylene
 - 23% propane


Case 2:

- 70,2% propylene
 - 26,2% propane
 - 3,3% ethylene
 - 0,3% ethane

				INSTRUMENT AND VALVE DATASHEET	
				Thermowell + Element	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 15 of 18 Based on P&ID Rev.01	


GENERAL	1	Tag Number		TT-PK6801-05	
	2	Service		Cooling water temperature	
	3	P&ID No.		23249-03	
	4	Location		Cooling water supply	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Cooling water	Liquid
	10	Pressure	Norm. Max.	8 bar(g)	
	11	Temperature	Norm. Max.	42 °C	
	12	Design	Press. Temp.	12 bar(g)	70 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL	L	
	15		H	HH	50 °C
	16				
TRANSMITTER	17	Function		Field mounted Transmitter	
	18	Transmitter Type		Temperature	
	19	RTD Types Supported		N/A	
	20	Thermocouples Types Supported		Yes, TC type 'K'	
	21	MV Type Supported		N/A	
	22	Cold Junction Compensation		Internal compensation	
	23	Housing Material		SS316	
	24	Power supply		24 VDC, 2 wire, loop powered	
	25	Electric Conn.		ISO M20 x 1.5	
	26	Accuracy		± 0.1% of span	
	27	Calibrated Range	Unit	0...100	°C
	28	Burn-out Protection/Loss of Input		Overrange	
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Adjustable Range		Yes	
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
	41				
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C
	43	Lightning And Surge Protection		N/A	
	44	Mounting facilities		Bracket	
	45	Housing ground connection		Yes, external (tightened with screws)	
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
CERTIFICATES	47	Calibration certificate		Yes	
	48	ATEX		Yes	
	49	IP certificate		No	
	50	SIL certificate	Level	No	N/A
	51				
PURCHASE	52				
	53	Manufacturer		According to approved vendor list	
	54	Model		Supplier to advise	
	55				
	56				
	57				

Notes:

				INSTRUMENT AND VALVE DATASHEET	
				Temperature Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Sheet 16 of 18 Based on P&ID Rev.01	


GENERAL	1	Tag Number		TT-PK6801-06	
	2	Service		Cooling water temperature	
	3	P&ID No.		23249-03	
	4	Location		Cooling water supply	
	5	Ingress Protection		IP65	
	6				
	7				
	8				
PROCESS CONDITIONS	9	Fluid	State	Cooling water	Liquid
	10	Pressure	Norm. Max.	6,5 bar(g)	
	11	Temperature	Norm. Max.	52 °C	
	12	Design	Press. Temp.	12 bar(g)	70 °C
	13	Ambient Temp.	Min. Max.	1 °C	55 °C
	14	Setpoint	LL	L	
	15		H	HH	55 °C
	16				
TRANSMITTER	17	Function		Field mounted Transmitter	
	18	Transmitter Type		Temperature	
	19	RTD Types Supported		N/A	
	20	Thermocouples Types Supported		Yes, TC type 'K'	
	21	MV Type Supported		N/A	
	22	Cold Junction Compensation		Internal compensation	
	23	Housing Material		SS316	
	24	Power supply		24 VDC, 2 wire, loop powered	
	25	Electric Conn.		ISO M20 x 1,5	
	26	Accuracy		± 0.1% of span	
	27	Calibrated Range	Unit	0...100	°C
	28	Burn-out Protection/Loss of Input		Overrange	
	29	Area Classification		Zone 1, Ex'i	
	30	Communication Protocol		Smart , HART	
	31	Output Signal		4 - 20 mA	
	32	Adjustable Range		Yes	
	33				
	34				
	35				
	36				
	37				
	38				
	39				
	40				
	41				
OPTIONS	42	Integral Meter	Scale	Yes, LCD	°C
	43	Lightning And Surge Protection		N/A	
	44	Mounting facilities		Bracket	
	45	Housing ground connection		Yes, external (tightened with screws)	
	46	Cable Gland		Yes, Eex 'd' certified (Airpack scope)	
CERTIFICATES	47	Calibration certificate		Yes	
	48	ATEX		Yes	
	49	IP certificate		No	
	50	SIL certificate	Level	No	N/A
	51				
PURCHASE	52				
	53	Manufacturer		According to approved vendor list	
	54	Model		Supplier to advise	
	55				
	56				

Notes:

				INSTRUMENT AND VALVE DATASHEET	
				Temperature Transmitter	
					
01	LK	16-6-2025	For Approval		
00	LK	23-4-2025	For Approval		
Rev	By	Date	Description	Based on P&ID Rev.01	

GENERAL	1	Thermowell Tag Number			TW-PK6801-05, TW-PK6801-06	
	2	Service			Cooling water temperature	
	3	P&ID No.			23249-03	
	4	Location			Correspondent transmitter	
	5					
	6					
	7					
	8					
PROCESS CONDITIONS	9	Fluid	State	Cooling water	Liquid	
	10	Pressure	Norm. Max.	6,5...8 bar(g)		
	11	Temperature	Norm. Max.	42...55 °C		
	12	Design	Press. Temp.	12 bar(g)	70 °C	
	13	Ambient Temp.	Min. Max.	1 °C	55 °C	
	14					
	15					
	16					
THERMOWELL	19	Material			SS 316	
	20	Construction			Solid bar stock	
	21	Process Connection			3/4" NPT-M	
	22	Instrument Connection			1/2" NPT-F	
	23	Stem Diameter			Tapered, 22...16 mm	
	24	Bore Diameter			6,6 mm	
	25	U-length			85 mm	
	26					
ELEMENT	30	Element Tag Number			TE-PK6801-05, TE-PK6801-06	
	31	Construction			Sensor with lead wire, transition and relief spring	
	32	Type Of Element			Thermocouple type 'K'	
	33	Type Of Element			Simplex	
	34	Accuracy Class			DIN - IEC-EN 60584 Class 1	
	35	Outside Diameter Sensor			6 mm	
	36	Connection			1/2" NPT-M x 6,0 mm OD coupling sliding on stem	
	37	Element Length			To fit in Thermowell	
	38	Type Of Cable			Armoured	
	39	Cable Length			10 m (default)	
	40	Sheat Material			SS 316	
	41					
OPTIONS	46					
	47					
	48					
CERTIFICATES	49	3.1 Material certificate			Yes	
	50	Functional test report (up-down) for element			No	
	51	Calibration certificate			No	
	52					
CALCULATIONS	53	Wake frequency calculation			No	
	54					
	55					
	56					
	57					

NOTES :

				INSTRUMENT AND VALVE DATASHEET			
				Thermowell + Element			
							
01	LK	16-6-2025	For Approval			Sheet	18 of 18
00	LK	23-4-2025	For Approval			Based on P&ID Rev.01	
Rev	By	Date	Description				